

Bay County

License Number: 1305963

HYATT PLACE

License Type: Permanent Food Service

15727 FRONT BEACH RD, PANAMA CITY BEACH 32413

Inspection Date: 07/15/2022

Inspection Number: 3189522

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Brevard County

License Number: 1505190 BAGEL 13
 License Type: Permanent Food Service 1301 S BABCOCK ST, MELBOURNE 32901

Inspection Date: 07/15/2022 Inspection Number: 3211112 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: BRAYBOY, LYNN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Silver extinguisher.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1506116 EL AMBIA CUBANO
 License Type: Permanent Food Service 950 E MELBOURNE AVENUE, MELBOURNE 32901

Inspection Date: 07/11/2022 Inspection Number: 3191857 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRAYBOY, LYNN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. In the back prep room. Company came out fixed it. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1506708 FLAVORS OF INDIA
 License Type: Permanent Food Service 5675 N ATLANTIC AVE # 117, COCOA BEACH 32931

Inspection Date: 07/11/2022 Inspection Number: 3195304 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HICKS, GEORGE RANDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By rear door. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1506768 SALSAS MEXICAN RESTAURANT
 License Type: Permanent Food Service 5675 N ATLANTIC AVE STE 119-121, COCOA BEACH 32931

Inspection Date: 07/11/2022 Inspection Number: 3199268 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: HICKS, GEORGE RANDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By rear door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1505627

BOB EVANS RESTAURANT 452

License Type: Permanent Food Service

100 SHERIFF DR, MELBOURNE 32940

Inspection Date: 07/14/2022

Inspection Number: 3216542

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FICHTER, GARRICK

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher next to walk in cooler is in the red. Operator stated that it was used for a fire in wooded area outside and has not yet been replaced

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1624024 PANERA BREAD BAKERY CAFE # 4735
 License Type: Permanent Food Service 4931 SHERIDAN ST, HOLLYWOOD 33021

Inspection Date: 07/14/2022 Inspection Number: 3228028 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ROGERS, VERNEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Main kitchen- observed exit door being blocked by empty boxes. Operator removed empty boxes. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1618359 DIANA FOOD GROUP
 License Type: Catering 4020 NE 10 WAY, POMPANO BEACH 33064

Inspection Date: 07/13/2022 Inspection Number: 1122570 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended
 Inspector Name: BRANN, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Between bays 5 and 6.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-03-4	- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. Between bays 5 and 6. - From follow-up inspection 2022-07-14: Observed electrical wiring in disrepair. For reporting purposes only. Between bays 5 and 6	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Storage room containing cleaning chemicals. Inspector will email inspection report Fire Marshall for review.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
48-04-4	- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Storage room containing cleaning chemicals. Inspector will email inspection report Fire Marshall	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2100575

DI JULIO'S

License Type: Permanent Food Service

5422 RATTLESNAKE HAMM RD, NAPLES 34112

Inspection Date: 07/15/2022

Inspection Number: 3243368

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: GRAVES, PETER

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. The single glass exit door at the front of the bar is locked. ****Warning****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2336996 CARROT EXPRESS
 License Type: Permanent Food Service 1111 BRICKELL AVE UNIT 155, MIAMI 33131

Inspection Date: 07/14/2022 Inspection Number: 3231454 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Prep area, back kitchen. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2336613 WENDY'S 12338
 License Type: Permanent Food Service 2370 SW 8 ST, MIAMI 33135

Inspection Date: 07/13/2022 Inspection Number: 3196590 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed boxes blocking back exit door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2334719 JIMMY JOHNS
 License Type: Permanent Food Service 1050 NW 14 ST, MIAMI 33136

Inspection Date: 07/11/2022 Inspection Number: 3205959 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed the back door nearby the restrooms blocked by a garbage can.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330642 COURTYARD FOOD SERVICE
 License Type: Permanent Food Service 1530 WASHINGTON AVE, MIAMI BEACH 33139

Inspection Date: 07/12/2022 Inspection Number: 3203028 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate expired.For reporting purposes only. Observed boiler jurisdiction number's 094477 & 094566; All expired on 5/28/2022. As per boiler safety search, Division of	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2336670 TASTY BEACH CAFE
 License Type: Permanent Food Service 4041 ROYAL PALM AVE, MIAMI BEACH 33140

Inspection Date: 07/13/2022 Inspection Number: 3212523 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed installation is in progress. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2317291 ALICIA COFFEE SHOP
 License Type: Permanent Food Service 1200 NW 22 ST, MIAMI 33142

Inspection Date: 07/13/2022 Inspection Number: 3197829 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BROWN, JARON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed two 20 pound propane tanks in bathroom area	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2331376 PANERA BREAD #1124
 License Type: Permanent Food Service 9717 NW 41 ST, DORAL 33166

Inspection Date: 07/13/2022 Inspection Number: 3197338 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, ERIK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed Extinguisher empty inside Bakery area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

DeSoto County

License Number: 2400244

DOMINOS

License Type: Permanent Food Service

1332 E OAK ST, ARCADIA 34266

Inspection Date: 07/14/2022

Inspection Number: 3197070

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: SCHNELL, PAMELA

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Observed open light socket, no cover or cap, in walk-in cooler.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2608510 CAPTAIN D'S #3380
 License Type: Permanent Food Service 2062 N MAIN ST, JACKSONVILLE 322063776

Inspection Date: 07/14/2022 Inspection Number: 3202808 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Front counter	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615227 EL CEMI RESTAURANT
 License Type: Permanent Food Service 6426 BOWDEN RD #202, JACKSONVILLE 32216

Inspection Date: 07/14/2022 Inspection Number: 3239165 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: VILBRUN, JOSUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Stored inside kitchen area next to walk in cooler. Employee removed and properly stored **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2611366 KRYSTAL
 License Type: Permanent Food Service 1009 DUNN AVE, JACKSONVILLE 32218

Inspection Date: 07/11/2022 Inspection Number: 3207471 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher by rear exit door is in recharge zone. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613388 ZAXBY'S
 License Type: Permanent Food Service 1372 AIRPORT RD, JACKSONVILLE 32218

Inspection Date: 07/14/2022 Inspection Number: 3244085 Inspection Type: Complaint Full Inspection Disposition: Emergency order recommended
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rear exit door blocked by large two door reach in cooler. Cooler moved. **Corrected On-Site** **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2616013 FAR WEST RODEO
 License Type: Permanent Food Service 10503 SAN JOSE BLVD STE 18, JACKSONVILLE 32257

Inspection Date: 07/11/2022 Inspection Number: 3242405 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended
 Inspector Name: GOSAI, MATT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Large Propane tank inside kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2608063 MCDONALDS
 License Type: Permanent Food Service 7245 MERRIL RD, JACKSONVILLE 32277

Inspection Date: 07/12/2022 Inspection Number: 3243385 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: THOMAS, PHILIP

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rear door blocked with broken down boxes and large roll cart for refuse in a manner where one cannot exit without moving or climbing over items. Manager cleared path without being prom	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3917857 SWEETFISH
 License Type: Permanent Food Service 811 N TAMPA ST STE 130, TAMPA 33602

Inspection Date: 07/13/2022 Inspection Number: 3196281 Inspection Type: Routine - Food Inspection Disposition: Emergency order recommended
 Inspector Name: EHLERS, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed employee frying shrimp in fryer in back area. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed employee frying shrimp in fryer in back area. **Repeat Violation	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3916529 TAQUERIA EMANUEL
 License Type: Permanent Food Service 2800 N MCDILL AVE STE E, TAMPA 33607

Inspection Date: 07/14/2022 Inspection Number: 3241309 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: CANNELLA, MARK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. K-class fire extinguisher stored on floor in kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3952981 BIG BAMBOO BAYSIDE
 License Type: Mobile Food Dispensing Vehicle 2506 N ROCKY POINT DR, TAMPA 33607

Inspection Date: 07/12/2022 Inspection Number: 1251495 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CANNELLA, MARK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. K class fire extinguisher stored on floor under three compartment sink.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3910985

JOE'S NEW YORK DINER LLC

License Type: Permanent Food Service

11701 N FLORIDA AVE, TAMPA 33612

Inspection Date: 07/11/2022

Inspection Number: 3210411

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: CESAR, RACHEL

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Red door leading to patio blocked by water line, table and fan.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Indian River County

License Number: 4101234

ECONOLOGDE

License Type: Permanent Food Service

950 US 1, VERO BCH 32960

Inspection Date: 07/11/2022

Inspection Number: 3206638

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHUCK, GREGORY

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Lee County

License Number: 4607462

THE TWISTED CRAB SEAFOOD AND BAR

License Type: Permanent Food Service

4125 CLEVELAND AVE STE 1100A, FORT MYERS 33901

Inspection Date: 07/11/2022

Inspection Number: 3190909

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WALTER, KAYLA

Violation Code ObservationViolation Citation

47-03-4 Observed electrical wiring in disrepair. For reporting purposes only. Observed cover of outlet as not well fitting on electrical outlet behind reach in freezer by fryer station.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4605126

MOJOE'S COFFEE BAR

License Type: Permanent Food Service

1740 ESTERO BLVD, FORT MYERS BEACH 33931

Inspection Date: 07/14/2022

Inspection Number: 3230509

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONDERMANN, FRANK

Violation Code ObservationViolation Citation

47-03-4 Observed electrical wiring in disrepair. For reporting purposes only. Wiring for dish machine in back storage room exposed.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5105442

BUFFALO WILD WINGS

License Type: Permanent Food Service

5235 UNIVERSITY PKWY, BRADENTON 34201

Inspection Date: 07/15/2022

Inspection Number: 3195184

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: EASLER, VERONICA

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone to the left of the rear exit door in kitchen by ice machine area. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5814122 FARM & HAUS
 License Type: Permanent Food Service 3201 CORRINE DRIVE SUITE 1, ORLANDO 32803

Inspection Date: 07/13/2022 Inspection Number: 3181484 Inspection Type: Routine - Food Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: VALERIO, GRACE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. - Flat grill top. - From follow-up inspection 2022-07-13: - Using flat	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5814743 LA BELLE
 License Type: Permanent Food Service 7400 SOUTHLAND BLVD SUITE 108, ORLANDO 32809

Inspection Date: 07/11/2022 Inspection Number: 3189292 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied
 Inspector Name: PASIECKI, VICTORIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. - From follow-up inspection 2022-07-11: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811176 CHIPOTLE MEXICAN GRILL #570
 License Type: Permanent Food Service 2850 S. KIRKMAN ROAD, ORLANDO 32811

Inspection Date: 07/14/2022 Inspection Number: 3238232 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: ARANA, MIRIAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. With empty boxes **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5809235 HOMEWOOD SUITES BY HILTON ORLANDO INTERNATIONAL DRIVE
 License Type: Permanent Food Service 8745 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 07/13/2022 Inspection Number: 3216332 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LUI, SUK HAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only./all 5 boilers with code violations and certificate of operation is suspended per Division of State Fire Marshal.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Osceola County

License Number: 5911667

POPEYES 13011

License Type: Permanent Food Service

852 BUENAVENTURA BOULEVARD, KISSIMMEE 34743

Inspection Date: 07/11/2022

Inspection Number: 3229902

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAVIS, DIANNA

Violation Code

Observation

Violation Citation

46-04-4 Exit door locked. For reporting purposes only. Exit door on mall side (possibly north side) locked and high chair in path as manager states it is not working correctly. Advised of exit status, for emergency departing.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6213987 NATURE'S TABLE CITY CENTER
 License Type: Permanent Food Service 100 2 AVE S, SAINT PETERSBURG 33701

Inspection Date: 07/13/2022 Inspection Number: 3223518 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MURPHY, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. In front prep area, eggs are being cooked on an induction cooktop and no hood system is present.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6218302 DEAD PRESIDENTS
 License Type: Permanent Food Service 1742 E CENTRAL AVE, ST PETERSBURG 33712

Inspection Date: 07/12/2022 Inspection Number: 3213321 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: HOBBS, ANDREW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. 2 table top fryers in kitchen no hood system **Repeat Violation** Admin Complaint**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216496 HYATT REGENCY CLEARWATER BEACH RESORT & SPA
 License Type: Permanent Food Service 301 GULFVIEW BLVD, CLEARWATER 33767

Inspection Date: 07/12/2022 Inspection Number: 3229929 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	Two boiler certificates expired. F1123659, F1123660 last two exp 7/25/2021 For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6216497 HYATT REGENCY CLEARWATER BEACH RESORT & SPA
 License Type: Permanent Food Service 301 GULF VIEW BLVD, CLEARWATER 33767

Inspection Date: 07/12/2022 Inspection Number: 3198750 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	Two boilers expired. F1123659, F1123660 last two exp 7/25/2021 For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Pinellas County

License Number: 6216515

HYATT REGENCY CLEARWATER BEACH RESORT & SPA

License Type: Permanent Food Service

301 GULF VIEW BLVD, CLEARWATER 33767

Inspection Date: 07/12/2022

Inspection Number: 3216122

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation Code

Observation

Violation Citation

48-01-5

Two boiler certificates expired. F1123659, F1123660 last two exp 7/25/2021 For reporting purposes only. ****Repeat Violation****

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Polk County

License Number: 6308552

CURRY MANGO

License Type: Permanent Food Service

6625 SOUTH FLORIDA AVE, LAKE LAND 33813

Inspection Date: 07/13/2022

Inspection Number: 3235081

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: VELAZQUEZ, STEPHANIE

Violation Code

Observation

Violation Citation

46-01-4

Marked path to marked exit blocked. For reporting purposes only.
Observed food being stored in front of prep tables blocking path to nearest exit in prep area. No other means of exiting area

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6903781

LEE'S FAMOUS RECIPE CHICKEN

License Type: Permanent Food Service

1905 S FRENCH AVE, SANFORD 32771

Inspection Date: 07/15/2022

Inspection Number: 3240016

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: ANGEL, TERRY

Violation Code ObservationViolation Citation49-03-4 Flammables stored/debris present in hot water heater room. For reporting
purposes only.
Card board box. **Corrected On-Site**61C-1.004(6) FAC Reporting: (6) Attics, basements,
boiler rooms, meter rooms, laundry rooms, and storage
rooms shall be kept clean and free of debris and
flammables. For reporting purposes only.

License Number: 6904569

PANDA EXPRESS #1177

License Type: Permanent Food Service

1460 RINEHART RD, SANFORD 32771

Inspection Date: 07/14/2022

Inspection Number: 3238277

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: ANGEL, TERRY

Violation Code ObservationViolation Citation46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.
Blocked by boxes.509.032(2)(d) FS Reporting: (d) The division, or its
agent, shall notify the local firesafety authority or the
State Fire Marshal of any readily observable violation of
a rule adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

Volusia County

License Number: 7405462

WENDY'S 2010

License Type: Permanent Food Service

900 DUNLAWTON AVE, PORT ORANGE 32127

Inspection Date: 07/15/2022

Inspection Number: 3214168

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: COREY, DEREK

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
 -exit path out back door blocked by cardboard boxes **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.