

**Alachua County**

License Number: 1103534

GAINESVILLE SOULFOOD KITCHEN

License Type: Permanent Food Service

2201 NE 2 ST, GAINESVILLE 32609

Inspection Date: 08/01/2022

Inspection Number: 3211572

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: CASEY, KEITH

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.  
Observed the red fire extinguisher by the back door is in the red zone. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Bay County**

License Number: 1305061

DIRTY DICK'S CRABHOUSE

License Type: Permanent Food Service

9800 FRONT BEACH RD, PANAMA CITY BEACH 32407

Inspection Date: 08/04/2022

Inspection Number: 3250457

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: LYNN, NICKOLAS

Violation Code    ObservationViolation Citation45-02-4    Portable fire extinguisher gauge in red zone. For reporting purposes only.  
Extinguisher by server station ice machine in over charge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1300759

BOARDWALK BEACH HOTEL AND CONVENTION CENTER

License Type: Permanent Food Service

9400 S THOMAS DR, PANAMA CITY BEACH 32408

Inspection Date: 08/05/2022

Inspection Number: 3233220

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code    ObservationViolation Citation45-02-4    Portable fire extinguisher gauge in red zone. For reporting purposes only. K class  
in front kitchen in recharge zone

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1305578

RUNAWAY ISLAND BAR &amp; GRILL

License Type: Permanent Food Service

14521 FRONT BEACH RD, PANAMA CITY BEACH 32413

Inspection Date: 08/03/2022

Inspection Number: 3250004

Inspection Type: Complaint Full

Inspection Disposition: Emergency order recommended

Inspector Name: LYNN, NICKOLAS

Violation Code    ObservationViolation Citation45-02-4    Portable fire extinguisher gauge in red zone. For reporting purposes only. K class  
in recharge zone closest to mop sink.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Brevard County**

License Number: 1504679

FLORIDA'S SEAFOOD BAR AND GRILL

License Type: Permanent Food Service

480 W COCOA BEACH CSWY, COCOA BEACH 32931

Inspection Date: 08/01/2022

Inspection Number: 3248353

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HICKS, GEORGE RANDY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Silver by 2 bay sink. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1623342 PAPA JOHN'S PIZZA  
 License Type: Permanent Food Service 1862 N YOUNG CIR, HOLLYWOOD 33020

Inspection Date: 08/02/2022 Inspection Number: 3198088 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: ROGERS, VERNEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Main kitchen rear exit door- observed exit door being blocked by empty boxes.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1625178 HARD BEAN GRAND CAFE  
 License Type: Permanent Food Service 1866 N YOUNG CIR STE 7B, HOLLYWOOD 33020

Inspection Date: 08/02/2022 Inspection Number: 3243053 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: ROGERS, VERNEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Main kitchen rear exit door- observed exit door being blocked by table.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1610753 WENDY'S 1949  
 License Type: Permanent Food Service 3535 HOLLYWOOD BLVD, HOLLYWOOD 33021

Inspection Date: 08/04/2022 Inspection Number: 3219793 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: ROGERS, VERNEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Main kitchen rear exit door- observed exit door being blocked by trash can. Operator removed trash can.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Charlotte County**

License Number: 1801657

HOLIDAY INN EXPRESS PORT CHARLOTTE

License Type: Permanent Food Service

24440 SANDHILL BLVD, PUNTA GORDA 33983

Inspection Date: 08/03/2022

Inspection Number: 3237568

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SAYED, MOHAMMED

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Dade County**

License Number: 2333016 SUBWAY OF PALMED  
 License Type: Permanent Food Service 7150 W 20 AVE STE M131, HIALEAH 33016

Inspection Date: 08/05/2022 Inspection Number: 3192015 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: CRUZ, EDGAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2335458 FOUR POINTS BY SHERIDAN  
 License Type: Permanent Food Service 3570 NW 74TH AVE, MIAMI 33122

Inspection Date: 08/03/2022 Inspection Number: 3234709 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: SANCHEZ, JAVIER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. FL 134359, FL 134358	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2332112 CHAMPIONS SPORTS BAR  
 License Type: Permanent Food Service 1201 NW LEJEUNE RD, MIAMI 33126

Inspection Date: 08/04/2022 Inspection Number: 3221839 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied  
 Inspector Name: ORDONEZ, CATALINA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boilers certificates expired. - From follow-up inspection 2022-07-28: No current insurance insp	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Dade County**

License Number: 2312591 VALERIE'S CAFE  
 License Type: Permanent Food Service 2148 NW 17 AVE #2, MIAMI 33142

Inspection Date: 08/05/2022 Inspection Number: 3204981 Inspection Type: Routine - Food Inspection Disposition: Emergency order recommended  
 Inspector Name: SAENZ, HILDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed at the right side of the main entrance. - From follow-up inspection 2022-05-13: **Time Extended** - From follow-up inspection 2022-08	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2335402 BOOBY TRAP ON THE RIVER  
 License Type: Permanent Food Service 3615 NW SOUTH RIVER DRIVE, MIAMI 33142

Inspection Date: 08/04/2022 Inspection Number: 3212425 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BROWN, JARON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed two LP gas tanks inside building beside reach in cooler Operator moved tanks outside. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2336954 ORNO  
 License Type: Permanent Food Service 1350 S. DIXIE HWY, CORAL GABLES 33146

Inspection Date: 08/03/2022 Inspection Number: 3236883 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MASKASEM, SUPPACHAI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Trash cart blocking the exit door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2336943

CHICK FIL A NORTH MIAMI BEACH

License Type: Permanent Food Service

820 N MIAMI BEACH BLVD, NORTH MIAMI BEACH 33162

Inspection Date: 08/02/2022

Inspection Number: 3249144

Inspection Type: Complaint Full

Inspection Disposition: Emergency order recommended

Inspector Name: STUBBS, CHRISTINE

Violation Code    ObservationViolation Citation

46-01-4    Marked exit/path to marked exit blocked. For reporting purposes only. Observed 20+ empty boxes on the kitchen floor by the door exit marked. \*\*Warning\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2327594

BURBOWL

License Type: Permanent Food Service

1673 SW 107 AVE, MIAMI 33165

Inspection Date: 08/04/2022

Inspection Number: 3205497

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ELDER, AUDREY

Violation Code    ObservationViolation Citation

46-01-4    Marked exit/path to marked exit blocked. For reporting purposes only. Observed back exit door blocked by table, chair and chalk board.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2337151

SHOMA BAZAAR

License Type: Permanent Food Service

9420 NW 41 ST, DORAL 33178

Inspection Date: 08/04/2022

Inspection Number: 3213368

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SWIGERT, RICHARD

Violation Code    ObservationViolation Citation

48-01-5    No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2337172

SHAHS OF KABOB

License Type: Permanent Food Service

9420 NW 41 ST # 13, DORAL 33178

Inspection Date: 08/04/2022

Inspection Number: 3207979

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SWIGERT, RICHARD

Violation Code    ObservationViolation Citation

48-01-5    No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



**Dade County**

License Number: 2337175 IN RAMEN, ASIAN STREET EATERY  
 License Type: Permanent Food Service 9420 NW 41 ST UNIT 102, DORAL 33178

Inspection Date: 08/04/2022 Inspection Number: 3237348 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SWIGERT, RICHARD

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.  
 For reporting purposes only.

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2337178 BFF BURGERS  
 License Type: Permanent Food Service 9420 NW 41 ST #110, DORAL 33178

Inspection Date: 08/04/2022 Inspection Number: 3237299 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SWIGERT, RICHARD

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.  
 For reporting purposes only.

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2337181 ASH PIZZA DORAL  
 License Type: Permanent Food Service 9420 NW 41 ST, # 108, DORAL 33178

Inspection Date: 08/04/2022 Inspection Number: 3213683 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SWIGERT, RICHARD

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.  
 For reporting purposes only.

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2337316 CHIKIN DORAL LLC  
 License Type: Permanent Food Service 9420 NW 41 ST UNIT 111, DORAL 33178

Inspection Date: 08/04/2022 Inspection Number: 3196901 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SWIGERT, RICHARD

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.  
 For reporting purposes only.

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Dade County**

License Number: 2335091

BULLA GASTROBAR

License Type: Permanent Food Service

5335 NW 87 AVE C102, MIAMI 33178

Inspection Date: 08/02/2022

Inspection Number: 3233526

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: SWIGERT, RICHARD

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed. five tanks upstairs next to the drink walk-in cooler. Observed another tank under the hand washing sink.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2613933 CASBAH CAFE  
 License Type: Permanent Food Service 3628 ST JOHNS AVE, JACKSONVILLE 32205

Inspection Date: 08/05/2022 Inspection Number: 3229018 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. For hookah	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2609811 THE MITT TEX-MEX CAFE  
 License Type: Permanent Food Service 4130 SALISBURY RD STE 1000, JACKSONVILLE 32216

Inspection Date: 08/04/2022 Inspection Number: 3237805 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: VILBRUN, JOSUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Operator uses stove and flat top plug in electrical grill in kitchen area with no hood system **Repea	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Lake County**

License Number: 4508780 POPEYES #12310  
 License Type: Permanent Food Service 16530 STATE RD 50, CLERMONT 34711

Inspection Date: 08/01/2022 Inspection Number: 3248768 Inspection Type: Complaint Full Inspection Disposition: Warning Issued  
 Inspector Name: NORVE, MICHELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4508836 HUNGRY HOWIE'S #3023  
 License Type: Permanent Food Service 1215 SUNRISE PLAZA DRIVE, SUITE A, CLERMONT 34714

Inspection Date: 08/05/2022 Inspection Number: 3250444 Inspection Type: Complaint Full Inspection Disposition: Warning Issued  
 Inspector Name: NORVE, MICHELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Manatee County**

License Number: 5105695

MAPLE STREET BISCUIT COMPANY

License Type: Permanent Food Service

8491 COOPER CREEK BLVD STE 107, UNIVERSITY 34201

Inspection Date: 08/04/2022

Inspection Number: 3235894

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: EASLER, VERONICA

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.  
Observed fire extinguisher across from the fryer station in the overcharged zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Marion County**

License Number: 5203062

TEXAS ROADHOUSE

License Type: Permanent Food Service

3015 SW 32 AVE, OCALA 34474

Inspection Date: 08/05/2022

Inspection Number: 3248384

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: FORBES, WAYNE

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.  
Extinguisher near walk-in cooler in red zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Okeechobee County**

License Number: 5700449

BEEF O BRADY'S

License Type: Permanent Food Service

608 S PARROTT AVE, OKEECHOBEE 34974

Inspection Date: 08/02/2022

Inspection Number: 3222438

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JACKS, ALBERT

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only by office with beer kegs. Operator removed from area to clear exit. **\*\*Corrected On-Site\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5814101 PETER'S KITCHEN CHINA BISTRO  
 License Type: Permanent Food Service 3922 E COLONIAL DR, ORLANDO 32803

Inspection Date: 08/01/2022 Inspection Number: 3216861 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: VALERIO, GRACE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. - Heavy grease accumulation near kitchen entrance between cook line. Flat top grill used to cook food	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810981 THE OLIVE GARDEN ITALIAN RESTAURANT #1614  
 License Type: Permanent Food Service 4101 CONROY RD, ORLANDO 32839

Inspection Date: 08/02/2022 Inspection Number: 3198607 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PASIECKI, VICTORIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Boxes blocking rear exit. Operator removed **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811440 BELLA TUSCANY RISTORANTE ITALIANO  
 License Type: Permanent Food Service 13424 SUMMERPORT VILLAGE PKWY, WINDERMERE 34786

Inspection Date: 08/04/2022 Inspection Number: 3233295 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: CONNOLLY, MADELINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6213562 THE GALLEY  
 License Type: Permanent Food Service 27 4 ST N, ST. PETERSBURG 33701

Inspection Date: 08/03/2022 Inspection Number: 3228194 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: MURPHY, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Five 20 lb propane tanks stored in rear storage area hallway.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215995 STACIES COTTAGE CAFE  
 License Type: Permanent Food Service 501 1 AVE N #108, ST. PETERSBURG 33701

Inspection Date: 08/01/2022 Inspection Number: 3228270 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MURPHY, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Eggs being cooked on cooktop grip with no hood system present.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216763 SAB CAFE  
 License Type: Permanent Food Service 111 2 AVE NE STE 100, ST. PETERSBURG 33701

Inspection Date: 08/04/2022 Inspection Number: 3248374 Inspection Type: Complaint Full Inspection Disposition: Warning Issued  
 Inspector Name: MURPHY, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. Exit door in rear prep area is locked.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Polk County**

License Number: 6306376

HAVANA CAFE DELIGHTS INC

License Type: Permanent Food Service

155 E MAIN ST, BARTOW 33830

Inspection Date: 08/04/2022

Inspection Number: 3211064

Inspection Type: Routine - Food

Inspection Disposition: Emergency order recommended

Inspector Name: VELAZQUEZ, STEPHANIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. <b>**Repeat Violation**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. <b>**Repeat Violation**</b> - From follow-up inspection 2022-08-05: Use of co	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Sarasota County**

License Number: 6805296

BOONBON RESTAURANT AND LOUNGE

License Type: Permanent Food Service

1118 N WASHINGTON BLVD, SARASOTA 34236

Inspection Date: 08/04/2022

Inspection Number: 3236449

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MCKEON, MICHAEL

Violation Code    Observation

Violation Citation

46-01-4    Marked exit/path to marked exit blocked. For reporting purposes only.  
 Marked exit at the back of the kitchen blocked by case of canned beverages,  
 brooms and dust pans.  
 Employees removed all items.  
 As a repeat violation the importance of following proper

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Seminole County**

License Number: 6904404

FLANAGAN'S SPORTS PUB & EATERY

License Type: Permanent Food Service

995 W SR 434 SUITE 4A, LONGWOOD 32750

Inspection Date: 08/05/2022

Inspection Number: 3230010

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. K class hand held in the red

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**St. Johns County**

License Number: 6502265

KEKES BREAKFAST CAFE

License Type: Permanent Food Service

135 JENKINS ST, ST AUGUSTINE 32086

Inspection Date: 08/02/2022

Inspection Number: 3237864

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: GROTZ, CINDY

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Fire pull at back door is taped off to prevent use.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7406957

BJ'S RESTAURANT &amp; BREWHOUSE 500

License Type: Permanent Food Service

2514 W INTERNATIONAL SPEEDWAY BLVD, DAYTONA BEACH 32114

Inspection Date: 08/02/2022

Inspection Number: 3229876

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: BRANNER, LISELOTTE

Violation Code    ObservationViolation Citation

49-03-4      Flammables stored/debris present in water heater room. For reporting purposes only.  
 -boxes stored in water heater room

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 7404426

SUBWAY #3867

License Type: Permanent Food Service

2429 N ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 08/05/2022

Inspection Number: 3229198

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code    ObservationViolation Citation

46-01-4      Marked exit/path to marked exit blocked. For reporting purposes only.  
 -large bag of garbage and shopping cart in front of rear marked exit door  
 \*\*Corrected On-Site\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406392

COLD STONE CREAMERY

License Type: Permanent Food Service

250 N ATLANTIC AVE STE 102, DAYTONA BEACH 32118

Inspection Date: 08/05/2022

Inspection Number: 3195661

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code    ObservationViolation Citation

47-03-4      Observed electrical wiring in disrepair. For reporting purposes only.  
 -near fire exit door next to electrical box, exposed wiring

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Walton County**

License Number: 7602298

IM SKEWED BAR AND GRILL

License Type: Permanent Food Service

11394 HWY 98 W STE A, MIRAMAR BEACH 32550

Inspection Date: 01/27/2022

Inspection Number: 3249132

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: SHANKLIN, CYNTHIA

Violation Code

Observation

Violation Citation

45-04-4

OBSERVED: USE OF COOKING EQUIPMENT PRODUCING GREASE LADEN VAPORS/SMOKE WITH PARTIALLY NOT UNDER HOOD SUPPRESSION SYSTEM INSTALLED. NOTIFIED FIRE AHJ. STOVE TOP NOT HOOKED UP. OWNER STATED THAT IT IS ONLY USED FOR STORAGE. REPORTING PURPOSES ONLY.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.