

**Alachua County**

License Number: 1102812

LA TIENDA LATINA

License Type: Permanent Food Service

2204 SW 13 ST, GAINESVILLE 32608

Inspection Date: 08/19/2022

Inspection Number: 3254457

Inspection Type: Complaint Partial

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FORBES, WAYNE

Violation Code    ObservationViolation Citation

45-02-4      Portable fire extinguisher gauge in red zone. For reporting purposes only.  
 Extinguisher across from ice machine in red.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1103314

WAFFLE HOUSE

License Type: Permanent Food Service

5130 NW 13 ST, GAINESVILLE 32609

Inspection Date: 08/17/2022

Inspection Number: 3221430

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: CASEY, KEITH

Violation Code    ObservationViolation Citation

45-02-4      Portable fire extinguisher gauge in red zone. For reporting purposes only.  
 Observed the silver fire extinguisher having the yellow indicator in the red zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1601552 SUB CENTER  
 License Type: Permanent Food Service 5913 HOLLYWOOD BLVD, HOLLYWOOD 33021-6328

Inspection Date: 08/19/2022 Inspection Number: 3197807 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: ROGERS, VERNEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed exit door being blocked by bread rack. Operator removed bread rack. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1616103 PIZZA HUT #012362  
 License Type: Permanent Food Service 4506 HOLLYWOOD BLVD, HOLLYWOOD 33021-6612

Inspection Date: 08/18/2022 Inspection Number: 3203656 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: ROGERS, VERNEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Main kitchen rear exit door- observed exit door being blocked by trash can.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1624197 PANDA EXPRESS #2601  
 License Type: Permanent Food Service 5860 HOLLYWOOD BLVD, HOLLYWOOD 33023

Inspection Date: 08/19/2022 Inspection Number: 3210498 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PIERRE, ENOSE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Between front line and Drive- thru.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1623035 RIVERSIDE MARKET  
 License Type: Permanent Food Service 608 SW 12 AVE, FORT LAUDERDALE 33312

Inspection Date: 08/17/2022 Inspection Number: 3232770 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended  
 Inspector Name: GANPAT, INDAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Outlet under flat grill in cook line is not attached to wall.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Citrus County**

License Number: 1901384

WENDY'S 11653

License Type: Permanent Food Service

2900 W NORVELL BRYANT HWY, LECANTO 34461

Inspection Date: 08/16/2022

Inspection Number: 3202457

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DEMARCO, AMBER

Violation Code    Observation

Violation Citation

45-02-4    Portable fire extinguisher gauge in red zone. For reporting purposes only.  
Fire extinguisher in back prep area next to tea machine.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Clay County**

License Number: 2001235

LUCA'S ITALIAN AMERICAN RESTAURANT

License Type: Permanent Food Service

1339 BLANDING BLVD#8, ORANGE PARK 32065

Inspection Date: 08/16/2022

Inspection Number: 3240308

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: BIAVA, GRANT

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Exit door in bathroom hallway has a bar across door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2001379

HOLEY MOLEY BAGEL BAR NYC

License Type: Permanent Food Service

179 COLLEGE DR STE 19, ORANGE PARK 32065

Inspection Date: 08/16/2022

Inspection Number: 3241147

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: BIAVA, GRANT

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Establishment has a small fryer in kitchen that is not under a hood system, hood system that is instal

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2001319

YUME FUSION

License Type: Permanent Food Service

2640 BLANDING BLVD STE 204, MIDDLEBURG, FL 32068 32068

Inspection Date: 08/19/2022

Inspection Number: 3238502

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: JONES, CHAUNA

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed two ladder and vacuum blocking back door near dining room. Operator removed items during inspection. \*\*Corrected On-Site\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Columbia County**

License Number: 2200171

WENDYS OLD FASHIONED HAMBURGER

License Type: Permanent Food Service

3081 US HWY 90, LAKE CITY 32055

Inspection Date: 08/18/2022

Inspection Number: 3205070

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. In the recharge zone in the hallway towards the office.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2330395

MIAMI GRILL CATERING

License Type: Permanent Food Service

2350 W 84 ST #8, HIALEAH 33016

Inspection Date: 08/18/2022

Inspection Number: 3227728

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: CRUZ, EDGAR

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2332360

MAIN KITCHEN &amp; BAY CAFE

License Type: Permanent Food Service

485 BRICKELL AVE, MIAMI 33131

Inspection Date: 08/15/2022

Inspection Number: 3216086

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

48-02-5

Insurance inspector boiler report not posted in boiler room. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2335110

SUPPORT KITCHEN 39 FLOOR

License Type: Permanent Food Service

788 BRICKELL PLAZA, MIAMI 33131

Inspection Date: 08/18/2022

Inspection Number: 3196106

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

45-06-4

Portable fire extinguisher is inaccessible. For reporting purposes only. Observed Special K fire extinguisher on kitchen floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2329582

GOLD KOSHER CATERING

License Type: Catering

19593 NE 10 AVE BLDG 4 BAY C, NORTH MIAMI 33179

Inspection Date: 08/15/2022

Inspection Number: 1122703

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: UNZAGA, MILADYS

Violation Code    ObservationViolation Citation

45-02-4      Portable fire extinguisher gauge in red zone. For reporting purposes only.  
Observed 1 extinguisher in needs of charge .

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2336835

THE RESERVE COFFEE SHOP

License Type: Permanent Food Service

2885 NE 191 STREET, AVENTURA 33180

Inspection Date: 08/15/2022

Inspection Number: 3212657

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TAYLOR, JOHN

Violation Code    ObservationViolation Citation

45-04-4      Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.  
Observed establishment cooking on 2 table top stoves with no hood suppression system installed.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





**Duval County**

License Number: 2613590 HAMBURGER MARY'S JACKSONVILLE  
 License Type: Permanent Food Service 3333-1 BEACH BLVD, JACKSONVILLE 32207

Inspection Date: 08/17/2022 Inspection Number: 3229538 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: YOUNG, JENNIFER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Walk in freezer is missing push bar to exit freezer from the inside **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615609 EL PATIO OLANCHANO  
 License Type: Permanent Food Service 5851 UNIVERSITY BLVD WEST, JACKSONVILLE 32216

Inspection Date: 08/17/2022 Inspection Number: 3231443 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: VILBRUN, JOSUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Located in dry storage food and supply room on wall at left side of door entrance	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613975 SUBWAY  
 License Type: Permanent Food Service 1440 DUNN AVE STE 12A, JACKSONVILLE 32218

Inspection Date: 08/15/2022 Inspection Number: 3252377 Inspection Type: Complaint Full Inspection Disposition: Warning Issued  
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rear exit door blocked by bread oven and blocked by wooden barrier. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2614073 GREEN PAPAYA  
 License Type: Permanent Food Service 13141 CITY STATION DR #149, JACKSONVILLE 32218

Inspection Date: 08/16/2022 Inspection Number: 3220640 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Exit to rear door in hallway by restrooms is blocked by alcohol and equipment. Area cleared. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2613059

BONO'S BBQ

License Type: Permanent Food Service

3303 SAN PABLO RD S, JACKSONVILLE 32224

Inspection Date: 08/18/2022

Inspection Number: 3213242

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: GONZALEZ, MAYRA

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.  
16lbs propane tank stored on cook line next to bbq pit. Manager moved propane tank outside. **\*\*Corrected On-Site\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3917515 BIG CITY GRILL CO  
 License Type: Permanent Food Service 2490 W BRANDON BLVD, BRANDON 33511

Inspection Date: 08/15/2022 Inspection Number: 3238273 Inspection Type: Routine - Food Inspection Disposition: Emergency order recommended  
 Inspector Name: MOULDER, BRITTANY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed exit door blocked by a soda cooler in lobby **Warning**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
46-01-4	- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. Observed exit door blocked by a soda cooler in lobby **Warning** - From follow-up inspection 2022-08-16: Observed exit door blocked by a soda cooler in	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3952511 THE SURLY MERMAID  
 License Type: Mobile Food Dispensing Vehicle 1311 OAK POND ST, RUSKIN 33570

Inspection Date: 08/15/2022 Inspection Number: 1256899 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: AUDETTE, DAKOTA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3900819 RUSWALD THEATRES  
 License Type: Permanent Food Service 5011 N U S HWY 41, RUSKIN 335723501

Inspection Date: 08/18/2022 Inspection Number: 3131126 Inspection Type: Routine - Food Inspection Disposition: Call Back - Admin. complaint recommended  
 Inspector Name: CRUZ, JABULANI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Cooking burgers on flattop grill- discussed using oven to cook - From	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Lee County**

License Number: 4607351 NONNIE'S DELI  
 License Type: Permanent Food Service 4150 HANCOCK BRIDGE PKWY UNIT 16, NORTH FORT MYERS 33903

Inspection Date: 08/15/2022 Inspection Number: 3202454 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: FREED, JOSEPH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. Observed back door locked during operating hours. Operator unlocked door during inspection. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4600236 GEORGE & WENDYS SEAFOOD GRILLE  
 License Type: Permanent Food Service 2499 PERIWINKLE WAY, SANIBEL 33957

Inspection Date: 08/16/2022 Inspection Number: 3218729 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GONDERMANN, FRANK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Exit door on dinning room side cannot be opened due to paver bricks having heaved and not allowing door to fully open.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4603061 DENNY'S  
 License Type: Permanent Food Service 1306 DEL PRADO BLVD S, CAPE CORAL 33990

Inspection Date: 08/18/2022 Inspection Number: 3200908 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MOREHEAD, PHILIP

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Manatee County**

License Number: 5102978

WINGS N THINGS

License Type: Permanent Food Service

7640 N LOCKWOOD RIDGE RD, SARASOTA 34243

Inspection Date: 08/17/2022

Inspection Number: 3220769

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: EASLER, VERONICA

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed ladder blocking rear exit door next to employee bathroom.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Marion County**

License Number: 5202955

J ROCKS PIZZERIA

License Type: Permanent Food Service

2606 SW 19 AVE RD #103, OCALA 34471

Inspection Date: 08/16/2022

Inspection Number: 3234935

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: FIGUEROA-ROBLES, TATIANA

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.  
Back door closed to office area blocked by pizza boxes, chairs and tables.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Martin County**

License Number: 5300700

DECK RESTAURANT (THE)

License Type: Permanent Food Service

307 N RIVER DR, STUART 34994-1119

Inspection Date: 08/19/2022

Inspection Number: 3197808

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. No electrical cover/outlet=kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Okaloosa County**

License Number: 5603523

BRUSTERS REAL ICE CREAM

License Type: Permanent Food Service

4655 GULFSTARR DR, DESTIN 32541

Inspection Date: 08/12/2022

Inspection Number: 3239391

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: SHANKLIN, CYNTHIA

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher stored on floor under hand wash sink.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5812305

TACOS EL RANCHO 3

License Type: Permanent Food Service

331 N ORANGE AVE, ORLANDO 32801

Inspection Date: 08/18/2022

Inspection Number: 3229812

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: MARTIN, LESLIE

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.  
-2 flat grills at front counter

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

License Number: 5908782

SONIC DRIVE-IN

License Type: Permanent Food Service

4350 W 13 ST, SAINT CLOUD 34769

Inspection Date: 08/15/2022

Inspection Number: 3235125

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: DAVIS, DIANNA

Violation Code    ObservationViolation Citation45-05-4    Portable fire extinguisher missing from its designated location. For reporting  
purposes only. Extinguisher on floor by mop sink509.032(2)(d) FS Reporting: (d) The division, or its  
agent, shall notify the local firesafety authority or the  
State Fire Marshal of any readily observable violation of  
a rule adopted under chapter 633 which relates to public  
lodging establishments or public food establishments,  
and the identification of such violation does not require  
any firesafety inspection certification. For reporting  
purposes only.

License Number: 5911239

JALAPENOS MEXICAN RESTAURANT

License Type: Permanent Food Service

4585 13TH STREET, ST. CLOUD 34769

Inspection Date: 08/17/2022

Inspection Number: 3191939

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: LORENZO, ANA

Violation Code    ObservationViolation Citation46-01-4    Marked exit/path to marked exit blocked. For reporting purposes only./ reach in  
cooler in front of exit door .509.032(2)(d) FS Reporting: (d) The division, or its  
agent, shall notify the local firesafety authority or the  
State Fire Marshal of any readily observable violation of  
a rule adopted under chapter 633 which relates to public  
lodging establishments or public food establishments,  
and the identification of such violation does not require  
any firesafety inspection certification. For reporting  
purposes only.

**Palm Beach County**

License Number: 6020264 HYATT PLACE WEST PALM BEACH  
 License Type: Permanent Food Service 295 LAKEVIEW AVE, WEST PALM BEACH 33401

Inspection Date: 08/16/2022 Inspection Number: 3234085 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: AHLE, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6021573 JIMMY JOHNS GOURMET SANDWICH STORE 3404  
 License Type: Permanent Food Service 3111 45TH ST, SUITE 10, WEST PALM BEACH 33407

Inspection Date: 08/16/2022 Inspection Number: 3210323 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: KHATOON, BEGUM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked by box . For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6007142 EM SQUARED RESTAURANTS LLC  
 License Type: Permanent Food Service 667 ROYAL PALM BEACH BLVD, ROYAL PALM BEACH 33411

Inspection Date: 08/18/2022 Inspection Number: 3235068 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GOODWIN, NICHOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed at silver fire extinguisher next to back door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6013102 TGI FRIDAYS  
 License Type: Permanent Food Service 580 N SR 7, ROYAL PALM BEACH 33411

Inspection Date: 08/19/2022 Inspection Number: 3223061 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GOODWIN, NICHOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed at fire extinguisher next to back door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6013720 I HOP  
 License Type: Permanent Food Service 4745 W ATLANTIC AVE, DELRAY BEACH 33445

Inspection Date: 08/17/2022 Inspection Number: 3253051 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GOODWIN, NICHOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed at fire extinguisher next back door in ware washing area	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6052477 LA CATRACHA  
 License Type: Mobile Food Dispensing Vehicle 3585 S CONGRESS AVE, PALM SPRINGS 33461

Inspection Date: 08/09/2022 Inspection Number: 1259053 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SINGH, GAJENDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-05-4	Observed: Flammables stored near a source of ignition. For reporting purposes only. No divider, shield or space between deep fryer and gas burning stove. Explained	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6217638 11 CHICKS WHOLESALAS DIV  
 License Type: Permanent Food Service 199 DR MLK JR ST N, ST. PETERSBURG 33701

Inspection Date: 08/19/2022 Inspection Number: 3210701 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MURPHY, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Exit door blocked in kitchen area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6217327 SEA GUINI  
 License Type: Permanent Food Service 430 S GULFVIEW BLVD, CLEARWATER 33767

Inspection Date: 08/16/2022 Inspection Number: 3198808 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	current insurance inspector boiler report or boiler certificate available for boiler expired. For reporting purposes only. F1124543, F1124544, F1124545. Exp 7/22/22	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-01-5	- From initial inspection : current insurance inspector boiler report or boiler certificate available for boiler expired. For reporting purposes only. F1124543, F1124544, F1124545. Exp 7/22/22 - From follow-up inspection 2022-08-17: **Time Extended**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6217396 SANDBAR - TIKI BAR @ OPAL SANDS RESORT  
 License Type: Permanent Food Service 430 SOUTH GULFVIEW BLVD, CLEARWATER 33767

Inspection Date: 08/16/2022 Inspection Number: 3216128 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	current insurance inspector boiler report or boiler certificate available for boiler, expired. For reporting purposes only. F1124543, F1124544, F1124545. Exp 7/22/22	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Pinellas County**

License Number: 6217397

BANQUET KITCHEN @ OPAL SANDS RESORT

License Type: Permanent Food Service

430 SOUTH GULFVIEW BLVD, CLEARWATER 33767

Inspection Date: 08/16/2022

Inspection Number: 3227841

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation Code

Observation

Violation Citation

48-01-5

current insurance inspector boiler report or boiler certificate available for boiler expired. For reporting purposes only. F1124543, F1124544, F1124545. Exp 7/22/22

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



**Polk County**

License Number: 6307809

PALACE PIZZA

License Type: Permanent Food Service

5235 HIGHWAY 98 S, LAKELAND 33812

Inspection Date: 08/16/2022

Inspection Number: 3253010

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VELAZQUEZ, STEPHANIE

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.  
Mixer plug has exposed wiring

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Sarasota County**

License Number: 6805281

LOPERA BAKERY BISTROT

License Type: Permanent Food Service

2336 GULF GATE DR, SARASOTA 34231

Inspection Date: 08/17/2022

Inspection Number: 3217137

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: RODARTE, ERIC

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.  
 Observed exit blocked by bakery rolling rack.  
 Operator moved rack and cleared path. \*\*Corrected On-Site\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**St. Johns County**

License Number: 6501615

GRILLED CHEESE GALLERY

License Type: Permanent Food Service

16 CATHEDRAL PL, SAINT AUGUSTINE 32084

Inspection Date: 08/15/2022

Inspection Number: 3234892

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: MAKOWSKI, JARED

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Establishment has self contained hood system but still has large amounts of grease laden vapors.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7406887

U CHINA

License Type: Permanent Food Service

326 SEABREEZE BLVD, DAYTONA BEACH 32118

Inspection Date: 08/18/2022

Inspection Number: 3211634

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Complied

Inspector Name: WOOD, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only.  -obstructed by tables - From follow-up inspection 2022-08-18: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.  -obstructed by tables	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.