

Brevard County

License Number: 1550865

RELISH THE GOOD TIMES HOT DOGS AND CATERING LLC

License Type: Mobile Food Dispensing Vehicle

1 ORANGE AVE, ROCKLEDGE 32955

Inspection Date: 08/26/2022

Inspection Number: 1250266

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FICHTER, GARRICK

Violation Code

Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2103536

LUCKY DAWGS 2

License Type: Permanent Food Service

12435 COLLIER BLVD UNIT 101, NAPLES 34116

Inspection Date: 08/23/2022

Inspection Number: 3201014

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MEADE, ARTHUR

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Several boxes blocking exit, side door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2336836 JOUJOU CARIBBEAN TAKE-OUT
 License Type: Permanent Food Service 331 WEST PALM DRIVE, FLORIDA CITY 33034

Inspection Date: 08/25/2022 Inspection Number: 3230480 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEIDECKER, EDILMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. At the storage area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2332569 ATELIER MONNIER
 License Type: Permanent Food Service 848 BRICKELL AVE #120, MIAMI 33131

Inspection Date: 08/23/2022 Inspection Number: 3204024 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2334381 VERMONIC'S CAFE
 License Type: Permanent Food Service 3191 CORAL WAY STE 111, CORAL GABLES 33145

Inspection Date: 08/24/2022 Inspection Number: 3217076 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed a single portable grease fryer in use to fry empanadas and croquettes. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2335573 LA DESPENSA KEY BISCAYNE
 License Type: Permanent Food Service 260 CRANDON BLVD UNIT 17, MIAMI 33149

Inspection Date: 08/22/2022 Inspection Number: 3210444 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CABANAS, NATALIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2324471

TACO BELL #5485

License Type: Permanent Food Service

599 NE 167 ST, MIAMI 33162

Inspection Date: 08/26/2022

Inspection Number: 3197967

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: STUBBS, CHRISTINE

Violation Code Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Observed garbage bin, and boxes of garbage.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2608566 J J'S CAFE
 License Type: Permanent Food Service 6622 SOUTHPOINT DR S, JACKSONVILLE 32216

Inspection Date: 08/22/2022 Inspection Number: 3234360 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VILBRUN, JOSUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Operator cooking on flat top grill with no hood suppression system **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2608586 DENNY'S #8006
 License Type: Permanent Food Service 14697 DUVAL RD, JACKSONVILLE 32218

Inspection Date: 08/22/2022 Inspection Number: 3253711 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher by walk in freezer in kitchen. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2614872 NEWK'S EATERY
 License Type: Permanent Food Service 14964 MAX LEGGETT PKWY #408, JACKSONVILLE 32218

Inspection Date: 08/25/2022 Inspection Number: 3238910 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher by rear exit door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2651335 KTL SERVICES
 License Type: Mobile Food Dispensing Vehicle 1401 WHEELS RD, JACKSONVILLE 32218

Inspection Date: 08/22/2022 Inspection Number: 1257211 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher by hand washing sink in vehicle.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2615645 MODU RAMEN
 License Type: Permanent Food Service 8602 BAYMEADOWS RD UNIT 24, JACKSONVILLE 32256

Inspection Date: 08/25/2022 Inspection Number: 3216906 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: JEFFERS, MARY-BETH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tank larger than 2.7 LBs stored in dry food storage area **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613096 PIZZA HUT 4274
 License Type: Permanent Food Service 6140 MERRILL RD, JACKSONVILLE 32277

Inspection Date: 08/25/2022 Inspection Number: 3238633 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: THOMAS, PHILIP

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. One door of double door exit locked in closed position. Operator opened second door. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Flagler County

License Number: 2800647

WENDY'S 9993

License Type: Permanent Food Service

440 SW PALM COAST PKWY, PALM COAST 32137

Inspection Date: 08/23/2022

Inspection Number: 3218535

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: HARTMANN, MICHELLE

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
Back door is blocked by boxes.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2800879

RED KOI

License Type: Permanent Food Service

101 PALM HARBOR PKWY, UNIT B-118, PALM COAST 32137

Inspection Date: 08/26/2022

Inspection Number: 3237968

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: HARTMANN, MICHELLE

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside
of the building. For reporting purposes only.
5 propane tanks on floor in dry storage area. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Highlands County

License Number: 3800806

SONIC DRIVE-IN 6668

License Type: Permanent Food Service

650 US HWY 27 N, SEBRING 33870

Inspection Date: 08/23/2022

Inspection Number: 3236153

Inspection Type: Routine - Food

Inspection Disposition: Emergency order recommended

Inspector Name: SCHNELL, PAMELA

Violation Code Observation

Violation Citation

47-03-4 Observed electrical wiring in disrepair. For reporting purposes only. Observed open light socket in walk-in freezer.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

47-03-4 - From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. Observed open light socket in walk-in freezer. - From follow-up inspection 2022-08-23: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lake County

License Number: 4502282

CRACKER BARREL #489

License Type: Permanent Food Service

1520 E HWY 50, CLERMONT 34711

Inspection Date: 08/23/2022

Inspection Number: 3227463

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: NORVE, MICHELLE

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Back exit door blocked by trash bins. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4607390 MEXICAN BOTANAS & FRUTAS LOCAS
 License Type: Permanent Food Service 80 PONDELLA RD STE D, NORTH FORT MYERS 33903

Inspection Date: 08/23/2022 Inspection Number: 3195090 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FREED, JOSEPH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed boards blocking rear exit.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4604207 TACO BELL #24552
 License Type: Permanent Food Service 4860 PALM BEACH BLVD, FORT MYERS 33905

Inspection Date: 08/22/2022 Inspection Number: 3220654 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FREED, JOSEPH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed large trash bin blocking rear exit door in kitchen. Operator had employee move bin during inspection. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4607532 SERRANO RESTAURANT
 License Type: Permanent Food Service 3940 METRO PKWY STE 122, FORT MYERS 33916-9407

Inspection Date: 08/26/2022 Inspection Number: 3231742 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: FREED, JOSEPH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed propane tanks used in kitchen area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5202283

KFC # L518067

License Type: Permanent Food Service

3810 SW COLLEGE RD, OCALA 34474

Inspection Date: 08/23/2022

Inspection Number: 3207942

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CASEY, KEITH

Violation CodeObservationViolation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.
Observed the light switch for the left walk-in cooler has visible wires and no cover.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5202414

LAKI'S RESTAURANT

License Type: Permanent Food Service

3405 SW COLLEGE RD, OCALA 34474

Inspection Date: 08/23/2022

Inspection Number: 3191349

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CASEY, KEITH

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Observed a fire extinguisher in the dry storage closet, indicator is in the red zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301652

SAILOR'S RETURN

License Type: Permanent Food Service

625 SW ANCHORAGE WAY, STUART 34994

Inspection Date: 08/24/2022

Inspection Number: 3213238

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Cover plate broken/employee restroom

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5814365 SUPER RICO COLOMBIAN RESTAURANT
 License Type: Permanent Food Service 62 W WASHINGTON ST, ORLANDO 32801

Inspection Date: 08/23/2022 Inspection Number: 3238144 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PLEICONES, KIM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Exit path behind door by stand up cooler has unused equipment and bar stools, in path to other direct exit door from building	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5814852 TAKE A SUSHI
 License Type: Permanent Food Service 4725 W SAND LAKE RD STE 101, ORLANDO 32819

Inspection Date: 08/24/2022 Inspection Number: 3230677 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: KOSTELNY, ROGER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. Inside owners office For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5813736 VIVOLI GELATERIA
 License Type: Permanent Food Service 1638 E BUENA VISTA DR, ORLANDO 32830

Inspection Date: 08/23/2022 Inspection Number: 3233560 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-05-4	Flammables stored near a source of ignition. For reporting purposes only. Observed two paint cans stored next to dry storage shelves.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5911468 MU RESTAURANT LLC
 License Type: Permanent Food Service 3092 MICHIGAN AVE, KISSIMMEE 34744

Inspection Date: 08/23/2022 Inspection Number: 3241503 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: DAVIS, DIANNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5911554 WENDY'S # 11932
 License Type: Permanent Food Service 3271 VINELAND RD, KISSIMMEE 34746

Inspection Date: 08/23/2022 Inspection Number: 3222441 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ZAPATA, MAUREEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rolling cart blocking the back exit door. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5911656 EL PAISA DE KISSIMMEE
 License Type: Permanent Food Service 4655 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 08/26/2022 Inspection Number: 3196071 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ZAPATA, MAUREEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. Trash can blocking the exit.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900811 INTERNATIONAL HOUSE OF PANCAKES #36-103
 License Type: Permanent Food Service 7529 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34747

Inspection Date: 08/22/2022 Inspection Number: 3252731 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DAVIS, DIANNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. Discussed Back door in dry storage area blocked but still usable.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5911668

GRAND HOTEL KISSIMMEE - BREAKFAST

License Type: Permanent Food Service

3104 PARKWAY BOULEVARD, KISSIMMEE 34747

Inspection Date: 08/26/2022

Inspection Number: 3190054

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

48-01-5

- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2022-08-26: **Time Extended**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Palm Beach County

License Number: 6019582 CHARLEY'S
 License Type: Permanent Food Service 601 N CONGRESS AVE #406, DELRAY BEACH 33445

Inspection Date: 08/23/2022 Inspection Number: 3224201 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GOODWIN, NICHOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed at fire extinguisher next to back door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6021223 COURTYARD BY MARRIOTT
 License Type: Permanent Food Service 4800 MAIN STREET, JUPITER 33458

Inspection Date: 08/22/2022 Inspection Number: 3207429 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MCCARTHY, RAMONA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. All expired on 8/17/22	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6005175 DENNY'S REST 9594
 License Type: Permanent Food Service 1311 W PALMETTO PARK W, BOCA RATON 33486

Inspection Date: 08/26/2022 Inspection Number: 3195486 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: STEUBER, RYAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. At cookline	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6217796 BENTO CAFE
 License Type: Permanent Food Service 320 3 ST S, ST PETERSBURG 33701

Inspection Date: 08/24/2022 Inspection Number: 3234557 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MURPHY, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Two fire extinguishers located on the floor below hand wash sink in kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6218339 TIENDA LA HUASTECA
 License Type: Permanent Food Service 1745 DREW ST, CLEARWATER 33755

Inspection Date: 08/22/2022 Inspection Number: 3202450 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KLINGENSMITH, DESIREE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. -Two propane tanks stored inside Restaurant in front of reach in cooler meat case, Discussed with manager, manager moved pro	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6212306 NEW CHINA BEACH 2 LLC
 License Type: Permanent Food Service 6170 ULMERTON RD #14, CLEARWATER 33760

Inspection Date: 08/23/2022 Inspection Number: 3193034 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILMOT, TASHARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. -exit door in kitchen blocked by bucket Operator moved bucket during time of inspection. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6213502 BOSTON MARKET #766
 License Type: Permanent Food Service 4001 E BAY DR, CLEARWATER 33764

Inspection Date: 08/24/2022 Inspection Number: 3228635 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: WILMOT, TASHARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. -by garbage can and cart	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6214093 PAPA JOHNS PIZZA
 License Type: Permanent Food Service 18378 HWY 19 N, CLEARWATER 33764

Inspection Date: 08/24/2022 Inspection Number: 3194196 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILMOT, TASHARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. -blocked by trays and boxes	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215828 JET'S PIZZA
 License Type: Permanent Food Service 2045 GULF TO BAY BLVD, CLEARWATER 33765

Inspection Date: 08/26/2022 Inspection Number: 3236195 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: KLINGENSMITH, DESIREE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. -Extinguisher gauge in red and needs to be recharged. Discussed with manager.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6217051 TWISTEE TREAT USA LLC
 License Type: Permanent Food Service 905 E TARPON AVE, TARPON SPRINGS 34689

Inspection Date: 08/25/2022 Inspection Number: 3200662 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: AIELLO, ROCCI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By side door of establishment.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6805723

RINCON TOLTECA

License Type: Permanent Food Service

4607 S TAMIAMI TRL, SARASOTA 34231

Inspection Date: 08/22/2022

Inspection Number: 3235152

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RODARTE, ERIC

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.
Observed wiring on steam table is melted.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6502280

TREYLOR PARK

License Type: Permanent Food Service

158 MARKETSIDE AVE #10, PONTE VEDRA 32081

Inspection Date: 08/26/2022

Inspection Number: 3237889

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: PERKINS, MARC

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Under the main prep table opposite the rear exterior door, red propane gas tank stored by the pressure washer. Operator relo

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6602803

HURRICANE GRILL AND WINGS

License Type: Permanent Food Service

2202 SE VETERANS MEMORIAL PKWY, PORT ST LUCIE 34952

Inspection Date: 08/26/2022

Inspection Number: 3186633

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: HARROD, JESSICA

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. - From follow-up inspection 2022-08-26: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406391

D I S PRODUCTION KITCHEN AREA 1 AND 2

License Type: Catering

1801 W INTNL SPEEDWAY BLVD, DAYTONA BEACH 32114

Inspection Date: 08/25/2022

Inspection Number: 1122352

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406718

WINGHOUSE BAR AND GRILL

License Type: Permanent Food Service

250 N ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 08/25/2022

Inspection Number: 3196572

Inspection Type: Routine - Food

Inspection Disposition: Emergency Order Callback Complied

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

49-01-4

- From initial inspection : Flammables stored/debris present in meter room. For reporting purposes only.

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

-equipment with gas tanks stored inside meter room - From follow-up inspection 2022-08-25: **Time Extended**

49-01-4

Flammables stored/debris present in meter room. For reporting purposes only.

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

-equipment with gas tanks stored inside meter room

License Number: 7403146

BAMBOO GARDEN

License Type: Permanent Food Service

749 S NOVA RD, ORMOND BEACH 32174

Inspection Date: 08/25/2022

Inspection Number: 3195300

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RUTLEDGE, REBECCA

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
-marked exit path blocked by various items being stored in hallway

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.