

**Bay County**

License Number: 1304170

THE OLIVE GARDEN ITALIAN RESTAURANT # 1395

License Type: Permanent Food Service

2397 SR 77, PANAMA CITY 32402

Inspection Date: 09/01/2022

Inspection Number: 3192926

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. K class near dish pit.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Brevard County**

License Number: 1501371

ASHLEY'S OF ROCKLEDGE

License Type: Permanent Food Service

1609 S US HWY 1, ROCKLEDGE 329552817

Inspection Date: 08/29/2022

Inspection Number: 3245224

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FICHTER, GARRICK

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.  
In shed

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1622663

TIJUANA FLATS BURRITO CO

License Type: Permanent Food Service

3357 SHERIDAN ST, HOLLYWOOD 33021

Inspection Date: 08/30/2022

Inspection Number: 3232651

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: ROGERS, VERNEL

Violation Code    ObservationViolation Citation46-01-4    Marked exit/path to marked exit blocked. For reporting purposes only. Main  
kitchen rear exit door- observed exit door being blocked by trash can.509.032(2)(d) FS Reporting: (d) The division, or its  
agent, shall notify the local firesafety authority or the  
State Fire Marshal of any readily observable violation of  
a rule adopted under chapter 633 which relates to public  
lodging establishments or public food establishments,  
and the identification of such violation does not require  
any firesafety inspection certification. For reporting  
purposes only.

License Number: 1617150

LA BAMBA MEXICAN AND SPANISH RESTAURANT IV

License Type: Permanent Food Service

10169 W SUNRISE BLVD, PLANTATION 33322-7617

Inspection Date: 08/31/2022

Inspection Number: 3254829

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GRAY, ANTHONY

Violation Code    ObservationViolation Citation46-01-4    Marked exit/path to marked exit blocked. For reporting purposes only.  
Observed next to bar boxes and ladder. Operator removed ladder. \*\*Corrective  
Action Taken\*\*509.032(2)(d) FS Reporting: (d) The division, or its  
agent, shall notify the local firesafety authority or the  
State Fire Marshal of any readily observable violation of  
a rule adopted under chapter 633 which relates to public  
lodging establishments or public food establishments,  
and the identification of such violation does not require  
any firesafety inspection certification. For reporting  
purposes only.

**Dade County**

License Number: 2334907 RICOLOMBIA RESTAURANT  
 License Type: Permanent Food Service 715 E 9 ST, HIALEAH 33010

Inspection Date: 08/29/2022 Inspection Number: 3198754 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: BENITEZ, YOANNA

| <u>Violation Code</u> | <u>Observation</u>  | <u>Violation Citation</u>   |
|-----------------------|---|---|
| 46-01-4               | Marked exit/path to marked exit blocked. For reporting purposes only. Observed exit door blocked with chairs by the customer restrooms. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 2332786 SALVADORAN CUISINE  
 License Type: Permanent Food Service 15260 SW 280TH STREET, HOMESTEAD 33032

Inspection Date: 09/02/2022 Inspection Number: 3227116 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GOMEZ-SANCHEZ, NELLY

| <u>Violation Code</u> | <u>Observation</u>  | <u>Violation Citation</u>   |
|-----------------------|---|---|
| 45-02-4               | Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed in kitchen area. **Repeat Violation** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 2359305 REEF KITCHENS - VIN 06068  
 License Type: Mobile Food Dispensing Vehicle 3452 N MIAMI AVE, MIAMI 33127

Inspection Date: 08/30/2022 Inspection Number: 1252271 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GONZALEZ, ERIK

| <u>Violation Code</u> | <u>Observation</u>   | <u>Violation Citation</u>   |
|-----------------------|--|---|
| 45-02-4               | Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher in recharge zone inside MFDV. Operator replaced empty for a fully charged per extinguisher. **Corrected On-Site** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 2359812 REEF KITCHENS - VIN 89696  
 License Type: Mobile Food Dispensing Vehicle 3452 N MIAMI AVE, MIAMI 33127

Inspection Date: 09/02/2022 Inspection Number: 1255181 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GONZALEZ, ERIK

| <u>Violation Code</u> | <u>Observation</u>   | <u>Violation Citation</u>   |
|-----------------------|--|---|
| 45-02-4               | Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher in recharge zone inside MFDV. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

**Dade County**

License Number: 2333486

LA GUADALUPANA ICE CREAM INC

License Type: Permanent Food Service

1058 SW 1 ST, MIAMI 33130

Inspection Date: 08/31/2022

Inspection Number: 3216651

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation Code    ObservationViolation Citation

45-04-4      Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.  
\*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2334708

DECK SIXTEEN

License Type: Permanent Food Service

1600 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 09/01/2022

Inspection Number: 3196798

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: HODGE, KRISTEN

Violation Code    ObservationViolation Citation

48-01-5      No current insurance inspector boiler report or expired boiler certificate available for boiler. Observed boiler jurisdiction number's 132830, 132829 & 132828 expired on 1/27/2022. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2317118

EL MEJOR PAN CON LECHON INC

License Type: Permanent Food Service

2928 NW 17 AVE, MIAMI 33142

Inspection Date: 08/30/2022

Inspection Number: 3221657

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BROWN, JARON

Violation Code    ObservationViolation Citation

48-04-4      Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2331271

HI-POT

License Type: Permanent Food Service

1665 SW 107TH AVE, MIAMI 33165

Inspection Date: 09/01/2022

Inspection Number: 3222667

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: ELDER, AUDREY

Violation Code    ObservationViolation Citation

46-01-4      Marked exit/path to marked exit blocked. For reporting purposes only. Observed at back exit door near bathrooms.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2337156

TINTTO BY TRIBUTTO

License Type: Permanent Food Service

9420 NW 41 STREET, DORAL 33178

Inspection Date: 08/19/2022

Inspection Number: 3201992

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SWIGERT, RICHARD

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. \*\*Repeat Violation\*\*

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**DeSoto County**

License Number: 2400210

EL CHARRO MEXICAN RESTAURANT

License Type: Permanent Food Service

420 N BREVARD AVE, ARCADIA 342664504

Inspection Date: 08/30/2022

Inspection Number: 3222265

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHNELL, PAMELA

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 20lb LP tank stored in building across from walk-in coolers.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

|  |   |   |  |
|--|---|---|--|
| License Number: 2611323                  |   | CROSS CREEK STEAKHOUSE  |  |
| License Type: Permanent Food Service     |   | 850 S LANE AVE, JACKSONVILLE 32205  |  |
| Inspection Date: 09/02/2022              | Inspection Number: 3258267  | Inspection Type: Complaint Full   | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: ESPINOSA-BECKERT, ILIANA |   |   |  |
| <u>Violation Code</u>                    | <u>Observation</u>  | <u>Violation Citation</u>   |  |
| 45-02-4                                  | Portable fire extinguisher gauge in red zone. For reporting purposes only. By entrance to kitchen **Repeat Violation**  | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |  |
| License Number: 2613358                  |   | SUBWAY #31891   |  |
| License Type: Permanent Food Service     |   | 8110 LEM TURNER RD #1, JACKSONVILLE 32208   |  |
| Inspection Date: 09/01/2022              | Inspection Number: 3204996  | Inspection Type: Routine - Food   | Inspection Disposition: Emergency order recommended              |
| Inspector Name: PERRY, DENNIS            |   |   |  |
| <u>Violation Code</u>                    | <u>Observation</u>  | <u>Violation Citation</u>   |  |
| 45-05-4                                  | Portable fire extinguisher missing from its designated location. For reporting purposes only.<br>Fire extinguisher by front counter. Fire extinguisher placed back into place.<br>**Corrected On-Site** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |  |
| License Number: 2613650                  |   | NAPOLIS PIZZA CUISINE   |  |
| License Type: Permanent Food Service     |   | 5624 ARLINGTON RD, JACKSONVILLE 32211   |  |
| Inspection Date: 08/29/2022              | Inspection Number: 3256593  | Inspection Type: Complaint Full   | Inspection Disposition: Administrative complaint recommended     |
| Inspector Name: THOMAS, PHILIP           |   |   |  |
| <u>Violation Code</u>                    | <u>Observation</u>  | <u>Violation Citation</u>   |  |
| 48-04-4                                  | Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.<br>5lb propane tank stored next to walk in cooler. Discussed          | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |  |
| License Number: 2611917                  |   | SUBWAY #1070  |  |
| License Type: Permanent Food Service     |   | 1030 N UNIVERSITY BLVD, JACKSONVILLE 322115532  |  |
| Inspection Date: 09/02/2022              | Inspection Number: 3257843  | Inspection Type: Complaint Full   | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: THOMAS, PHILIP           |   |   |  |
| <u>Violation Code</u>                    | <u>Observation</u>  | <u>Violation Citation</u>   |  |
| 46-04-4                                  | Exit door locked. For reporting purposes only.<br>One door of double door marked exit at front of store locked.   | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |  |



**Duval County**

License Number: 2609884                      BONO'S BBQ  
 License Type: Permanent Food Service                      5711 BOWDEN RD #19, JACKSONVILLE 322166160

Inspection Date: 08/31/2022      Inspection Number: 3202744      Inspection Type: Routine - Food      Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: VILBRUN, JOSUE

| <u>Violation Code</u> | <u>Observation</u>  | <u>Violation Citation</u>   |
|-----------------------|---|---|
| 46-01-4               | Marked exit/path to marked exit blocked. For reporting purposes only.<br>Dining room exit back door blocked with cases of to go cups and plates | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 2615845                      DOS VATOS TACOS  
 License Type: Permanent Food Service                      1451 ATLANTIC BLVD, NEPTUNE BEACH 32266

Inspection Date: 08/31/2022      Inspection Number: 3201948      Inspection Type: Routine - Food      Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: THOMAS, PHILIP

| <u>Violation Code</u> | <u>Observation</u>   | <u>Violation Citation</u>   |
|-----------------------|--|---|
| 48-04-4               | Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.<br>5lb propane tank inside kitchen area. Operator removed. **Corrected On-Site** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

**Hillsborough County**

License Number: 3915813 SUBWAY #34711  
 License Type: Permanent Food Service 1208 E BRANDON BLVD, BRANDON 33511

Inspection Date: 08/31/2022 Inspection Number: 3196766 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MOULDER, BRITTANY

| <u>Violation Code</u> | <u>Observation</u>  | <u>Violation Citation</u>   |
|-----------------------|---|---|
| 46-01-4               | Marked exit/path to marked exit blocked. For reporting purposes only.<br>Observed exit blocked with trash can and old boxes<br>Corrected-observed employee remove **Corrected On-Site** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 3910962 KENTUCKY FRIED CHICKEN  
 License Type: Permanent Food Service 3102 E COLLEGE AVE, RUSKIN 335705225

Inspection Date: 09/02/2022 Inspection Number: 3220228 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: CRUZ, JABULANI

| <u>Violation Code</u> | <u>Observation</u>   | <u>Violation Citation</u>   |
|-----------------------|--|---|
| 45-02-4               | Portable fire extinguisher gauge in red zone. For reporting purposes only. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

**Indian River County**

License Number: 4105310

EL SAUSSIE

License Type: Permanent Food Service

4211 20 ST, VERO BEACH 32960

Inspection Date: 08/29/2022

Inspection Number: 3225383

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHUCK, GREGORY

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Operator states that fire marshal has approved use of propane tanks. Unable to contact fire marshal and no written approval

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Lee County**

License Number: 4605627

PFC HOSPITALITY

License Type: Catering

5031 S CLEVELAND AVE, FORT MYERS 33907

Inspection Date: 08/30/2022

Inspection Number: 1122670

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WALTER, KAYLA

Violation Code    ObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed propane tank inside of kitchen. Operator moved item for proper storage. **\*\*Corrected On-Site\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4606936

CHIPOTLE MEXICAN GRILL #2809

License Type: Permanent Food Service

22941 LYDEN DR 100, ESTERO 33928

Inspection Date: 09/02/2022

Inspection Number: 3200835

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FREED, JOSEPH

Violation Code    ObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed large rolling trash bin blocking rear exit out of kitchen. Operator moved bin. **\*\*Corrected On-Site\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4606914

CULVERS

License Type: Permanent Food Service

9340 BEN C PRATT PKWY, FORT MYERS 33966

Inspection Date: 09/01/2022

Inspection Number: 3198776

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DOMKOWSKI, DANIEL

Violation Code    ObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Next to office.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Leon County**

License Number: 4702786

HAMPTON INN CENTRAL

License Type: Permanent Food Service

2979 APALACHEE PKWY, TALLAHASSEE 32301

Inspection Date: 09/02/2022

Inspection Number: 3239815

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: WARD, JOWANNA

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed expired boiler certificate in boiler room dated 9/16/21.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Manatee County**

License Number: 5105819

PANERA BREAD #6119

License Type: Permanent Food Service

6351 MANATEE AVENUE W, BRADENTON 34209

Inspection Date: 08/31/2022

Inspection Number: 3257426

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PIPIC, DINKA

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed bags with garbage stored in front back exit door. Operator removed the bags to dumpster. As a repeat violation the importance of following proper protocol with this violation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5105892

PAPA JOES SPORTS BAR

License Type: Permanent Food Service

1242 WHITFIELD AVE, SARASOTA 34243

Inspection Date: 09/01/2022

Inspection Number: 3224083

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: EASLER, VERONICA

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone behind bar in the middle of the establishment to the left of the emergency exit door. For reporting purposes only. As a repeat violation the importance of following proper protocol with this violation was rein

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Okaloosa County**

License Number: 5603518

SONIC DRIVE-IN 4685

License Type: Permanent Food Service

34960 EMERALD COAST PKWY, DESTIN 32541

Inspection Date: 08/26/2022

Inspection Number: 3195303

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SHANKLIN, CYNTHIA

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher stored on floor at back kitchen exit.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5812501 GRINGOS LOCOS  
 License Type: Permanent Food Service 22 E WASHINGTON ST, ORLANDO 32801

Inspection Date: 08/30/2022 Inspection Number: 3226792 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PLEICONES, KIM

| <u>Violation Code</u> | <u>Observation</u>  | <u>Violation Citation</u>   |
|-----------------------|---|---|
| 45-04-4               | Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Flat top griddle by the rice warners is not under a hood suppression system. Evidence of grease Laden | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 5854837 CHEF JEAN CUISINE  
 License Type: Mobile Food Dispensing Vehicle 1206 W ROBINSON ST, ORLANDO 32805

Inspection Date: 08/29/2022 Inspection Number: 1253131 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BUCKNER, ELLIOT

| <u>Violation Code</u> | <u>Observation</u>  | <u>Violation Citation</u>   |
|-----------------------|---|---|
| 48-04-4               | Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.<br><br>Tank in unit. **Repeat Violation** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 5800383 HARDEES  
 License Type: Permanent Food Service 5212 SILVER STAR RD, ORLANDO 32808

Inspection Date: 08/29/2022 Inspection Number: 3223481 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GREENE, MARVIN

| <u>Violation Code</u> | <u>Observation</u>  | <u>Violation Citation</u>   |
|-----------------------|---|---|
| 45-02-4               | Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher next to walk in cooler. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 5811265 Q'KENAN  
 License Type: Permanent Food Service 8117 VINELAND AVE, ORLANDO 32821

Inspection Date: 08/30/2022 Inspection Number: 3191495 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: LEVINS, NICHOLAS

| <u>Violation Code</u> | <u>Observation</u>   | <u>Violation Citation</u>   |
|-----------------------|--|---|
| 48-04-4               | Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. **Repeat Violation** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |



**Orange County**

License Number: 5800816 AMERICAN KITCHEN  
 License Type: Permanent Food Service 1905 HOTEL PLAZA BLVD, LAKE BUENA VISTA 32830

Inspection Date: 09/02/2022 Inspection Number: 3215623 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

| <u>Violation Code</u> | <u>Observation</u>  | <u>Violation Citation</u>   |
|-----------------------|---|---|
| 47-03-4               | Observed electrical wiring in disrepair. For reporting purposes only.<br>Observed electrical extension cord used for waffle iron. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 5811592 LECHONERA EL BARRIO OCOEE RESTAUARNT LLC  
 License Type: Permanent Food Service 2759 OLD WINTER GARDEN RD, OCOEE 34761

Inspection Date: 08/31/2022 Inspection Number: 3236381 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: GREENE, MARVIN

| <u>Violation Code</u> | <u>Observation</u>   | <u>Violation Citation</u>   |
|-----------------------|--|---|
| 45-04-4               | Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.<br>Small fryer on table at entrance of kitchen | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

**Osceola County**

License Number: 5900659 ARBY'S  
 License Type: Permanent Food Service 5015 W IRLO BRONSON MEMORIAL, KISSIMMEE 34746

Inspection Date: 09/02/2022 Inspection Number: 3207955 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: ZAPATA, MAUREEN

| <u>Violation Code</u> | <u>Observation</u>   | <u>Violation Citation</u>   |
|-----------------------|--|---|
| 47-03-4               | Observed electrical wiring in disrepair. For reporting purposes only.<br><br>Back prep area oven's outlet cover. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 5911310 POBLANOS MEXICAN RESTAURANT  
 License Type: Permanent Food Service 4747 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 08/26/2022 Inspection Number: 3192537 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: ZAPATA, MAUREEN

| <u>Violation Code</u> | <u>Observation</u>  | <u>Violation Citation</u>   |
|-----------------------|---|---|
| 46-01-4               | Marked exit/path to marked exit blocked. For reporting purposes only.<br><br>Storage area back exit door. Hard to maneuver in case of an emergency. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

Inspection Date: 08/29/2022 Inspection Number: 3192537 Inspection Type: Routine - Food Inspection Disposition: Call Back - Admin. complaint recommended  
 Inspector Name: ZAPATA, MAUREEN

| <u>Violation Code</u> | <u>Observation</u>   | <u>Violation Citation</u>   |
|-----------------------|--|---|
| 46-01-4               | - From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only.<br><br>Storage area back exit door. Hard to maneuver in case of an emergency. -<br>From follow-up inspection 2022-08-29: **Time Extended** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

**Palm Beach County**

License Number: 6020578

CHIPOTLE MEXICAN GRILL 1565

License Type: Permanent Food Service

4655 PGA BLVD, PALM BEACH GARDENS 33418

Inspection Date: 09/02/2022

Inspection Number: 3257830

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Complied

Inspector Name: GOODWIN, NICHOLAS

Violation Code   ObservationViolation Citation

45-02-4   - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed at fire extinguisher next to back door   - From follow-up inspection 2022-09-02: Same

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-02-4   Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed at fire extinguisher next to back door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6007667

OLD MARSH GOLF CLUB MENS GRILL

License Type: Permanent Food Service

7500 OLD MARSH RD, PALM BEACH GARDENS 33418-7501

Inspection Date: 09/02/2022

Inspection Number: 3203681

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation Code   ObservationViolation Citation

45-02-4   Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6009926

LA VILLA PIZZERIA

License Type: Permanent Food Service

1100 LINTON BLVD SUITE C3-C4, DELRAY BEACH 33444

Inspection Date: 08/30/2022

Inspection Number: 3213213

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation Code   ObservationViolation Citation

46-04-4   Exit door locked. For reporting purposes only. Observed at rear door outside of walk in cooler. Exit door blocked by storage rack

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6022427 THE MODERN ROSE DELRAY  
 License Type: Permanent Food Service 33 SE 3 AVE #14, DELRAY BEACH 33483

Inspection Date: 09/02/2022 Inspection Number: 3212882 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: FRANCE, GASTON

| <u>Violation Code</u> | <u>Observation</u>  | <u>Violation Citation</u>  |
|-----------------------|---|--|
| 48-01-5               | No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. | 61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only. |

License Number: 6022428 ROOTS  
 License Type: Permanent Food Service 33 SE 3 AVE UNIT 31, DELRAY BEACH 33483

Inspection Date: 09/01/2022 Inspection Number: 3237225 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: FRANCE, GASTON

| <u>Violation Code</u> | <u>Observation</u>  | <u>Violation Citation</u>  |
|-----------------------|---|--|
| 48-01-5               | No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.   | 61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only. |
| 48-01-5               | - From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2022-09-02: | 61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only. |

**Pinellas County**

License Number: 6213686

DOE DOES DINER

License Type: Permanent Food Service

9395 BAY PINES BLVD, ST. PETERSBURG 33708

Inspection Date: 09/02/2022

Inspection Number: 3209714

Inspection Type: Routine - Food

Inspection Disposition: Emergency  
Order Callback Not Complied

Inspector Name: CORRADO, NICHOLAS

Violation Code      ObservationViolation Citation

45-04-4      - From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.  
Beef being cooked in side prep area producing grease laden vapors and no h

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-04-4      - From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.  
Beef being cooked in side prep area producing grease laden vapors and no h

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-04-4      Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.  
Beef being cooked in side prep area producing grease laden vapors and no hood fire suppression system

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6217055

SUBWAY #56247

License Type: Permanent Food Service

2677 ROOSEVELT BLVD, CLEARWATER 33760

Inspection Date: 08/31/2022

Inspection Number: 3200480

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: WILMOT, TASHARA

Violation Code      ObservationViolation Citation

46-01-4      Marked exit/path to marked exit blocked. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6206597

WENDY'S PROPERTIES LLC

License Type: Permanent Food Service

4960 E BAY DR, CLEARWATER 33764

Inspection Date: 09/01/2022

Inspection Number: 3218041

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: WILMOT, TASHARA

Violation Code      ObservationViolation Citation

46-01-4      Marked exit/path to marked exit blocked. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6200142

KFC

License Type: Permanent Food Service

1960 GULF TO BAY BLVD, CLEARWATER 33765

Inspection Date: 09/01/2022

Inspection Number: 3226925

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: KLINGENSMITH, DESIREE

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical in disrepair. For reporting purposes only.  
-During time of inspection whole restaurants kitchen and dining room lights went out because of a rain storm. Employee states that this happens when it rains a lot.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6217667

KOGI GRILL

License Type: Permanent Food Service

7161 ULMERTON RD, LARGO 33771

Inspection Date: 09/01/2022

Inspection Number: 3217705

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILMOT, TASHARA

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.  
-blocked by seat  
Operator moved items during time of inspection. **\*\*Corrected On-Site\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Putnam County**

License Number: 6400785

BLUE WATER BAY

License Type: Permanent Food Service

319 SR 26, MELROSE 32666

Inspection Date: 09/02/2022

Inspection Number: 3220319

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: BADDING, MELANIE

Violation Code    Observation

Violation Citation

45-02-4    Portable fire extinguisher gauge in red zone. For reporting purposes only. At double pan sink by tea station.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Santa Rosa County**

License Number: 6701403

RIO BRAVO MEXICAN RESTAURANT GULF BREEZE INC

License Type: Permanent Food Service

3755 GULF BREEZE PKWY UNITS I, J, H, GULF BREEZE 32563

Inspection Date: 08/30/2022

Inspection Number: 3238924

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: ALBRITTON, GREGORY

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Circuit breaker box next to walk in cooler door kitchen.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Sarasota County**

License Number: 6806013 DEEP LAGOON SEAFOOD AND OYSTER HOUSE  
 License Type: Permanent Food Service 482 BLACKBURN POINT RD, OSPREY 34229

Inspection Date: 09/01/2022 Inspection Number: 3257836 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: RODARTE, ERIC

| <u>Violation Code</u> | <u>Observation</u>  | <u>Violation Citation</u>   |
|-----------------------|---|---|
| 46-01-4               | Marked exit/path to marked exit blocked. For reporting purposes only. Observed a cart in front of the fire exit by the ice machine. Operator moved the cart.<br>**Corrected On-Site** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 6805256 GECKOS GRILL & PUB  
 License Type: Permanent Food Service 6606 S TAMIAMI TRL, SARASOTA 34231

Inspection Date: 08/30/2022 Inspection Number: 3193500 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: RODARTE, ERIC

| <u>Violation Code</u> | <u>Observation</u>   | <u>Violation Citation</u>   |
|-----------------------|--|---|
| 46-01-4               | Marked exit/path to marked exit blocked. For reporting purposes only. Observed exit door blocked in back by dry storage area. Operator cleared path to door. **Corrected On-Site** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 6800060 SANDCASTLE RESTAURANT  
 License Type: Permanent Food Service 1540 BEN FRANKLIN DR, SARASOTA 34236

Inspection Date: 09/01/2022 Inspection Number: 3227327 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MCKEON, MICHAEL

| <u>Violation Code</u> | <u>Observation</u>   | <u>Violation Citation</u>   |
|-----------------------|--|---|
| 47-03-4               | Observed electrical wiring in disrepair. For reporting purposes only. Exposed electrical wiring under the heat wells in the expo area. As a repeat violation the importance of following proper protocol with this violation was reinforced with the employee. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

**Seminole County**

License Number: 6905177

SANFORD BREWING COMPANY

License Type: Permanent Food Service

400 S. SANFORD AVE, SANFORD 32771

Inspection Date: 08/29/2022

Inspection Number: 3201677

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Sumter County**

License Number: 7000467

SONNYS REAL PIT BAR B Q

License Type: Permanent Food Service

1128 CANAL STREET, THE VILLAGES 32162

Inspection Date: 08/29/2022

Inspection Number: 3203407

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DEMARCO, AMBER

Violation Code    Observation

Violation Citation

45-02-4    Portable fire extinguisher gauge in red zone. For reporting purposes only.  
Extinguisher between prep area and dish machine area

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7405440

STARLITE DINER

License Type: Permanent Food Service

401 N ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 08/30/2022

Inspection Number: 3240453

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

49-05-4

Flammables stored near a source of ignition. For reporting purposes only.

-wood trap next to vent stack flame source at water heater

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

