

Alachua County

License Number: 1150337 GATOR GLIZZY
 License Type: Mobile Food Dispensing Vehicle 1220 W UNIVERSITY AVE, GAINESVILLE 32601

Inspection Date: 09/12/2022 Inspection Number: 1259615 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FORBES, WAYNE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-01-4	No portable fire extinguisher present. For reporting purposes only. Hot dog cart no fire extinguisher available.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1103366 TONY & AL'S
 License Type: Permanent Food Service 14960 MAIN ST, ALACHUA 32615

Inspection Date: 09/12/2022 Inspection Number: 3237803 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: BAILEY, KIMBERLY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher on wait station in the recharge zone. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1622882 LITTLE CAESARS PIZZA
 License Type: Permanent Food Service 2301 N SR 7, HOLLYWOOD 33021

Inspection Date: 09/09/2022 Inspection Number: 3221123 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ROGERS, VERNEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Main kitchen rear exit door- observed exit door being blocked by trash can.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1619679 D & G RESTAURANT
 License Type: Permanent Food Service 6833 MIRAMAR PKWY, MIRAMAR 33023

Inspection Date: 09/12/2022 Inspection Number: 3232771 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: PIERRE, ENOSE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Counter top fryer on prep table by kitchen exit door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1622634 CROCANTE
 License Type: Permanent Food Service 2708 N UNIVERSITY DR, CORAL SPRINGS 33065

Inspection Date: 09/16/2022 Inspection Number: 3220899 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GRAY, ANTHONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. -Observed hot plates in used. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330696 BORSALINO CAFE
 License Type: Permanent Food Service 119 SE 1ST AVENUE, MIAMI 33131

Inspection Date: 09/12/2022 Inspection Number: 3235801 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed operator cooking Scramble eggs at times of inspection producing vapors/smoke.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2316948 TOTAL CAFETERIA
 License Type: Permanent Food Service 1401 NW 23 ST, MIAMI 33142

Inspection Date: 09/14/2022 Inspection Number: 3204389 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BROWN, JARON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed three propane containers in upstairs area	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2317167 EL TORO LOCO CHURRASCARIA
 License Type: Permanent Food Service 10501 SW 88 ST STE A101, MIAMI 33176

Inspection Date: 09/15/2022 Inspection Number: 3260615 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: BENITEZ, YOANNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. Located in the front area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2651714 LEWEY'S SEAFOOD AND WINGS
 License Type: Mobile Food Dispensing Vehicle 6510 NORMANDY BLVD, JACKSONVILLE 32205

Inspection Date: 09/15/2022 Inspection Number: 1251571 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Behind cooler	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615243 EL TAINO BAR AND GRILL
 License Type: Permanent Food Service 4347 UNIVERSITY BLVD S STE 5, JACKSONVILLE 32216

Inspection Date: 09/16/2022 Inspection Number: 3216671 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: VILBRUN, JOSUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Back door block by tables and equipments in back storage area **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615694 POPEYES LOUISIANA KITCHEN
 License Type: Permanent Food Service 9309 MERRILL RD, JACKSONVILLE 32225

Inspection Date: 09/13/2022 Inspection Number: 3206992 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: THOMAS, PHILIP

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher between walk in cooler and walk in freezer has gauge in recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3911847

TACO BELL #29588

License Type: Permanent Food Service

11315 CAUSEWAY BLVD, BRANDON 33511

Inspection Date: 09/16/2022

Inspection Number: 3230096

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: MOULDER, BRITTANY

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only.
Observed near back door - From follow-up inspection 2022-09-16: Observed near back door **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4604509

SUBWAY #18883

License Type: Permanent Food Service

14561 PALM BEACH BLVD #33, FORT MYERS 33905

Inspection Date: 09/12/2022

Inspection Number: 3240289

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: FREED, JOSEPH

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Observed path blocked by rolling rack. Operator moved out of path. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4605878

DUNKIN 343981

License Type: Permanent Food Service

16970 S TAMIAMI TRAIL, FORT MYERS 33908

Inspection Date: 09/12/2022

Inspection Number: 3196204

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SOMMERS, KARA

Violation Code ObservationViolation Citation

47-02-4 Observed scorch marks around electrical outlet/outlet broken in women's restroom. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4600072

WHISKEY CREEK STATION

License Type: Permanent Food Service

11481 MCGREGOR BLVD, FORT MYERS 33919

Inspection Date: 09/15/2022

Inspection Number: 3219464

Inspection Type: Routine - Food

Inspection Disposition: Emergency Order Callback Time Extension

Inspector Name: FREED, JOSEPH

Violation Code ObservationViolation Citation47-03-4 - From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. Exposed wires at exhaust fan mounted to wall by back door. -
From follow-up inspection 2022-09-15: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

47-03-4 Observed electrical wiring in disrepair. For reporting purposes only. Exposed wires at exhaust fan mounted to wall by back door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5104127

BUTTERFIELDS FAMILY RESTAURANT

License Type: Permanent Food Service

8205 US HWY 301, PARRISH 34219

Inspection Date: 09/09/2022

Inspection Number: 3226323

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KNORR, DAVID

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed in kitchen area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5200012

FAT BOYS B B Q

License Type: Permanent Food Service

4132 NE SILVER SPGS BLVD, OCALA 344705004

Inspection Date: 09/14/2022

Inspection Number: 3191328

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: DRIGGERS, MANDY

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Propane tank with torch attached on cart near back door. Employee stated torch is used to light fire in smoker daily.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5807781

SAZON'S RESTAURANT BUFFET & GRILL

License Type: Permanent Food Service

701 W LANCASTER RD, ORLANDO 32809

Inspection Date: 09/12/2022

Inspection Number: 3218253

Inspection Type: Routine - Food

Inspection Disposition: Emergency
Order Callback Not Complied

Inspector Name: PASIECKI, VICTORIA

Violation Code ObservationViolation Citation

47-03-4	- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. Behind flattop grill. On walk-in cooler exterior - From follow-up inspection 2022-09-12: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Behind flattop grill. On walk-in cooler exterior	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-03-4	- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. Behind flattop grill. On walk-in cooler exterior - From follow-up inspection 2022-09-12: **Time Extended** - From follow-up inspection 2022-09-13:	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811401

WENDY'S #9899

License Type: Permanent Food Service

1050 MCCOY RD, ORLANDO 32809

Inspection Date: 09/16/2022

Inspection Number: 3233808

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: PASIECKI, VICTORIA

Violation Code ObservationViolation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rack of buns in front of rear exit, Operator moved **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	---

License Number: 5812542

SUBWAY #12524

License Type: Permanent Food Service

16889 E COLONIAL DR, ORLANDO 32820

Inspection Date: 09/13/2022

Inspection Number: 3232477

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: VAZQUEZ, JULITZA

Violation Code ObservationViolation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	---

Osceola County

License Number: 5907509

PAPA JOHNS PIZZA #919

License Type: Permanent Food Service

5345 W IRLO BRONSON HWY, KISSIMMEE 34746

Inspection Date: 09/12/2022

Inspection Number: 3197571

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: ZAPATA, MAUREEN

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. - From follow-up inspection 2022-09-12: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6209636 TANGERINE
 License Type: Permanent Food Service 333 1 STREET S, ST. PETERSBURG 33701

Inspection Date: 09/16/2022 Inspection Number: 3222448 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: MURPHY, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6215233 ASTRA PIZZA
 License Type: Permanent Food Service 2915 16 ST N, ST. PETERSBURG 33704

Inspection Date: 09/13/2022 Inspection Number: 3202063 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LOZANO, KELVIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Establishment was a no seating establishment increased to 2 seats. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215988 FORTUNATO'S ALFRESCO
 License Type: Permanent Food Service 212 37 AVE N, ST. PETERSBURG 33704

Inspection Date: 09/14/2022 Inspection Number: 3236585 Inspection Type: Routine - Food Inspection Disposition: Emergency Order Callback Not Complied
 Inspector Name: LOZANO, KELVIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	- From initial inspection : Portable fire extinguisher missing from its designated location. For reporting purposes only. Establishment was a 20-seat establishment increased to 40 seats **Repeat Violation** - From follow-up inspection 2022-09-14:	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-05-4	- From initial inspection : Portable fire extinguisher missing from its designated location. For reporting purposes only. Establishment was a 20-seat establishment increased to 40 seats **Repeat Violation** - From follow-up inspection 2022-09-14:	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Establishment was a 20-seat establishment increased to 40 seats **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215687 HARRY'S BEACH BAR
 License Type: Permanent Food Service 5300 GULF BLVD, ST.PETE BEACH 33706

Inspection Date: 09/14/2022 Inspection Number: 3198955 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DAY-WALKER, LISA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Wires hanging from ceiling in prep room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216820 MCDONALD'S RESTAURANT
 License Type: Permanent Food Service 2675 ROOSEVELT BLVD, CLEARWATER 33760

Inspection Date: 09/16/2022 Inspection Number: 3201322 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILMOT, TASHARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. -garbage cans at exit door in back storage area Operator moved garbage cans during time of inspection. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216496 HYATT REGENCY CLEARWATER BEACH RESORT & SPA
 License Type: Permanent Food Service 301 GULFVIEW BLVD, CLEARWATER 33767

Inspection Date: 09/12/2022 Inspection Number: 3229929 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	- From initial inspection : Two boiler certificates expired. F1123659, F1123660 last two exp 7/25/2021 For reporting purposes only. **Repeat Violation** - From follow-up inspection 2022-09-12: **Time Extended**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6216900 FIREHOUSE SUBS 744
 License Type: Permanent Food Service 10500 ULMERTON RD STE 750, LARGO 33771

Inspection Date: 09/16/2022 Inspection Number: 3260624 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILMOT, TASHARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6308638

ARBY'S #8181

License Type: Permanent Food Service

35995 US-27, HAINES CITY 33844

Inspection Date: 09/14/2022

Inspection Number: 3200991

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JACKSON, SHARON

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
Exit door blocked by boxes of trash and garbage can items were removed.
Corrected On-Site

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6805244 SUPER BUFFET
 License Type: Permanent Food Service 5471 FRUITVILLE RD, SARASOTA 34232

Inspection Date: 09/12/2022 Inspection Number: 3227073 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HELGESON, ERIC

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed rear exit blocked by stored items. As a repeat violation the importance of following proper protocol with this violation was reinforced with the employee. **Repeat Violation*	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6805375 HOTEL VENEZIA A RAMADA HOTEL
 License Type: Permanent Food Service 425 US 41 BYPASS N, VENICE 34285

Inspection Date: 09/14/2022 Inspection Number: 3236879 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: KEATING, PATRICK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. Observed exit door in dry storage area lock with bolt lock. Observed operator unlock lock. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6805864 FUJI SUSHI HIBACHI NOODLES
 License Type: Permanent Food Service 12205 MERCADO DR, VENICE 34293

Inspection Date: 09/13/2022 Inspection Number: 3223470 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KEATING, PATRICK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-06-4	Portable fire extinguisher is inaccessible. For reporting purposes only. Observed fire extinguisher by 3 compartment sink at end of cooks line blocked by boxes. Observed employee move boxes. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6904872

GRAFFITI JUNKTION 4

License Type: Permanent Food Service

950 MARKET PROMENADE AVE, SUITE 1200, LAKE MARY 32746

Inspection Date: 09/16/2022

Inspection Number: 3222893

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: THORNCROFT, ROBERT

Violation Code ObservationViolation Citation47-03-4 Observed electrical wiring in disrepair. For reporting purposes only.
Light is hanging in the hoods from the wires , not supported

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6905122

NOODLES AND COMPANY 9032

License Type: Permanent Food Service

850 S SUN DR, LAKE MARY 32746

Inspection Date: 09/15/2022

Inspection Number: 3195068

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation Code ObservationViolation Citation45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
-at the back door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6903451

RED LOBSTER #0848

License Type: Permanent Food Service

20 TOWN CENTER CIR, SANFORD 32771

Inspection Date: 09/14/2022

Inspection Number: 3217185

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ANGEL, TERRY

Violation Code ObservationViolation Citation49-03-4 Flammables stored/debris present in hot water heater room.
Gas can.
For reporting purposes only.

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Suwannee County

License Number: 7100049

HARDEE'S RESTAURANT

License Type: Permanent Food Service

608 OHIO AVE S, LIVE OAK 32064

Inspection Date: 09/14/2022

Inspection Number: 3222932

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher by back door in the recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7407613 THE DAYTONA AUTOGRAPH COLLECTION
 License Type: Permanent Food Service 1870 VICTORY CIR, DAYTONA BEACH 32114

Inspection Date: 09/16/2022 Inspection Number: 3217254 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Expired 135766,5/19/22	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 7406191 ALBERTO'S PIZZERIA
 License Type: Permanent Food Service 1501 S RIDGEWOOD AVE, EDGEWATER 32132

Inspection Date: 09/13/2022 Inspection Number: 3219863 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PICHARDO, RENEE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Blocked by large plant **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407046 BRUNO'S PIZZA
 License Type: Permanent Food Service 1254 OCEANSHORE BLVD, ORMOND BEACH 32176

Inspection Date: 09/12/2022 Inspection Number: 3192760 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RUTLEDGE, REBECCA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7450726 VIOLETTE KITCHEN LLC
 License Type: Mobile Food Dispensing Vehicle 1200 PROVIDENCE BLVD, DELTONA 32725

Inspection Date: 09/16/2022 Inspection Number: 1254297 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ANGEL, TERRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Counter top fryers. Notified Lisa Nadeau, Deltona Fire Inspector. 386-878-8656.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.