

Bay County

License Number: 1305348

POMPANO JOE'S BAY COUNTY

License Type: Permanent Food Service

16202 FRONT BEACH RD, PANAMA CITY BEACH 32413

Inspection Date: 09/19/2022

Inspection Number: 3228802

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: HAASE, TINA

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Observed fire extinguisher in red zone at expo area and blocked fire extinguisher at bar.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1501854 ASIAN HOUSE RESTAURANT
 License Type: Permanent Food Service 407 CHENEY HWY, TITUSVILLE 32780

Inspection Date: 09/21/2022 Inspection Number: 3214465 Inspection Type: Routine - Food Inspection Disposition: Emergency order recommended
 Inspector Name: FRANZ, LINDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. K class on cook line	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. K class on cook line - From follow-up inspection 2022-09-22: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1504760 RED LOBSTER #6205
 License Type: Permanent Food Service 2355 W NEW HAVEN AVE, MELBOURNE 32904

Inspection Date: 09/23/2022 Inspection Number: 3236444 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRAYBOY, LYNN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. 2 of them. One near mop sink and one near back door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1622402 SR CEVICHE
 License Type: Permanent Food Service 2086 N UNIVERSITY DR, PEMBROKE PINES 33024

Inspection Date: 09/19/2022 Inspection Number: 3233099 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LONDONO, GLORIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1625605 SUBWAY
 License Type: Permanent Food Service 7800 SHERIDAN STREET, SUBWAY MEMORIAL HOSPITAL PEMBROKE, PEMBROKE PINES 33024

Inspection Date: 09/23/2022 Inspection Number: 2971229 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GANPAT, INDAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certificates expired .	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2320101 MI RINCONCITO MEXICANO
 License Type: Permanent Food Service 1961 SW 8 ST, MIAMI 33135

Inspection Date: 09/21/2022 Inspection Number: 3214659 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Bakery area, door blocked by a wheeled cart. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2335356 LA TAVERNA CALLE 8
 License Type: Permanent Food Service 1652 SW 8 ST, MIAMI 33135

Inspection Date: 09/21/2022 Inspection Number: 3213478 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed in the kitchen, a portable gas fryer. Discussed with the operator.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2336495 PATE CREOL
 License Type: Permanent Food Service 12997 W DIXIE HWY, NORTH MIAMI 33161

Inspection Date: 09/22/2022 Inspection Number: 3194219 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: SUAREZ, LEOPOLDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 2 gas tank largest tha 2.7 OB inside kitchen. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2326341

PAELLA PARTY

License Type: Permanent Food Service

16155 SW 117 AVE STE 8, MIAMI 33177

Inspection Date: 09/23/2022

Inspection Number: 3226086

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LEIDECKER, EDILMA

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed three propane tanks next to stoves at the back of the kitchen. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2614735 ONE BAR AND LOUNGE
 License Type: Permanent Food Service 2665 PARK ST, JACKSONVILLE 32204

Inspection Date: 09/21/2022 Inspection Number: 3236132 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By rear door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2607778 POPEYES LOUISIANA KITCHEN #148
 License Type: Permanent Food Service 5715 NORMANDY BLVD, JACKSONVILLE 32205

Inspection Date: 09/19/2022 Inspection Number: 3213529 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By cook line	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612676 SONIC DRIVE-IN 4120
 License Type: Permanent Food Service 7045 NORMANDY BLVD, JACKSONVILLE 32205

Inspection Date: 09/19/2022 Inspection Number: 3213090 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By entrance	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613681 CARIBBEAN SUNRISE BAKERY & RESTAURANT
 License Type: Permanent Food Service 4106 N MAIN ST, JACKSONVILLE 32206

Inspection Date: 09/21/2022 Inspection Number: 3220419 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By rear door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2600619

MURF'S FAMILY COUNTER

License Type: Permanent Food Service

2923 CORINTHIAN AVE, JACKSONVILLE 32210

Inspection Date: 09/21/2022

Inspection Number: 3237262

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: MERCER, THOMAS

Violation Code ObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Establishment has 4 cooking griddles/ burners, cooking hamburger, no hood system.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2610711

NIYA MG

License Type: Permanent Food Service

4500 SALISBURY RD #185, JACKSONVILLE 32216

Inspection Date: 09/23/2022

Inspection Number: 3240110

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Complied

Inspector Name: VILBRUN, JOSUE

Violation Code ObservationViolation Citation

45-04-4 - From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. No hood system when cooking and frying foods at open stove top in kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. No hood system when cooking and frying foods at open stove top in kitchen area
Repeat Violation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615243

EL TAINO BAR AND GRILL

License Type: Permanent Food Service

4347 UNIVERSITY BLVD S STE 5, JACKSONVILLE 32216

Inspection Date: 09/22/2022

Inspection Number: 3216671

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Complied

Inspector Name: VILBRUN, JOSUE

Violation Code ObservationViolation Citation

46-01-4 - From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. Back door block by tables and equipments in back storage area **Repeat Violation** - From follow-up inspection 2022-09-22: Still the same **Time Extende

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2614225		CHIPOTLE MEXICAN GRILL #1181	
License Type: Permanent Food Service		11113 SAN JOSE BLVD, JACKSONVILLE 32223	
Inspection Date: 09/19/2022	Inspection Number: 3191777	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GOSAI, MATT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rear exit blocked by boxes. Moved by manager.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2613228		ROD'S CRAB SHACK	
License Type: Permanent Food Service		1301 MONUMENT RD #13, JACKSONVILLE 32225	
Inspection Date: 09/21/2022	Inspection Number: 3233673	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: THOMAS, PHILIP			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Four propane tanks stored in back storage room **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2610891		SOUTHERN COAST SEAFOOD	
License Type: Permanent Food Service		1301 MONUMENT RD #1, JACKSONVILLE 322256462	
Inspection Date: 09/21/2022	Inspection Number: 3240972	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: THOMAS, PHILIP			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher near rear door from cook line has gauge in red	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2613603		PANERA BREAD #943	
License Type: Permanent Food Service		4720 TOWN CROSSING DR #G01, JACKSONVILLE 32246	
Inspection Date: 09/19/2022	Inspection Number: 3261824	Inspection Type: Complaint Partial	Inspection Disposition: Warning Issued
Inspector Name: CENTENO, ANGEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-06-4	Observed the fire alarm pull at back door to have a sign stating out of service. Manager stated the Johnsons control who services the establishment to have placed the sign there and that pull switch was faulty. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Duval County

License Number: 2652246 JOCELYN'S FISH AND CHICKEN
 License Type: Mobile Food Dispensing Vehicle 2120 EDGEWOOD AVE N, JACKSONVILLE 32254

Inspection Date: 09/23/2022 Inspection Number: 1251941 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615770 MOES SOUTHWEST GRILL #243
 License Type: Permanent Food Service 10478 SAN JOSE BLVD UNIT 1, JACKSONVILLE 32257

Inspection Date: 09/19/2022 Inspection Number: 3229819 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: GOSAI, MATT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rear exit blocked by boxes.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3917857 SWEETFISH
 License Type: Permanent Food Service 811 N TAMPA ST STE 130, TAMPA 33602

Inspection Date: 09/21/2022 Inspection Number: 3247197 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: EHLERS, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2022-09-22: **Time E	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3952868 EL TACOLGANDO
 License Type: Mobile Food Dispensing Vehicle 7001 N HIMES AVE, TAMPA 33614

Inspection Date: 09/20/2022 Inspection Number: 1253048 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: JAIME, ANTONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Under stove top	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3953171 JA ISLAND SPICE MINI RESTAURANT
 License Type: Mobile Food Dispensing Vehicle 9743 W HILLSBOROUGH AVE, TAMPA 33615

Inspection Date: 09/22/2022 Inspection Number: 1255988 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ZHANG, JACKY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 20 lbs propane tank stored inside the unit.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4650791 LOS TAQUITOS MEXICAN FOOD
 License Type: Mobile Food Dispensing Vehicle 4217 PALM BEACH BLVD, FORT MYERS 33905

Inspection Date: 09/20/2022 Inspection Number: 1260278 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FREED, JOSEPH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 2 LP tanks stored in secondary truck behind food truck.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4607575 AUSSIE GRILL
 License Type: Permanent Food Service 12916 S CLEVELAND AVE, FORT MYERS 33907

Inspection Date: 09/20/2022 Inspection Number: 3196502 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: LETOURNEAU, MARLA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-01-4	Flammables stored/debris present in meter room. For reporting purposes only. Paint stored in electrical vault	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 4607455 400 RABBITS MEXICAN KITCHEN AND TEQUILARIA
 License Type: Permanent Food Service 975 RABBIT RD, SANIBEL 33957

Inspection Date: 09/22/2022 Inspection Number: 3207068 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONDERMANN, FRANK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rear exit door by dish machine - one door is blocked with rolling cart and in door panic bar is broken and does not open when pushed.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5804647 KING EXPRESS
 License Type: Permanent Food Service 2225 W OAKRIDGE RD, ORLANDO 32809

Inspection Date: 09/21/2022 Inspection Number: 3191340 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PASIECKI, VICTORIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Near back door. Operator moved outside **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811401 WENDY'S #9899
 License Type: Permanent Food Service 1050 MCCOY RD, ORLANDO 32809

Inspection Date: 09/19/2022 Inspection Number: 3233808 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: PASIECKI, VICTORIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. Rack of buns in front of rear exit, Operator moved **Corrected On-Site** - From follow-up inspection 2022-09-19: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5807928 BOSTON MARKET #0920
 License Type: Permanent Food Service 4621 S KIRKMAN RD, ORLANDO 328112832

Inspection Date: 09/19/2022 Inspection Number: 3220253 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: ARANA, MIRIAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. By trash cans and empty boxes **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5807754 CASTLE HOTEL ANTLER LOUNGE
 License Type: Permanent Food Service 8629 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 09/19/2022 Inspection Number: 3261786 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LUI, SUK HAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only./boiler certificate expired 9/1/2022.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Orange County

License Number: 5807755 CASTLE HOTEL GARDEN BISTRO AND BAR
 License Type: Permanent Food Service 8629 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 09/19/2022 Inspection Number: 3261649 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LUI, SUK HAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only./boiler certificate expired 9/1/2022.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5814559 PARADISE BAKERY AND LOUNGE LLC
 License Type: Permanent Food Service 12485 S ORANGE BLOSSOM TRL, ORLANDO 32837

Inspection Date: 09/20/2022 Inspection Number: 3239874 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: BORRERO, AUDREY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Gas tank of 20/25lbs next to stove for rotisserie chicken machine	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5800491 COUNTRY HOUSE RESTAURANT
 License Type: Permanent Food Service 13394 W. COLONIAL DR., WINTER GARDEN 34787

Inspection Date: 09/20/2022 Inspection Number: 3235717 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ARANA, MIRIAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Emergency fire exit blocked with a chair in dining area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
46-04-4	Exit door locked. For reporting purposes only. Emergency fire exit blocked with a chair in dining area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6011764 INDIA GRILL AND BAR
 License Type: Permanent Food Service 650 ROYAL PALM BEACH BLVD #A1, WEST PALM BEACH 33411

Inspection Date: 09/19/2022 Inspection Number: 3262163 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended
 Inspector Name: GOODWIN, NICHOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Operator removed **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6022391 BEACON/TOPSIDE
 License Type: Permanent Food Service 1107 LIGHTHOUSE PROMENADE, JUPITER 33477

Inspection Date: 09/22/2022 Inspection Number: 3212480 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: GOLDMAN, BARRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Baby fryer in pastry station. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6113865 TACOS EL PATRÓN #2
 License Type: Permanent Food Service 5841 GOLDVIEW PARKWAY UNIT 101, WESLEY CHAPEL 33544

Inspection Date: 09/22/2022 Inspection Number: 3235890 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: COLE, GABRIELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Exit door to kitchen blocked by soda cooler.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6101444 TWO D'S DINER
 License Type: Permanent Food Service 10039 US HWY 19 N, PORT RICHEY 34668

Inspection Date: 09/23/2022 Inspection Number: 3237517 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: BENEDICT, TRACY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher in kitchen at recharge	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6212478 THE MILL RESTAURANT
 License Type: Permanent Food Service 200 CENTRAL AVE #100, ST. PETERSBURG 33701

Inspection Date: 09/23/2022 Inspection Number: 3213935 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MURPHY, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher by rear door is in the red zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216254 TACO BELL
 License Type: Permanent Food Service 3401 5TH AVE N, ST. PETERSBURG 33713

Inspection Date: 09/22/2022 Inspection Number: 3218000 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RAHAL, LAUREN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Next to back exit door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6802006

TACO BELL 24532

License Type: Permanent Food Service

430 VENICE BY PASS N, VENICE 34292

Inspection Date: 09/21/2022

Inspection Number: 3262607

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RODARTE, ERIC

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
 Observed trash cans blocking rear exit.
 Operator moved the trash cans to make clear path for exit. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6905488

DAYS INN AND SUITES

License Type: Permanent Food Service

150 S WESTMONTE DR, ALTAMONTE SPRINGS 32714

Inspection Date: 09/22/2022

Inspection Number: 3225888

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: MARTIN, LESLIE

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.
-exposed wiring in women's restroom near lobby.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6650417

JIREH'S KITCHEN

License Type: Mobile Food Dispensing Vehicle

3210 ORANGE AVE STE A, FORT PIERCE 34951

Inspection Date: 09/16/2022

Inspection Number: 1253474

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JUSTINIANO, SONIA

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Portable fryer on counter

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Suwannee County

License Number: 7100178

THE KEG ROOM

License Type: Permanent Food Service

22671 SR 247, LAKE CITY 32024

Inspection Date: 09/22/2022

Inspection Number: 3213977

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRODEWALD, PAUL

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Fire extinguisher in outside bar area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

