

Bay County

License Number: 1305569

OFF THE HOOK BAR AND GRILL

License Type: Permanent Food Service

5711 N LAGOON DR, PANAMA CITY BEACH 32408

Inspection Date: 09/26/2022

Inspection Number: 3264199

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: LYNN, NICKOLAS

Violation Code ObservationViolation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
Extinguisher by breaker box in over charged zone. K class in kitchen in recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-06-4 Portable fire extinguisher is inaccessible. For reporting purposes only.
Extinguisher by breaker box concealed by styrofoam cups. Cup moved at time of inspection. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1305932

CUBEZ TROPICAL SEAFOOD AND OYSTER BAR

License Type: Permanent Food Service

8501 THOMAS DR, PANAMA CITY BEACH 32408

Inspection Date: 09/28/2022

Inspection Number: 3213361

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code ObservationViolation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire
extinguisher in recharge zone near dry storage area. K class near fryers in
recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2334796 PUROAST COFFEE
 License Type: Permanent Food Service 632 S MIAMI AVE, MIAMI 33130

Inspection Date: 09/30/2022 Inspection Number: 3215954 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2335026 RESIDENCE INN MIAMI SOUTH BEACH
 License Type: Permanent Food Service 1231 17TH STREET, MIAMI BEACH 33139

Inspection Date: 09/26/2022 Inspection Number: 3240313 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate expired for boiler. Observed boiler jurisdiction number's 098797; 098796 expired on 9/22/2022. A boiler inspection was conducted on 9/07/22, hotel establishment is waiting on follow up inspection from boiler inspector in order to renew and obtain certificates. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2325761 TACO RICO
 License Type: Permanent Food Service 7921 SW 40 ST 47-48, MIAMI 33155

Inspection Date: 09/26/2022 Inspection Number: 3209750 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ELDER, AUDREY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed exit door near woman's bathroom blocked by metal stands, plastic container and chairs.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2325850 EUROPEAN DELIGHTS MARKET AND DELI
 License Type: Permanent Food Service 17082 COLLINS AVE, SUNNY ISLES BEACH 33160

Inspection Date: 09/26/2022 Inspection Number: 3263066 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: TAYLOR, JOHN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Observed exposed wiring in kitchen area ceiling.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2324239

PIZZA HUT DELIVERY #710711

License Type: Permanent Food Service

13715 NW 7 AVE, NORTH MIAMI 331682903

Inspection Date: 09/26/2022

Inspection Number: 3214241

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SUAREZ, LEOPOLDO

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. observed shelves and plastic garbage containers blocking the exit door. Advised manager she removed them. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2615096 POUR HOUSE
 License Type: Permanent Food Service 3325 PLYMOUTH ST, JACKSONVILLE 32205

Inspection Date: 09/26/2022 Inspection Number: 3217952 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 2 in kitchen	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2651840 GATOR WINGS & THINGS
 License Type: Mobile Food Dispensing Vehicle 2356 W BEAVER ST, JACKSONVILLE 32209

Inspection Date: 09/27/2022 Inspection Number: 1251274 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612182 GOLDEN CORRAL # 631
 License Type: Permanent Food Service 4250 SOUTHSIDE BLVD, JACKSONVILLE 32216

Inspection Date: 09/26/2022 Inspection Number: 3240942 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: VILBRUN, JOSUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certificate posted in boiler room shows expired 6-21-17 Jurisdiction #097645	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Hillsborough County

License Number: 3911879

SUITES PANTRY LSA PLSA

License Type: Permanent Food Service

4116 N HIMES AVE, TAMPA 33607

Inspection Date: 09/25/2022

Inspection Number: 3235533

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CANNELLA, MARK

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher used as door stop.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5200036

LORITOS ITALIAN KITCHEN

License Type: Permanent Food Service

1801 E SILVER SPRINGS BLVD, OCALA 34470

Inspection Date: 09/26/2022

Inspection Number: 3211330

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: CASEY, KEITH

Violation Code

Observation

Violation Citation

49-05-4

Flammables stored near a source of ignition. For reporting purposes only. Observed multiple flammable items stored on top of the gas powered hot water heater. All items were removed or discarded. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5814759	PANADERIA EL CAFETAL LLC		
License Type: Permanent Food Service	6125 SOUTH SEMORAN BLVD, SUITE 101 AND 102, ORLANDO 32822		
Inspection Date: 09/26/2022	Inspection Number: 3205606	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: LORENZO, ANA			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5808793	PAPA JOHNS #1121		
License Type: Permanent Food Service	11775 E COLONIAL DR, ORLANDO 32826		
Inspection Date: 09/26/2022	Inspection Number: 3208545	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VAZQUEZ, JULITZA			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only.Both exits in back.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5911668

GRAND HOTEL KISSIMMEE - BREAKFAST

License Type: Permanent Food Service

3104 PARKWAY BOULEVARD, KISSIMMEE 34747

Inspection Date: 09/26/2022

Inspection Number: 3190054

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Admin. complaint recommended

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

48-01-5

- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2022-08-26: **Time Extended** - From follow-up inspection 2022-09-26: **Time Extended**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Palm Beach County

License Number: 6000504

THE CIRCLE AND HMF

License Type: Permanent Food Service

S COUNTY RD, PALM BEACH 33480

Inspection Date: 09/30/2022

Inspection Number: 3204063

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: AHLE, ROBERT

Violation Code ObservationViolation Citation48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6011287

THE BREAKERS PALM BEACH BANQUET SERVICES

License Type: Permanent Food Service

1 S COUNTY RD, PALM BEACH 33480

Inspection Date: 09/30/2022

Inspection Number: 3221424

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: AHLE, ROBERT

Violation Code ObservationViolation Citation48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6011598

SEAFOOD BAR

License Type: Permanent Food Service

1 S COUNTY RD, PALM BEACH 33480

Inspection Date: 09/30/2022

Inspection Number: 3221435

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: AHLE, ROBERT

Violation Code ObservationViolation Citation48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Pinellas County

License Number: 6206147

POSTCARD INN SNACK SHACK BEACH BAR AND TIKI BARS

License Type: Permanent Food Service

6300 GULF BLVD, ST. PETE BEACH 33706

Inspection Date: 09/26/2022

Inspection Number: 3219494

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WILMOT, TASHARA

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.
-expired 121747 and 8/18/22

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6206942

BOATHOUSE RESTAURANT, P S GRIND COFFEE SHOP, STAMPS INTERIOR BAR

License Type: Permanent Food Service

6300 GULF BLVD, ST. PETE BEACH 33706

Inspection Date: 09/26/2022

Inspection Number: 3213876

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WILMOT, TASHARA

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.
-121747 and 8/18/22

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Seminole County

License Number: 6905107

MELLOW MUSHROOM

License Type: Permanent Food Service

1831 RINEHART RD, SANFORD 32771

Inspection Date: 09/26/2022

Inspection Number: 3240788

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Admin. complaint recommended

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

49-03-4

- From initial inspection : Flammables stored/debris present in hot water heater room. For reporting purposes only. - From follow-up inspection 2022-09-26: **Time Extended**

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Walton County

License Number: 7602188

MEZCAL MEXICAN GRILL

License Type: Permanent Food Service

80 SEASCAPE DRIVE STE 101, MIRAMAR BEACH 32550

Inspection Date: 09/29/2022

Inspection Number: 3233896

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SHANKLIN, CYNTHIA

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher stored on floor near front entry.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.