

Dade County

License Number: 2330443 ARBELOS
 License Type: Apartment 31 W 7 ST, HIALEAH 33010

Inspection Date: 07/01/2020 Inspection Number: 1490083 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection
 Inspector Name: SANCHEZ, JAVIER Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. Next to unit 4.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2324625 J X & SON'S LLC
 License Type: Apartment 1127 NE 1 AVE, HOMESTEAD 33030

Inspection Date: 06/30/2020 Inspection Number: 1476853 Inspection Type: Routine - Lodging Inspection Disposition: Administrative
 Inspector Name: LEIDECKER, EDILMA complaint recommended

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located at laundry room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329540 VERDE GARDENS
 License Type: Apartment 12550 SW 282 ST, HOMESTEAD 33033

Inspection Date: 07/01/2020 Inspection Number: 1496029 Inspection Type: Routine - Lodging Inspection Disposition: Inspection
 Inspector Name: GONZALEZ, RICARDO Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed missing fire extinguishers on building 12500.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310288 INGRAM PARK APARTMENTS
 License Type: Apartment 14350-14460 NW 22 AVE, OPA-LOCKA 33054

Inspection Date: 07/02/2020 Inspection Number: 1509550 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection
 Inspector Name: SUAREZ, LEOPOLDO Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2310550 POLYNESIAN GARDENS
 License Type: Apartment 7521 - 7535 NE 2 CT, MIAMI 33138

Inspection Date: 06/29/2020 Inspection Number: 1490009 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SEYBA, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Ground level of Both 7521 & 7535 buildings.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329168 THE VILLA, CASA CASURINA
 License Type: Hotel 1116 OCEAN DR, MIAMI BEACH 33139

Inspection Date: 06/30/2020 Inspection Number: 1153427 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PICO, JORGE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329346 CASA BOUTIQUE HOTEL
 License Type: Hotel 1334 WASHINGTON AVE, MIAMI BEACH 33139

Inspection Date: 06/29/2020 Inspection Number: 1153304 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SUAREZ, LEOPOLDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329420 NEW AGE 2012 LLC
 License Type: Hotel 807 ALTON RD, MIAMI BEACH 33139

Inspection Date: 06/29/2020 Inspection Number: 1151463 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MASKASEM, SUPPACHAI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2301957 BEACH PARADISE HOTEL
 License Type: Hotel 600 OCEAN DR, MIAMI BEACH 331396219

Inspection Date: 06/29/2020 Inspection Number: 1153319 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PICO, JORGE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2305265 BEACON HOTEL
 License Type: Hotel 720 OCEAN DR, MIAMI BEACH 331396220

Inspection Date: 06/29/2020 Inspection Number: 1153384 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PICO, JORGE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-07-4	Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2322781 FOUR GIRLS APTS
 License Type: Apartment 227 1 ST, MIAMI BEACH 331397325

Inspection Date: 06/29/2020 Inspection Number: 1473166 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. On second floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3904663

MARRIOTT TAMPA WESTSHORE

License Type: Hotel

1001 N WESTSHORE BLVD, TAMPA 33607

Inspection Date: 07/01/2020

Inspection Number: 1153412

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: FEDERORVITCH, CASEY

Violation Code

Observation

Violation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2020-06-18: **Time Extended** - From follow-up inspection 2020-07-01: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Indian River County

License Number: 4100185

BARRBACH HIDEAWAY APARTMENTS LLC

License Type: Apartment

1777 HIGHLAND AVE, VERO BEACH 32960

Inspection Date: 06/30/2020

Inspection Number: 1490033

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SCHOENLY, BARBARA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
back if building

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811138

GDC ORLANDO HOTEL OWNER LLC

License Type: Hotel

500 S ORANGE AVE, ORLANDO 32801

Inspection Date: 07/02/2020

Inspection Number: 1154422

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: QUINONES, ANTONIO

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5809051

EMBASSY SUITES HOTELS

License Type: Hotel

5835 T G LEE BLVD, ORLANDO 32822

Inspection Date: 07/02/2020

Inspection Number: 1156166

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RULLAN, ALFONSO

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel 7 th floor corridor smoke detector.. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900523 LAKESIDE TERRACE INN AND SUITES
 License Type: Motel 4880 W IRLO BRONSON HWY, KISSIMMEE 34746

Inspection Date: 04/08/2020 Inspection Number: 1210991 Inspection Type: Complaint Full Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: DAVIS, DIANNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-01-4	- From initial inspection : Various electrical cords plugged into this facility, strung across parking lot to Lake Cecile property that is not a licensed facility. - From follow-up inspection 2020-04-08: Plugs still snaked across the parking lot. **A	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-01-4	- From initial inspection : Extensions cord running from licensed facility to neighboring unlicensed facility. Fire Marshall was contacted. - From follow-up inspection 2020-04-08: Cord still in place **Admin Complaint**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5901189 CHAMPIONS WORLD RESORT
 License Type: Motel 8660 W IRLO BRONSON HWY, KISSIMMEE 34747

Inspection Date: 07/02/2020 Inspection Number: 1211594 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LORENZO, ANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-04-4	Fire alarm control panel has no power. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215732

SPRINGHILL SUITES BY MARRIOTT

License Type: Hotel

3485 ULMERTON RD, CLEARWATER 33762

Inspection Date: 06/30/2020

Inspection Number: 1153474

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LANTIGUA, ROBERTO

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel in office area. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6903650

EXTENDED STAY AMERICA #9634

License Type: Hotel

302 NORTHLAKE BLVD, ALTAMONTE SPRINGS 32701

Inspection Date: 06/29/2020

Inspection Number: 1152082

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: MARTIN, LESLIE

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
-boiler certificates posted in boiler room expired. 1 boiler tag number does not match. - From follow-up inspection 2020-06-11

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6900081

LAKE KATHRYN MOTEL

License Type: Motel

1995 US 17-92 S, LONGWOOD 32750

Inspection Date: 07/02/2020

Inspection Number: 1210564

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: PICHARDO, RENEE

Violation CodeObservationViolation Citation

01-03-4

- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
Between unit 3 and 4 - From follow-up inspection 2020-05-29: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406503 R & L AMBASSADOR RESORT
 License Type: Motel 940 N ATLANTIC BLVD, DAYTONA BEACH 32118

Inspection Date: 06/29/2020 Inspection Number: 1209603 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-01-4	Damaged electrical wire(s). For reporting purposes only. Observed long blue wire hooked to white and black wire in electric box . Blue wire is running out of electrical box. Operator states construction company is using for power. Electrical panel room t	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406495 HOLIDAY INN DAYTONA BEACH LPGA
 License Type: Hotel 137 AUTOMALL CIR, DAYTONA BEACH 32124

Inspection Date: 07/02/2020 Inspection Number: 1155201 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. System trouble and system silence lights on . Maintenance states has called tech.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.