

Bay County

License Number: 1304699

WEBB RENTAL

License Type: Apartment

1540 MULBERRY AVE, PANAMA CITY 32402

Inspection Date: 07/30/2020

Inspection Number: 1509671

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Between 3F and 3G

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1604658

AVENTURE INVESTMENT REALTY INC

License Type: Apartment

712 NE 8 ST, HALLANDALE 33009

Inspection Date: 07/31/2020

Inspection Number: 1499625

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GANPAT, INDAR

Violation CodeObservationViolation Citation

06-03-4

Marked exit sign not properly affixed by unit 204. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1608996

MIRAMAR GARDENS LLC

License Type: Apartment

6024 SW 26 ST, MIRAMAR 33023

Inspection Date: 07/28/2020

Inspection Number: 1494142

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GANPAT, INDAR

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Between units 207 and 208.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620734

CAMDEN LAS OLAS

License Type: Apartment

501 SE 2 ST STE 302, FORT LAUDERDALE 33301

Inspection Date: 07/31/2020

Inspection Number: 1498401

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation CodeObservationViolation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only. Exit sign hanging by wire at West elevators, 7th Floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621193

ELAN 16FORTY

License Type: Apartment

1640 E SUNRISE BLVD, FORT LAUDERDALE 33304

Inspection Date: 07/31/2020

Inspection Number: 1496346

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BRANN, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By Apt 1113 and 1313.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
06-03-4	Marked exit is inaccessible. Door at Stair N2 - 1 would not open. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Citrus County

License Number: 1900735

QUALITY INN

License Type: Motel

4486 N SUNCOAST BLVD, CRYSTAL RIVER 34428

Inspection Date: 07/28/2020

Inspection Number: 1211960

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: DODGE, DAVID

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Columbia County

License Number: 2200275

AMBERWOOD HILLS APARTMENTS

License Type: Apartment

826 SW AMBERWOOD LOOP #103, LAKE CITY 32025

Inspection Date: 07/31/2020

Inspection Number: 1507693

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRODEWALD, PAUL

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
Fire extinguisher outside of laundry room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2327711

MIAMI LAKES TOWNEPLACE SUITES

License Type: Hotel

8079 NW 154 ST, MIAMI LAKES 33016

Inspection Date: 07/28/2020

Inspection Number: 1154805

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CRUZ, EDGAR

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329245

MEDINA DIAZ APTS INC

License Type: Apartment

305 SW 4 AVE, HOMESTEAD 33030

Inspection Date: 07/28/2020

Inspection Number: 1495684

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed portable fire extinguisher locked in a box located at second floor between unit 1 and unit 2.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329588

MAJD APTS

License Type: Apartment

837 SW 5 ST, HOMESTEAD 33030-6962

Inspection Date: 07/28/2020

Inspection Number: 1500903

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed fire extinguisher locked in a box located between unit 7 and 8 second floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2318723

MAYFAIR HOTEL & SPA

License Type: Hotel

3000 FLORIDA AVE, MIAMI 33133

Inspection Date: 07/28/2020

Inspection Number: 1154649

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MASKASEM, SUPPACHAI

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2310374		JULIA MOTEL	
License Type: Motel		3030 W FLAGLER ST, MIAMI 33135	
Inspection Date: 07/30/2020	Inspection Number: 1212848	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2303212		MELERO APARTMENTS	
License Type: Apartment		111 SW 18 AVE, MIAMI 331352040	
Inspection Date: 07/30/2020	Inspection Number: 1507218	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
06-01-4	Path to door marked as an exit is blocked. For reporting purposes only. 2 and 3 floor plans, Furniture, etc.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2328949		RIVERSIDE HOTEL	
License Type: Motel		498 NE 78 ST, MIAMI 33138	
Inspection Date: 07/30/2020	Inspection Number: 1214147	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: SEYBA, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-04-4	Fire alarm control panel has no power. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329100		THE SETAI HOTEL	
License Type: Hotel		2001 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 07/31/2020	Inspection Number: 1154268	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ALVAREZ, MARGARET			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329295		BOULAN HOTEL	
License Type: Hotel		220 21 ST, MIAMI BEACH 33139	
Inspection Date: 07/30/2020	Inspection Number: 1154675	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ALVAREZ, MARGARET			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2310682		LISI APTS	
License Type: Apartment		729 EUCLID AVE, MIAMI BEACH 331396134	
Inspection Date: 07/29/2020	Inspection Number: 1504714	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. On 1st floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2326476		RIU PLAZA MIAMI BEACH	
License Type: Hotel		3101 COLLINS AVE, MIAMI BEACH 33140	
Inspection Date: 07/27/2020	Inspection Number: 1156014	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2328318 SOKOLOV LTD
 License Type: Hotel 4101 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 07/31/2020 Inspection Number: 1154671 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, VICENTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329296 THE CONFIDANTE
 License Type: Hotel 4041 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 07/29/2020 Inspection Number: 1154834 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, VICENTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2307620 INTERNATIONAL INN MOTEL AT CSW
 License Type: Motel 2301 NORMANDY DR, MIAMI BEACH 331414410

Inspection Date: 07/30/2020 Inspection Number: 1211409 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device on fire extinguisher located between room 114 and 115.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2310393

WILLIAM BAY APARTMENTS

License Type: Apartment

1160 100 ST, BAY HARBOR 33154

Inspection Date: 07/28/2020

Inspection Number: 1507628

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. The one located in the laundry .

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2301455

DAYS INN MIAMI AIRPORT NORTH

License Type: Motel

4767 NW 36 ST, MIAMI SPRINGS 33166

Inspection Date: 07/30/2020

Inspection Number: 1214150

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HERNANDEZ, NILYAM

Violation CodeObservationViolation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Observed in room #108. **Corrected On-Site**

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2326874

EXTENDED STAY AMERICA #9639

License Type: Hotel

8720 NW 33RD ST, MIAMI 33172

Inspection Date: 07/30/2020

Inspection Number: 1154892

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed in lobby.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329416 HILTON MIAMI DADELAND
 License Type: Hotel 9100 N KENDALL DR, MIAMI 33176

Inspection Date: 07/31/2020 Inspection Number: 1155983 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ORDONEZ, CATALINA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329367 AC HOTEL MIAMI AVENTURA
 License Type: Hotel 20805 BISCAYNE BLVD, AVENTURA 33180

Inspection Date: 07/29/2020 Inspection Number: 1156204 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: TAYLOR, JOHN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2324860 CUTLER HAMMOCK APTS
 License Type: Apartment 10376 SW 212 ST, MIAMI 331893065

Inspection Date: 07/31/2020 Inspection Number: 1490419 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: AZPURUA, JULIO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed box missing breaking device. Next to unit 106	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3900509

SWAN MOTEL

License Type: Motel

6411 NEBRASKA AVE, TAMPA 336046260

Inspection Date: 07/27/2020

Inspection Number: 1212349

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: MARQUETTI, JESSICA

Violation CodeObservationViolation Citation

01-05-4

- From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Near unit 5 - From follow-up inspection 2020-07-27:
Time Extended

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3905288

BW RRI III LLC

License Type: Motel

5001 US 301 N, TAMPA 33610

Inspection Date: 07/31/2020

Inspection Number: 1212941

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MARQUETTI, JESSICA

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
2 building first floor

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4605192

HAMPTON INN & SUITES FT MYERS BEACH SANIBEL GATEWAY

License Type: Hotel

11281 SUMMERLIN DR, FORT MYERS BEACH 33931

Inspection Date: 07/28/2020

Inspection Number: 1156555

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WICK, JENNIFER

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed on first floor between rooms 122 and 120.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Nassau County

License Number: 5500098

SHIP INN

License Type: Motel

542953 US HWY 1, CALLAHAN 32011

Inspection Date: 07/30/2020

Inspection Number: 1212564

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation Code

Observation

Violation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. In laundry room

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5805056		RED ROOF PLUS	
License Type: Hotel		8342 JAMAICAN CT, ORLANDO 32819	
Inspection Date: 07/29/2020	Inspection Number: 1155092	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: BACHOO, SAVITRI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
05-02-5	Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Room 111.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5809236		HOMWOOD SUITES BY HILTON ORLANDO INTERNATIONAL DRIVE	
License Type: Hotel		8745 INTERNATIONAL DR, ORLANDO 32819	
Inspection Date: 07/29/2020	Inspection Number: 1154833	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BACHOO, SAVITRI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificates or insurance inspector's boiler report expired. For reporting purposes only. **Corrected On-Site**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5809850		HYATT PLACE ORLANDO UNIVERSAL	
License Type: Hotel		5895 CARAVAN CT, ORLANDO 32819	
Inspection Date: 07/27/2020	Inspection Number: 1155591	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CONNOLLY, MADELINE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only in boiler room	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Orange County

License Number: 5811173

BUFFALO ORLANDO III LLC

License Type: Hotel

5910 AMERICAN WAY, ORLANDO 32819

Inspection Date: 07/29/2020

Inspection Number: 1156285

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CONNOLLY, MADELINE

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5808887

RAMADA SUITES ORLANDO INTERNATIONAL AIRPORT

License Type: Hotel

7500 AUGUSTA NATIONAL DR, ORLANDO 32822

Inspection Date: 07/30/2020

Inspection Number: 1154538

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RULLAN, ALFONSO

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel, room 325. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5809318

STAYBRIDGE SUITES ORLANDO AIRPORT

License Type: Hotel

7450 AUGUSTA NATIONAL DR, ORLANDO 32822

Inspection Date: 07/28/2020

Inspection Number: 1156241

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RULLAN, ALFONSO

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5810888 DISNEY'S POP CENTURY RESORT
 License Type: Motel 1050 CENTURY DRIVE, LAKE BUENA VISTA 32830

Inspection Date: 07/28/2020 Inspection Number: 1212157 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed two boiler certification expired 089004 10/9/2017 and 089005 2/17/2018. Engineering notify. **Corrective Action Taken**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5800462 DAYS INN MIDTOWN
 License Type: Motel 3300 S ORANGE BLOSSOM TRL, ORLANDO 328398968

Inspection Date: 07/27/2020 Inspection Number: 1211428 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DIOP, DONALD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Near room 115.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6003516

SOUTH LAKE APARTMENTS #2

License Type: Apartment

530 W KALMIA DR, LAKE PARK 33403-2261

Inspection Date: 07/31/2020

Inspection Number: 1500646

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MCCARTHY, RAMONA

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6203632 SKYLARK MOTEL
 License Type: Motel 10149 GULF BLVD, TREASURE ISLAND 337064808

Inspection Date: 07/28/2020 Inspection Number: 1211431 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DAY-WALKER, LISA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
06-01-4	Path to door marked as an exit is blocked. For reporting purposes only. Path blocked to stairwell by chairs. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-02-4	Frayed electrical wire(s). For reporting purposes only. Frayed wires hanging from light fixture near unit 8. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6201835 HEIGHTS APARTMENTS
 License Type: Apartment 4249 76 AVE N, PINELLAS PARK 33781

Inspection Date: 07/29/2020 Inspection Number: 1509792 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILMOT, TASHARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. -Portable fire extinguisher next to unit 206 and 203 Portable fire extinguisher missing from it's designated location (sign present indica	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6903796

EXTENDED STAY AMERICA #1619

License Type: Hotel

1036 GREENWOOD BLVD, LAKE MARY 32746

Inspection Date: 05/15/2020

Inspection Number: 1156590

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: GUTTERMAN, KENNETH

Violation CodeObservationViolation Citation

05-02-5

Observed: Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.
Hearing impaired smoke detector needs to be wired.
Priority: Reporting

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Observed: Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
5/16/19 expired
Priority: Reporting

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-04-4

Observed: Boiler certificate not posted in the boiler room. For reporting purposes only.
Priority: Reporting

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400060

THE SANDALS INN

License Type: Motel

133 S OCEAN AVE, DAYTONA BEACH 32118

Inspection Date: 07/28/2020

Inspection Number: 1212938

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Unit room 202

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406519

BAYMONT INN & SUITES

License Type: Motel

175 INTERCHANGE BLVD, ORMOND BEACH 32174

Inspection Date: 07/28/2020

Inspection Number: 1214116

Inspection Type: Complaint Partial

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RUTLEDGE, REBECCA

Violation CodeObservationViolation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Room 114, 116.

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406511

COURTYARD DELAND HISTORIC DOWNTOWN

License Type: Hotel

308 N WOODLAND BLVD, DELAND 32720

Inspection Date: 07/31/2020

Inspection Number: 1155698

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: OCASIO-LOPEZ, LISA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. By front desk. For reporting purposes only. Trouble light on. As per operator, issue is with the sensor. Service is scheduled to replace sensor.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.