

Broward County

License Number: 1603045 FILLMORE APARTMENTS INC
 License Type: Apartment 6018 FILLMORE ST, HOLLYWOOD 33024

Inspection Date: 08/05/2020 Inspection Number: 1508456 Inspection Type: Routine - Lodging Inspection Disposition: Call Back -
 Inspector Name: BENJAMIN, ALEXANDER Complied

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In front of apartment 5W - From follow-up inspection 2020-08-05: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In front of apartment 5W	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1617123 VERONA VIEW BY ARIUM
 License Type: Apartment 10900 NW 17 ST, PLANTATION 33322-6985

Inspection Date: 08/07/2020 Inspection Number: 1509389 Inspection Type: Routine - Lodging Inspection Disposition: Inspection
 Inspector Name: MARTINEZ, RHEANNE Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher next to apt 190 in building on west side of property.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed extinguisher missing next to apt 421 and 319 on west side of property.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1608199 SUMMERFIELD APARTMENTS
 License Type: Apartment 3200 NW 84 AVE, SUNRISE 33351

Inspection Date: 08/07/2020 Inspection Number: 1508226 Inspection Type: Routine - Lodging Inspection Disposition: Inspection
 Inspector Name: MARTINEZ, RHEANNE Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-03-4	Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. In hallway of apt 325/326/327/328. Observed same in hallway of apt 521/522/523/524.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1619776

INTOWN SUITES

License Type: Motel

8191 W COMMERCIAL BLVD, TAMARAC 33351

Inspection Date: 08/04/2020

Inspection Number: 1212426

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MARTINEZ, RHEANNE

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. On 3rd floor, next to maintenance locker room and stairwell.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Columbia County

License Number: 2200197

GATEWAY INN

License Type: Motel

3783 W HWY 90, LAKE CITY 32055

Inspection Date: 08/05/2020

Inspection Number: 1211759

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRODEWALD, PAUL

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher in front office lobby. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2321514		HOLIDAY INN EXPRESS & SUITES - MIAMI/HIALEAH	
License Type: Hotel		6650 W 20 AVE, HIALEAH 33016	
Inspection Date: 08/07/2020	Inspection Number: 1155363	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CRUZ, EDGAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329184		HOMEWOOD SUITES BY HILTON MIAMI AIRPORT WEST	
License Type: Hotel		3590 NW 74 AVE, MIAMI 33122	
Inspection Date: 08/06/2020	Inspection Number: 1156127	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SANCHEZ, JAVIER			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-04-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. Observed 4 LP gas tank stored on the fire alarm room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329244		EXTENDED STAY AMERICA #1760	
License Type: Hotel		298 SW 15 RD, MIAMI 33129	
Inspection Date: 08/07/2020	Inspection Number: 1154114	Inspection Type: Complaint Full	Inspection Disposition: Call Back - Complied
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 097115 exp 6/12/20, 097116 exp 6/12/20 - From follow-up inspection 2020-06-25: **Time Extended** - From follow-up inspect	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2300554		1036	
License Type: Apartment		1036 SW 5TH ST, MIAMI 33130	
Inspection Date: 08/03/2020	Inspection Number: 1509697	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2319919		BORINQUEN APARTMENTS	
License Type: Apartment		425-435 SW 10 AVE, MIAMI 33130	
Inspection Date: 08/03/2020	Inspection Number: 1509783	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
07-01-4	Damaged/exposed electrical wire(s). For reporting purposes only. Observed exposed electrical wires hanging from fire alarm inside apartment unit 109 at building 435.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329238		HOTEL ARYA	
License Type: Hotel		2889 MCFARLANE RD, COCONUT GROVE 33133	
Inspection Date: 08/05/2020	Inspection Number: 1154887	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MASKASEM, SUPPACHAI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329171		Z OCEAN	
License Type: Hotel		1437 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 08/03/2020	Inspection Number: 1154188	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ALVAREZ, MARGARET			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Called to be serviced **Corrective Action Taken**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329200		OCEAN REEF HOTEL	
License Type: Hotel		1130 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 08/04/2020	Inspection Number: 1155019	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329208 GRAND BEACH HOTEL
 License Type: Hotel 4835 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 08/03/2020 Inspection Number: 1156612 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, VICENTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329221 SOHO HOUSE
 License Type: Hotel 4385 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 08/04/2020 Inspection Number: 1154473 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, VICENTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4		61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329253 WESTOVER ARMS HOTEL
 License Type: Hotel 4100 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 08/07/2020 Inspection Number: 1155335 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, VICENTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329277		HILTON CABANA MIAMI BEACH	
License Type: Hotel		6261 COLLINS AVE, MIAMI BEACH 33140	
Inspection Date: 08/05/2020	Inspection Number: 1155881	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only. **Corrected On-Site**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2304345		CHARLES BERNARD LTD	
License Type: Hotel		4333 COLLINS AVE, MIAMI BEACH 331403212	
Inspection Date: 08/07/2020	Inspection Number: 1154960	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2308870		CAMBRIDGE APTS	
License Type: Apartment		6231 SW 78 ST, SOUTH MIAMI 331434964	
Inspection Date: 07/31/2020	Inspection Number: 1504816	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PICO, JORGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. observed fire extinguisher located under the stairs to the second floor between apartments #1 and 21. Fire extinguisher by the entran	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2305348		SUNSET HOUSE APARTMENTS	
License Type: Apartment		7441 SW 59 PL, SOUTH MIAMI 331435138	
Inspection Date: 07/31/2020	Inspection Number: 1499939	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PICO, JORGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. observed fire extinguisher box located on the second floor by apartment 22 locked and missing the hammer to break the glass.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329378

TRYP BY WYNDHAM MIAMI BAY HARBOR

License Type: Hotel

9540 W BAY HARBOR DR, BAY HARBOR ISLANDS 33154

Inspection Date: 08/06/2020

Inspection Number: 1154321

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329270

GRAND BEACH HOTEL SURFSIDE

License Type: Hotel

9449 COLLINS AVE, SURFSIDE 33154

Inspection Date: 08/04/2020

Inspection Number: 1156614

Inspection Type: Complaint Partial

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. As per Chief Engineer, the inspection was conducted on February and paid the fee for the certificates, but they haven't received them.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2301713

REALBIZ MANAGEMENT LLC

License Type: Apartment

17080 NE 23 AVE, NORTH MIAMI BEACH 33160

Inspection Date: 08/05/2020

Inspection Number: 1501792

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: TAYLOR, JOHN

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Located next to apt 2.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329338		HILTON GARDEN INN MIAMI DOLPHIN MALL	
License Type: Hotel		1695 NW 111 AVE, SWEETWATER 33172	
Inspection Date: 08/04/2020	Inspection Number: 1155114	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2329416		HILTON MIAMI DADELAND	
License Type: Hotel		9100 N KENDALL DR, MIAMI 33176	
Inspection Date: 07/31/2020	Inspection Number: 1155983	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ORDONEZ, CATALINA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2327646		COURTYARD MARRIOTT AT AVENTURA	
License Type: Hotel		2825 NE 191 ST, AVENTURA 33180	
Inspection Date: 08/03/2020	Inspection Number: 1155517	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2329393		ALOFT MIAMI AVENTURA	
License Type: Hotel		2910 NE 207 ST, AVENTURA 33180	
Inspection Date: 08/04/2020	Inspection Number: 1154878	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Hernando County

License Number: 3700948

ZOLLER STREET APARTMENTS

License Type: Apartment

202 ZOLLER ST, BROOKSVILLE 34601

Inspection Date: 08/04/2020

Inspection Number: 1506010

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MEAKINS, ALLISON

Violation Code

Observation

Violation Citation

06-03-4

Back gate is chained and padlocked on both sides. Causing a potential safety issue if residents cannot get out the front door and need to escape through the back fenced in area.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4605590

RESIDENCE INN FORT MYERS SANIBEL

License Type: Hotel

20371 SUMMERLIN RD, FORT MYERS 33908

Inspection Date: 08/03/2020

Inspection Number: 1155021

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SOMMERS, KARA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher between Room 224 and 226.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4602988

COURTYARD FORT MYERS CAPE CORAL

License Type: Hotel

4455 METRO PARKWAY, FORT MYERS 33916

Inspection Date: 08/04/2020

Inspection Number: 1154378

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MOREHEAD, PHILIP

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400573

AMARA CAY RESORT

License Type: Hotel

80001 OVERSEAS HWY, ISLAMORADA 33036

Inspection Date: 08/06/2020

Inspection Number: 1155375

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5809224		MERCURY 3100 TT LLC	
License Type: Apartment		3100 ALAFAYA CLUB DR, ORLANDO 32817	
Inspection Date: 06/05/2020	Inspection Number: 1509848	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: FRANZ, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Observed: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.- blinking red light on alarm at building 3166 Priority: Reporting	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5801823		FOUR POINTS BY SHERATON STUDIO CITY	
License Type: Hotel		5905 INTERNATIONAL DR, ORLANDO 32819	
Inspection Date: 08/04/2020	Inspection Number: 1154291	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CONNOLLY, MADELINE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Trouble:smoke -lon Smoke FACP	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5805056		RED ROOF PLUS	
License Type: Hotel		8342 JAMAICAN CT, ORLANDO 32819	
Inspection Date: 08/06/2020	Inspection Number: 1156672	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: BACHOO, SAVITRI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
05-02-5	Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.Room 111.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5810969		SUPER 8 ORLANDO INTERNATIONAL DRIVE	
License Type: Motel		5900 AMERICIAN WAY, ORLANDO 32819	
Inspection Date: 08/06/2020	Inspection Number: 1212196	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CONNOLLY, MADELINE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Boiler room #1	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Orange County

License Number: 5808761

FAIRFIELD INN & SUITES BY MARRIOTT ORLANDO LAKE BUENA VISTA

License Type: Hotel

12191 S APOPKA VINELAND RD, ORLANDO 32836

Inspection Date: 08/07/2020

Inspection Number: 1155444

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Boiler certifications has expired 6/15/2020

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900729

DAYS INN KISSIMMEE HOTEL

License Type: Motel

4125 W VINE ST, KISSIMMEE 34741

Inspection Date: 08/05/2020

Inspection Number: 1212590

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BELTRAN, SANDRA

Violation CodeObservationViolation Citation

04-03-4

Smoke detector/alarm in guest room/unit need to change battery, in the handicap room For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-04-4

Electrical outlet hanging from wall located behind the bed in room 7112. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900534

SUN INN & SUITES

License Type: Motel

5020 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 08/05/2020

Inspection Number: 1214188

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: BELTRAN, SANDRA

Violation CodeObservationViolation Citation

04-02-4

No smoke detector provided in guest room/unit, in room 217. For reporting purposes only.

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6012655

FAIRFIELD INN & SUITES JUPITER

License Type: Hotel

6748 INDIANTOWN RD, JUPITER 33458

Inspection Date: 08/06/2020

Inspection Number: 1155925

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.all exp 03/15/2019, 121021, 121022, 095111.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6013438

APPLE TEN HOSPITALITY MANAGEMENT INC

License Type: Hotel

8201 CONGRESS AVE, BOCA RATON 33487

Inspection Date: 08/05/2020

Inspection Number: 1156017

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: AHLE, ROBERT

Violation CodeObservationViolation Citation

04-07-4

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only. **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7401977 BEST WESTERN INTERNATIONAL SPEEDWAY
 License Type: Hotel 2620 INTERNATIONAL SPEEDWAY BLVD, DAYTONA BEACH 32114

Inspection Date: 08/07/2020 Inspection Number: 1154185 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-01-4	Damaged electrical wire(s). For reporting purposes only. Light bulb or light fixture making popping sound when turn on in water heater room by room 258.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406514 THE DAYTONA AUTOGRAPH COLLECTION
 License Type: Hotel 1870 VICTORY CIR, DAYTONA BEACH 32114

Inspection Date: 08/07/2020 Inspection Number: 1154374 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-04-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. Lp tank stored in boiler room. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
06-01-4	Path to door marked as an exit is blocked. For reporting purposes only. Exit path partial by boxes by boiler room.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406495 HOLIDAY INN DAYTONA BEACH LPGA
 License Type: Hotel 137 AUTOMALL CIR, DAYTONA BEACH 32124

Inspection Date: 08/04/2020 Inspection Number: 1155201 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. System trouble and system silence lights on . Maintenance states has called tech. - From follow-up inspection 2020-08-04:	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.