

**Bay County**

License Number: 1304557

LA QUINTA INN &amp; SUITES #975

License Type: Hotel

1030 E 23RD STREET, PANAMA CITY 32405

Inspection Date: 08/10/2020

Inspection Number: 1154715

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 4-30-20

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1305147

PALM GROVE

License Type: Motel

14513 FRONT BEACH RD, PANAMA CITY BEACH 32413

Inspection Date: 08/11/2020

Inspection Number: 1211365

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: MARSHALL, MICHAEL D

Violation CodeObservationViolation Citation

12-04-4

High Priority - Balcony collapsed.  
Room 6202 has balcony missing.  
Room can't be rented until repairs are made and callback inspection is conducted.  
\*\*Warning\*\*

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

**Brevard County**

License Number: 1505695

EXTENDED STAY AMERICA #9505

License Type: Hotel

4835 HELEN HAUSER BLVD, TITUSVILLE 32780

Inspection Date: 08/10/2020

Inspection Number: 1156378

Inspection Type: Lodging-Licensing  
Inspection

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: WILSON, LANETTE

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Have not had inspection yet.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1618998		PEMBROKE PARK APTS	
License Type: Apartment		3501 SW 52 AVE, PEMBROKE PARK 33023	
Inspection Date: 08/14/2020	Inspection Number: 1496046	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GANPAT, INDAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Building 3509 and 3503.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1621281		SIBI BEACH HOTEL	
License Type: Apartment		2916 BAYSHORE DR, FORT LAUDERDALE 33304	
Inspection Date: 08/13/2020	Inspection Number: 1483518	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: BRANN, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. By Apt 10. - From follow-up inspection 2020-08-13: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1600892		SKY ISLANDS	
License Type: Motel		4117 N OCEAN BLVD, FORT LAUDERDALE 33308	
Inspection Date: 08/14/2020	Inspection Number: 1212553	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DEJONG, STEVEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
05-02-5	Hearing-impaired smoke detector is not functioning, could not test due power cord missing. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1608574		ALFA INVESTMENTS LLC	
License Type: Apartment		842 NW 1ST AVE, FT LAUDERDALE 33311	
Inspection Date: 08/14/2020	Inspection Number: 1506519	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MATTIELLO-ATASSI, MARIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. At fire extinguisher located at apt 1.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Broward County**

License Number: 1608706

GOLFVIEW FLATS, LLC

License Type: Apartment

8445 SPRINGTREE DRIVE, SUNRISE 33351

Inspection Date: 08/14/2020

Inspection Number: 1499506

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: MARTINEZ, RHEANNE

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed in hallway next to apt 307 B.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620262

COMFORT SUITES SAWGRASS

License Type: Hotel

8301 W COMMERCIAL BLVD, TAMARAC 33351

Inspection Date: 08/13/2020

Inspection Number: 1154479

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: MARTINEZ, RHEANNE

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only-  
1.)On first floor next to vending machine and ice machine area.  
2.) on second floor bldg B next to room 327.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Charlotte County**

License Number: 1801531

EXTENDED STAY AMERICA 9504

License Type: Hotel

24100 BEATRIX BLVD, PORT CHARLOTTE 33954

Inspection Date: 08/10/2020

Inspection Number: 1156282

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FERRY, WILLIAM

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.  
\*\*Corrected On-Site\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Collier County**

License Number: 2100459

BW RRI III LLC

License Type: Hotel

1925 DAVIS BLVD, NAPLES 34104

Inspection Date: 08/14/2020

Inspection Number: 1155231

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: DILLON, TIMOTHY

Violation Code

Observation

Violation Citation

04-07-4

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only. Observed the trouble light is on the fire panel. Per the operator there is a part missing to the panel.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2312295 CHAPLE APTS  
 License Type: Apartment 1085 W 27 ST, HIALEAH 33010

Inspection Date: 08/14/2020 Inspection Number: 1509891 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SANCHEZ, JAVIER Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Second floor by unit 5.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2313384 RENEDO APARTMENTS  
 License Type: Apartment 2170 NW 11 ST, MIAMI 331252753

Inspection Date: 08/11/2020 Inspection Number: 1499895 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MARTIN, RAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguishers on all floors approximately 10 locked in a box with no means of access to the fire extinguisher. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2300387 BARLINGTON HOTEL  
 License Type: Hotel 1350 NW 2 ST, MIAMI 331255699

Inspection Date: 08/11/2020 Inspection Number: 1155514 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MARTIN, RAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to unit number 201 on south side. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
06-06-4	Door marked as an exit locked with a lock that requires a key. For reporting purposes only. Observed exit door south side locked at time of inspection next to unit 201 **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329213

HILTON GARDEN INN MIAMI BRICKELL SOUTH

License Type: Hotel

2500 BRICKELL AVENUE, MIAMI 33129

Inspection Date: 08/10/2020

Inspection Number: 1154791

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328208

MANDARIN ORIENTAL MIAMI

License Type: Hotel

500 BRICKELL KEY DR, MIAMI 33131

Inspection Date: 08/11/2020

Inspection Number: 1155792

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. As per operator provided the paperwork for the inspection of the boiler, the inspection was conducted on 5/22/20 by Arise. The certificate of compliance has n

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329190

EPIC HOTEL

License Type: Hotel

270 BISCAYNE BLVD WAY, MIAMI 33131

Inspection Date: 08/12/2020

Inspection Number: 1155136

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2330156 X MIAMI  
 License Type: Apartment 230 NE 4 ST, MIAMI 33132

Inspection Date: 08/12/2020 Inspection Number: 1509589 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PAGAN, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2306594 SIDONIA 110 LLC  
 License Type: Apartment 110 SIDONIA AVE, CORAL GABLES 33134

Inspection Date: 08/11/2020 Inspection Number: 1500836 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: AZPURUA, JULIO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light Zone #3.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329259 BLANC KARA  
 License Type: Hotel 205 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 08/11/2020 Inspection Number: 1156110 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2324540		CASA GRANDE HOTEL	
License Type: Hotel		834 OCEAN DR, MIAMI BEACH 331395809	
Inspection Date: 08/12/2020	Inspection Number: 1156780	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2326492		SIXTY SIXTY RESORT	
License Type: Hotel		6060 INDIAN CREEK DR, MIAMI BEACH 33140	
Inspection Date: 08/12/2020	Inspection Number: 1154481	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2307985		6936 BYRON AVE LLC	
License Type: Apartment		6936 BYRON AVE, MIAMI BEACH 33141	
Inspection Date: 08/11/2020	Inspection Number: 1509534	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Dade County**

License Number: 2330468 925 CHAIM LLC , 925 DEBBIE LLC  
 License Type: Apartment 925 MARSEILLE DR, MIAMI BEACH 33141

Inspection Date: 08/14/2020 Inspection Number: 1509908 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: UNZAGA, MILADYS Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher located behind building 935 between units 1 and 2.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device for fire extinguisher located between units 5 and 6 , building 925.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328367 EXTENDED STAY AMERICA #1740  
 License Type: Hotel 3640 SW 22 ST, MIAMI 33145

Inspection Date: 08/14/2020 Inspection Number: 1156537 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329331 RESIDENCE INN BY MARRIOTT  
 License Type: Hotel 9200 COLLINS AVE, SURFSIDE 33154

Inspection Date: 08/11/2020 Inspection Number: 1154816 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificates expired on 6/19/2020.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Duval County**

License Number: 2609190

MARRIOTT JACKSONVILLE HOTEL

License Type: Hotel

4670 SALISBURY RD, JACKSONVILLE 32256

Inspection Date: 08/11/2020

Inspection Number: 1154992

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VILBRUN, JOSUE

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.  
Boilers certificate expired.  
Jurisdiction # 098813 exp 5-16-20. Jurisdiction # 057863 exp 5-16-20. Jurisdiction # 131400 exp 5-16-20.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Escambia County**

License Number: 2702613

QUALITY INN & SUITES

License Type: Motel

7601 SCENIC HWY, PENSACOLA 32504

Inspection Date: 08/11/2020

Inspection Number: 1214263

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ALBRITTON, GREGORY

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hamilton County**

License Number: 3400163

MUSTANG INN

License Type: Motel

8075 SR 6 W, JASPER 32052

Inspection Date: 08/11/2020

Inspection Number: 1213483

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: GRODEWALD, PAUL

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.  
In front of room 157.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3913631

HOTEL ALBA TAMPA

License Type: Hotel

5303 W KENNEDY BLVD, TAMPA 33609

Inspection Date: 08/12/2020

Inspection Number: 1154461

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KLUSENDORF, JEANNE

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Indian River County**

License Number: 4100202

HOLIDAY INN OCEANSIDE

License Type: Motel

3384 OCEAN DR, VERO BEACH 32963

Inspection Date: 08/11/2020

Inspection Number: 1214295

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: SCHUCK, GREGORY

Violation Code

Observation

Violation Citation

08-06-4

Combustibles stored in boiler room. For reporting purposes only. Platform bed bases and podium. \*\*Warning\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Lee County**

License Number: 4605593

WESTIN CAPE CORAL RESORT AT MARINA VILLAGE (THE)

License Type: Hotel

5951 SILVER KING BLVD, CAPE CORAL 33914

Inspection Date: 08/13/2020

Inspection Number: 1154229

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: EHMER, ANNETTE

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 6/20/20.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4600941

KONA KAI OF SANIBEL

License Type: Motel

1539 PERIWINKLE WAY, SANIBEL 33957

Inspection Date: 08/14/2020

Inspection Number: 1212107

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: WICK, JENNIFER

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed across from Tahiti room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Manatee County**

License Number: 5103072

HOLIDAY INN EXPRESS & SUITES BRADENTON WEST

License Type: Hotel

4450 47 ST W, BRADENTON 34210

Inspection Date: 08/12/2020

Inspection Number: 1156182

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RICHENDOLLAR, SANDRA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Per operator, a service looked at FACP, said it was okay. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Martin County**

License Number: 5300995

SANDCASTLE APARTMENTS

License Type: Apartment

25 E SEMINOLE ST, STUART 34994

Inspection Date: 08/14/2020

Inspection Number: 1490482

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In laundry room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5811275 CAMDEN THORNTON PARK  
 License Type: Apartment 420 E CHURCH ST, ORLANDO 32801

Inspection Date: 08/14/2020 Inspection Number: 1485152 Inspection Type: Routine - Lodging Inspection Disposition: Call Back -  
 Inspector Name: QUINONES, ANTONIO Complied

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. System on trouble stair 1 floor 1, wet tamper. - From follow-up inspection 2020-08-14: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5800300 EAGLE SUMMIT APARTMENTS  
 License Type: Apartment 3000 S RIO GRANDE AVE, ORLANDO 32805

Inspection Date: 08/10/2020 Inspection Number: 1506664 Inspection Type: Routine - Lodging Inspection Disposition: Administrative  
 Inspector Name: DIOP, DONALD complaint recommended

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In laundry facility.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5807756 CASTLE HOTEL AUTOGRAPH COLLECTION  
 License Type: Hotel 8629 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 08/14/2020 Inspection Number: 1156016 Inspection Type: Routine - Lodging Inspection Disposition: Inspection  
 Inspector Name: MANTI, KATHRYN Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5808945		EXTENDED STAY AMERICA #9636	
License Type: Hotel		4101 EQUITY ROW, ORLANDO 32819	
Inspection Date: 08/11/2020	Inspection Number: 1154590	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: CONNOLLY, MADELINE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5810939		PINNACLE POINTE	
License Type: Apartment		13001 AMBER LAKES BLVD, ORLANDO 32824	
Inspection Date: 08/10/2020	Inspection Number: 1497922	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ALVIS, DAVID			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5811195		UNIVERSITY HOUSE CENTRAL FLORIDA, L.L.C.	
License Type: Apartment		3200 N ALAFAYA TRL, ORLANDO 32826	
Inspection Date: 08/11/2020	Inspection Number: 1493696	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: THORNCROFT, ROBERT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Unit display is in trouble	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5801553		DAYS INN ORLANDO	
License Type: Motel		2500 W 33 ST, ORLANDO 32839	
Inspection Date: 08/14/2020	Inspection Number: 1213201	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DIOP, DONALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Palm Beach County**

License Number: 6001554		PALMS COURTYARD	
License Type: Apartment		1475 FOREST HILL BLVD, WEST PALM BEACH 33406-6030	
Inspection Date: 08/14/2020	Inspection Number: 1493454	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KAMM, DARYL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Next to unit 2.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6001575		4611 S CONGRESS LLC	
License Type: Apartment		4611 S CONGRESS AVE, LAKE WORTH 33461	
Inspection Date: 08/14/2020	Inspection Number: 1508669	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: KAMM, DARYL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to unit 213.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6014174		CONGRESS APARTMENTS	
License Type: Apartment		4177 S CONGRESS AVE, LAKE WORTH 33461	
Inspection Date: 08/10/2020	Inspection Number: 1508239	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KAMM, DARYL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. Next to unit 7. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6014058		WYNDHAM GRAND JUPITER AT HARBOURSIDE PLACE	
License Type: Hotel		122 SOUNDINGS AVE, JUPITER 33477	
Inspection Date: 08/13/2020	Inspection Number: 1155196	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ROTONDI, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.main panel.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Pinellas County**

License Number: 6200466		WELK ARMS APARTMENTS	
License Type: Apartment		4701 68 ST N, ST. PETERSBURG 33709	
Inspection Date: 08/13/2020	Inspection Number: 1508143	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HOBBS, ANDREW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. In front of unit 6a	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6209245		MELROSE ON THE BAY	
License Type: Apartment		16321 BOLESTA RD, CLEARWATER 33760	
Inspection Date: 08/13/2020	Inspection Number: 1509900	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LANTIGUA, ROBERTO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
07-01-4	Exposed electrical wires for smoke detector from where leak previously occurred per the tenant and operator. Unit 213. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6205892		SHERATON SAND KEY HOTEL	
License Type: Hotel		1160 GULF BLVD, CLEARWATER BCH 33767	
Inspection Date: 08/12/2020	Inspection Number: 1155294	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KOUSTIS, TIMOTHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 2 expired. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6204885		BEST WESTERN PLUS YACHT HARBOR INN	
License Type: Motel		150 MARINA PLAZA, DUNEDIN 34698	
Inspection Date: 08/12/2020	Inspection Number: 1213367	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PIATT, PAUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Between rooms 131-132	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	



**Seminole County**

License Number: 6903656

HAWTHORN SUITES BY WYNDHAM

License Type: Hotel

644 RAYMOND AVE, ALTAMONTE SPRINGS 32701

Inspection Date: 08/13/2020

Inspection Number: 1154230

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: MARTIN, LESLIE

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes.  
-Hearing Impaired Smoke Detector in room 111 not functioning when tested.  
\*\*Warning\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6903392

COURTYARD BY MARRIOTT

License Type: Hotel

135 INTERNATIONAL PKWY, LAKE MARY 32746

Inspection Date: 08/14/2020

Inspection Number: 1155657

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GUTTERMAN, KENNETH

Violation CodeObservationViolation Citation

07-04-4

Electrical outlet damaged to indicate a malfunction. For reporting purposes only.  
Face plate on alarm is missing two screws in room # 106

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**St. Lucie County**

License Number: 6602457

HAMPTON INN & SUITES

License Type: Hotel

155 SW PEACOCK BLVD, PORT ST. LUCIE 34986

Inspection Date: 08/12/2020

Inspection Number: 1155649

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HYNES, MONICA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. 3 rd floor

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7403613

SPRUCEWOOD APTS

License Type: Apartment

1450 S PALMETTO AVE, DAYTONA BEACH 32114

Inspection Date: 08/13/2020

Inspection Number: 1499539

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

07-01-4

Observed extension cord plug in laundry room and going out window to south side of building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406093

COASTLINE COVE APARTMENTS

License Type: Apartment

101 RACEWAY POINTE DR, DAYTONA BEACH 32114

Inspection Date: 08/12/2020

Inspection Number: 1509243

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

02-04-4

Motorcycle parked under landing by stairway building 6 by apartment 102. Motorcycle stored under stairway by apartment 103 building 2. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Supervisor light and system silence lights on in office area. manager states tech on site

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400525

THE PLAZA RESORT &amp; SPA

License Type: Hotel

600 N ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 08/11/2020

Inspection Number: 1154919

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Both boilers expired 7/2020.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

