

Bay County

License Number: 1305234 REDROOF INN
 License Type: Hotel 217 HWY 231, PANAMA CITY 32405

Inspection Date: 08/21/2020 Inspection Number: 1154923 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LYNN, NICKOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside room 320	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1300758 BOARDWALK BEACH HOTEL AND CONVENTION CENTER
 License Type: Motel 9600 S THOMAS DR, PANAMA CITY BCH 32408-4234

Inspection Date: 08/19/2020 Inspection Number: 1214397 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LYNN, NICKOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Side exterior wall of 4342	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1305754 ZIA VACATION RENTALS LLC
 License Type: Vacation Rental - Condo 16819 FRONT BEACH RD #2302, PANAMA CITY BEACH 32413

Inspection Date: 08/17/2020 Inspection Number: 1088371 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: LYNN, NICKOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In laundry, replaced at time of inspection. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1505400 CRANE CREEK SENIOR APARTMENTS
 License Type: Apartment 2309 S BABCOCK ST, MELBOURNE 32901

Inspection Date: 08/19/2020 Inspection Number: 1495046 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: MITTEN, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Laundry room by 110 Laundry room by 205	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1505692 HOME2 SUITES CAPE CANAVERAL
 License Type: Hotel 9004 ASTRONAUT BLVD, CAPE CANAVERAL 32920-4601

Inspection Date: 08/20/2020 Inspection Number: 1154684 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HICKS, GEORGE RANDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620848		CITY VIEW FLATS	
License Type: Apartment		254 E DANIA BEACH BLVD, DANIA 33004	
Inspection Date: 08/21/2020	Inspection Number: 1505233	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LONDONO, GLORIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
07-02-4	Frayed electrical wire(s). For reporting purposes only. back of building, below Window.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1621368		FILLMORE APATTMENTS INC	
License Type: Apartment		6219 SW 30 ST, MIRAMAR 33023	
Inspection Date: 08/21/2020	Inspection Number: 1491973	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GANPAT, INDAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1602665		PIERCE PENTHOUSE AP	
License Type: Apartment		6101 PIERCE ST, HOLLYWOOD 33024-7985	
Inspection Date: 08/14/2020	Inspection Number: 1493498	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BENJAMIN, ALEXANDER			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Next to apartment 4	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1620249		HAMPTON INN FORT LAUDERDALE DOWNTOWN LAS OLAS AREA	
License Type: Hotel		250 N ANDREWS AVE, FORT LAUDERDALE 33301	
Inspection Date: 08/20/2020	Inspection Number: 1156148	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANN, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Downstairs Lobby near restrooms.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Broward County

License Number: 1613680 H.O.M.E.S INC RESIDENTIAL RENTAL UNITS
 License Type: Apartment 1212 - 1222 NE 6 AVE, FORT LAUDERDALE 33304

Inspection Date: 08/18/2020 Inspection Number: 1502850 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRANN, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-04-4	Electrical outlet damaged to indicate a malfunction. 2 electrical outlets hanging by wire on South side of Building 1212. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1618777 ARIUM SUNRISE
 License Type: Apartment 1501 NW 124 TER, SUNRISE 33323

Inspection Date: 08/18/2020 Inspection Number: 1494758 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTINEZ, RHEANNE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed at bldg 2 next to apt. 2208.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. 1.)Observed at bldg 5 next to apt 5206. 2.)Observed at bldg 6 next to apt 6306. 3.)Observed at bldg 6 next to apt 6104. 4.)Observed	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Charlotte County

License Number: 1801421

HAMPTON INN

License Type: Hotel

24480 SANDHILL BLVD, PORT CHARLOTTE 33983

Inspection Date: 08/17/2020

Inspection Number: 1154289

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SAYED, MOHAMMED

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed expiration date of 06/11/2020 on boiler certificate. ****Repeat Violation****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2100188

LIGHT HOUSE INN

License Type: Motel

9140 GULF SHORE DRIVE N, NAPLES 34108

Inspection Date: 08/19/2020

Inspection Number: 1212747

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PFENNING, BRUNO

Violation Code

Observation

Violation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. In room #9. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2308540 WEST BUENA VISTA
 License Type: Apartment 145 W 28 ST, HIALEAH 33010

Inspection Date: 08/21/2020 Inspection Number: 1501263 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SANCHEZ, JAVIER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. By apartment 2. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By apartment 7 **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2317560 AVAZ INVESTMENT GROUP INC
 License Type: Apartment 1135 W 76 ST, HIALEAH 33016

Inspection Date: 08/19/2020 Inspection Number: 1505295 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CRUZ, EDGAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed in front of unit #2 and #8 **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2304761 NEXX MOTEL
 License Type: Motel 841 N KROME AVE, HOMESTEAD 33030

Inspection Date: 08/21/2020 Inspection Number: 1213488 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEIDECKER, EDILMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329827 THE BUSH INVESTMENT SVCS
 License Type: Apartment 314 SW 3 AVE, HOMESTEAD 33030

Inspection Date: 08/19/2020 Inspection Number: 1509917 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEIDECKER, EDILMA Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed portable fire extinguisher locked in a box located between unit 9 and 10.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329244 EXTENDED STAY AMERICA #1760
 License Type: Hotel 298 SW 15 RD, MIAMI 33129

Inspection Date: 08/17/2020 Inspection Number: 1152148 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: MASKASEM, SUPPACHAI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2020-08-17: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329491 SANDRA INVESTMENT GROUP INC
 License Type: Apartment 922 SW 3 ST, MIAMI 33130

Inspection Date: 08/19/2020 Inspection Number: 1478262 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: CRUZ, EDGAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. - From follow-up inspection 2020-08-19: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329329 EAST MIAMI
 License Type: Hotel 788 BRICKELL PLAZA, MIAMI 33131

Inspection Date: 08/21/2020 Inspection Number: 1156150 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Operator provided Aig inspection forms completed on 6/19/20. As per operator, still awaiting the certificates.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2324851 YVE HOTEL MIAMI
 License Type: Hotel 146 BISCAYNE BLVD, MIAMI 33132

Inspection Date: 08/17/2020 Inspection Number: 1154249 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PAGAN, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2314988 CAMPS APARTMENTS
 License Type: Apartment 1744 SW 5 ST, MIAMI 331353516

Inspection Date: 08/17/2020 Inspection Number: 1495251 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
06-01-4	Path to hallways marked as an exit is blocked. For reporting purposes only. Furniture in hallway second floor	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329441

DUNNS JOSEPHINE HOTEL

License Type: Hotel

1028 N.W. 3RD AVE, MIAMI 33136

Inspection Date: 08/18/2020

Inspection Number: 1155783

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: HENLEY, LATONYA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. By the double glass door.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328949

RIVERSIDE HOTEL

License Type: Motel

498 NE 78 ST, MIAMI 33138

Inspection Date: 08/21/2020

Inspection Number: 1214147

Inspection Type: Complaint Full

Inspection Disposition: Call Back - Complied

Inspector Name: SEYBA, JAMES

Violation CodeObservationViolation Citation

04-04-4

- From initial inspection : Fire alarm control panel has no power. For reporting purposes only. - From follow-up inspection 2020-08-21: Observed fire alarm panel has power but trouble light is illuminated.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2327567

PRESIDENT HOTEL

License Type: Hotel

1423 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 08/19/2020

Inspection Number: 1155518

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ALVAREZ, MARGARET

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Operator is replacing smoke detector **Corrective Action Taken**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328050

WHITELAW HOTEL & LOUNGE

License Type: Hotel

808 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 08/20/2020

Inspection Number: 1155979

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329419		LENNOX MIAMI	
License Type: Hotel		1900 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 08/18/2020	Inspection Number: 1156255	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ALVAREZ, MARGARET			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329265		NEW POINT MIAMI	
License Type: Hotel		5445 COLLINS AVE STE CU 15, MIAMI BEACH 33140	
Inspection Date: 08/20/2020	Inspection Number: 1156875	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329452		GIRASOLE APARTMENTS	
License Type: Hotel		5445 COLLINS AVE, MIAMI BEACH 33140	
Inspection Date: 08/20/2020	Inspection Number: 1156855	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2308174		HAMMER APTS	
License Type: Apartment		525 77 ST, MIAMI BEACH 33141	
Inspection Date: 08/17/2020	Inspection Number: 1500275	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed fire extinguisher box, 2nd floor, in disrepair with danger of falling cover glass and extinguisher.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329725		AQUA USA PROPERTY MANAGEMENT LLC	
License Type: Apartment		7917 WEST DR, NORTH BAY VILLAGE 33141	
Inspection Date: 08/19/2020	Inspection Number: 1493921	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking devices on extinguishers located by unit 9 and 1 backside. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2302135		PALM PLAZA APARTMENTS LLP	
License Type: Apartment		5791 SW 74 TERR, SOUTH MIAMI 33143	
Inspection Date: 08/20/2020	Inspection Number: 1504219	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PICO, JORGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed extinguisher on the second floor by elevator shaft in front of apartment 18 needing recharge	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2307942		MIAMI INT'L AIRPORT HOTEL	
License Type: Hotel		MIAMI INT'L AIRPORT, MIAMI 33159	
Inspection Date: 08/18/2020	Inspection Number: 1155709	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SANCHEZ, JAVIER			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. 059146,059147 no certified provided. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329451		RAMADA PLAZA MARCO POLO BEACH RESORT	
License Type: Hotel		19201 COLLINS AVENUE, SUNNY ISLES BEACH 33160	
Inspection Date: 08/14/2020	Inspection Number: 1156589	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Elevators undergoing maintenance at time of licensing.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2306754

COINCO INVESTMENT COMPANY

License Type: Apartment

12133 NE 5 AVE, MIAMI 33161

Inspection Date: 08/21/2020

Inspection Number: 1499232

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SUAREZ, LEOPOLDO

Violation Code

Observation

Violation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only. Observed fire alarm panel off

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2608861

BEST STAY INN

License Type: Motel

8220 DIX ELLIS TRAIL, JACKSONVILLE 32256

Inspection Date: 08/21/2020

Inspection Number: 1214406

Inspection Type: Complaint Full

Inspection Disposition: Administrative complaint recommended

Inspector Name: VILBRUN, JOSUE

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.
No smoke detector in room 103

509.215(1) and (2) and 509.032(2)(d) FS Reporting:
509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4603642

MAR BELLA APARTMENTS

License Type: Apartment

7961 GLADIOLUS DR, FORT MYERS 33908

Inspection Date: 08/17/2020

Inspection Number: 1509814

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SOMMERS, KARA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguishers between Units 206 & 208, Building 2, 302 & 304, Building 3.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301447

SUBURBAN EXTENDED STAY HOTEL STUART

License Type: Hotel

1900 SE FEDERAL HWY, STUART 34994

Inspection Date: 08/21/2020

Inspection Number: 1154518

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation Code

Observation

Violation Citation

04-05-4

No smoke detector provided in guest room/unit. For reporting purposes only.
Room 319.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811133		ECONOLOGDE	
License Type: Hotel		7102 INTERNATIONAL DR, ORLANDO 32819	
Inspection Date: 08/20/2020	Inspection Number: 1154778	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: YOUNG, COLIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5804083		SHERATON LAKE BUENA VISTA RESORT	
License Type: Motel		12205 AOPKA VINELAND RD, LAKE BUENA VISTA 32836	
Inspection Date: 08/17/2020	Inspection Number: 1214353	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SPEIGHTS, BLANCHIE MACHELLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed three boiler certification expired on 3/27/2020 spoke to Manager concerning status of the certification.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inpector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5802176		ARROW MOTEL	
License Type: Motel		5425 S ORANGE BLOSSOM TRL, ORLANDO 32839-2705	
Inspection Date: 08/20/2020	Inspection Number: 1214398	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: DIOP, DONALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Near room 148.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Osceola County

License Number: 5900523

LAKESIDE TERRACE INN AND SUITES

License Type: Motel

4880 W IRLO BRONSON HWY, KISSIMMEE 34746

Inspection Date: 08/20/2020

Inspection Number: 1214328

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: DAVIS, DIANNA

Violation CodeObservationViolation Citation

07-04-4

Power has been turned off to facility and 4-5 generators are running throughout property. **Warning**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Hotel

7769 W. IRLO BRONSON MEMORIAL HWY., KISSIMMEE 34747

Inspection Date: 08/21/2020

Inspection Number: 1155372

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LORENZO, ANA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014079

RESIDENCE INN BY MARRIOTT PALM BEACH GARDENS

License Type: Hotel

4250 DESIGN CENTER DR, PALM BEACH GARDENS 33410

Inspection Date: 08/20/2020

Inspection Number: 1156915

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GOLDMAN, BARRY

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. 3 boilers with 700,000btu/h.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6001575

4611 S CONGRESS LLC

License Type: Apartment

4611 S CONGRESS AVE, LAKE WORTH 33461

Inspection Date: 08/18/2020

Inspection Number: 1508669

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: KAMM, DARYL

Violation CodeObservationViolation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to unit 213.
 - From follow-up inspection 2020-08-17: **Time Extended** - From follow-up in

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to unit 213.
 - From follow-up inspection 2020-08-17: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6102921

HOLIDAY INN EXPRESS & SUITES TAMPA NORTH WESLEY CHAPEL

License Type: Hotel

2775 CYPRESS RIDGE BLVD, WESLEY CHAPEL 33544

Inspection Date: 08/19/2020

Inspection Number: 1155705

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: AIELLO, ROCCI

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Water leaking onto fire alarm, fire department was here today already.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215906

FAITH APARTMENTS

License Type: Apartment

7095 110 ST, SEMINOLE 33772

Inspection Date: 08/18/2020

Inspection Number: 1493716

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Next to unit 2. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216089

THE ALLURE AT GATEWAY APARTMENTS

License Type: Apartment

8851 US HWY 19 N, PINELLAS PARK 33782

Inspection Date: 08/17/2020

Inspection Number: 1509871

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WILMOT, TASHARA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
-the left of unit 2434

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6213599

BREEZEWAY VILLAS APARTMENTS

License Type: Apartment

4950 N 91 AVE, PINELLAS PARK 337825210

Inspection Date: 08/20/2020

Inspection Number: 1505064

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WILMOT, TASHARA

Violation CodeObservationViolation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6300396

WINTER HAVEN GARDENS INN & BANQUET CENTER

License Type: Motel

1150 3 ST SW, WINTER HAVEN 33880

Inspection Date: 08/20/2020

Inspection Number: 1213678

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: WHITE, CHERYL

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Santa Rosa County

License Number: 6700842

DAYS INN & SUITES

License Type: Motel

8700 NAVARRE PKWY, NAVARRE 32566

Inspection Date: 08/21/2020

Inspection Number: 1213007

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ADAMSON, ROBERT

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6602014

COLLEGE PARK APARTMENTS

License Type: Apartment

2703 VIRGINIA AVE, FORT PIERCE 34981

Inspection Date: 08/21/2020

Inspection Number: 1498804

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HARROD, JESSICA

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only. Looks like when painting all fire extinguishers were removed and not put back on any buildings.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Suwannee County

License Number: 7100241

ROYAL INN

License Type: Motel

966 US 129 N, LIVE OAK 32064

Inspection Date: 08/17/2020

Inspection Number: 1212859

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: GRODEWALD, PAUL

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher in front of room 203.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7401092

QUALITY INN

License Type: Motel

700 N ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 08/20/2020

Inspection Number: 1213550

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. System trouble, system silenced - From follow-up inspection 2020-08-20: **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406515

DAYTONA BEACH RESORT & CONF. CENTER

License Type: Hotel

2700 NORTH ATLANTIC AVENUE, DAYTONA BEACH 32118

Inspection Date: 08/19/2020

Inspection Number: 1154427

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7405218

EXTENDED STAY OF ORMOND

License Type: Motel

1608 N US HWY 1, ORMOND BEACH 32174

Inspection Date: 08/20/2020

Inspection Number: 1211647

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: RUTLEDGE, REBECCA

Violation CodeObservationViolation Citation

04-02-4

No smoke detector provided in guest room/unit number 167. For reporting purposes only.

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.