

Broward County

License Number: 1603078

STUDIO 825 RENTALS LLC

License Type: Hotel

825 NW 27 AVE, FORT LAUDERDALE 33311

Inspection Date: 09/16/2020

Inspection Number: 1155869

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MATTIELLO-ATASSI, MARIA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
For extinguisher across 212.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

02-07-4

Flammable chemicals stored near a source of ignition. For reporting purposes only.
Paint , wood stored next to water heater. Maintenance clean up area. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1614872

WELLEBY LAKE CLUB

License Type: Apartment

10931 NW 39 ST, SUNRISE 33351

Inspection Date: 09/18/2020

Inspection Number: 1506507

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MARTINEZ, RHEANNE

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed at 3rd story level in hallway at bldg 6.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2327683		GISELA INC APTS	
License Type: Apartment		1456 W 29 ST, HIALEAH 33012	
Inspection Date: 09/18/2020	Inspection Number: 1492170	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CUDEMOS, VIRNA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2327187		REMYNGTON APARTMENTS	
License Type: Apartment		925 NW KROME AVE, HOMESTEAD 33030	
Inspection Date: 09/18/2020	Inspection Number: 1507367	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LEIDECKER, EDILMA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed portable fire extinguishers locked in a box located one next to unit 12, one next to unit 7, one next to unit 25.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2327536		PARK GREEN APARTMENTS LLC	
License Type: Apartment		1060 NW 9 AVE, FLORIDA CITY 33034	
Inspection Date: 09/18/2020	Inspection Number: 1502076	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LEIDECKER, EDILMA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2328471		CAMERON CREEK LTD	
License Type: Apartment		1720 NW 3 TERR, FLORIDA CITY 33034	
Inspection Date: 09/16/2020	Inspection Number: 1504906	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LEIDECKER, EDILMA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed one fire extinguisher in the laundry room locked in a box.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2313673 2198 APARTMENTS
 License Type: Apartment 2198 NW 17 ST, MIAMI 331252234

Inspection Date: 09/16/2020 Inspection Number: 1494210 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTIN, RAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Located on second floor by unit number nine	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2327515 EXTENDED STAY AMERICA
 License Type: Hotel 6605 NW 7 ST, MIAMI 33126

Inspection Date: 09/18/2020 Inspection Number: 1156217 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ORDONEZ, CATALINA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher by room 162 on the second floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328462 SPRINGHILL SUITES MIAMI AIRPORT SOUTH
 License Type: Hotel 6700 NW 7 ST, MIAMI 33126

Inspection Date: 09/16/2020 Inspection Number: 1154608 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTINEZ, YANET

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329374

TOWNEPLACE SUITES MIAMI AIRPORT

License Type: Hotel

4021 NW 11TH ST, MIAMI 33126

Inspection Date: 09/11/2020

Inspection Number: 1155927

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MARTINEZ, YANET

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2313518

METRO SUN 1065 APTS

License Type: Apartment

1150 NW 29 ST, MIAMI 33127

Inspection Date: 09/17/2020

Inspection Number: 1492338

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: MARTIN, RAUL

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device for portable fire extinguisher locked in box on first floor level.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330122

VISTA GARDENS LLC

License Type: Apartment

4740 NW 7 AVE, MIAMI 33127

Inspection Date: 09/16/2020

Inspection Number: 1492117

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MARTIN, RAUL

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device on fire extinguisher located next to unit number 1 **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329257 ALOFT MARY BRICKELL
 License Type: Hotel 1001 SW 2 AVE, MIAMI 33130

Inspection Date: 09/18/2020 Inspection Number: 1151823 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: CABANAS, NATALIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2020-09-18: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed boiler jurisdiction number FL132827. No boiler certificate available. Unable to determine expiration date. - Fro	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inpector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2301965 CARRENO APTS
 License Type: Apartment 852 SW 1 ST, MIAMI 331301231

Inspection Date: 09/16/2020 Inspection Number: 1507251 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Both extinguishers missing breaking piece.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330233 HIGHLAND PARK 1020
 License Type: Apartment 1020 NW 7 AVE, MIAMI 33136

Inspection Date: 09/16/2020 Inspection Number: 1510106 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. By unit 102 in building 701. By unit 102, building 1091.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2306387		ALBITE APARTMENTS	
License Type: Apartment		8317 HARDING AVE, MIAMI BEACH 331411453	
Inspection Date: 09/17/2020	Inspection Number: 1499850	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device for fire extinguisher box. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2309493		1029 79 ST BLDG	
License Type: Apartment		1029 79 ST, MIAMI BEACH 331411822	
Inspection Date: 09/18/2020	Inspection Number: 1490216	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed missing breaking device in fire extinguisher box, Apt. 5	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2322921		LA QUINTA INN & SUITES #4040	
License Type: Hotel		3501 NW 42 AVE LEJEUNE RD, MIAMI 33142	
Inspection Date: 09/14/2020	Inspection Number: 1154354	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certification for both boiler's 135426 & 135427 expired on 8/22/2020	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329707		CENTURION MANAGEMENT	
License Type: Apartment		1816 NW 46 ST, MIAMI 33142	
Inspection Date: 09/16/2020	Inspection Number: 1493929	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location) located at front of apartment building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329884		BROWNSVILLE TRANSIT VILLAGE IV LLC	
License Type: Apartment		5185 NW 29 AVE, MIAMI 33142	
Inspection Date: 09/17/2020	Inspection Number: 1510070	Inspection Type: Complaint Full	Inspection Disposition: Call Back - Complied
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only located on the 1st floor next to management office. - From follow-up inspection 2020-09-17: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2307023		RUNWAY INN MIAMI AIRPORT	
License Type: Hotel		656 EAST DR, MIAMI SPRINGS 33166	
Inspection Date: 09/16/2020	Inspection Number: 1157221	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed extinguisher with no braking device located by units 227, 231, and 258.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
03-04-4	Fire sprinkler head obstructed/covered. For reporting purposes only. Observed in different units around the building	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2304222		JAMAICA ISLAND HOUSE	
License Type: Apartment		3700 NW 62 AVE, MIAMI 331667088	
Inspection Date: 09/17/2020	Inspection Number: 1504754	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HERNANDEZ, NILYAM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2313331

REBECCA'S VILLAGE

License Type: Apartment

10953 SW 4 ST, SWEETWATER 331741356

Inspection Date: 09/17/2020

Inspection Number: 1495130

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed extinguisher between units 2 and 3.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613256

HOMEWOOD SUITES BY HILTON JACKSONVILLE DOWNTOWN SOUTHBANK

License Type: Hotel

1201 KINGS AVE, JACKSONVILLE 32207

Inspection Date: 09/14/2020

Inspection Number: 1156187

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: ARMSTRONG, RICO

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
099962 099963 certificates expired on 10/18/19.61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613257

HILTON GARDEN INN JACKSONVILLE DOWNTOWN SOUTHBANK

License Type: Hotel

1201 KINGS AVE, JACKSONVILLE 32207

Inspection Date: 09/14/2020

Inspection Number: 1156184

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: ARMSTRONG, RICO

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
099962 099963 certificates expired on 10/18/19. ****Repeat Violation****61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Indian River County

License Number: 4100202

HOLIDAY INN OCEANSIDE

License Type: Motel

3384 OCEAN DR, VERO BEACH 32963

Inspection Date: 09/16/2020

Inspection Number: 1214295

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: SCHUCK, GREGORY

Violation Code

Observation

Violation Citation

08-06-4

- From initial inspection : Combustibles stored in boiler room. For reporting purposes only. Platform bed bases and podium. ****Warning**** - From follow-up inspection 2020-09-16: ****Time Extended****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Jackson County

License Number: 4200429

MARIANNA INN AND SUITES

License Type: Motel

2222 HWY 71, MARIANNA 32448

Inspection Date: 09/15/2020

Inspection Number: 1211921

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: YANDELL, TIMOTHY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Alarm light is illuminated on red alarm panel. A3 code.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4605577 PINK SHELL BEACH RESORT & SPA CAPTIVE VILLAS (CAPTIVA VILLAS)
 License Type: Hotel 190 ESTERO BLVD, FORT MYERS BEACH 33931

Inspection Date: 09/17/2020 Inspection Number: 1154181 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WICK, JENNIFER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. Observed on boiler at Sanibel building. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4605531 PINK SHELL BEACH RESORT AND SPA (SANIBEL)
 License Type: Hotel 140 ESTERO BLVD, FT MYERS BEACH 33931

Inspection Date: 09/17/2020 Inspection Number: 1154178 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WICK, JENNIFER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. Observed on boiler at Sanibel building. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4605517 PINK SHELL BEACH RESORT AND SPA (WHITE SANDS)
 License Type: Hotel 200 ESTERO BLVD, FT MYERS BEACH 33931

Inspection Date: 09/17/2020 Inspection Number: 1155273 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WICK, JENNIFER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed on boiler at Sanibel building.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5105080

CYPRESS WINDS APARTMENTS

License Type: Apartment

6904 MANATEE AVE W, BRADENTON 34209

Inspection Date: 09/15/2020

Inspection Number: 1510043

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: RICHENDOLLAR, SANDRA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Building 41.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5403172 ISLANDER BAYSIDE
 License Type: Hotel 81450 OVERSEAS HWY, ISLAMORADA 33036

Inspection Date: 09/15/2020 Inspection Number: 1155046 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: WHITEHURST, SCOTT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel located in the office . For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5402993 BATES B & B
 License Type: Bed and Breakfast 84791 OLD HWY, ISLAMORADA, VLG OF I 33036

Inspection Date: 09/15/2020 Inspection Number: 1093837 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WHITEHURST, SCOTT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
03-01-4	No fire sprinkler system installed in a transient lodging establishment three stories or more in height, or over 75 feet in height. For reporting purposes only.	509.215 and 509.032(2)(d) FS Reporting: 509.215 Any public lodging establishment, as defined in this chapter, which is of three stories or more, or over 75 feet in height shall be equipped with an automatic sprinkler system installed in compliance with the provisions prescribed in the National Fire Protection Association publication NFPA No. 13 "Standards for the Installation of Sprinkler Systems. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okeechobee County

License Number: 5700412	TANGLEWOOD APARTMENTS		
License Type: Apartment	420 NW 9 ST, OKEECHOBEE 349722121		
Inspection Date: 09/17/2020	Inspection Number: 1507481	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JACKS, ALBERT			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge in laundry room. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5700005	BUDGET INN		
License Type: Motel	201 S HWY 441, OKEECHOBEE 349744338		
Inspection Date: 09/17/2020	Inspection Number: 1211430	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JACKS, ALBERT			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5801836 ORLANDO ON THE LAKE APARTMENTS
 License Type: Apartment 701 S IVEY LN, ORLANDO 32811

Inspection Date: 09/14/2020 Inspection Number: 1494494 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: LUI, SUK HAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only./laundry room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811298 ARIEL
 License Type: Apartment 14001 BENVOLIO CIR, ORLANDO 32824

Inspection Date: 09/16/2020 Inspection Number: 1506535 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: ALVIS, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5804763 LAKE NONA CLUB
 License Type: Hotel 9100 CHILTERN DR, ORLANDO 328277029

Inspection Date: 09/14/2020 Inspection Number: 1154151 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: RULLAN, ALFONSO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. Expired 10-24-19.For reporting purposes only. - From follow-up inspection 2020-09-14: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811301 NONA PLACE ACQUISITION LLC
 License Type: Apartment 12855 SUNSLONE AVE, ORLANDO 32832

Inspection Date: 09/16/2020 Inspection Number: 1494962 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ALVIS, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811199

COLONIAL GRAND AT WINDERMERE # 127101

License Type: Apartment

11598 LACHLAN LN, WINDERMERE 34786

Inspection Date: 09/15/2020

Inspection Number: 1509284

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

Violation Code

Observation

Violation Citation

06-04-4

No door knob/opening device on marked exit door. For reporting purposes only.
Observed emergency lights not illuminated when tested in building #1,
Maintenance Manager checking on the status.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900523 LAKESIDE TERRACE INN AND SUITES
 License Type: Motel 4880 W IRLO BRONSON HWY, KISSIMMEE 34746

Inspection Date: 09/15/2020 Inspection Number: 1214718 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended
 Inspector Name: YOUNG, COLIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-04-4	Fire alarm control panel has no power. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-04-4	- From initial inspection : Power has been turned off to facility and 4-5 generators are running throughout property. **Warning** - From follow-up inspection 2020-08-24: Observed a man adding gas to a generator. **Admin Complaint** - From follow-	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-04-4	- From initial inspection : The facility does not have electricity, some units are running on generators. **Admin Complaint** - From follow-up inspection 2020-09-04: Electricity no provided . Observed generators running, in empty unit 103, the vanit	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900708 PARADISE INN
 License Type: Motel 4501 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746-5416

Inspection Date: 09/16/2020 Inspection Number: 1214720 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended
 Inspector Name: YOUNG, COLIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By room 114	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014017

THE BEARS CLUB-GUEST SUITE

License Type: Hotel

250 BEARS CLUB DR, JUPITER 33477

Inspection Date: 09/17/2020

Inspection Number: 1156048

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6205626		SAND COVE APTS	
License Type: Apartment		3813 GULF BLVD, ST.PETE BEACH 33706	
Inspection Date: 09/18/2020	Inspection Number: 1510064	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DAY-WALKER, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher on 2nd floor in laundry room in recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6202516		BAY POINTE TOWER APARTMENTS	
License Type: Apartment		880 OLEANDER WAY S, SOUTH PASADENA 33707	
Inspection Date: 09/17/2020	Inspection Number: 1510101	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: HOBBS, ANDREW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6205444		101 FERNWOOD APTS	
License Type: Apartment		101 N FERNWOOD AVE, CLEARWATER 33765	
Inspection Date: 09/11/2020	Inspection Number: 1492953	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: AIELLO, ROCCI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher upstairs hallway	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6201831		MAGNUSON HOTEL CLEARWATER BEACH	
License Type: Motel		421 S GULFVIEW BLVD, CLEARWATER BEACH 33767	
Inspection Date: 09/17/2020	Inspection Number: 1213188	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KOUSTIS, TIMOTHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to 222.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Pinellas County

License Number: 6215785

COCONUT COVE SUITES

License Type: Hotel

678 S GULFVIEW BLVD, CLEARWATER BEACH 33767

Inspection Date: 09/18/2020

Inspection Number: 1154740

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. In process of testing, yellow light alert.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6903656

HAWTHORN SUITES BY WYNDHAM

License Type: Hotel

644 RAYMOND AVE, ALTAMONTE SPRINGS 32701

Inspection Date: 09/14/2020

Inspection Number: 1154230

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: MARTIN, LESLIE

Violation CodeObservationViolation Citation

05-02-5

- From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes.
 -Hearing Impaired Smoke Detector in room 111 not functioning when tested.
 Warning - From follow-up inspection 2020-09-14: Room

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6900365

BIRCHWOOD LANDINGS CASSELBERRY

License Type: Apartment

1485 ASH CIR, CASSELBERRY 327076515

Inspection Date: 09/09/2020

Inspection Number: 1497837

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. At the laundry room at the office

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7401233

TROPICAL MANOR

License Type: Motel

2237 S ATLANTIC AVE, DAYTONA BCH SHORES 321185319

Inspection Date: 09/17/2020

Inspection Number: 1212619

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

03-01-4

No fire sprinkler system installed in a transient lodging establishment three stories or more in height, or over 75 feet in height. For reporting purposes only. Central building on property is 3 stories tall, maintenance employee states no sprinkler sys

509.215 and 509.032(2)(d) FS Reporting: 509.215 Any public lodging establishment, as defined in this chapter, which is of three stories or more, or over 75 feet in height shall be equipped with an automatic sprinkler system installed in compliance with the provisions prescribed in the National Fire Protection Association publication NFPA No. 13 "Standards for the Installation of Sprinkler Systems. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406509

INTEGRA LANDINGS

License Type: Apartment

1112 INTEGRA LANDINGS DR, ORANGE CITY 32763

Inspection Date: 09/16/2020

Inspection Number: 1506313

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: OCASIO-LOPEZ, LISA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. In the Office, building 2, building E, buildings, building H, Building 6, Building d, Fire panel has trouble light on. **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.