

Alachua County

License Number: 1102751

HILTON UNIVERSITY OF FLORIDA CONFERENCE CENTER GAINESVILLE

License Type: Hotel

1714 SW 34 ST, GAINESVILLE 32607

Inspection Date: 09/21/2020

Inspection Number: 1154886

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CASEY, KEITH

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Observed 1 fire extinguisher in the laundry, indicator is in the red zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bay County

License Number: 1300013

CHATEAU BY THE SEA

License Type: Motel

12525 W FRONT BEACH RD, PANAMA CITY BEACH 32407

Inspection Date: 09/22/2020

Inspection Number: 1213207

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MARSHALL, MICHAEL D

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1505671

COUNTRY INN & SUITES CAPE CANAVERAL

License Type: Hotel

9009 ASTRONAUT BLVD, CAPE CANAVERAL 32920

Inspection Date: 09/24/2020

Inspection Number: 1155272

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: HICKS, GEORGE RANDY

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Room 248. Would not flash when button was pushed on wall outside door. ****Warning****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620698

COURTYARD BY MARRIOTT

License Type: Hotel

400 GULF STREAM WAY, DANIA 33004

Inspection Date: 09/21/2020

Inspection Number: 1155278

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LONDONO, GLORIA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
J# 058963, 04/12/20; J# 058961, 04/12/20; J#098778, 04/12/20; J# 059137, 04/12/20.61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620917

TRU BY HILTON FORT LAUDERDALE AIRPORT

License Type: Hotel

44 N FEDERAL HWY, DANIA BEACH 33004

Inspection Date: 09/25/2020

Inspection Number: 1155245

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LONDONO, GLORIA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to room 501

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620893

HAMPTON INN FORT LAUDERDALE/POMPANO BEACH

License Type: Hotel

900 S FEDERAL HWY, POMPANO BEACH 33062

Inspection Date: 09/24/2020

Inspection Number: 1155929

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BURGGRAVE, BROCK

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Clay County

License Number: 2000918

FAIRFIELD INN

License Type: Hotel

450 ELDRIDGE PKWY, ORANGE PARK 32073

Inspection Date: 09/25/2020

Inspection Number: 1154820

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BIAVA, GRANT

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
 Trouble reading on fire panel, personal replacing fire panel during inspection.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2101115

INN OF NAPLES

License Type: Hotel

4055 TAMIAMI TRAIL N, NAPLES 34103

Inspection Date: 09/25/2020

Inspection Number: 1155887

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: PENN, BRIAN

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed expiration date of 7/18/2020.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2306402		SAN JORGE APARTMENTS	
License Type: Apartment		3601 W 12 AVE, HIALEAH 33012	
Inspection Date: 09/24/2020	Inspection Number: 1507714	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CUDEMOS, VIRNA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2303984		BLACKSTONE VILLAS	
License Type: Apartment		3699 W 12 AVE, HIALEAH 330124994	
Inspection Date: 09/24/2020	Inspection Number: 1499931	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CUDEMOS, VIRNA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Near apto #21111@	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2311941		BELLA VILLA APTS	
License Type: Apartment		1150 W 79 ST, HIALEAH 330143580	
Inspection Date: 09/22/2020	Inspection Number: 1499174	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VILCHEZ, NABEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. At the laundry room and next to apartment 214,102,114 on building A. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2312003		SPECTRUM NETWORK	
License Type: Apartment		31 NW 5 ST, HOMESTEAD 33030	
Inspection Date: 09/21/2020	Inspection Number: 1490723	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: LEIDECKER, EDILMA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed portable fire extinguisher locked in a box between unit 11 and 12.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2328181 1225 NE 1 TERR APTS
 License Type: Apartment 1225 NE 1 TERR, HOMESTEAD 33030

Inspection Date: 09/24/2020 Inspection Number: 1493086 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEIDECKER, EDILMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Pull fire alarm locked in a box with no means of access to the fire extinguisher. For reporting purposes only. One located next to unit 2, and one next to unit 9 first floor, one next to unit 17 second floor. And fire extinguisher located outside of lau	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329133 KENNIT CORP 308 SW 4 AVE
 License Type: Apartment 308 SW 4 AVE, HOMESTEAD 33030

Inspection Date: 09/25/2020 Inspection Number: 1502865 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEIDECKER, EDILMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located second floor building 308 next to unit 3.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328195 TROVATO
 License Type: Apartment 76 SW 8 AVE, FLORIDA CITY 33034

Inspection Date: 09/23/2020 Inspection Number: 1507748 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEIDECKER, EDILMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed fire extinguisher locked in a box with no means of access between unit 76C and 76D.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329564 ORCHID GROVE
 License Type: Apartment 750 NW 8 ST, FLORIDA CITY 33034

Inspection Date: 09/22/2020 Inspection Number: 1495993 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEIDECKER, EDILMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed Fire alarm push in/push down locked in a box with no means of access at building one in front of the stairs next to unit 11	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2309016		PERRYS MOTEL	
License Type: Apartment		2196 ALIBABA AVE, OPA LOCKA 330542842	
Inspection Date: 09/23/2020	Inspection Number: 1490218	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SUAREZ, LEOPOLDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2301531		2285 LLC	
License Type: Apartment		2285 NW 2 ST, MIAMI 33125	
Inspection Date: 09/22/2020	Inspection Number: 1494078	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MARTIN, RAUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Fire panel displayed a yellow maintenance light at the time of inspection	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2327712		JIMENEZ APARTMENTS	
License Type: Apartment		1801 NW 18 TERR, MIAMI 33125	
Inspection Date: 09/24/2020	Inspection Number: 1505474	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MARTIN, RAUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only. Observed near apartment 5, screws in the wall where fire extinguisher box was installed. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329239		VITA INVESTMENTS	
License Type: Apartment		1429 NW 2 ST, MIAMI 33125	
Inspection Date: 09/22/2020	Inspection Number: 1502884	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MARTIN, RAUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device on second floor fire extinguisher box next to unit number 6 at time of inspection	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2310764

RENE APARTMENTS

License Type: Apartment

1342 NW 3 ST, MIAMI 331255636

Inspection Date: 09/25/2020

Inspection Number: 1492639

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MARTIN, RAUL

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to apartment number two

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2316439

CASA BONITA APTS

License Type: Apartment

345 NW 57 AVE, MIAMI 331264862

Inspection Date: 09/24/2020

Inspection Number: 1495149

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MARTINEZ, YANET

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed on first floor by apartment 102.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. 01-06-4 Observed: Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purpose

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2311239

JOCEL CORPORATION

License Type: Apartment

729 SW 2 ST, MIAMI 33130

Inspection Date: 09/24/2020

Inspection Number: 1507739

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. First floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330310		1134 APT LLC	
License Type: Apartment		1134 SW 4 ST, MIAMI 33130	
Inspection Date: 09/18/2020	Inspection Number: 1489957	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located on 2nd floor next to Apt 9. - From follow-up inspection 2020-09-18: Portable fire extinguis	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2314753		HILTON MIAMI DOWNTOWN	
License Type: Hotel		1601 BISCAYNE BLVD, MIAMI 33132	
Inspection Date: 09/23/2020	Inspection Number: 1155049	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: PAGAN, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-07-4	Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only. Fire alarm technicians working at the time of inspection.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329207		SPRINGHILL SUITES BY MARRIOTT	
License Type: Hotel		1311 NW 10TH AVE, MIAMI 33136	
Inspection Date: 09/23/2020	Inspection Number: 1156355	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329441		DUNNS JOSEPHINE HOTEL	
License Type: Hotel		1028 N.W. 3RD AVE, MIAMI 33136	
Inspection Date: 09/21/2020	Inspection Number: 1155783	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. By the double glass door. - From follow-up inspection 2020-09-21: During the callback inspection, observed the trouble/alarm lig	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2330172		BENJAMIN RE OVERTOWN 613 LLC	
License Type: Apartment		1837 NW 3 AVE, MIAMI 33136	
Inspection Date: 09/21/2020	Inspection Number: 1510072	Inspection Type: Complaint Full	Inspection Disposition: Call Back - Complied
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. By unit 1, 5, 12. - From follow-up inspection 2020-09-21: Portable fire extinguis	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2306777		PRETORIA ESTATE AG LLC	
License Type: Apartment		934 MERIDIAN AVE, MIAMI BEACH 33139	
Inspection Date: 08/04/2020	Inspection Number: 1505942	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329040		BENTLEY BEACH HOTEL	
License Type: Hotel		101 OCEAN DRIVE, MIAMI BEACH 33139	
Inspection Date: 09/23/2020	Inspection Number: 1155266	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2020-08-26: **Time Extended** - From follow-up inspection 2020-09-2	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2326199		FININVEST BAY CORP	
License Type: Apartment		7050 BONITA DR, MIAMI BEACH 33141	
Inspection Date: 09/23/2020	Inspection Number: 1505551	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329161

FININVEST BAY CORP

License Type: Apartment

7080 BONITA DR, MIAMI BEACH 33141

Inspection Date: 09/23/2020

Inspection Number: 1508008

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device on fire extinguishers located by unit 28 and unit 30.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330126

SEASIDE APARTMENT HOTEL

License Type: Apartment

7600 HARDING AVE, MIAMI BEACH 33141

Inspection Date: 09/22/2020

Inspection Number: 1494440

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed main panel with trouble light illuminated. Manager reseted it . **Corrected On-Site**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330487

YINDCO GROUP LLC

License Type: Apartment

7724 HARDING AVE, MIAMI BEACH 33141

Inspection Date: 09/23/2020

Inspection Number: 1490082

Inspection Type: Lodging-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed extinguisher located by unit 14 in red zone, needing recharge .

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only . Observed no breaking device on extinguisher located by unit 9.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2319933		EMBASSY SUITES HOTEL MIAMI AIRPORT	
License Type: Hotel		3974 NW SOUTH RIVER DR, MIAMI 33142	
Inspection Date: 09/24/2020	Inspection Number: 1154335	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler jurisdiction number's 120328, 075518, 123961; All expired on 4/04/2020	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only. None made available at the time expect for boiler jurisdiction number 120328, with an expired certification as of 4/04/2020.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2328958		HOLIDAY INN	
License Type: Motel		7927 NW 7 AVE, MIAMI 33150	
Inspection Date: 09/21/2020	Inspection Number: 1212609	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JOSEPH, VANRIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2312181		671 BUILDING	
License Type: Apartment		671 S ROYAL POINCIANA BLVD, MIAMI SPGS 331667282	
Inspection Date: 09/22/2020	Inspection Number: 1492669	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HERNANDEZ, NILYAM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed near apartment 207.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2313775

PARK TOWERS APARTMENTS

License Type: Apartment

777 NW 155 LANE, MIAMI 33169

Inspection Date: 09/21/2020

Inspection Number: 1491335

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: STUBBS, CHRISTINE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed main final panel trouble light is on. (10th floor). Property Manager called Advanced Fire & Security Co.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328877

MY ROOM

License Type: Bed and Breakfast

12901 NW 11 TERRACE, MIAMI 33182

Inspection Date: 09/24/2020

Inspection Number: 1093829

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed extinguisher overcharged inside room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2608252

RED ROOF INN

License Type: Motel

6099 YOUNGERMAN CIR, JACKSONVILLE 32244

Inspection Date: 09/23/2020

Inspection Number: 1214800

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By room 137.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3902285

SANDANAY APARTMENTS

License Type: Apartment

13132 N 19 ST, TAMPA 33612

Inspection Date: 09/18/2020

Inspection Number: 1508712

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MCINTYRE, REGIS

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Between apartment 214 and 215.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Jackson County

License Number: 4200454

SUPER 8 MOTEL

License Type: Motel

2226 HWY 71, MARIANNA 32448

Inspection Date: 09/21/2020

Inspection Number: 1211631

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: YANDELL, TIMOTHY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside unit 215.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lake County

License Number: 4500220

MISSION INN

License Type: Motel

10400 CR 48, HOWEY IN THE HILLS 34737

Inspection Date: 09/24/2020

Inspection Number: 1213868

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FREY, RANDY

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4602914

DAYS INN SPRINGS RESORT

License Type: Motel

18051 SOUTH TAMIAMI TRAIL, FORT MYERS 33908

Inspection Date: 09/21/2020

Inspection Number: 1212220

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SOMMERS, KARA

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5202487

PAREL RENTAL

License Type: Apartment

1890 NW 40 AVE RD, OCALA 34482

Inspection Date: 09/21/2020

Inspection Number: 1508762

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WEATHERS, TIM

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Fire extinguisher outside D2 lacks breaker bar for glass. Chain present, but no bar.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Nassau County

License Number: 5500867

THE SURF RESTAURANT AND BAR

License Type: Motel

3199 S FLETCHER AVE, FERNANDINA BEACH 32034

Inspection Date: 09/24/2020

Inspection Number: 1213176

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In laundry room

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811136

THE ALFOND INN

License Type: Hotel

300 E NEW ENGLAND AVE, WINTER PARK 32789

Inspection Date: 09/23/2020

Inspection Number: 1154678

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: MONTGOMERY, DOREEN

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Both certificates expired 2/20/20

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811250

55 WEST APARTMENTS

License Type: Apartment

55 W CHURCH ST, ORLANDO 32801

Inspection Date: 09/25/2020

Inspection Number: 1506101

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: QUINONES, ANTONIO

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

11 and 12 floors common trouble.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5801847

QUALITY INN AND SUITES

License Type: Hotel

626 LEE RD, ORLANDO 32810

Inspection Date: 09/21/2020

Inspection Number: 1156380

Inspection Type: Complaint Full

Inspection Disposition: Call Back - Admin. complaint recommended

Inspector Name: LUI, SUK HAN

Violation CodeObservationViolation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only./on silence, alarm panel at front counter. - From follow-up inspection 2020-08-21: At callback 8/21/20, alarm company called for

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811161

HOMEWOOD SUITES ORLANDO CONVENTION CENTER SOUTH

License Type: Hotel

6940 WESTWOOD BLVD, ORLANDO 32821

Inspection Date: 09/22/2020

Inspection Number: 1156220

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: YOUNG, COLIN

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.

Room 211, tested with door bell, the device did not work

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5804794		CYPRESS RUN APARTMENTS	
License Type: Apartment		7100 GATESHEAD CIR, ORLANDO 32822	
Inspection Date: 09/23/2020	Inspection Number: 1497732	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RULLAN, ALFONSO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
06-02-4	Door marked as an exit is blocked. Inside maintenance shop. For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5809051		EMBASSY SUITES HOTELS	
License Type: Hotel		5835 T G LEE BLVD, ORLANDO 32822	
Inspection Date: 09/24/2020	Inspection Number: 1156319	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RULLAN, ALFONSO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5805772		MONCLER VISTA VERDE	
License Type: Apartment		1658 S HIAWASSEE RD, ORLANDO 32835	
Inspection Date: 09/25/2020	Inspection Number: 1494008	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LUI, SUK HAN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only./single garage building next to building 16.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5811199		COLONIAL GRAND AT WINDERMERE # 127101	
License Type: Apartment		11598 LACHLAN LN, WINDERMERE 34786	
Inspection Date: 09/24/2020	Inspection Number: 1509284	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: SPEIGHTS, BLANCHIE MACHELLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
06-04-4	- From initial inspection : No door knob/opening device on marked exit door. For reporting purposes only. Observed emergency lights not illuminated when tested in building #1, Maintenance Manager checking on the status. - From follow-up inspection 2	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Pinellas County

License Number: 6215013		LEXINGTON CLUB APARTMENTS	
License Type: Apartment		1200 S MISSOURI AVE, CLEARWATER 33756	
Inspection Date: 09/24/2020	Inspection Number: 1509794	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LANTIGUA, ROBERTO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
07-02-4	Frayed electrical wire(s) on exit door around the corner from unit 156. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6207593		HILTON CLEARWATER BEACH RESORT	
License Type: Hotel		400 MANDALAY AVE, CLEARWATER 33767	
Inspection Date: 09/24/2020	Inspection Number: 1154509	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KOUSTIS, TIMOTHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FI 058653,056656,122236 all exp 1/25/2020 **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inpector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6215808		WYNDHAM GRAND CLEARWATER BEACH RESORT	
License Type: Hotel		100 CORONADO DR, CLEARWATER 33767	
Inspection Date: 09/22/2020	Inspection Number: 1155659	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KOUSTIS, TIMOTHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6215774		THE TARPON INN	
License Type: Motel		110 W TARPON AVE, TARPON SPRINGS 34689	
Inspection Date: 09/21/2020	Inspection Number: 1213220	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HIRST, DAN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher on second floor of second building between rooms 221 and 222 is in the recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Seminole County

License Number: 6903656 HAWTHORN SUITES BY WYNDHAM
 License Type: Hotel 644 RAYMOND AVE, ALTAMONTE SPRINGS 32701

Inspection Date: 09/24/2020 Inspection Number: 1154230 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: MARTIN, LESLIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
05-02-5	- From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes. -Hearing Impaired Smoke Detector in room 111 not functioning when tested. **Warning** - From follow-up inspection 2020-09-14: Room	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6903260 OVIEDO DUPLEXES
 License Type: Apartment 993 SHARON COURT, OVIEDO 32765

Inspection Date: 09/22/2020 Inspection Number: 1496815 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: THORNCROFT, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Several fire extinguisher missing from the red boxes **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6900482 MARINERS VILLAGE APARTMENTS
 License Type: Apartment 3202 S ORLANDO DR, SANFORD 32773

Inspection Date: 09/24/2020 Inspection Number: 1497058 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GUTTERMAN, KENNETH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-02-4	Frayed electrical wire(s). For reporting purposes only. At the AC unit next to unit #1001	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6500693

ST AUGUSTINE OCEAN INN

License Type: Motel

3955 HWY A1A S, ST AUGUSTINE 32080

Inspection Date: 09/25/2020

Inspection Number: 1211770

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FRANCO, RICHARD

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher in front of room115 has needle in red zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6600774

BEST WESTERN PORT ST LUCIE

License Type: Motel

7900 S US #1, PORT SAINT LUCIE 34952

Inspection Date: 09/25/2020

Inspection Number: 1212997

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HYNES, MONICA

Violation Code

Observation

Violation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Maintenance is replacing battery.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400226 SEA SCAPE INN
 License Type: Motel 2601 S ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 09/25/2020 Inspection Number: 1214653 Inspection Type: Complaint Full Inspection Disposition: Call Back -
 Inspector Name: WOOD, JUSTIN Complied

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-03-4	- From initial inspection : Evidence of major fire/soot/scorch marks in laundry room . For reporting purposes only. - From follow-up inspection 2020-09-11: **Time Extended** - From follow-up inspection 2020-09-14: **Time Extended** - From f	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-03-4	- From initial inspection : Evidence of major fire/soot/scorch marks in laundry room . For reporting purposes only. - From follow-up inspection 2020-09-11: **Time Extended** - From follow-up inspection 2020-09-14: **Time Extended** - From f	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406606 VIRGIL AND ELLEN ROSENFELD FAMILY TRUST
 License Type: Apartment 419 N WILD OLIVE AVE, DAYTONA BEACH 32118

Inspection Date: 09/22/2020 Inspection Number: 1510150 Inspection Type: Complaint Full Inspection Disposition: Warning
 Inspector Name: WOOD, JUSTIN Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Unit 6 from consumer complaint	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-05-4	No smoke detector provided in guest room/unit. For reporting purposes only. Unit 6 from consumer complaint.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406411 HAWAIIAN INN
 License Type: Vacation Rental - Condo 2301 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 09/21/2020 Inspection Number: 1088381 Inspection Type: Complaint Full Inspection Disposition: Call Back -
 Inspector Name: WOOD, JUSTIN Extension given, pending

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Trouble lights on, low battery smoke detector and "CO - Boiler room". - From follow-up inspection 2020-09-21: **Time Extended*	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7403589 THE BOULEVARD
 License Type: Apartment 1757 S CLYDE MORRIS BLVD, DAYTONA BEACH 32119

Inspection Date: 09/24/2020 Inspection Number: 1492349 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Building 33 trouble and disable lights on. - From follow-up inspection 2020-09-24: Maintenance states tech is getting a new batt	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Building 33 trouble and disable lights on.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401244 DRIFTWOOD RESORT
 License Type: Motel 657 S ATLANTIC AVE, ORMOND BEACH 32176

Inspection Date: 09/24/2020 Inspection Number: 1212769 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RUTLEDGE, REBECCA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-02-4	No smoke detector provided in guest room/unit 318. For reporting purposes only.	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.