

Broward County

License Number: 1606303 TARA APARTMENT
 License Type: Apartment 1754 FUNSTON ST, HOLLYWOOD 33020

Inspection Date: 01/15/2021 Inspection Number: 1503007 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CASTILLO, JESSIKA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher in recharge zone for FE located on 3rd floor by unit 5C.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1605407 4800/4928 HB LLC
 License Type: Apartment 4928 HOLLYWOOD BLVD, HOLLYWOOD 33021

Inspection Date: 01/15/2021 Inspection Number: 1502014 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTINEZ, RHEANNE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed at fire extinguisher in hallway next to apt #15.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1606897 HOLLYWOOD SQUARE APTS
 License Type: Apartment 5500 WASHINGTON ST, HOLLYWOOD 33021

Inspection Date: 01/15/2021 Inspection Number: 1506382 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTINEZ, RHEANNE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-04-4	1.) No portable fire extinguisher present on the premises. For reporting purposes only. Observed fire extinguisher missing from wall on 2nd floor hallway just north of apt 210. Bldg D	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
	2.) Observed fire extinguisher on 1st Floor in recharge zone-south end of hallway. Bldg C	
04-05-4	No smoke detector provided in hallway on 3rd floor- Bldg C, north end of hallway. Observed missing smoke detector missing from ceiling. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1603450 POMPANO GARDEN APARTMENTS
 License Type: Apartment 610 NW 7 AVE, POMPANO BEACH 33060-5860

Inspection Date: 01/13/2021 Inspection Number: 1500605 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BURGGRAVE, BROCK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Next to apt #24 at north end.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621487 AVERY PLACE LLC
 License Type: Apartment 275 N FEDERAL HWY, POMPANO BEACH 33062

Inspection Date: 01/14/2021 Inspection Number: 1504503 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: BURGGRAVE, BROCK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1607551 ABL HOMES MRT LLC
 License Type: Apartment 1151 NE 16 CT, FORT LAUDERDALE 33305

Inspection Date: 01/15/2021 Inspection Number: 1501639 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MATTIELLO-ATASSI, MARIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-04-4	Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Exit sign at apt 16 is not attached to the soffit. Hanging from 1 wire.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621433 PARC 3400
 License Type: Apartment 3400 DAVIE RD, DAVIE 33314

Inspection Date: 01/15/2021 Inspection Number: 1501750 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BARTON, GEOFFREY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Fire control panel east end Building 2 level 1 flashing indicating system trouble. Management aware of issue and working to resolve.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Charlotte County

License Number: 1801529 HOLIDAY INN EXPRESS & SUITES PUNTA GORDA
 License Type: Hotel 9075 MAC DR, PUNTA GORDA 33950

Inspection Date: 01/11/2021 Inspection Number: 1154597 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SAYED, MOHAMMED

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Jurisdiction No. 134468. Expiration: 08/17/2020	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329363 SELINA OPERATION MIAMI RIVER
 License Type: Hotel 445 SW 2 ST, MIAMI 33130

Inspection Date: 01/14/2021 Inspection Number: 1157245 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: CABANAS, NATALIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed next to unit 501 and 502.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329846 GROVE STATION TOWER
 License Type: Apartment 2701 SW 27 CT, MIAMI 33133

Inspection Date: 01/13/2021 Inspection Number: 1501389 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: MASKASEM, SUPPACHAI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. The operator mentioned that they already had the inspector came and renewed boiler certificate. **Corrective Action Taken** - From follow-up inspection 2020-12-18: **Time Extended** - From follow-up inspection 2021-01-13: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4605597 HOLIDAY INN
 License Type: Hotel 2431 CLEVELAND AVENUE, FORT MYERS 33901

Inspection Date: 01/14/2021 Inspection Number: 1155626 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WALTER, KAYLA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light on in main fire panel.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4600320 TRAVEL INN
 License Type: Motel 2939 CLEVELAND AVE, FORT MYERS 339016005

Inspection Date: 01/14/2021 Inspection Number: 1213604 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: WALTER, KAYLA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. Observed no smoke detector in room 116.	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Madison County

License Number: 5000122

SUPER 8 MOTEL

License Type: Motel

SR 53 & I-10, MADISON 32340

Inspection Date: 01/14/2021

Inspection Number: 1212472

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SMITH, PAUL

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only. Cover plate missing from electrical outlet room 111.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5403209 BUNGALOWS KEY LARGO
 License Type: Hotel 99060 OVERSEAS HWY, KEY LARGO 33037

Inspection Date: 01/15/2021 Inspection Number: 1156729 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: GONZALEZ, RICARDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5402738 1424 NEWTON ST APARTMENTS
 License Type: Apartment 1424 NEWTON ST, KEY WEST 33040

Inspection Date: 01/11/2021 Inspection Number: 1495392 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ORDONEZ, CATALINA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher located by unit B on the second floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5402759 COURTYARD BY MARRIOTT
 License Type: Hotel 3031 N ROOSEVELT BLVD, KEY WEST 33040

Inspection Date: 01/13/2021 Inspection Number: 1154989 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: GONZALEZ, RICARDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5400192 NEWTON STREET APTS/NSA
 License Type: Apartment 1321-1325 NEWTON ST, KEY WEST 330407025

Inspection Date: 01/11/2021 Inspection Number: 1498839 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTINEZ, YANET

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Located in the 1st floor by unit 1321.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811128 KATERINA HOTEL ORLANDO
 License Type: Hotel 830 LEE RD, ORLANDO 32810

Inspection Date: 01/11/2021 Inspection Number: 1156170 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: MONTESANO, MISTI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. -Boiler certificate for FL131960 expired 9/26/2020 - From follow-up inspection 2021-01-11: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5804539 LA QUINTA INN ORLANDO AIRPORT WEST #642
 License Type: Motel 7931 DAETWYLER DR, ORLANDO 32812

Inspection Date: 01/11/2021 Inspection Number: 1214698 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RULLAN, ALFONSO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5805708 DOUBLETREE BY HILTON ORLANDO AIRPORT
 License Type: Hotel 5555 HAZELTINE NATIONAL DR, ORLANDO 32812

Inspection Date: 01/14/2021 Inspection Number: 1157231 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FRANZ, LISA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.- inspected in December, have not received certificates yet.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5810516

COUNTRY INN & SUITES ORLANDO AIRPORT

License Type: Hotel

5440 FORBES PL, ORLANDO 32812

Inspection Date: 01/15/2021

Inspection Number: 1157260

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: FRANZ, LISA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900225

SERALAGO HOTEL AND SUITES MAINGATE EAST

License Type: Hotel

5678 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 01/12/2021

Inspection Number: 1155452

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: FERTIL, SYLVERST

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6103013

OSPREY POINTE

License Type: Apartment

12780 COURTYARD ESTATES BLVD, DADE CITY 33525

Inspection Date: 01/15/2021

Inspection Number: 1509764

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: POWELL, DAVID

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Gauge is turned to back of box and unable to determine charge on fire extinguishers in locked boxes.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Some fire extinguisher boxes are locked and tools to obtain access are not present.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6214016 PALM GROVE INN
 License Type: Hotel 711 3 AVE S OFFICE, ST. PETERSBURG 33701

Inspection Date: 01/14/2021 Inspection Number: 1158495 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: VILLEGAS, TATTYANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Second floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6205531 DON CESAR HOTEL
 License Type: Hotel 3400 GULF BLVD, ST.PETE BEACH 33706

Inspection Date: 01/15/2021 Inspection Number: 1158137 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DAY-WALKER, LISA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only. Boiler certificates not posted in the boiler room. Employee placing certificates in boiler room. **Corrective Action Taken**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6206509 PINWOOD APARTMENTS
 License Type: Apartment 5430 1ST AVE S, ST. PETERSBURG 33707

Inspection Date: 01/11/2021 Inspection Number: 1503236 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HOBBS, ANDREW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. In laundry room	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6201261 EITEL-SYNDER APARTMENTS
 License Type: Apartment 301 NIMBUS AVE S, CLEARWATER 33765

Inspection Date: 01/13/2021 Inspection Number: 1490737 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BENEDICT, TRACY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By unit 7 **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215784 HYATT REGENCY CLEARWATER BEACH RESORT & SPA
 License Type: Hotel 301 GULF VIEW BLVD, CLEARWATER 33767

Inspection Date: 01/15/2021 Inspection Number: 1157401 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215786 PIER HOUSE 60
 License Type: Hotel 101 CORONADO DR, CLEARWATER 33767

Inspection Date: 01/13/2021 Inspection Number: 1156561 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6201831 MAGNUSON HOTEL CLEARWATER BEACH
 License Type: Motel 421 S GULFVIEW BLVD, CLEARWATER BEACH 33767

Inspection Date: 01/15/2021 Inspection Number: 1214793 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to room 222. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6304829 PLANTATION APARTMENTS OF LAKELAND LLC
 License Type: Apartment 515 BON AIR ST, LAKELAND 33805

Inspection Date: 01/14/2021 Inspection Number: 1502207 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WARE, CRYSTAL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location) on side of building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6303266 IMPERIAL SWAN HOTEL & SUITES
 License Type: Hotel 4141 S FLORIDA AVE, LAKELAND 33813

Inspection Date: 01/12/2021 Inspection Number: 1158469 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended
 Inspector Name: BEAULIEU, STEPHANIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 074517 expired 5-14-2020. Front desk rep said inspector came by today and will certify boiler **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6903790

VISTA HAVEN APARTMENT HOMES

License Type: Apartment

4100 GERANIUM LN, SANFORD 32771

Inspection Date: 01/11/2021

Inspection Number: 1497318

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Notified Dan Taylor, Sanford Fire Inspector, 407-562-2788. Left Voice Message. - From follow-up inspection 2021-01-11:

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400673 BEST WESTERN DAYTONA INN SEABREEZE
 License Type: Motel 730 N ATLANTIC AVE, DAYTONA BCH 321183805

Inspection Date: 01/14/2021 Inspection Number: 1215019 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: WOOD, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Trouble/Silenced lights, stating "Fire Trouble Room 223". Manager states previous fire in room, unit is not currently being rented	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7403386 RIVERVIEW HOTEL
 License Type: Hotel 103 FLAGLER AVE, NEW SMYRNA BEACH 32169

Inspection Date: 01/13/2021 Inspection Number: 1158470 Inspection Type: Complaint Full Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: PICHARDO, RENEE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2021-01-13: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2021-01-13: **Time Extended** - From follow-up inspection 2021-01-14: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7402163 BUDGET INN OF DELAND
 License Type: Motel 2801 E NEW YORK AVE, DELAND 32724

Inspection Date: 01/11/2021 Inspection Number: 1216198 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied
 Inspector Name: OCASIO-LOPEZ, LISA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-03-4	- From initial inspection : Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Room 207. - From follow-up inspection 2021-01-11: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.