

Alachua County

License Number: 1102959

TOWNEPLACE SUITES BY MARRIOTT

License Type: Hotel

745 W NEWBERRY RD, GAINESVILLE 32605

Inspection Date: 01/20/2021

Inspection Number: 1157555

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WEATHERS, TIM

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher by room 120. Per maintenance a new extinguisher has been ordered. ****Corrective Action Taken****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Supervisor, Trouble, and silence lights illuminated. Per maintenance in process to repair with fire company. ****Corrective Action Taken****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1102968

LA QUINTA INN AND SUITES GAINESVILLE

License Type: Hotel

908 NW 69 TER, GAINESVILLE 32605

Inspection Date: 01/21/2021

Inspection Number: 1157725

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WEATHERS, TIM

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Trouble light on panel. Part had been replaced, went bad again. Per Manager a new replacement part has been ordered. ****Corrective Action Taken****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bay County

License Number: 1304429

LOLLYE ON THE BEACH/SUNNY SANDS

License Type: Motel

8507 SURF DR, PANAMA CITY BEACH 32408

Inspection Date: 01/21/2021

Inspection Number: 1214639

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. On east side of yellow building.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1505693 UNIVERSITY VILLAGE AT MELBOURNE
 License Type: Apartment 3502 DAVINCI WAY, MELBOURNE 32901

Inspection Date: 01/22/2021 Inspection Number: 1506116 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MITTEN, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-06-4	Fire alarm control panel emitting an audible alarm. For reporting purposes only. Smoke detector chirping in apartment battery Apartment 2078 building 8	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1502495 THE PAVILIONS AT MONTEREY LLC
 License Type: Apartment 1635 MONTEREY DR, PALM BAY 32905

Inspection Date: 01/19/2021 Inspection Number: 1501642 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: SCHOENLY, BARBARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	For reporting purposes only. Fire alarm panel system put in silence mode Manager will follow up as to why the system is silenced	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1500863 AMERICA'S BEST VALUE INN
 License Type: Motel 3220 N COCOA BLVD, COCOA 329266699

Inspection Date: 01/20/2021 Inspection Number: 1212662 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: WILSON, LANETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. 3rd floor housekeeping laundry room	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620893 HAMPTON INN FORT LAUDERDALE/POMPANO BEACH
 License Type: Hotel 900 S FEDERAL HWY, POMPANO BEACH 33062

Inspection Date: 01/21/2021 Inspection Number: 1157362 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: BURGGRAVE, BROCK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Panel near front desk.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1600017 TOWN MOTEL
 License Type: Motel 1140 S SR 7, PLANTATION 33317

Inspection Date: 01/21/2021 Inspection Number: 1215956 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: NEALY, VALENCIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. -Observed fire extinguisher across from front office in recharging zone. Operator replaced with new fire extinguisher. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2102045

LAUREL RIDGE TOWNHOMES

License Type: Apartment

5460 LAUREL RIDGE LN, NAPLES 34116

Inspection Date: 01/20/2021

Inspection Number: 1496022

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PENN, BRIAN

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only. Observed no fire extinguisher in unit 86. Operator replaced during inspection. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2324630 AVIARY APT
 License Type: Apartment 115 NE 11 STREET, MIAMI 33030

Inspection Date: 01/20/2021 Inspection Number: 1495626 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: LEIDECKER, EDILMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. One located on the second floor outside of unit 1152.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329187 HILTON GARDEN INN MIAMI AIRPORT WEST
 License Type: Hotel 3550 NW 74 AVE, MIAMI 33122

Inspection Date: 01/21/2021 Inspection Number: 1156595 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SANCHEZ, JAVIER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2309473 RODRIQUEZ APT
 License Type: Apartment 1641 NW 5 ST, MIAMI 331254636

Inspection Date: 01/21/2021 Inspection Number: 1497498 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, ERIK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed between units 1 and 3. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330332 ART PLAZA
 License Type: Apartment 58 NE 14 ST, MIAMI 33132

Inspection Date: 01/19/2021 Inspection Number: 1509351 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: PAGAN, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-07-4	- From initial inspection : Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only. - From follow-up inspection 2021-01-19: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2300550		2020 APARTMENTS LLC	
License Type: Apartment		2020 SW 6 ST, MIAMI 33135	
Inspection Date: 01/19/2021	Inspection Number: 1494242	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2326492		SIXTY SIXTY RESORT	
License Type: Hotel		6060 INDIAN CREEK DR, MIAMI BEACH 33140	
Inspection Date: 01/20/2021	Inspection Number: 1154481	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2021-01-20: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inpector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2330433		EL GALLITO INVESTMENTS, LLC	
License Type: Apartment		1325 SW 14 ST, MIAMI 33145	
Inspection Date: 01/22/2021	Inspection Number: 1504579	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ORDONEZ, CATALINA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2327646		COURTYARD MARRIOTT AT AVENTURA	
License Type: Hotel		2825 NE 191 ST, AVENTURA 33180	
Inspection Date: 01/20/2021	Inspection Number: 1156684	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Duval County

License Number: 2608324

RED ROOF INN

License Type: Motel

1063 AIRPORT RD, JACKSONVILLE 32218

Inspection Date: 01/19/2021

Inspection Number: 1216402

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
 Only one certificate present. Missing second certification for second boiler.
 Repeat Violation

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2705806

WOODSPRING SUITES PENSACOLA NORTHWEST

License Type: Hotel

2310 W DETROIT BLVD, PENSACOLA 32534

Inspection Date: 01/21/2021

Inspection Number: 1154680

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: STEINMAN, MARC

Violation Code

Observation

Violation Citation

07-01-4

Exposed electrical wire(s). For reporting purposes only.
Hallway AC unit adjacent to room 301

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3905029 HILTON DOWNTOWN TAMPA
 License Type: Hotel 211 N TAMPA ST, TAMPA 33602

Inspection Date: 01/19/2021 Inspection Number: 1158338 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: COLEMAN, TONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913644 LE MERIDIEN TAMPA
 License Type: Hotel 601 N FLORIDA AVE, TAMPA 33602

Inspection Date: 01/22/2021 Inspection Number: 1158395 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: COLEMAN, TONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3906542 HOLIDAY INN TAMPA AIRPORT WESTSHORE
 License Type: Hotel 700 N WESTSHORE BLVD, TAMPA 33609

Inspection Date: 01/19/2021 Inspection Number: 1157928 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: KLUSENDORF, JEANNE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4602285

HERONWOOD APARTMENTS

License Type: Apartment

13809 HERONWOOD LN, FORT MYERS 33919

Inspection Date: 01/15/2021

Inspection Number: 1508695

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ORDONEZ, ADABELLA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In front of unit 29. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4703112

HYATT HOUSE TALLAHASSEE CAPITOL - UNIVERSITY

License Type: Hotel

1100 RAILROAD AVE, TALLAHASSEE 32310

Inspection Date: 01/21/2021

Inspection Number: 1157448

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: TRUESDALE, CHRIS

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5102536

SUNRISE INN

License Type: Motel

668 67 ST CIRCLE E, BRADENTON 34208

Inspection Date: 01/21/2021

Inspection Number: 1216418

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HELGESON, ERIC

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
Observed outside room 404 on exterior wall. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Nassau County

License Number: 5500960

HOLIDAY INN EXPRESS HOTEL & SUITES

License Type: Hotel

76071 SIDNEY PLACE, YULEE 32097

Inspection Date: 01/19/2021

Inspection Number: 1154457

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: NEVILLE, DAVID

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher in guest laundry room gauge is in red for recharge

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811198 ALOFT ORLANDO INTERNATIONAL DRIVE
 License Type: Hotel 5750 CENTRAL FLORIDA PARKWAY, ORLANDO 32821

Inspection Date: 01/20/2021 Inspection Number: 1157706 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: YOUNG, COLIN Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811199 ELEMENT ORLANDO INTERNATIONAL DRIVE
 License Type: Hotel 5730 CENTRAL FLORIDA PARKWAY, ORLANDO 32821

Inspection Date: 01/20/2021 Inspection Number: 1157707 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: YOUNG, COLIN Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5806918 HYATT REGENCY ORL INTL AIRPORT
 License Type: Hotel 9300 AIRPORT BLVD, ORLANDO 328274385

Inspection Date: 01/21/2021 Inspection Number: 1154704 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LORENZO, ANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900115 CHURCH ST APARTMENTS
 License Type: Apartment 414 CHURCH ST, KISSIMMEE 34741

Inspection Date: 01/20/2021 Inspection Number: 1510951 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LORENZO, ANA Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-04-4	Electrical outlet missing to indicate a malfunction. For reporting purposes only./ by unit #4	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5908462 BOHEMIA HOTEL CELEBRATION
 License Type: Hotel 700 BLOOM ST, CELEBRATION 34747

Inspection Date: 01/20/2021 Inspection Number: 1156445 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: BELTRAN, SANDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6012059 9481 ROAN LANE APARTMENTS
 License Type: Apartment 9481 ROAN LN, LAKE PARK 33403

Inspection Date: 01/22/2021 Inspection Number: 1508305 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ROTONDI, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only.no visible fire extinguishers from outside.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6011090 GROVES OF DELRAY (THE)
 License Type: Apartment 1301 SW 10 AVE, DELRAY BEACH 33444-1276

Inspection Date: 01/21/2021 Inspection Number: 1505506 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GOODWIN, NICHOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher located in maintenance shop.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6014165 COLONIAL LAKES APARTMENTS
 License Type: Apartment 4050 MILNER CIR, LAKE WORTH 33463

Inspection Date: 01/22/2021 Inspection Number: 1508195 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: AHLE, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed at 4143 apt 104	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6216024 TERRACE PARK VILLAS LLC
 License Type: Apartment 206 9 AVE NE, ST. PETERSBURG 33701

Inspection Date: 01/21/2021 Inspection Number: 1509559 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VILLEGAS, TATTYANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to laundry room	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6205750 LAKESHORE APARTMENTS
 License Type: Apartment 7045 N 30 AVE, ST PETERSBURG 337103021

Inspection Date: 01/20/2021 Inspection Number: 1505050 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HOBBS, ANDREW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Second floor near elevator	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215808 WYNDHAM GRAND CLEARWATER BEACH RESORT
 License Type: Hotel 100 CORONADO DR, CLEARWATER 33767

Inspection Date: 01/21/2021 Inspection Number: 1157328 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. F1124576-fl124575-fl124574 all exp 12/4/2020	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6211194

MARRIOTT SANDKEY

License Type: Hotel

1201 GULF BLVD, CLEARWATER BCH 33767

Inspection Date: 01/19/2021

Inspection Number: 1156962

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection

Inspector Name: KOUSTIS, TIMOTHY

Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FI 134097, FI 134098, FI 134099, FI 134100 all exp. 9/12/2020

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6903762 SPRINGHILL SUITES SANFORD
 License Type: Motel 201 N TOWNE RD, SANFORD 32771

Inspection Date: 01/21/2021 Inspection Number: 1215185 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: ANGEL, TERRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Notified Dan Taylor, Sanford Fire Inspector, 407-562-2788.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6903996 COLONIAL VILLAGE AT TWIN LAKES
 License Type: Apartment 11500 MYRTLEWOOD DR, SANFORD 32771

Inspection Date: 01/21/2021 Inspection Number: 1497096 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: ANGEL, TERRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Notified Dan Taylor, Sanford Fire Inspector. 407-562-2788. - From follow-up inspection 2021-01-21:	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6602260

SPRINGHILL SUITES BY MARRIOTT

License Type: Hotel

2000 NW COURTYARD CIR, PORT ST LUCIE 34986

Inspection Date: 01/22/2021

Inspection Number: 1157041

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HYNES, MONICA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7403476 THE OASIS
 License Type: Apartment 1250 WOODCREST DR, DAYTONA BEACH 32114

Inspection Date: 01/19/2021 Inspection Number: 1502003 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: LARSON, SARAH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401000 BEST WESTERN AKU TIKI INN
 License Type: Motel 2225 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 01/22/2021 Inspection Number: 1216062 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: WOOD, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7403560 NAUTILUS INN
 License Type: Hotel 1515 S ATLANTIC AVE, DAYTONA BEACH 32118-4954

Inspection Date: 01/19/2021 Inspection Number: 1158500 Inspection Type: Lodging-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WOOD, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Room 402 on wall inside kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7401634

DAYS INN

License Type: Motel

1608 N US HWY 1, ORMOND BEACH 32174

Inspection Date: 01/22/2021

Inspection Number: 1215023

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: RUTLEDGE, REBECCA

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit 216. For reporting purposes only.

509.215(1) and (2) and 509.032(2)(d) FS Reporting:
 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.