

Alachua County

License Number: 1103014

GNV CITY CENTER LLC - THE PALMS

License Type: Apartment

230 SW 2 AVE, GAINESVILLE 32601

Inspection Date: 01/25/2021

Inspection Number: 1509027

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WEATHERS, TIM

Violation Code

Observation

Violation Citation

04-06-4

Fire alarm control panel emitting an audible alarm. For reporting purposes only.
Audible alarm coming from room marked FACP, Fire Sprinkler Riser Room.
Repeat Violation

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1504248 COGGESHALL HALL LLC
 License Type: Apartment 2100 MELBOURNE CT, MELBOURNE 32901

Inspection Date: 01/27/2021 Inspection Number: 1507826 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: QUINONES, ANTONIO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only. Bldg 2100-6 Bldg 2100-5 Bldg 2100-4	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
06-02-4	Door marked as an exit is blocked. For reporting purposes only. Old doors blocking buildings entrance. Bldg 2100-7 Bldg 2100-6	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1505700 VILLAS AT PALM BAY
 License Type: Apartment 1880 MOGRA CIR NE, PALM BAY 32905

Inspection Date: 01/29/2021 Inspection Number: 1500418 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: SCHOENLY, BARBARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-06-4	Fire alarm control panel emitting an audible alarm. For reporting purposes only. Sintax has part on order for building 1-unit is in supervisory mode	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1502461 CLEAR POND ESTATES
 License Type: Apartment 811 CRESTVIEW DR, COCOA 32922

Inspection Date: 01/25/2021 Inspection Number: 1504128 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: WILSON, LANETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Bldg M	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1612148		329 NE APARTMENTS	
License Type: Apartment		329 NE 4 ST, HALLANDALE 33009-3414	
Inspection Date: 01/29/2021	Inspection Number: 1508013	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GANPAT, INDAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. On wall between units 2 & 3.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1621315		CRYSTAL RIVIYERA	
License Type: Apartment		3801 CRYSTAL LAKE DR STE 100, DEERFIELD BEACH 33064	
Inspection Date: 01/26/2021	Inspection Number: 1496748	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LEWIS, LYNDEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1621209		NEW RIVER YACHT CLUB	
License Type: Apartment		400 SW 1 AVE, FORT LAUDERDALE 33301	
Inspection Date: 01/29/2021	Inspection Number: 1491474	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: BRANN, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Broward County

License Number: 1607869

RED CARPET INN-AIRPORT

License Type: Motel

2460 W SR 84, FORT LAUDERDALE 33312

Inspection Date: 01/26/2021

Inspection Number: 1216450

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: BARTON, GEOFFREY

Violation CodeObservationViolation Citation

04-06-4

Fire alarm control panel emitting an audible alarm. For reporting purposes only.
Observed audible alarm from Fire Control Panel first floor north east corner.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1619117

EXTENDED STAY AMERICA #1561

License Type: Hotel

1450 SE 17 ST CSWY, FORT LAUDERDALE 33316

Inspection Date: 01/25/2021

Inspection Number: 1155383

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back - Complied

Inspector Name: EVANS, EUGENE

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
094411: 094412 4/10/2020 exp **Repeat Violation** - From follow-up inspection
2021-01-25: Establishment waiting for inspectio

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1618492

EXTENDED STAY AMERICA #9642

License Type: Hotel

7550 SR 84, DAVIE 33317

Inspection Date: 01/28/2021

Inspection Number: 1158186

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: NEALY, VALENCIA

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
-Observed Fire extinguisher in overcharge zone, building 1 , between rooms 115-117

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1602591

PLANTATION INN

License Type: Motel

375 N ST RD 7, PLANTATION 33317

Inspection Date: 01/29/2021

Inspection Number: 1215925

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: NEALY, VALENCIA

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
 -Fire extinguisher overcharge zone, room 313.
 -Fire extinguisher recharge zone, room 111.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Charlotte County

License Number: 1801531

EXTENDED STAY AMERICA 9504

License Type: Hotel

24100 BEATRIX BLVD, PORT CHARLOTTE 33954

Inspection Date: 01/27/2021

Inspection Number: 1156766

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: MOREHEAD, PHILIP

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.
Repeat Violation

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2310653

GLADYS APARTMENTS

License Type: Apartment

115 E 9 ST, HIALEAH 330104253

Inspection Date: 01/26/2021

Inspection Number: 1495103

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: PRIETO, EDGAR

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located in front of apartment #17 and #18.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2326052

1330 SE 9 AVE APTS

License Type: Apartment

1330 SE 9 AVE, HIALEAH 330105912

Inspection Date: 01/25/2021

Inspection Number: 1502528

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PRIETO, EDGAR

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed in front of apartment #2, #5 and #7.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2317292

HOLIDAY INN

License Type: Hotel

7707 NW 103 ST, HIALEAH GARDENS 33016

Inspection Date: 01/27/2021

Inspection Number: 1157162

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: CRUZ, EDGAR

Violation CodeObservationViolation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328266 EXTENDED STAY AMERICA #1600
 License Type: Hotel 8655 NW 21 TERRACE, MIAMI 33122

Inspection Date: 01/26/2021 Inspection Number: 1157724 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: SANCHEZ, JAVIER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FL97596 expired 01/16/17, FL 97595 expired 01/16/17. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2306779
 License Type: Apartment 765 NW 36 AVE, MIAMI 331253886

Inspection Date: 01/26/2021 Inspection Number: 1504797 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ALVAREZ, MARGARET

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed in laundry room **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2323779 HAY INVESTMENTS.
 License Type: Apartment 1060 NW 47 ST, MIAMI 33127

Inspection Date: 01/29/2021 Inspection Number: 1492272 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed alarm light illuminated on trouble. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2301120 ENRIQUE ZACUR APARTMENTS
 License Type: Apartment 621 SW 5 ST, MIAMI 331302654

Inspection Date: 01/28/2021 Inspection Number: 1497566 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CRUZ, EDGAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed next to unit # e	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2307593 BONITA APARTMENTS
 License Type: Apartment 942 SW 6 ST, MIAMI 331303204

Inspection Date: 01/25/2021 Inspection Number: 1490191 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CABANAS, NATALIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed at fire extinguisher above mail box.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328942 FOUR SEASONS HOTEL MIAMI
 License Type: Hotel 1435 BRICKELL AVE, MIAMI 33131

Inspection Date: 01/29/2021 Inspection Number: 1157188 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FI 017975, expires 07/24/20; FL 017974, expires 05/23/20, - From follow-up inspection 2021-01-29: During the callback inspecti	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2324737

APARTMENTS

License Type: Apartment

2120 SW 4 ST, MIAMI 331351859

Inspection Date: 01/27/2021

Inspection Number: 1497647

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2306763

1558 APARTMENTS

License Type: Apartment

1558 NW 1 AVE, MIAMI 33136

Inspection Date: 01/28/2021

Inspection Number: 1493990

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By unit 9. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-06-4

- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By unit 9. - From follow-up inspection 2021-01-28: During the callback inspection, portable fire ext

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330533

DOWNTOWN VILLAS

License Type: Apartment

419 NW 8 ST, MIAMI 33136

Inspection Date: 01/27/2021

Inspection Number: 1511003

Inspection Type: Lodging-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By 102,

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2318888

CLEVELANDER HOTEL

License Type: Hotel

1020 OCEAN DR, MIAMI BEACH 33139

Inspection Date: 01/28/2021

Inspection Number: 1157598

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329049

HOTEL VICTOR

License Type: Hotel

1144 OCEAN DR, MIAMI BEACH 33139

Inspection Date: 01/25/2021

Inspection Number: 1156530

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-07-4

Observed leaking pipe from boiler. iFor reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329320

NAUTILUS

License Type: Hotel

1825 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 01/25/2021

Inspection Number: 1158541

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: HODGE, KRISTEN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble/ alarm light illuminated on fire panel located behind front desk.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only. Current boiler certificates not kept in the boiler room regarding jurisdiction number's 133321 and 133322. General manager was provided with current boiler certificates via em

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330373 7ST, LLC
 License Type: Apartment 1000 7 ST, MIAMI BEACH 33139

Inspection Date: 01/27/2021 Inspection Number: 1509390 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Second floor, near apartment 9.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2323582 RODEWAY INN SOUTH MIAMI - CORAL GABLES
 License Type: Hotel 5959 SW 71 ST, MIAMI 33143

Inspection Date: 01/26/2021 Inspection Number: 1157113 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: PICO, JORGE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. Observed the smoke detector of room 407 without the battery . Observed smoke detector of room 410 missing.	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329180 RITZ CARLTON BAL HARBOUR
 License Type: Hotel 10295 COLLINS AVE, BAL HARBOUR 33154

Inspection Date: 01/27/2021 Inspection Number: 1157236 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, VICENTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2612763

HAMPTON INN PONTE VEDRA

License Type: Hotel

1220 MARSH LANDING PKWY, JACKSONVILLE BEACH 32250

Inspection Date: 01/29/2021

Inspection Number: 1157596

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: VILBRUN, JOSUE

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Jurisdiction 097623 expiration 1-23-21. Operator has inspection scheduled for 2-9-21 and showed emailed ****Corrective Action Taken****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3906225

FOUR POINTS SHERATON TAMPA AIRPORT WESTSHORE

License Type: Hotel

4400 W CYPRESS ST, TAMPA 33607

Inspection Date: 01/29/2021

Inspection Number: 1157970

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CANNELLA, MARK

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913577

EXTENDED STAY AMERICA #1805

License Type: Hotel

4312 W SPRUCE ST, TAMPA 33607

Inspection Date: 01/26/2021

Inspection Number: 1156466

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CANNELLA, MARK

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913671

CONCORD HOSPITALITY ENTERPRISES

License Type: Hotel

3650 MIDTOWN DR, TAMPA 33607

Inspection Date: 01/27/2021

Inspection Number: 1158568

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CANNELLA, MARK

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3911682

EMBASSY SUITES BY HILTON TAMPA USF

License Type: Hotel

3705 SPECTRUM BLVD, TAMPA 33612

Inspection Date: 01/25/2021

Inspection Number: 1157669

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: EHLERS, MICHAEL

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. 11/13/2020.
(inspected 12/02/2020, certificate not received from inspector)
For reporting purposes only.61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is
required annually for power boilers and high
pressure/high temperature boilers and biannually for low
pressure steam or vapor heating boilers. 509.032(2)(d)
The division, or its agent, shall notify the local firesafety
authority or the State Fire Marshal of any readily
observable violation of a rule adopted under chapter 633
which relates to public lodging establishments or public
food establishments, and the identification of such
violation does not require any firesafety inspection
certification. For reporting purposes only.

License Number: 3912329

HILTON GARDEN INN TAMPA NORTH

License Type: Hotel

13305 TAMPA OAKS BLVD, TEMPLE TERRACE 33637

Inspection Date: 01/27/2021

Inspection Number: 1157506

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BEAULIEU, STEPHANIE

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting
purposes only.61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is
required annually for power boilers and high
pressure/high temperature boilers and biannually for low
pressure steam or vapor heating boilers. 509.032(2)(d)
The division, or its agent, shall notify the local firesafety
authority or the State Fire Marshal of any readily
observable violation of a rule adopted under chapter 633
which relates to public lodging establishments or public
food establishments, and the identification of such
violation does not require any firesafety inspection
certification. For reporting purposes only.

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report
expired. For reporting purposes only. - From follow-up inspection 2021-01-28:
Time Extended61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is
required annually for power boilers and high
pressure/high temperature boilers and biannually for low
pressure steam or vapor heating boilers. 509.032(2)(d)
The division, or its agent, shall notify the local firesafety
authority or the State Fire Marshal of any readily
observable violation of a rule adopted under chapter 633
which relates to public lodging establishments or public
food establishments, and the identification of such
violation does not require any firesafety inspection
certification. For reporting purposes only.

Manatee County

License Number: 5100390

WINDMILL APARTMENTS THE

License Type: Apartment

4711 U S 41 N, PALMETTO 342218513

Inspection Date: 01/28/2021

Inspection Number: 1511030

Inspection Type: Complaint Full

Inspection Disposition: Administrative complaint recommended

Inspector Name: RICHENDOLLAR, SANDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Observed: Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only, by unit 8. Priority: Reporting	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-01-4	- From initial inspection : Observed: Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only, by unit 8. Priority: Reporting - From follow-up inspection 2021-01-29: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-04-4	- From initial inspection : Observed: Electrical outlet damaged to indicate a malfunction. Observed electrical junction box without cover at exterior of units 1-5. Observed cover missing from electrical box at back of unit 6. For reporting purposes onl	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-04-4	Observed: Electrical outlet damaged to indicate a malfunction. Observed electrical junction box without cover at exterior of units 1-5. Observed cover missing from electrical box at back of unit 6. For reporting purposes only. Priority: Reporting	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5200119

ALAMO MOTEL

License Type: Motel

2809 E SILVER SPRINGS BLVD, OCALA 34470

Inspection Date: 01/27/2021

Inspection Number: 1214973

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRODEWALD, PAUL

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher in front of room 16.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400573

AMARA CAY RESORT

License Type: Hotel

80001 OVERSEAS HWY, ISLAMORADA 33036

Inspection Date: 01/28/2021

Inspection Number: 1156721

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WHITEHURST, SCOTT

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
2- new 360,000 BTU WATER heaters with 600 Gal. Holding tank.
As per chief engineer, certificate not required due to under 400,000 BTU

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5401721

HYATT CENTRIC KEY WEST

License Type: Hotel

601 FRONT ST, KEY WEST 330406676

Inspection Date: 01/25/2021

Inspection Number: 1154996

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5603610

TOWNEPLACE SUITES BY MARRIOTT

License Type: Hotel

843 EGLIN PKWY, FORT WALTON BEACH 32547

Inspection Date: 01/28/2021

Inspection Number: 1158100

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BURROUGHS, RICHARD

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
 - establishment has 3 boilers and all the certificates have expired: 130385, 11/27/2019; 130386, 11/27/2019; 130387, 11/27/2019.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811136

THE ALFOND INN

License Type: Hotel

300 E NEW ENGLAND AVE, WINTER PARK 32789

Inspection Date: 01/28/2021

Inspection Number: 1157340

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: MONTGOMERY, DOREEN

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only, no boiler certificate available for (1) boiler

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5800225

TOPSECRET RESORT OF ORLANDO LLC

License Type: Hotel

3155 S JOHN YOUNG PKWY, ORLANDO 32805

Inspection Date: 01/26/2021

Inspection Number: 1157977

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: DIOP, DONALD

Violation CodeObservationViolation Citation

06-01-4

Path to door marked as an exit is blocked. For reporting purposes only. Down stairs laundry facility path blocked by furniture.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5800263

LAKE SUNSET APARTMENTS LLC

License Type: Apartment

512 SUNSET DR, ORLANDO 32805

Inspection Date: 01/27/2021

Inspection Number: 1509084

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DIOP, DONALD

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Near unit 23/24.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5808899

LA QUINTA INN & SUITES #171

License Type: Hotel

7160 FRONTAGE RD, ORLANDO 32812

Inspection Date: 01/25/2021

Inspection Number: 1157869

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FRANZ, LISA

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Between rooms 115 and 117

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5801023

WYNDHAM RESORT ORLANDO I-DRIVE

License Type: Motel

8001 INTERNATIONAL DRIVE, ORLANDO 32819

Inspection Date: 01/29/2021

Inspection Number: 1214383

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: KOSTELNY, ROGER

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. For room 1334

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5809219

SPRINGHILL SUITES

License Type: Hotel

8840 UNIVERSAL BLVD, ORLANDO 32819

Inspection Date: 01/25/2021

Inspection Number: 1158545

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: NIEVES, RAFAEL

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Observed at alarm panel located in front office. **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5800779

B RESORT

License Type: Hotel

1905 HOTEL PLAZA BLVD, LAKE BUENA VISTA 32830

Inspection Date: 01/29/2021

Inspection Number: 1157176

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed trouble light on the fire alarm panel located at front desk . **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Boiler certificate has expired 4/16/2020 **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6006208

EMBASSY SUITES WEST PALM BEACH AIRPORT HOTEL

License Type: Hotel

1601 BELVEDERE RD, WEST PALM BEACH 33406

Inspection Date: 01/29/2021

Inspection Number: 1157710

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GONZALEZ, DENNIS

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired in 2020, more than sixty days

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6000575

DOUBLETREE BY HILTON PALM BEACH GARDENS

License Type: Hotel

4431 PGA BLVD, PALM BEACH GARDENS 33410

Inspection Date: 01/28/2021

Inspection Number: 1158004

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GOLDMAN, BARRY

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. J#133388, 099443, 090951, 094941 - 12/06/2020. Boiler Inspector to arrive next week. **Corrective Action Taken**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6100111

KING MOTEL

License Type: Apartment

18902 S US 41 S, BROOKSVILLE 34610

Inspection Date: 01/27/2021

Inspection Number: 1501985

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: DAHL, MICHELE

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Beeps but does not light

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6203729		TRADEWINDS ISLAND GRAND JACARANDA	
License Type: Motel		5500 GULF BLVD, ST. PETE BEACH 33706	
Inspection Date: 01/25/2021	Inspection Number: 1215274	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DAY-WALKER, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 131373 6/28/2020, 131372 6/28/2020, 131371 6/28/2020	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6203002		MT VORON APTS	
License Type: Apartment		16850 1 ST E, REDINGTON BEACH 33708	
Inspection Date: 01/29/2021	Inspection Number: 1495641	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BEACHAM, MICHELLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6200043		ORANGE MOTEL	
License Type: Motel		1736 GULF TO BAY BLVD, CLEARWATER 33755	
Inspection Date: 01/27/2021	Inspection Number: 1215257	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: BENEDICT, TRACY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to unit 29	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6209569		ORANGE MOTEL 400	
License Type: Motel		1736 GULF TO BAY BLVD, CLEARWATER 33755	
Inspection Date: 01/27/2021	Inspection Number: 1215293	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: BENEDICT, TRACY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to unit 61	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Pinellas County

License Number: 6215802

WOODSPRING SUITES CLEARWATER

License Type: Hotel

15672 US HIGHWAY 19 N, CLEARWATER 33764

Inspection Date: 01/26/2021

Inspection Number: 1158549

Inspection Type: Complaint Full

Inspection Disposition: Administrative
complaint recommended

Inspector Name: DAY-WALKER, LISA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Fire panel has yellow trouble lights illuminated.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6203452

SHEPHARDS BEACH RESORT

License Type: Motel

619 S GULFVIEW BLVD, CLEARWATER BCH 33767

Inspection Date: 01/25/2021

Inspection Number: 1211485

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: KOUSTIS, TIMOTHY

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Gulf Tower.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Gulf Tower. - From follow-up inspection 2021-01-25: **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6209041

ECONO LODGE

License Type: Motel

32000 US HWY 19, PALM HARBOR 34684

Inspection Date: 01/25/2021

Inspection Number: 1213811

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PIATT, PAUL

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Missing between rooms 205 and 206

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6303266

IMPERIAL SWAN HOTEL & SUITES

License Type: Hotel

4141 S FLORIDA AVE, LAKE LAND 33813

Inspection Date: 01/26/2021

Inspection Number: 1158469

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: BEAULIEU, STEPHANIE

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
074517 expired 5-14-2020. Front desk rep said inspector came by today and will certify boiler ****Repeat Violation**** - From fol

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Putnam County

License Number: 6400618

CRYSTAL COVE RESORT

License Type: Motel

133 CRYSTAL COVE DR, PALATKA 32177

Inspection Date: 01/28/2021

Inspection Number: 1214322

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: DOTY, JOSEPH

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher in between rooms 134 & 136

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6904062

LAKE MONROE APARTMENTS

License Type: Apartment

800 MARBELLA LN, SANFORD 32771

Inspection Date: 01/27/2021

Inspection Number: 1497295

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

02-04-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. Maintenance shop.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406510

FAIRFIELD INN & SUITES DAYTONA BEACH SPEEDWAY/AIRPORT

License Type: Hotel

1820 CHECKERED FLAG BLVD, DAYTONA BEACH 32114

Inspection Date: 01/29/2021

Inspection Number: 1157420

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: LARSON, SARAH

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2021-01-29:

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406519

HAWAIIAN INN BEACH RESORT

License Type: Hotel

2301 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 01/26/2021

Inspection Number: 1158254

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

-main FACP troubled/silenced - "test failures"

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Boiler inspection certificate expired 5/03/2020

Verified on state of florida division of boilers public access portal.

License Number: 7406522

OM HOSPITALITY OF DELTONA LLC

License Type: Motel

481 DELTONA BLVD, DELTONA 32725

Inspection Date: 01/27/2021

Inspection Number: 1214956

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: ANGEL, TERRY

Violation CodeObservationViolation Citation

02-04-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. Maintenance shop.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.