

**Alachua County**

License Number: 1102959 TOWNEPLACE SUITES BY MARRIOTT  
 License Type: Hotel 7451 W NEWBERRY RD, GAINESVILLE 32605

Inspection Date: 02/19/2021 Inspection Number: 1157555 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied  
 Inspector Name: CASEY, KEITH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Supervisor, Trouble, and silence lights illuminated. Per maintenance in process to repair with fire company. <b>**Corrective Action Taken**</b> - From follow-up inspection 2021-02-19: Still a trouble light, has been inspected and parts ordered. <b>**Time Extended**</b>	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1102123 BAYMONT INN & SUITES  
 License Type: Motel 6901 NW 4 BLVD, GAINESVILLE 32607

Inspection Date: 02/18/2021 Inspection Number: 1216573 Inspection Type: Complaint Partial Inspection Disposition: Warning Issued  
 Inspector Name: CASEY, KEITH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificates: Jurisdiction #s 099999 and 087938, both expired on 8-15-2020.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Brevard County**

License Number: 1500775

DIXIE MOTEL APARTMENTS LLC

License Type: Motel

301 FORREST AVE, COCOA 32922

Inspection Date: 02/17/2021

Inspection Number: 1214920

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: WILSON, LANETTE

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. By 121

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1621094		ALVIFIN CORPORATION	
License Type: Apartment		1830 SHERIDAN ST, HOLLYWOOD 33020	
Inspection Date: 02/17/2021	Inspection Number: 1498552	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHRISTGEN, THOM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged near unit 107. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1607309		SUNSET PALMS UNITED LLC	
License Type: Apartment		7400 STIRLING RD STE 110, HOLLYWOOD 33024	
Inspection Date: 02/18/2021	Inspection Number: 1508743	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: FEIGELES, MITCHELL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  Building 1 - Laundry Room Building 5 - First floor across from laundry room Building 6 - First floor across from laundry room	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.  Building 8 - First Floor Building 16 - First Floor	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1621504		VENTURA POINTE	
License Type: Apartment		7850 PASADENA BLVD, PEMBROKE PINES 33024	
Inspection Date: 02/19/2021	Inspection Number: 1509490	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: FEIGELES, MITCHELL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  Building 7900 - Second floor by elevators.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Broward County**

License Number: 1613397		OAKLAND HILLS APARTMENTS	
License Type: Apartment		5501 SW 11 ST #A, MARGATE 33068	
Inspection Date: 02/19/2021	Inspection Number: 1498668	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRADY, OSSIAN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.  Observed missing fire extinguisher at building 5581.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1612548		MARRIOTT FORT LAUDERDALE NORTH	
License Type: Hotel		6650 N ANDREWS AVE, FORT LAUDERDALE 33309	
Inspection Date: 02/15/2021	Inspection Number: 1157201	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BENJAMIN, ALEXANDER			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Operator states a new inspection was completed on 10/26/2020 but will need to locate certification	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inpector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only. Expired boiler certification posted in boiler room. Operator states current copy is stored in office	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1621581		CURV	
License Type: Apartment		410 SE 16TH COURT, FORT LAUDERDALE 33316	
Inspection Date: 02/18/2021	Inspection Number: 1511192	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BARTON, GEOFFREY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed system trouble light on Fire Control Panel. Technician already scheduled for repair/check.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Broward County**

License Number: 1602591

PLANTATION INN

License Type: Motel

375 N ST RD 7, PLANTATION 33317

Inspection Date: 12/01/2020

Inspection Number: 1212629

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: NEALY, VALENCIA

Violation Code

Observation

Violation Citation

01-02-4

Observed: Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. -Observed fire extinguisher in recharge zone room 111.  
-Observed no fire extinguisher provided near rooms 301, 313, 213 and 114.  
Priority: Reporting

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2309450		75 WEST APARTMENTS	
License Type: Apartment		75 WEST 28 ST, HIALEAH 33010	
Inspection Date: 02/17/2021	Inspection Number: 1502782	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: PRIETO, EDGAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed between apartments #8 and 9 and between apartments #2 and #3.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2318417		PRASAD NARAYANA	
License Type: Apartment		55 W 6 ST, HIALEAH 33010	
Inspection Date: 02/16/2021	Inspection Number: 1498576	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: PRIETO, EDGAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed in front of the apartment #1A.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2308662		DELRIO MOYA PEREZSANZ & PUIGCE	
License Type: Apartment		80 W 23 ST, HIALEAH 330102256	
Inspection Date: 02/17/2021	Inspection Number: 1492615	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: PRIETO, EDGAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Located between apartments #7 and #8.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2308499		RODRIGUEZ APTS	
License Type: Apartment		74 W 12 ST, HIALEAH 330103992	
Inspection Date: 02/19/2021	Inspection Number: 1490208	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: PRIETO, EDGAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed between apartments #2 and #3.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Dade County**

License Number: 2302002		WINSTON APARTMENTS	
License Type: Apartment		25 W 6 ST, HIALEAH 330104778	
Inspection Date: 02/19/2021	Inspection Number: 1499946	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SANCHEZ, JAVIER			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. Back of the building close to unit 5.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2310927		WATERVIEW VILLAS INC APTS	
License Type: Apartment		1225 W OKEECHOBEE RD, HIALEAH 330107900	
Inspection Date: 02/19/2021	Inspection Number: 1504707	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: SANCHEZ, JAVIER			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2021-02-19: Still observed Trouble/alarm light illuminated on the fire alarm control panel. **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2320410		DELUXE INN MOTEL	
License Type: Motel		28475 S DIXIE HWY, MIAMI 33033	
Inspection Date: 02/17/2021	Inspection Number: 1214753	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: GONZALEZ, RICARDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Breaking device missing on fire extinguisher by unit 20.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Dade County**

License Number: 2307353

GABLES COVE

License Type: Motel

4700 SW 8 ST, CORAL GABLES 33134

Inspection Date: 02/19/2021

Inspection Number: 1215309

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: GONZALEZ, ALEJANDRO

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. \*\*Warning\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. \*\*Warning\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330543

DOWNTOWN VILLAS

License Type: Apartment

439 NW 8 ST, MIAMI 33136

Inspection Date: 02/19/2021

Inspection Number: 1511200

Inspection Type: Lodging-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. By unit 103.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328949

RIVERSIDE HOTEL

License Type: Motel

498 NE 78 ST, MIAMI 33138

Inspection Date: 02/16/2021

Inspection Number: 1213872

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: PICO, JORGE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2305235		MAJESTIC HOTEL	
License Type: Hotel		660 OCEAN DR, MIAMI BEACH 33139	
Inspection Date: 02/15/2021	Inspection Number: 1156657	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-04-4	Fire alarm control panel has no power. For reporting purposes only. As per manager, sprinkler system was under repair. Power was restored to fire alarm panel. **Corrected On-Site**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329171		Z OCEAN	
License Type: Hotel		1437 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 02/16/2021	Inspection Number: 1156655	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329174		ANGLER'S BOUTIQUE RESORT	
License Type: Hotel		660 WASHINGTON AVE, MIAMI BEACH 33139	
Inspection Date: 02/15/2021	Inspection Number: 1156723	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329241		BENTLEY SOUTH BEACH	
License Type: Hotel		510 OCEAN DR, MIAMI BEACH 33139	
Inspection Date: 02/15/2021	Inspection Number: 1156449	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Dade County**

License Number: 2329419		LENNOX MIAMI	
License Type: Hotel		1900 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 02/17/2021	Inspection Number: 1156896	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only. Chief Engineer is in the process of posting boiler certificates in boiler room. **Corrected On-Site**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329435		KIMPTON HOTEL PALOMAR SOUTH BEACH	
License Type: Hotel		1750 ALTON RD, MIAMI BEACH 33139	
Inspection Date: 02/17/2021	Inspection Number: 1156509	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only. Boiler's are located at roof type area of hotel establishment, no boiler certificates posted near boiler's. Chief engineer printed certificates and in the process of posting near boiler's. **Corrective Action Taken**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2301703		ISLAND HOUSE	
License Type: Hotel		1428 COLLINS AVE, MIAMI BEACH 331394102	
Inspection Date: 02/16/2021	Inspection Number: 1156028	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light illuminated on fire panel located at hallway area of hotel establishment.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2303938		631 39 13 ST APTS	
License Type: Apartment		631 13 ST, MIAMI BEACH 331394434	
Inspection Date: 02/15/2021	Inspection Number: 1490265	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Dade County**

License Number: 2329265

NEW POINT MIAMI

License Type: Hotel

5445 COLLINS AVE STE CU 15, MIAMI BEACH 33140

Inspection Date: 02/16/2021

Inspection Number: 1156923

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. One of the boiler has the certificate already expired since 3/6/2020. ( FL 092741)

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329277

HILTON CABANA MIAMI BEACH

License Type: Hotel

6261 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 02/19/2021

Inspection Number: 1156705

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light illuminated on panel located behind concierge desk.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329399

DESIGN SUITES MIAMI BEACH

License Type: Hotel

5445 COLLINS AVE STE CU14, MIAMI BEACH 33140

Inspection Date: 02/16/2021

Inspection Number: 1156467

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. One of the boiler has the certificate already expired since 3/6/2020. ( FL 092741)

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329452

GIRASOLE APARTMENTS

License Type: Hotel

5445 COLLINS AVENUE CU 10, MIAMI BEACH 33140

Inspection Date: 02/16/2021

Inspection Number: 1156919

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. No breaking device for extinguisher located in front of the office.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. One of the boiler has the certificate already expired since 3/6/2020.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2307620

INTERNATIONAL INN MOTEL AT CSW

License Type: Motel

2301 NORMANDY DR, MIAMI BEACH 331414410

Inspection Date: 02/17/2021

Inspection Number: 1214174

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed fire extinguisher box with no breaking means, between units 114 y 115. \*\*Repeat Violation\*\* \*\*Warning\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329408

EVEN MIAMI AIRPORT HOTEL

License Type: Hotel

3499 NW 25 ST, MIAMI 33142

Inspection Date: 02/15/2021

Inspection Number: 1157413

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: APONTE RIVERA, MELISA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificate 314081 and 314082 expired on 01-01-2020.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329270		GRAND BEACH HOTEL SURFSIDE	
License Type: Hotel		9449 COLLINS AVE, SURFSIDE 33154	
Inspection Date: 02/16/2021	Inspection Number: 1158650	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2309692		THUNDERBIRD HOTEL	
License Type: Motel		18401 COLLINS AVE, MIAMI BEACH 331602497	
Inspection Date: 02/16/2021	Inspection Number: 1214467	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. As of 8/15/20.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inpector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2319921		COURTYARD BY MARRIOTT HOTEL	
License Type: Hotel		3929 NW 79 AVE, MIAMI 33166	
Inspection Date: 02/16/2021	Inspection Number: 1157508	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed extinguisher in recharge zone located on second floor between rooms 229 and 231.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Dade County**

License Number: 2329457 MIAMI GARDENS INN & SUITES  
 License Type: Hotel 16805 NW 12 AVE, MIAMI GARDENS 33169

Inspection Date: 02/16/2021 Inspection Number: 1157523 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended  
 Inspector Name: STUBBS, CHRISTINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed no glass on portable fire extinguisher on 4th floor in front of room #401.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
06-01-4	Path to door marked as an exit is blocked. For reporting purposes only. Observed a ladder blocking stairs on 4th floor hallway (facing East). Employee removed ladder. <b>**Corrected On-Site**</b>	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329173 BEST WESTERN HOTEL & SUITES  
 License Type: Hotel 8560 SW 124 AVE, MIAMI 33183

Inspection Date: 02/17/2021 Inspection Number: 1158219 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: ELDER, AUDREY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed on fourth floor near room 416.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2609468		OMNI JACKSONVILLE HOTEL (THE)	
License Type: Hotel		245 WATER ST, JACKSONVILLE 32202	
Inspection Date: 02/17/2021	Inspection Number: 1157935	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: YOUNG, JENNIFER			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.  Certificates expired 1/22/21 per manager they have already been inspected but is waiting on certificates	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2600740		MT VERNON MOTOR LODGE	
License Type: Motel		3201 PHILLIPS HWY, JACKSONVILLE 322074309	
Inspection Date: 02/15/2021	Inspection Number: 1215487	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: JEFFERS, MARY-BETH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
07-02-4	Frayed electrical wire(s). For reporting purposes only. Wire on AC cord in room #38 frayed/exposed	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2613291		LONG BRANCH MHP LLC	
License Type: Apartment		5101 N MAIN ST, JACKSONVILLE 32208	
Inspection Date: 02/16/2021	Inspection Number: 1506525	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: PERRY, DENNIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. By apartment 2.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2600639		ALMIRA GARDEN APARTMENTS	
License Type: Apartment		1616 ALMIRA ST, JACKSONVILLE 322115302	
Inspection Date: 02/15/2021	Inspection Number: 1492759	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: THOMAS, PHILIP			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Missing Fire extinguisher from newer red box with signage near unit 17 upstairs. Missing fire extinguisher from white box with signage between units 7 and 8 downstairs **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Duval County**

License Number: 2609134 THE PARK AT VIA VENETO  
 License Type: Apartment 445 MONUMENT RD, JACKSONVILLE 32225

Inspection Date: 02/16/2021 Inspection Number: 1511125 Inspection Type: Complaint Full Inspection Disposition: Warning Issued  
 Inspector Name: THOMAS, PHILIP

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher between units 812 and 811 in recharge zone. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2603121 APM INN AND SUITES JACKSONVILLE  
 License Type: Motel 510 LN AVE S, JACKSONVILLE 32254

Inspection Date: 02/19/2021 Inspection Number: 1216494 Inspection Type: Complaint Full Inspection Disposition: Warning Issued  
 Inspector Name: MERCER, THOMAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-03-4	Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Smoke detector in room 349 is disconnected. Manager stated they are changing batteries.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Escambia County**

License Number: 2702778

KEY WEST INN

License Type: Motel

6900 PENSACOLA BLVD, PENSACOLA 32505

Inspection Date: 02/19/2021

Inspection Number: 1216563

Inspection Type: Complaint Partial

Inspection Disposition: Warning Issued

Inspector Name: RUSSELL, SARAH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. In room 208.	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
06-03-4	Marked exit is inaccessible. In room 208 back door is unable to lock. Dead bolt stuck. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Highlands County**

License Number: 3800993

9057 LYONS LLC

License Type: Apartment

39 OBSERVATION ST, LAKE PLACID 33852

Inspection Date: 02/16/2021

Inspection Number: 1508925

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JACKS, ALBERT

Violation Code

Observation

Violation Citation

04-05-4

No smoke detector provided in guest room/unit #47.For reporting purposes only. Operator retrieved a smoke detector and placed in unit. \*\*Corrected On-Site\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3902312

LENOX PLACE APARTMENTS

License Type: Apartment

11311 N 22ND ST, TAMPA 33612

Inspection Date: 02/15/2021

Inspection Number: 1509112

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: MCINTYRE, REGIS

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. In second floor laundry room in building B. -  
From follow-up inspection 2020-12-02: **\*\*Time Extended\*\*** - From follow-up inspection 2020-12-22: **\*\*Time Extended\*\*** - From follow-up inspection 2021-02-15: **\*\*Time Extended\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-06-4

- From initial inspection : Fire alarm control panel emitting an audible alarm. For reporting purposes only. In building A. - From follow-up inspection 2020-12-02: **\*\*Time Extended\*\*** - From follow-up inspection 2020-12-22: **\*\*Time Extended\*\*** - From follow-up inspection 2021-02-15: **\*\*Time Extended\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Indian River County**

License Number: 4100689

OCEANAIRE MOTEL

License Type: Motel

1021 21 ST, VERO BEACH 32960

Inspection Date: 02/17/2021

Inspection Number: 1213088

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: DAVIS, DIANNA

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Manatee County**

License Number: 5104362

BEST WESTERN PLUS BRADENTON HOTEL & SUITES

License Type: Motel

648 67 ST CIR E, BRADENTON 34208

Inspection Date: 02/18/2021

Inspection Number: 1215209

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: CHETE, JUSTIN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Monroe County**

License Number: 5402187

KNOWLES HOUSE (THE)

License Type: Bed and Breakfast

1004 EATON ST, KEY WEST 330406925

Inspection Date: 02/19/2021

Inspection Number: 1093798

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: ORDONEZ, CATALINA

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Observed smoke detector for the hearing impaired with no visual flashing.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Okaloosa County**

License Number: 5601238

ECONOLOGDE CRESTVIEW

License Type: Motel

3101 S FERDON BLVD, CRESTVIEW 32536

Inspection Date: 02/19/2021

Inspection Number: 1215782

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BURROUGHS, RICHARD

Violation CodeObservationViolation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.  
 - exit sign on second floor at the northwest end hanging from the wires.  
 - additionally, three of the four emergency exit signs do not work.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5603626

RESIDENCE INN BY MARRIOTT

License Type: Hotel

2 MIRACLE STRIP PKWY SE, FORT WALTON BEACH 32548

Inspection Date: 02/16/2021

Inspection Number: 1156856

Inspection Type: Lodging-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ADAMSON, ROBERT

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5600787

WYNDHAM GARDENS

License Type: Motel

573 SANTA ROSA BLVD, FT WALTON BCH 32548

Inspection Date: 02/18/2021

Inspection Number: 1215053

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ADAMSON, ROBERT

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.  
 Operator currently working with State authority to rectify issue. \*\*Corrective Action Taken\*\* \*\*Repeat Violation\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Orange County**

License Number: 5811165		MARRIOTT ORLANDO DOWNTOWN	
License Type: Hotel		400 W LIVINGSTON ST, ORLANDO 32801	
Inspection Date: 02/09/2021	Inspection Number: 1156438	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: MONTESANO, MISTI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - 134507 expired 1/10/21 **Warning**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5811320		WASHINGTON ST APARTMENTS	
License Type: Apartment		4100 W WASHINGTON ST, ORLANDO 32805	
Inspection Date: 02/17/2021	Inspection Number: 1504323	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DIOP, DONALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Cactus and plants impeding access to fire extinguisher between unit 4112 and 4114.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5811219		CASA VIDA TH LLC	
License Type: Apartment		2127 VERANDA CIRCLE, ORLANDO 32808	
Inspection Date: 02/18/2021	Inspection Number: 1511197	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: DIOP, DONALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only. Near 2032.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5810984		CMM HOUSING LLC	
License Type: Apartment		3620 KHAYYAM AVE, ORLANDO 32826	
Inspection Date: 02/16/2021	Inspection Number: 1510971	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JENKINS, JOSHUA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Orange County**

License Number: 5810160

DISNEY'S ANIMAL KINGDOM LODGE

License Type: Hotel

2901 OSCEOLA PKWY, BAY LAKE 32830

Inspection Date: 02/15/2021

Inspection Number: 1157577

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BACHOO, SAVITRI

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6014077		THE BEN WEST PALM	
License Type: Hotel		251 N NARCISSUS AVE, WEST PALM BEACH 33401	
Inspection Date: 02/15/2021	Inspection Number: 1158016	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GOLDMAN, BARRY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. 3 iHot water systems rated at 751,000 /714,000 BTU.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6014078		WEST PALM BEACH CANOPY	
License Type: Hotel		380 TRINITY PL, WEST PALM BEACH 33401	
Inspection Date: 02/18/2021	Inspection Number: 1157965	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GOLDMAN, BARRY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Both boiler plates state 799000 btu and tank capacity 350 gallons. Boiler requirements: Maximum heat input of 400,000 BTUH; or 2. Water temperature of 210 1/2 F; or 3. Water capacity of 120 gallons. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6002370		APARNA SRIRAM	
License Type: Apartment		2921 2 AVE N, LAKE WORTH 33461	
Inspection Date: 02/17/2021	Inspection Number: 1511198	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, DENNIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged on south east corner of the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6012369		TOWNEPLACE SUITES	
License Type: Hotel		5110 NW 8 AVE, BOCA RATON 33487	
Inspection Date: 02/18/2021	Inspection Number: 1157625	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KHATOON, BEGUM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-03-4	Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. ..room 208	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Pinellas County**

License Number: 6205897		PLANTATION INN	
License Type: Apartment		1830 N 9 ST, ST PETERSBURG 337044267	
Inspection Date: 02/16/2021	Inspection Number: 1495440	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: LOZANO, KELVIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Wall opposite apt 101.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6203632		SKYLARK MOTEL	
License Type: Motel		10149 GULF BLVD, TREASURE ISLAND 337064808	
Inspection Date: 02/17/2021	Inspection Number: 1214132	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: DAY-WALKER, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
07-02-4	Frayed electrical wire(s). For reporting purposes only. Frayed wires hanging from unit 1 light fixture. <b>**Repeat Violation**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6206472		BEARCREEK APTS S	
License Type: Apartment		6262 S EMERSON AVE, ST PETERSBURG 337072306	
Inspection Date: 02/17/2021	Inspection Number: 1490537	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HOBBS, ANDREW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Near unit#22	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6212122		REGENCY OAKS	
License Type: Apartment		2751 REGENCY OAKS BLVD, CLEARWATER 33759	
Inspection Date: 02/15/2021	Inspection Number: 1511147	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: BENEDICT, TRACY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only. Current boiler certification posted in boiler room are expired	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	



**Polk County**

License Number: 6301099 STAY PLUS INN  
 License Type: Motel 33224 HWY 27 S, HAINES CITY 33844

Inspection Date: 02/18/2021 Inspection Number: 1215287 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: JACKSON, SHARON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. Room 108, 110., 157, 158. The maintenance person replaced the smoke detectors.	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6309174 COMFORT INN & SUITES ORLANDO SOUTH DAVENPORT  
 License Type: Hotel 4095 HOTEL DR, DAVENPORT 33897

Inspection Date: 02/16/2021 Inspection Number: 1157026 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: JACKSON, SHARON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6309191 UNCLE JOES FISH CAMP  
 License Type: Apartment 4535 WALK-IN-WATER RD, LAKE WALES 33898-7281

Inspection Date: 02/19/2021 Inspection Number: 1508255 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: WHITE, CHERYL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Apartment 1	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Seminole County**

License Number: 6902155

THE PARK AT RAVELLO

License Type: Apartment

401 W SEMINOLE BLVD, SANFORD 32771

Inspection Date: 02/16/2021

Inspection Number: 1501227

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Building I. Notified Dan Taylor, Sanford Fire Inspector. 407-562-2788. Voice Mail. - From follow-up inspection 2021-02-16:

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**St. Lucie County**

License Number: 6602528

FORT PIERCE BEACH RESORT

License Type: Hotel

110 S OCEAN DR, FORT PIERCE 34949

Inspection Date: 02/15/2021

Inspection Number: 1157393

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: SCHUCK, GREGORY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Volusia County**

License Number: 7401104

LA QUINTA INN & SUITES

License Type: Motel

816 N ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 02/16/2021

Inspection Number: 1215031

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.