

Alachua County

License Number: 1102440

RICHARD SCHACKOW APTS

License Type: Apartment

1213 NW 39 AVE BLDG F, GAINESVILLE 326091926

Inspection Date: 02/22/2021

Inspection Number: 1497432

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CASEY, KEITH

Violation CodeObservationViolation Citation

06-02-4

Door is blocked. For reporting purposes only.
Observed between F5 and F6, exit of the apartments are obstructed by a stuffed couch on the balcony.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1100097

TRAVELER'S INN

License Type: Motel

3103 NW 13 ST, GAINESVILLE 326092176

Inspection Date: 02/23/2021

Inspection Number: 1215903

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CASEY, KEITH

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
Observed locked fire extinguisher, no breaker bar, by 232.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1505822

RIVERSIDE MOTEL

License Type: Apartment

6220 US HWY 1, GRANT 32949

Inspection Date: 02/25/2021

Inspection Number: 1507072

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: SCHOENLY, BARBARA

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1600416		DANIA TOWERS	
License Type: Apartment		20 SW 4 AVE, DANIA 33004-3266	
Inspection Date: 02/23/2021	Inspection Number: 1495860	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LONDONO, GLORIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. In front of Unit 1	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1605616		CARLO APT	
License Type: Apartment		2222 POLK ST, HOLLYWOOD 33020-6733	
Inspection Date: 02/24/2021	Inspection Number: 1505621	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: NEALY, VALENCIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. -Unit 14.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1620916		HYATT CENTRIC LAS OLAS FORT LAUDERDALE	
License Type: Hotel		100 E LAS OLAS BLVD, FORT LAUDERDALE 33301	
Inspection Date: 02/24/2021	Inspection Number: 1157117	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: BRANN, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1621213		VU NEW RIVER	
License Type: Apartment		510 SE 5 AVE, FORT LAUDERDALE 33301	
Inspection Date: 02/22/2021	Inspection Number: 1498778	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: BRANN, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. 18th floor by main elevators.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Broward County

License Number: 1602446

CYPRESS GROVE APARTMENTS

License Type: Apartment

4200 NW 19TH STREET, LAUDERHILL 33313

Inspection Date: 02/22/2021

Inspection Number: 1502119

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BRADY, OSSIAN

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge in laundry room by front door. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2311092		RAAN PROPERTY BUILDINGS	
License Type: Apartment		318 E 21 ST, HIALEAH 33010	
Inspection Date: 02/25/2021	Inspection Number: 1501980	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, EDGAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located between apartments #2 and #3.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2309310		MANNYS APTS	
License Type: Apartment		2710 W 10 AVE, HIALEAH 330101261	
Inspection Date: 02/24/2021	Inspection Number: 1490211	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, EDGAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Between apartments #5 and #6.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2305642		420 APTS	
License Type: Apartment		420 W 17 ST, HIALEAH 330102434	
Inspection Date: 02/24/2021	Inspection Number: 1497658	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, EDGAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed in front of the apartment #29; between apartments #21 and #22; in front of the apartment #13; between apartments #35 and #3	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2308432		FERNANDEZ APTS	
License Type: Apartment		160 W 7 ST, HIALEAH 330104348	
Inspection Date: 02/22/2021	Inspection Number: 1495211	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, EDGAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed between apartments #3 and #4.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2311240

FLORIDA BUILDING CORP APTS

License Type: Apartment

235 E 8 ST, HIALEAH 330104499

Inspection Date: 02/22/2021

Inspection Number: 1502462

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PRIETO, EDGAR

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed between apartments #8 and #9 and between apartments #1 and #2. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329403

GUILD (THE)

License Type: Hotel

230 NE 4 ST, MIAMI 33128

Inspection Date: 02/22/2021

Inspection Number: 1156979

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: PICO, JORGE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation** **Warning**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2300698

NATHALIE COURTS APARTMENTS

License Type: Apartment

1521 SW 6 STREET, MIAMI 33135

Inspection Date: 02/25/2021

Inspection Number: 1476661

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: MARTINEZ, YANET

Violation CodeObservationViolation Citation

01-06-4

- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed in 2 floor by unit 201. - From follow-up inspection 2021-02-25: During the callback inspect

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2021-02-25: During the callback inspection observed trouble alarm light on. **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2306270

CITYWALK APARTMENTS

License Type: Apartment

415 NW 9 ST, MIAMI 33136

Inspection Date: 02/24/2021

Inspection Number: 1491816

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Building 419, by unit 31.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2305134

TRAVELODGE BY WYNDHAM BISCAYNE BAY

License Type: Motel

5255 N BISCAYNE BLVD, MIAMI 33137

Inspection Date: 02/24/2021

Inspection Number: 1215434

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SEYBA, JAMES

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Next to room #8.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2326548		BELLE MEADE STUDIOS LLC	
License Type: Apartment		7623 BISCAYNE BLVD, MIAMI 33138	
Inspection Date: 02/25/2021	Inspection Number: 1498143	Inspection Type: Complaint Full	Inspection Disposition: Administrative complaint recommended
Inspector Name: SEYBA, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By unit 4.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2304159		CENTURY HOTEL	
License Type: Hotel		140 OCEAN DR, MIAMI BEACH 33139	
Inspection Date: 02/25/2021	Inspection Number: 1157609	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Near room 111.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2304994		THE BLUE MOON HOTEL	
License Type: Hotel		944 & 926 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 02/26/2021	Inspection Number: 1154576	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: PICO, JORGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2305469		SHELBORNE SOUTH BEACH	
License Type: Hotel		1801 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 02/23/2021	Inspection Number: 1157778	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: MASKASEM, SUPPACHAI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 055333; 055334 All expired 4/28/2019	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2328176		TOWNHOUSE HOTEL	
License Type: Hotel		150 20 ST, MIAMI BEACH 33139	
Inspection Date: 02/22/2021	Inspection Number: 1157765	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel located behind front desk. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2308583		ELSA'S APARTMENT	
License Type: Apartment		1327 WEST AVE, MIAMI BEACH 331393731	
Inspection Date: 02/26/2021	Inspection Number: 1495087	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only. Observed no fire extinguisher or fire extinguisher signage on exterior of apartment building.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2304345		HOLIDAY INN MIAMI BEACH OCEANFRONT	
License Type: Hotel		4333 COLLINS AVE, MIAMI BEACH 33140	
Inspection Date: 02/24/2021	Inspection Number: 1158694	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light illuminated on main panel.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed expired certificate 2/11/2021, as per Chief Engineering the inspection was done already, just waiting for the report and the certificates.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329050

CHATEAU, VERSAILLES, FONTAINEBLEAU FLORIDA TOWER II & III

License Type: Hotel

4441 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 02/23/2021

Inspection Number: 1156418

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed light illuminated, technician was working on it.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329218

BEACH PLACE HOTEL

License Type: Hotel

8601 HARDING AVE, MIAMI BEACH 33141

Inspection Date: 02/24/2021

Inspection Number: 1156511

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed beside unit 119. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613425

PINE HILL APARTMENTS

License Type: Apartment

7920 ORIOLE ST, JACKSONVILLE 32208

Inspection Date: 02/24/2021

Inspection Number: 1511103

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation CodeObservationViolation Citation

06-01-4

Path to an exit is blocked. For reporting purposes only.
Large grill at end of stairway from unit 504.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2600052

FORT ARCO LLC

License Type: Apartment

1035 ARCO DR, JACKSONVILLE 32211

Inspection Date: 02/23/2021

Inspection Number: 1497339

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: THOMAS, PHILIP

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher in laundry has gauge in red recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2603631

TROLLIE LANE APTS

License Type: Apartment

2600 TROLLIE LN APT 10, JACKSONVILLE 322113851

Inspection Date: 02/25/2021

Inspection Number: 1490324

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: THOMAS, PHILIP

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
Fire extinguisher mounted on maintenance shed between buildings 2620 and 2600 in red overcharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2702778

KEY WEST INN

License Type: Motel

6900 PENSACOLA BLVD, PENSACOLA 32505

Inspection Date: 02/22/2021

Inspection Number: 1216563

Inspection Type: Complaint Partial

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: RUSSELL, SARAH

Violation Code

Observation

Violation Citation

04-02-4

- From initial inspection : No smoke detector provided in guest room/unit. For reporting purposes only. In room 208. - From follow-up inspection 2021-02-22: **Time Extended**

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

06-03-4

- From initial inspection : Marked exit is inaccessible. In room 208 back door is unable to lock. Dead bolt stuck. For reporting purposes only. - From follow-up inspection 2021-02-22: **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913678

HYATT PLACE / HYATT HOUSE TAMPA DOWNTOWN

License Type: Hotel

325 N FLORIDA AVE, TAMPA 33602

Inspection Date: 02/22/2021

Inspection Number: 1158043

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Inspection
Completed - No Further Action

Inspector Name: COLEMAN, TONYA

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. 2 Boilers with BTU at 1,001,000 and used as hot water heaters per Chief Engineer. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3912125

TAMPA LIFE PLAN VILLAGE

License Type: Apartment

12401 N 22 ST, TAMPA 33612

Inspection Date: 02/24/2021

Inspection Number: 1511039

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Warning
Issued

Inspector Name: MCINTYRE, REGIS

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boilers have been inspected, operator waiting for certificates.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913615

STAYBRIDGE SUITES TAMPA EAST/BRANDON

License Type: Hotel

3624 N FALKENBURG RD, TAMPA 33619

Inspection Date: 02/26/2021

Inspection Number: 1158710

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: CANNELLA, MARK

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4600131

PALM VILLAS

License Type: Apartment

8372 BEACON BLVD, FORT MYERS 33907

Inspection Date: 02/18/2021

Inspection Number: 1501773

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ORDONEZ, ADADBELLA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Across from unit 212.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5403186

NYAH KEY WEST

License Type: Hotel

823 FLEMING ST, KEY WEST 33040

Inspection Date: 02/22/2021

Inspection Number: 1154508

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: HENLEY, LATONYA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Front counter. **Warning**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5603609

HOLIDAY INN RESORT FORT WALTON BEACH

License Type: Hotel

1299 MIRACLE STRIP PKWY, FORT WALTON BEACH 32548

Inspection Date: 02/24/2021

Inspection Number: 1158048

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: ADAMSON, ROBERT

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5801619 DNRK PROPERTY LLC
 License Type: Apartment 314 BEECH AVE, ORLANDO 32805

Inspection Date: 02/25/2021 Inspection Number: 1504280 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: DIOP, DONALD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Near 312-B	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Near 316B and 316A. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5807872 THE ARBORS AT MAITLAND SUMMIT
 License Type: Apartment 8636 VILLA POINT, ORLANDO 32810

Inspection Date: 02/25/2021 Inspection Number: 1494467 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: THORNCROFT, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-04-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. Stored inside the maintenance area	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811101 INTOWN SUITES
 License Type: Hotel 736 LEE RD, ORLANDO 32810

Inspection Date: 02/24/2021 Inspection Number: 1158139 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RUTLEDGE, REBECCA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811328

THE TIFFANY AT MAITLAND WEST

License Type: Apartment

9301 SUMMIT CENTRE WAY, ORLANDO 32810

Inspection Date: 02/26/2021

Inspection Number: 1499496

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: THORNCROFT, ROBERT

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. System in trouble

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811225

BARBER PARK APARTMENTS

License Type: Apartment

5300 LAKE MARGARET DR, ORLANDO 32812

Inspection Date: 02/24/2021

Inspection Number: 1508777

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: FRANZ, LISA

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. B5492 by unit 1813

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6013279

COURTYARD BY MARRIOTT WEST PALM BEACH AIRPORT

License Type: Hotel

1800 CENTRE PARK DR E, WEST PALM BEACH 33401

Inspection Date: 02/11/2021

Inspection Number: 1158684

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: LANZALOTTO, JR

Violation CodeObservationViolation Citation

04-01-4

Observed: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Unit is giving trouble signs due to faulty equipment. Work order has been put in.
Priority: Reporting

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Observed: Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Both boiler certificates expired on 1-10-2020 Priority: Reporting

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6014001

HAMPTON INN WEST PALM BEACH CENTRAL AIRPORT

License Type: Hotel

1601 WORTHINGTON RD, WEST PALM BEACH 33409

Inspection Date: 02/26/2021

Inspection Number: 1157599

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: DE JESUS, ARLENNY

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Boiler certificates expired B00068068 exp 01/15/2021 & B00067957 exp 01/15/2021.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6007726

RESIDENCE INN BY MARRIOTT

License Type: Hotel

525 NW 77TH ST., BOCA RATON 33427

Inspection Date: 02/22/2021

Inspection Number: 1157590

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: KHATOON, BEGUM

Violation CodeObservationViolation Citation

04-07-4

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6002759

CONGRESS MOTEL AND APARTMENTS

License Type: Motel

4787 S CONGRESS AVE, LAKE WORTH 33461

Inspection Date: 02/26/2021

Inspection Number: 1215997

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GONZALEZ, DENNIS

Violation CodeObservationViolation Citation

06-02-4

Door marked as an exit is blocked. For reporting purposes only. Exit gates all chained closed, was instructed to removed chains on exits.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6000929

BREAKERS HOTEL

License Type: Hotel

1 S COUNTY RD, PALM BEACH 33480

Inspection Date: 02/26/2021

Inspection Number: 1155323

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: AHLE, ROBERT

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed floor mezzanine stairwell M. System is on bypass, service is on site. **Corrective Action Taken**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6205754

THE FOUR OAKS APTS

License Type: Apartment

462 77 AVE N, ST. PETERSBURG 33702

Inspection Date: 02/25/2021

Inspection Number: 1497946

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LOZANO, KELVIN

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. View obstructed to fire extinguisher charge zone due tag being in front of it outside of apartment 10. Outside of apartment 1 unable to view charge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216079

JEFFERSON MANOR APARTMENTS

License Type: Apartment

209 NW JEFFERSON CIR N, ST. PETERSBURG 33702

Inspection Date: 02/25/2021

Inspection Number: 1506776

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LOZANO, KELVIN

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Outside unit 3. No mallet.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6205263

GRANADA GATES EAST

License Type: Apartment

450 N 76 AVE, ST PETERSBURG 337025340

Inspection Date: 02/24/2021

Inspection Number: 1500164

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LOZANO, KELVIN

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Between apartments 210e and 211e. Next to apartment 302e

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only. Between apartment 208e and 209e.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. View obstructed between apartments 103 and 104, 205 and 204, 308 and 309. Plastic covering is not see-through.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6202308

GRANADA GATES WEST

License Type: Apartment

600 N 76 AVE, ST PETERSBURG 337025341

Inspection Date: 02/23/2021

Inspection Number: 1492967

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: LOZANO, KELVIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Between apartment 208e and 209e.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-01-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Between apartment 208e and 209e. - From follow-up inspection 2021-02-24:	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Between apartment 315w and 314w. Between apartments 210e and 211e. Next to apartment 302e.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-02-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Between apartment 315w and 314w. Between apartments 210e and 211e. Next to apartment 302e. - From fo	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-05-4	- From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Unable to view fire extinguisher charge zone between apartments 117 and 118, 208 and 209, 206 and 207, 217 and 218, and between 212 and 211, 31	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Unable to view fire extinguisher charge zone between apartments 117 and 118, 208 and 209, 206 and 207, 217 and 218, and between 212 and 211, 311 and 312, 318 and 317. East	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6214433

ROSE GARDEN APARTMENT (THE)

License Type: Apartment

5025 S 28 AVE, GULFPORT 33707

Inspection Date: 02/23/2021

Inspection Number: 1490552

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HOBBS, ANDREW

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Unit 3

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215833

TRU BY HILTON ST PETERSBURG DOWNTOWN CENTRAL AVE

License Type: Hotel

20 17 ST S, ST. PETERSBURG 33712

Inspection Date: 02/24/2021

Inspection Number: 1158059

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: HOBBS, ANDREW

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Near room 428

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6209581

INLET BAY AT GATEWAY LLC

License Type: Apartment

12000 4 ST N, ST PETERSBURG 33716

Inspection Date: 02/24/2021

Inspection Number: 1502145

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: LOZANO, KELVIN

Violation CodeObservationViolation Citation

04-06-4

Fire alarm control panel emitting an audible alarm. For reporting purposes only. Side of building 23. Box is screwed closed. Unable to view system. Building 24 side of apartment 2401.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Putnam County

License Number: 6400778

HOLLY RIDGE SENIOR APARTMENTS

License Type: Apartment

6401 ST JOHNS AVE, PALATKA 32177

Inspection Date: 02/24/2021

Inspection Number: 1507585

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: DOTY, JOSEPH

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher across from apartment 267

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6900160

GOLDELM AT REGENCY OAKS LLC

License Type: Apartment

200 MALTESE CIR, FERN PARK 32730

Inspection Date: 02/23/2021

Inspection Number: 1496938

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: MARTIN, LESLIE

Violation CodeObservationViolation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.
-exit light hanging from wire in 2nd floor hallway at top of stairs between units 15 and 17.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6903889

ARBOR LAKES CONDOMINIUMS

License Type: Apartment

100 ARBOR LAKES CIR, SANFORD 32771

Inspection Date: 02/25/2021

Inspection Number: 1508859

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: ANGEL, TERRY

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Garages.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406543

GOOD SAMARITAN SOCIETY DAYTONA BEACH

License Type: Apartment

340 S RIDGEWOOD AVE, DAYTONA BEACH 32114

Inspection Date: 02/25/2021

Inspection Number: 1505767

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: LARSON, SARAH

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7405179

BAHAMA HOUSE

License Type: Motel

2001 S ATLANTIC AVE, DAYTONA BEACH SHORES 321185007

Inspection Date: 02/26/2021

Inspection Number: 1213540

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.