

Alachua County

License Number: 1101003

STONERIDGE APT

License Type: Apartment

3800 SW 34 ST, GAINESVILLE 326086562

Inspection Date: 03/08/2021

Inspection Number: 1492565

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PACE, PATRICK

Violation Code

Observation

Violation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only.
No light on. No digital readout. At building B.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1505813 SAI PROPERTY INVESTMENTS INC
 License Type: Apartment 200 BUCHANAN AVE, CAPE CANAVERAL 32920

Inspection Date: 03/10/2021 Inspection Number: 1494979 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HICKS, GEORGE RANDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Porch of unit 200.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1501012 COCOA AFFORDABLE LIVING CENTER
 License Type: Motel 900 FRIDAY RD, COCOA 32926

Inspection Date: 03/11/2021 Inspection Number: 1215697 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: WILSON, LANETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Between units 219 and 217	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
05-02-5	Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Strobe not coming on , sound only Manager ordered new, **Corrective Action Taken**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1503844 HOLIDAY INN MELBORNE
 License Type: Hotel 8298 N WICKHAM RD, MELBOURNE 32940

Inspection Date: 03/10/2021 Inspection Number: 1158064 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FRANZ, LINDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Only paperwork available has expired 2-6-2021/ stated boilers were inspected previous week, no paperwork available at this time.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620861

FOUR POINT BY SHERATON FORT LAUDERDALE AIRPORT-DANIA BEACH

License Type: Hotel

1900 STIRLING RD, DANIA BEACH 33004

Inspection Date: 03/08/2021

Inspection Number: 1157649

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LONDONO, GLORIA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620910

HYDE BEACH HOUSE RESORT & RESIDENCES

License Type: Hotel

4010 S OCEAN DR, HOLLYWOOD 33019

Inspection Date: 03/09/2021

Inspection Number: 1155209

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: LONDONO, GLORIA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Fault

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1617346

2435 PIERCE LLC APARTMENTS

License Type: Apartment

2435 PIERCE ST, HOLLYWOOD 33020

Inspection Date: 03/12/2021

Inspection Number: 1508126

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SMITH, CORETTA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge by apt 23 and 28. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1601293

HANNA & HANNA APT

License Type: Apartment

1908 SHERIDAN ST, HOLLYWOOD 33020-2119

Inspection Date: 03/08/2021

Inspection Number: 1493416

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: CHRISTGEN, THOM

Violation CodeObservationViolation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620670		THE HAMPTONS ON HERON BAY	
License Type: Apartment		11100 HERON BAY BLVD, CORAL SPRINGS 33076	
Inspection Date: 03/09/2021	Inspection Number: 1500761	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MATTIELLO-ATASSI, MARIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Apt 2424 and 2222	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1621442		THE MARIN BY ARIUM	
License Type: Apartment		3880 W BROWARD BLVD STE 10, FT LAUDERDALE 33312	
Inspection Date: 03/09/2021	Inspection Number: 1509157	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: BARTON, GEOFFREY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed beside door to unit 204 Bld. 3980	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed extinguishers in recharge zone 1) outside door to unit 101 Bld.3860 2) outside door to unit 111 Bld. 3980 3) between unit	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1618409		EXTENDED STAY AMERICA #328	
License Type: Hotel		1200 FAU RESEARCH PARK BLVD, DEERFIELD BEACH 33441	
Inspection Date: 03/10/2021	Inspection Number: 1157488	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LEWIS, LYNDEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Clay County

License Number: 2000674

ZEN LIVING SUITES

License Type: Motel

150 PARK AVE, ORANGE PARK 32073

Inspection Date: 03/11/2021

Inspection Number: 1215801

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BIAVA, GRANT

Violation CodeObservationViolation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.
Operator has a copy of the boiler certification on his phone but not posted61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2000407

INN OF WINTERBOURNE

License Type: Bed and Breakfast

2104 W WINTERBOURNE, ORANGE PARK 320735603

Inspection Date: 03/08/2021

Inspection Number: 1094111

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BIAVA, GRANT

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Trouble light on fire panel located in small back room connected to the kitchen

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2300112		ALEGRIA APARTMENTS	
License Type: Apartment		365 W 10 ST, HIALEAH 33010	
Inspection Date: 03/11/2021	Inspection Number: 1508160	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, EDGAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Between apartments #2 and #3 building #365.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329182		ALFONSO RAMOS	
License Type: Apartment		270 E 7 STREET, HIALEAH 33010	
Inspection Date: 03/11/2021	Inspection Number: 1498014	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, EDGAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Located on the front side of the apartment #7.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2300430		BEL INN	
License Type: Motel		1202 N KROME AVE, HOMESTEAD 33030	
Inspection Date: 03/11/2021	Inspection Number: 1215870	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: ORDONEZ, CATALINA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By room 2 and 3.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2308299		PARK MOTEL	
License Type: Motel		600 S KROME AVE, HOMESTEAD 33030	
Inspection Date: 03/11/2021	Inspection Number: 1216019	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: ORDONEZ, CATALINA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Between room 18 and 19. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329137		HOLIDAY INN EXPRESS	
License Type: Hotel		35200 SOUTH DIXIE HWY, FLORIDA CITY 33034	
Inspection Date: 03/11/2021	Inspection Number: 1157897	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: AZPURUA, JULIO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2304562		JJF INVESTMENT.	
License Type: Apartment		1515 NW 19 ST, MIAMI 33125	
Inspection Date: 03/08/2021	Inspection Number: 1504387	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: VILCHEZ, NABEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. On the first floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329915		ALVAREZ RENTAL	
License Type: Apartment		1636 NW 16 ST, MIAMI 33125	
Inspection Date: 03/08/2021	Inspection Number: 1501464	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: VILCHEZ, NABEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. On the first floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2301452		269 BUILDING	
License Type: Apartment		269 NW 30 ST, MIAMI 33127	
Inspection Date: 03/08/2021	Inspection Number: 1511371	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed extinguishers in recharge zone located by unit 2, and between units 5 and 6. Operator replaced them for new ones. **Correc	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329343		SLS BRICKELL HOTEL	
License Type: Hotel		1300 S MIAMI AVE, MIAMI 33130	
Inspection Date: 03/08/2021	Inspection Number: 1157521	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CABANAS, NATALIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2307362		MARIA APARTMENTS	
License Type: Apartment		930 SW 5 ST, MIAMI 331302569	
Inspection Date: 03/10/2021	Inspection Number: 1502417	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CRUZ, EDGAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed by unit 1 and by unit 8	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2307900		S C 93	
License Type: Apartment		2120 -2140 SW 1 ST, MIAMI 331351684	
Inspection Date: 03/10/2021	Inspection Number: 1490860	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Warning**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2313107		SCORPIO APARTMENTS	
License Type: Apartment		1515 NW NO RIVER DR, MIAMI 33136	
Inspection Date: 03/11/2021	Inspection Number: 1497519	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By apartment 4.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2327558 LOEWS MIAMI BCH HOTEL
 License Type: Hotel 1601 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 03/10/2021 Inspection Number: 1156941 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler jurisdiction number's 086663, 133030, 133393, 131418, 131417, 130721, 086664, 086665, 095285, 095284 All expired on 1/10/21.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328823 GENEVA HOTEL
 License Type: Hotel 1520 COLLINS AVENUE, MIAMI BEACH 33139

Inspection Date: 03/12/2021 Inspection Number: 1156982 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge located next to room number 2, on the 1st floor. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel located at hallway area on 1st floor. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329049 HOTEL VICTOR
 License Type: Hotel 1144 OCEAN DR, MIAMI BEACH 33139

Inspection Date: 03/09/2021 Inspection Number: 1158735 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329400

HENROSA HOTEL

License Type: Hotel

1435 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 03/12/2021

Inspection Number: 1155447

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: HODGE, KRISTEN

Violation CodeObservationViolation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel located behind front desk. For reporting purposes only. - From follow-up inspection 2021-03-12: Observed Trouble/alarm light illuminated on the fire alarm con

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel located behind front desk. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2306670

SURFCOMBER HOTEL (THE)

License Type: Hotel

1717 COLLINS AVE, MIAMI BEACH 331392081

Inspection Date: 03/11/2021

Inspection Number: 1156360

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: URIBE, GUISELLA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Exp. 07/19/2020

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2301114

LA FLORA HOTEL

License Type: Hotel

1238 COLLINS AVE, MIAMI BEACH 331394607

Inspection Date: 03/09/2021

Inspection Number: 1157933

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2302009 THE ALEXANDER HOTEL
 License Type: Hotel 5225 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 03/09/2021 Inspection Number: 1158745 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: UNZAGA, MILADYS Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light illuminated.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. As per Chief Engineer, inspection is scheduled for next week.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328969 CADILLAC HOTEL & BEACH CLUB, AUTOGRAPH COLLECTION
 License Type: Hotel 3925 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 03/10/2021 Inspection Number: 1156395 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329463 DCROSS MANAGEMENT
 License Type: Hotel 5445 COLLINS AVENUE UNIT C17, MIAMI BEACH 33140

Inspection Date: 03/09/2021 Inspection Number: 1158116 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. One of the boiler has the certificate already expired since 3/6/2020. (FL 092741)	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2319938

LEXINGTON BY HOTEL RL MIAMI BEACH

License Type: Hotel

4299 COLLINS AVE, MIAMI BEACH 331403290

Inspection Date: 03/08/2021

Inspection Number: 1158181

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificate expired on 2/11/2021.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only. No boiler certificate was posted.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2323650

THE PALMS SOUTH BEACH HOTEL

License Type: Hotel

3025 COLLINS AVE, MIAMI BEACH 331404106

Inspection Date: 03/11/2021

Inspection Number: 1154147

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light illuminated. **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2307986

BYRON CHATEAU LLC

License Type: Apartment

7815 BYRON AVE, MIAMI BEACH 33141

Inspection Date: 03/09/2021

Inspection Number: 1479479

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back - Complied

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

01-06-4

- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device on fire extinguisher located between units 3 and 4. - From follow-up ins

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2309545

CORAL127 NM LLC

License Type: Apartment

1595 NE 135 ST, NORTH MIAMI 33161

Inspection Date: 03/09/2021

Inspection Number: 1504060

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: SUAREZ, LEOPOLDO

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3901853

PACIFICA FOXCROFT LLC

License Type: Apartment

3807 TOWER RD, TAMPA 33614

Inspection Date: 03/10/2021

Inspection Number: 1497251

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ZHANG, JACKY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By unit 101 of building 3838.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. By unit 102 building 3839, by unit 101 of building 3832.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Indian River County

License Number: 4101335

STAR SUITES BY RIVERSIDE THEATRE

License Type: Hotel

2550 FLIGHT SAFETY DR, VERO BEACH 32960

Inspection Date: 03/10/2021

Inspection Number: 1158023

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAVIS, DIANNA

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Sound didn't alert when tested in 106.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4703105

DAYS INN & SUITES

License Type: Hotel

2900 N MONROE ST, TALLAHASSEE 32303

Inspection Date: 03/09/2021

Inspection Number: 1157752

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: TRUESDALE, CHRIS

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5100390

WINDMILL APARTMENTS THE

License Type: Apartment

4711 U S 41 N, PALMETTO 342218513

Inspection Date: 03/12/2021

Inspection Number: 1511030

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: MCKEON, MICHAEL

Violation Code

Observation

Violation Citation

01-01-4

- From initial inspection : Observed: Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only, by unit 8.
Priority: Reporting - From follow-up inspection 2021-01-29: **Time Extended**
- Fr

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301447

SUBURBAN EXTENDED STAY HOTEL STUART

License Type: Hotel

1900 SE FEDERAL HWY, STUART 34994

Inspection Date: 03/08/2021

Inspection Number: 1156935

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: PETROW, MICHAEL

Violation Code

Observation

Violation Citation

04-02-4

- From initial inspection : No smoke detector provided in guest room/unit. For reporting purposes only. Missing in room 114. - From follow-up inspection 2021-03-08: Room is currently occupied. **Time Extended**

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5403240

TRADEWINDS HAMMOCKS APARTMENTS

License Type: Apartment

100 HAMMOCK TRL, KEY LARGO 33037

Inspection Date: 03/08/2021

Inspection Number: 1499429

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, RICARDO

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Observed several fire extinguishers missing breaking device.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5810954

HERITAGE HOTEL

License Type: Motel

7900 S ORANGE BLOSSOM TRAIL, ORLANDO 32809

Inspection Date: 03/09/2021

Inspection Number: 1213363

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: FRANZ, LISA

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. - by room 2018

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 51981 and 122138 expired 7/19/2018

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5809885

FAIRFIELD INN ORLANDO LK BUENA VISTA

License Type: Hotel

8615 VINELAND AVE, ORLANDO 32821

Inspection Date: 03/12/2021

Inspection Number: 1154165

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: YOUNG, COLIN

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 1/25/2021

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5809995

SPRINGHILL SUITES ORLANDO LK BUENA VISTA

License Type: Hotel

8601 VINELAND AVE, ORLANDO 32821

Inspection Date: 03/12/2021

Inspection Number: 1154444

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: YOUNG, COLIN

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 1/25/21

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5809167		LA QUINTA INN & SUITES UCS #180	
License Type: Hotel		11805 RESEARCH PKWY, ORLANDO 32826	
Inspection Date: 03/08/2021	Inspection Number: 1158096	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: JENKINS, JOSHUA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
05-02-5	Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5804083		SHERATON ORLANDO LAKE BUENA VISTA RESORT	
License Type: Motel		12205 S APOPKA VINELAND RD, ORLANDO 32836	
Inspection Date: 03/09/2021	Inspection Number: 1216616	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SPEIGHTS, BLANCHIE MACHELLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certification expired 4/21/2018	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5800462		DAYS INN MIDTOWN	
License Type: Motel		3300 S ORANGE BLOSSOM TRL, ORLANDO 328398968	
Inspection Date: 03/10/2021	Inspection Number: 1216642	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: RULLAN, ALFONSO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Osceola County

License Number: 5912061

RAMADA KISSIMMEE DOWNTOWN HOTEL

License Type: Hotel

4018 W VINE ST, KISSIMMEE 34741

Inspection Date: 03/11/2021

Inspection Number: 1158766

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LORENZO, ANA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only./ 123352 , 099479, 122629, 122628 exp 11/12/20

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5913652

STAYMORE EXTENDED STUDIOS

License Type: Motel

2407 WEST VINE ST, KISSIMMEE 34741

Inspection Date: 03/12/2021

Inspection Number: 1215419

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: LORENZO, ANA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5906532

SECRETS HIDEAWAY

License Type: Motel

2145 EAST IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34744

Inspection Date: 03/09/2021

Inspection Number: 1214647

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BORRERO, AUDREY

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Is a new boiler

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5912068

MM LAKE HOTEL LLC

License Type: Hotel

4944 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 03/08/2021

Inspection Number: 1157806

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BELTRAN, SANDRA

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6005960

SUPER 8 MOTEL

License Type: Motel

4112 W BLUE HERON BLVD, RIVIERA BEACH 33404-4855

Inspection Date: 03/12/2021

Inspection Number: 1215154

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: HORTON, TIMOTHY

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6011917

RESIDENCE INN WEST PALM BEACH

License Type: Hotel

2461 METROCENTRE BLVD, WEST PALM BEACH 33407

Inspection Date: 03/12/2021

Inspection Number: 1157835

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: HORTON, TIMOTHY

Violation CodeObservationViolation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable.
For reporting purposes only.

Room 211 - hard wired hearing impaired smoke detection device test button inoperable.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6013908

WPB MULTIFAMILY PROPERTY I LLC

License Type: Apartment

4400 PORTOFINO WAY, WEST PALM BEACH 33409

Inspection Date: 03/12/2021

Inspection Number: 1497330

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: SEVILLA, FREDDY

Violation CodeObservationViolation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Building 2 empty fire extinguisher second floor next to apartment 204 - From follow-up inspection

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Building 2 empty fire extinguisher second floor next to apartment 204

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Building 7 missing fire extinguisher first floor next to apartment 110

01-03-4

- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Building 7 missing fire extinguisher first floor next to apartment 110 - From fo

License Number: 6001033

BOCA MANOR APARTMENTS

License Type: Apartment

2500 N FEDERAL HWY, BOCA RATON 33431

Inspection Date: 03/10/2021

Inspection Number: 1501460

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CUDEMOS, HAIDA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Observed next to apartment # 211.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014003

APTS 824-828

License Type: Apartment

824 N G ST, LAKE WORTH 33460

Inspection Date: 03/12/2021

Inspection Number: 1495713

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SINGH, GAJENDRA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In between apartment 6 and 7

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6008599

LAQUINTA INN

License Type: Motel

34 FISHERMANS WHARF, JUPITER 33477

Inspection Date: 03/11/2021

Inspection Number: 1216647

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

06-03-4

Marked exit is inaccessible. For reporting purposes only.no emergency exit sign/diagram/fire evacuation floor plan posted on door.#308,#215,#200.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6000173

BRAZILIAN COURT

License Type: Hotel

301 AUSTRALIAN AVE, PALM BEACH 33480-4659

Inspection Date: 03/10/2021

Inspection Number: 1155298

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: AHLE, ROBERT

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215792		HAVANA INN	
License Type: Hotel		1007 GULF WAY, ST.PETE BEACH 33706	
Inspection Date: 03/12/2021	Inspection Number: 1158166	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HOBBS, ANDREW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Second floor near room 208	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6215897		KAI LUA LLC	
License Type: Apartment		1200 70 ST N, ST. PETERSBURG 33710	
Inspection Date: 03/09/2021	Inspection Number: 1511330	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HOBBS, ANDREW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Second floor near unit 204	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6215833		TRU BY HILTON ST PETERSBURG DOWNTOWN CENTRAL AVE	
License Type: Hotel		20 17 ST S, ST. PETERSBURG 33712	
Inspection Date: 03/09/2021	Inspection Number: 1158059	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: HOBBS, ANDREW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Near room 428 - From follow-up inspection 2021-03-09: Fire extinguisher still needs to be recharged	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Pinellas County

License Number: 6206179

SIENNA BAY APARTMENTS

License Type: Apartment

10501 3 ST N, ST. PETERSBURG 33716

Inspection Date: 03/10/2021

Inspection Number: 1506072

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LOZANO, KELVIN

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. 10501-C, 10742-C

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. 10452-B, 10404-A, 10481-B, 10531-A fire extinguisher covered by glass and no means to break it.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215858

PINE COVE VILLAS

License Type: Apartment

1824 VILLAS DR #22, CLEARWATER 33760

Inspection Date: 03/08/2021

Inspection Number: 1503131

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WILMOT, TASHARA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
-first floor at building 1836
-first floor at building 1844

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6300808

FLORIDA GARDEN MOTEL

License Type: Motel

2345 8 ST NW, WINTER HAVEN 338811333

Inspection Date: 03/10/2021

Inspection Number: 1214632

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: JACKSON, SHARON

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.
Room 102

509.215(1) and (2) and 509.032(2)(d) FS Reporting:
509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6602525

RENO MOTEL

License Type: Motel

1923 AVENUE D, FORT PIERCE 34950

Inspection Date: 03/10/2021

Inspection Number: 1215211

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: HARROD, JESSICA

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Unit is not properly working. Does not sound.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406520

EXTENDED STAY AMERICA #9512

License Type: Hotel

275 INTERCHANGE BLVD, ORMOND BEACH 32174

Inspection Date: 03/10/2021

Inspection Number: 1158590

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Call Back -
Complied

Inspector Name: RUTLEDGE, REBECCA

Violation Code

Observation

Violation Citation

08-04-4

- From initial inspection : Boiler certificate not posted in the boiler room. Operator provided a satisfactory initial first inspection report for both boilers. For reporting purposes only. - From follow-up inspection 2021-03-10: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.