

Alachua County

License Number: 1102931

VERDANT COVE APARTMENTS

License Type: Apartment

4260 SE 10 PL, GAINESVILLE 32641

Inspection Date: 03/30/2021

Inspection Number: 1502245

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: GRODEWALD, PAUL

Violation Code

Observation

Violation Citation

07-02-4

Frayed electrical wire(s). For reporting purposes only.
 Tube in ground behind building 1159, between building and play ground.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1504848

PALM COVE APARTMENTS

License Type: Apartment

531 JACKSON AVE, CAPE CANAVERAL 32920

Inspection Date: 03/29/2021

Inspection Number: 1499777

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DAVIS, DIANNA

Violation CodeObservationViolation Citation

07-04-4

Electrical outlet missing covers - located at south side of both buildings.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1505735

420-430 S BREVARD AVE

License Type: Apartment

420 S BREVARD AVE, 420-430, COCOA BEACH 32931

Inspection Date: 04/01/2021

Inspection Number: 1508162

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HICKS, GEORGE RANDY

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In carport of 420.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620913		LE MERIDIEN DANIA BEACH AT FORT LAUDERDALE AIRPORT	
License Type: Hotel		1825 GRIFFIN RD, DANIA BEACH 33004	
Inspection Date: 03/30/2021	Inspection Number: 1158120	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LONDONO, GLORIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1600158		1639 MADISON LLC	
License Type: Apartment		1639 MADISON ST, HOLLYWOOD 33020	
Inspection Date: 03/31/2021	Inspection Number: 1499495	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: FEIGELES, MITCHELL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
06-03-4	Marked exit is inaccessible. Some rooms have metal bars over their windows, preventing secondary exits. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1604100		1707 TAFT ST APTS	
License Type: Apartment		1707 TAFT ST, HOLLYWOOD 33020	
Inspection Date: 03/31/2021	Inspection Number: 1494330	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHRISTGEN, THOM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Extinguisher near unit 5.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1605797		MEDFORD N 14TH LLC	
License Type: Apartment		1720 N 17 AVE, HOLLYWOOD 33020	
Inspection Date: 03/31/2021	Inspection Number: 1499265	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: CHRISTGEN, THOM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Fire extinguisher near Unit 4.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Broward County

License Number: 1620916		HYATT CENTRIC LAS OLAS FORT LAUDERDALE	
License Type: Hotel		100 E LAS OLAS BLVD, FORT LAUDERDALE 33301	
Inspection Date: 03/29/2021	Inspection Number: 1157117	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: BRANN, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2021-03-29: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1620848		HILTON FT LAUDERDALE BEACH RESORT	
License Type: Hotel		505 N FT LAUDERDALE BEACH BLVD, FORT LAUDERDALE 33304	
Inspection Date: 04/01/2021	Inspection Number: 1157065	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANN, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. 26th FL 121130 no certificate 134334 no certificate 134333 no certificate.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inpector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1619051		HOMETOWNE STUDIOS - FORT LAUDERDALE 3512	
License Type: Hotel		3031 W COMMERCIAL BLVD, FORT LAUDERDALE 33309	
Inspection Date: 03/31/2021	Inspection Number: 1158790	Inspection Type: Complaint Full	Inspection Disposition: Administrative Complaint Time Extension
Inspector Name: BENJAMIN, ALEXANDER			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Elevator next to room 222 - From follow-up inspection 2021-03-31: Observed same **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1620857		FERRARA HOLDINGS LLC	
License Type: Motel		4288 DAVIE RD, FORT LAUDERDALE 33314	
Inspection Date: 03/31/2021	Inspection Number: 1215283	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: BARTON, GEOFFREY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Empty extinguisher box back (north) side of main building.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Broward County

License Number: 1606598

OAKWOOD APARTMENTS

License Type: Apartment

4050 NE 1 AVE #117, OAKLAND PARK 33334

Inspection Date: 04/01/2021

Inspection Number: 1503231

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BENJAMIN, ALEXANDER

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Ext to unit 105 of building 4050

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1604928

COUNTRY CREST APTS

License Type: Apartment

6400 NE 18 AVE, FORT LAUDERDALE 33334-5108

Inspection Date: 03/31/2021

Inspection Number: 1498327

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BENJAMIN, ALEXANDER

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to apartment 2 on south side building

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2102706

HOME2 SUITES BY HILTON NAPLES I-75 PINE RIDGE RD

License Type: Hotel

3685 KRAMER DR, NAPLES 34109

Inspection Date: 03/29/2021

Inspection Number: 1157446

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PENN, BRIAN

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Operator still working to get insurance company out to inspect. This is a repeat violation from 9/30/2020. **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2311230 SEIJAS APTS
 License Type: Apartment 350 W 20 ST, HIALEAH 330102563

Inspection Date: 03/29/2021 Inspection Number: 1504836 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, EDGAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed between apartments #14 and #15; apartment #11; between apartments #8 and #9; in front of the apartment #2.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed between apartments #6 and #7; between apartments #14 and #15; apartment #11; between apartments #8 and #9; in front of the apartment #4.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2301390 SUNSIDE PARKS APTS
 License Type: Apartment 355 W 20 ST, HIALEAH 330102567

Inspection Date: 03/29/2021 Inspection Number: 1502300 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: PRIETO, EDGAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Apartments #201; #205; #209; #214;	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Apartment #305;	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2324092 JORCA CORPORATION APTS
 License Type: Apartment 34 E 21 ST, HIALEAH 330102710

Inspection Date: 03/31/2021 Inspection Number: 1502475 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, EDGAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. By apartment #15.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2309032 E & G REALTY APTS
 License Type: Apartment 179 W 9 ST, HIALEAH 330104085

Inspection Date: 03/29/2021 Inspection Number: 1490219 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, EDGAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Apartment #3E.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Apartment #1A; apartment #7A.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2326980 417 & 425 E 31 ST APTS
 License Type: Apartment 417 E 31 ST, HIALEAH 33012

Inspection Date: 03/31/2021 Inspection Number: 1504932 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: RUSSO, THOMAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only. No fire extinguisher observed.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-04-4	Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Observed on the north side of building 425 next to apartment #4.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330127 LEGACY LAS PALMAS
 License Type: Apartment 3505 W 10 AVE, HIALEAH 33012

Inspection Date: 03/30/2021 Inspection Number: 1496964 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: RUSSO, THOMAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed in building 5 next to Apartment 104 and 107 and in building 2 between apartments 103 and 104, and in building 10, between Apartments 103 and 104, and also next to the garbage compactor at the maintenance shed.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2313258		SUNFLOWER APARTMENTS (THE)	
License Type: Apartment		3675 W 11 AVE, HIALEAH 330124992	
Inspection Date: 04/02/2021	Inspection Number: 1499894	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: RUSSO, THOMAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next to the following apartments: 203, 209, 214, 220, 303, 309, 314 and 320.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2322413		1501 APTS	
License Type: Apartment		1501 W 41 ST, HIALEAH 330125816	
Inspection Date: 04/01/2021	Inspection Number: 1504864	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: RUSSO, THOMAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed between apartments 2A and 3A and between apartments 5A and 6A.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2310804		LAS BRISAS GARDEN APARTMENTS	
License Type: Apartment		201 W 65 ST, HIALEAH 330126766	
Inspection Date: 04/02/2021	Inspection Number: 1506682	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: RUSSO, THOMAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed in building 201 next to apartment 101, 108, 112, and 202. And building 207 next to apartment 103 and 203 and in building 209 next to apartments 101, 114 and 214.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2310543		WESTLAND APARTMENTS	
License Type: Apartment		4951 W 14 LN, HIALEAH 330128107	
Inspection Date: 04/01/2021	Inspection Number: 1499874	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: RUSSO, THOMAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed next to apartment 105	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2313789 1559-60 NW 15 ST RD LLC
 License Type: Apartment 1560 NW 15 ST RD, MIAMI 33125

Inspection Date: 04/02/2021 Inspection Number: 1493991 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: PRIETO, VICENTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed missing breaking device in all fire extinguisher boxes.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2312088 GASOLIH R/E HOLDINGS LLC
 License Type: Apartment 651 SW 3 ST, MIAMI 33130

Inspection Date: 03/30/2021 Inspection Number: 1499574 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: AZPURUA, JULIO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing glass breaking device installed on box next to apartment 3 and apartment 5. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2312972 VENTO 7 LLC
 License Type: Apartment 921 SW 7 ST, MIAMI 33130

Inspection Date: 03/31/2021 Inspection Number: 1496783 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328422 VILLAS OF HAVANA LLC
 License Type: Apartment 717 SW 11 AVE, MIAMI 33130

Inspection Date: 03/30/2021 Inspection Number: 1501171 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: AZPURUA, JULIO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2309459

LISMAR APTS

License Type: Apartment

404 SW 6 ST, MIAMI 331302872

Inspection Date: 03/29/2021

Inspection Number: 1497497

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: URIBE, GUISELLA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
By Unit 25, fourth floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2312032

MENDEZ APT

License Type: Apartment

1010 SW 6 ST, MIAMI 331303163

Inspection Date: 03/31/2021

Inspection Number: 1511718

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: URIBE, GUISELLA

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
By unit 2.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2302642

LLANES APARTMENTS

License Type: Apartment

649-661-671 SW 7 ST, MIAMI 331303353

Inspection Date: 03/31/2021

Inspection Number: 1496626

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CRUZ, EDGAR

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed in building 649.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Building 349 by unit 1

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2307247 BRICKELL WEST APARTMENTS
 License Type: Apartment 180 SW 9 ST, MIAMI 331303568

Inspection Date: 04/01/2021 Inspection Number: 1499959 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: URIBE, GUISELLA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2313017 TERRY APARTMENTS
 License Type: Apartment 620 SW 10 ST, MIAMI 331303863

Inspection Date: 04/02/2021 Inspection Number: 1495127 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: URIBE, GUISELLA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2320030 TRANSCARIBE APTS
 License Type: Apartment 1772 SW 5 ST, MIAMI 331353554

Inspection Date: 03/29/2021 Inspection Number: 1490345 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Extinguisher located on the ground floor , on the left side.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2304763		DE VIVAR APT	
License Type: Apartment		1629 SW 4 ST, MIAMI 331353685	
Inspection Date: 03/29/2021	Inspection Number: 1497552	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed extinguisher located by unit 9 without breaking device.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2310250		CLAVEL APTS	
License Type: Apartment		1241 SW 7 ST, MIAMI 331354016	
Inspection Date: 04/01/2021	Inspection Number: 1497511	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ORDONEZ, CATALINA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed fire extinguisher being blocked by a tree. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2327624		ST JOHN VILLAGES 17TH & 1ST LLC	
License Type: Apartment		1613 NW 1 PL, MIAMI 33136	
Inspection Date: 03/30/2021	Inspection Number: 1504173	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located between apartments 2 & 3.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329614		ST JOHN PROPERTIES LLC	
License Type: Apartment		1731-1741 NW 1 COURT, MIAMI 33136	
Inspection Date: 03/30/2021	Inspection Number: 1492162	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location. For reporting purposes only. Located in building 1741 and missing on wall between apt 2 & 3.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329683 ST JOHN VILLAGE 1410 LLC
 License Type: Apartment 1410 NW 1ST AVE, MIAMI 33136

Inspection Date: 03/30/2021 Inspection Number: 1506689 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: TAYLOR, JOHN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2303044 1140 APT
 License Type: Apartment 1140 NW 1 PL, MIAMI 331362763

Inspection Date: 04/02/2021 Inspection Number: 1507216 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By unit 1 **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329309 NORMANDY ISLES II APTS
 License Type: Apartment 647 NE 61 ST, MIAMI 33137

Inspection Date: 03/29/2021 Inspection Number: 1505395 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: PAGAN, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Next to apartment 1 observed fire extinguisher locked in a box missing breaking device.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329381 HYDE SUITES MIDTOWN
 License Type: Hotel 3401 NE 1 AVE, MIAMI 33137

Inspection Date: 04/01/2021 Inspection Number: 1158432 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: SEYBA, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330141		2500 BISCAYNE	
License Type: Apartment		2500 BISCAYNE BLVD, MIAMI 33137	
Inspection Date: 03/29/2021	Inspection Number: 1509043	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PAGAN, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2303941		747 PROPERTY, LLC	
License Type: Apartment		747 NE 83 TERRACE, MIAMI 33138	
Inspection Date: 03/30/2021	Inspection Number: 1491578	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: SEYBA, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no means to access locked fire boxes at every fire extinguisher.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2308669		BAYSHORE UNITED LLC	
License Type: Apartment		1101 NE 80 ST, MIAMI 33138	
Inspection Date: 03/31/2021	Inspection Number: 1491752	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: PAGAN, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Missing breaking device on fire extinguisher box located at first floor next to apartment 106.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329336		URBANICA THE MERIDIAN HOTEL	
License Type: Hotel		418 MERIDIAN AVE, MIAMI BEACH 33139	
Inspection Date: 04/02/2021	Inspection Number: 1156690	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2021-04-02: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2307184		STARLITE APARTMENTS	
License Type: Hotel		750 OCEAN DR, MIAMI BEACH 33139-6294	
Inspection Date: 03/31/2021	Inspection Number: 1158020	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329398		GENERATOR	
License Type: Hotel		3120 COLLINS AVENUE, MIAMI BEACH 33140	
Inspection Date: 04/02/2021	Inspection Number: 1157945	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed FL 135551 and 135552, both with expiration date on 1/23/2021.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2305447		7418- 7424-7428 HARDING AVE	
License Type: Apartment		7418- 7428 HARDING AVE, MIAMI BEACH 33141	
Inspection Date: 04/01/2021	Inspection Number: 1511720	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-05-4	No smoke detector provided in guest room/unit. For reporting purposes only. Observed in units 1, 3 and 8.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2328444		HACH ALLUCH I LLC	
License Type: Apartment		7820 HARDING AVE, MIAMI BEACH 33141	
Inspection Date: 03/31/2021	Inspection Number: 1502875	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed missing breaking device for the fire extinguisher box at north side of the building.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2318819	J P VISTA LLC
License Type: Apartment	3226 3234 NW 22 AVE, MIAMI 33142

Inspection Date: 03/26/2021	Inspection Number: 1500460	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: URIBE, GUISELLA			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only, by Unit 8.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2611653		REMINGTON I APARTMENTS	
License Type: Apartment		2960 REMINGTON ST, JACKSONVILLE 322057598	
Inspection Date: 03/29/2021	Inspection Number: 1502461	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ESPINOSA-BECKERT, ILIANA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By apt 4	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2601148		ROYAL PALMS APTS	
License Type: Apartment		275 E SAILFISH DR, ATLANTIC BCH 322334128	
Inspection Date: 03/31/2021	Inspection Number: 1492773	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, MAYRA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. By apartment number 209 **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2609446		WEST CREEK II APARTMENTS	
License Type: Apartment		5601 CALIFORNIA AVE-OFFIC, JACKSONVILLE 32244	
Inspection Date: 03/29/2021	Inspection Number: 1503634	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BELLEMARE, RYAN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
07-04-4	Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Extension cord running from building 1, to building 2, tied to a tree in between, going to a metal junction box for security cameras. All attached with electrical tape.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Escambia County

License Number: 2705437

HUBANKS APTS

License Type: Apartment

1608 ATWOOD DRIVE, PENSACOLA 32503

Inspection Date: 04/02/2021

Inspection Number: 1502009

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: ALBRITTON, GREGORY

Violation Code

Observation

Violation Citation

12-04-4

High Priority - Balcony collapsed.
Behind Apartment H. **Warning**

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

Hillsborough County

License Number: 3913779	DREW PARK GARDENS		
License Type: Apartment	4611 N HUBERT AVE, TAMPA 33614		
Inspection Date: 03/29/2021	Inspection Number: 1511632	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ZHANG, JACKY			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By apt 8. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only. Behind Apt 5.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913972	SWAN LAKE APARTMENTS		
License Type: Apartment	3303 N LAKEVIEW DR, TAMPA 33618		
Inspection Date: 03/30/2021	Inspection Number: 1511335	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ZHANG, JACKY			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-03-4	Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Removed. Apt 3816.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913615	STAYBRIDGE SUITES TAMPA EAST/BRANDON		
License Type: Hotel	3624 N FALKENBURG RD, TAMPA 33619		
Inspection Date: 03/29/2021	Inspection Number: 1158710	Inspection Type: Complaint Full	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: CANNELLA, MARK			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2021-03-29: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3912329

HILTON GARDEN INN TAMPA NORTH

License Type: Hotel

13305 TAMPA OAKS BLVD, TEMPLE TERRACE 33637

Inspection Date: 03/30/2021

Inspection Number: 1157506

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: BEAULIEU, STEPHANIE

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2021-01-28: **Time Extended** - From follow-up inspection 2021-03-30: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lake County

License Number: 4501384

QUALITY INN

License Type: Motel

16630 HWY 441 W, MOUNT DORA 32757

Inspection Date: 04/01/2021

Inspection Number: 1216706

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CONNOLLY, MADELINE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4502672

HAMPTON INN LEESBURG

License Type: Hotel

9630 US HWY 441, LEESBURG 34788

Inspection Date: 03/31/2021

Inspection Number: 1158607

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: CONNOLLY, MADELINE

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. **Warning**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4604656 LAGO DEL SOL APARTMENTS
 License Type: Apartment 10770 CLEAR LAKE LOOP, FORT MYERS 33908

Inspection Date: 04/02/2021 Inspection Number: 1503246 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: SOMMERS, KARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-06-4	Fire alarm control panel emitting an audible alarm. For reporting purposes only. Buildings 15061 and 15101.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-01-4	Damaged electrical wire(s). For reporting purposes only. Observed emergency lights detached and hanging by wires, 2nd and 3rd floor, Building 15061. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4605213 TH PALMS OF MONTERREY
 License Type: Apartment 15250 SONOMA DR, FORT MYERS 33908

Inspection Date: 04/01/2021 Inspection Number: 1498513 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SOMMERS, KARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguishers on 3rd floor near Unit 302, Building 7; 2nd floor near Unit 201, Building 7	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4603054 SANIBEL HARBOUR RESORT & SPA
 License Type: Hotel 17260 HARBOUR POINTE DR, FT MYERS 33908

Inspection Date: 04/01/2021 Inspection Number: 1158705 Inspection Type: Complaint Full Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: SOMMERS, KARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2021-04-01:	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400679

HOLIDAY ISLE RESORT & MARINA - POSTCARD INN

License Type: Motel

84001 OVERSEAS HWY, ISLAMORADA 33036

Inspection Date: 03/31/2021

Inspection Number: 1215143

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
LAUNDRY ROOM AREA FL 112651 1/9/16 no Data tag on boiler.61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5402991

GARDENS

License Type: Hotel

526 ANGELA STREET, KEY WEST 33040

Inspection Date: 03/29/2021

Inspection Number: 1155524

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: DEMARTINI, JOSEPH

Violation CodeObservationViolation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.
Electric box side of building near laundry room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811136 THE ALFOND INN
 License Type: Hotel 300 E NEW ENGLAND AVE, WINTER PARK 32789

Inspection Date: 03/30/2021 Inspection Number: 1157340 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: MONTGOMERY, DOREEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only, no boiler certificate available for (1) boiler - From follow-up inspection 2021-03-30: BOILER - # 122082 - expired 2/20/20 **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5800281 PROSPERITY PLACE
 License Type: Apartment 621 W S ST, ORLANDO 32805

Inspection Date: 03/30/2021 Inspection Number: 1503978 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: DIOP, DONALD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Near unit 9.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5800439 PROSPERITY PLACE
 License Type: Apartment 635 W S ST, ORLANDO 32805

Inspection Date: 03/30/2021 Inspection Number: 1503979 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: DIOP, DONALD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Near unit 5.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5800448 SOUTH RIDGE APARTMENTS
 License Type: Apartment 440 W OAK RIDGE RD, ORLANDO 32809

Inspection Date: 03/30/2021 Inspection Number: 1495693 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RULLAN, ALFONSO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
06-01-4	Path to door marked as an exit is blocked, mattress in hallway by apt 5. For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5801661 LA QUINTA INN
 License Type: Motel 5825 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 04/02/2021 Inspection Number: 1216773 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KOSTELNY, ROGER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 5/26/2020	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.Laundry room.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5804299 MCKINLEY AT PORTOFINO
 License Type: Apartment 5974 WINDHOVER DR, ORLANDO 32819

Inspection Date: 03/31/2021 Inspection Number: 1511688 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KOSTELNY, ROGER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel building #4956. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810213 FAIRFIELD INN & SUITES ORLANDO INTERNATIONAL DR/CONVENTION CNTR
 License Type: Hotel 8214 UNIVERSAL BLVD, ORLANDO 32819

Inspection Date: 03/29/2021 Inspection Number: 1158543 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KOSTELNY, ROGER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 3/12/21	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811131

DRURY INN & SUITES ORLANDO

License Type: Hotel

7301 W SAND LAKE RD, ORLANDO 32819

Inspection Date: 03/29/2021

Inspection Number: 1158867

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MANTI, KATHRYN

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5800779

B RESORT

License Type: Hotel

1905 HOTEL PLAZA BLVD, LAKE BUENA VISTA 32830

Inspection Date: 03/31/2021

Inspection Number: 1157176

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

Violation CodeObservationViolation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed trouble light on the fire alarm panel located at front desk . **Repeat Violation** - From follow-up inspection 2021-03-31: Spoke with General Manager concerning update on fire Alarm Reedy Creek will be inspected in month April.
Trouble lights remain on at callback inspection.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Observed boiler certification has expired 052578 4/16/2020 expired Per Manager new boilers being installed.61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811010

RETREAT AT LAKE NONA

License Type: Apartment

10203 FALCON PARC BLVD, ORLANDO 32832

Inspection Date: 03/29/2021

Inspection Number: 1498505

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ALVIS, DAVID

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900225

SERALAGO HOTEL AND SUITES MAINGATE EAST

License Type: Hotel

5678 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 04/02/2021

Inspection Number: 1158908

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: LORENZO, ANA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only./ SYSTEM GROUND FAULT

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inpector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2021-03-15: **Time Extended** - From follow-up inspection 2021-04-02: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inpector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900576

RED LION HOTEL LAKE BUENA VISTA SOUTH

License Type: Hotel

5150 W IRLO BRONSON HWY, KISSIMMEE 34746

Inspection Date: 03/30/2021

Inspection Number: 1158587

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BELTRAN, SANDRA

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inpector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5913650

STUDIO 6 #6050

License Type: Motel

5733 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 03/29/2021

Inspection Number: 1215403

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BELTRAN, SANDRA

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. For one boiler

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014044

HAWTHORN SUITES WEST PALM BEACH

License Type: Hotel

301 LAMBERTON DR, WEST PALM BEACH 33401

Inspection Date: 03/26/2021

Inspection Number: 1158854

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LANZALOTTO, JR

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6002361

AQUA MOTEL

License Type: Motel

7802 S DIXIE HWY, WEST PALM BEACH 33405-4820

Inspection Date: 03/29/2021

Inspection Number: 1216742

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: MCCARTHY, RAMONA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge in guest laundry room. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6014001

HAMPTON INN WEST PALM BEACH CENTRAL AIRPORT

License Type: Hotel

1601 WORTHINGTON RD, WEST PALM BEACH 33409

Inspection Date: 03/31/2021

Inspection Number: 1157599

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: DE JESUS, ARLENNY

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Boiler certificates expired B00068068 exp 01/15/2021 & B00067957 exp 01/15/2021. - From follow-up inspection 2021-03-31: Same **Time Extended**61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6000575		DOUBLETREE BY HILTON PALM BEACH GARDENS	
License Type: Hotel		4431 PGA BLVD, PALM BEACH GARDENS 33410	
Inspection Date: 04/02/2021	Inspection Number: 1158822	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: ROTONDI, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.all exp 12/6/2020, #133388, 099443, 094941, 097136. **Repeat Violation** - From follow-up inspection 2021-04-02: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6002779		BELLE GLADE ONE LLC	
License Type: Apartment		564 W AVE A1, BELLE GLADE 33430	
Inspection Date: 04/01/2021	Inspection Number: 1503631	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SEVILLA, FREDDY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. West side of the building.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6010468		MCKINSEY APTS	
License Type: Apartment		608 W AVE A, BELLE GLADE 33430	
Inspection Date: 04/01/2021	Inspection Number: 1496145	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SEVILLA, FREDDY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
06-03-4	Marked exit is inaccessible. For reporting purposes only. Second floor window facing south is covered with wired mesh.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6010704		BELLE GLADE ONE LLC	
License Type: Apartment		612 SW MARTIN LUTHER KING JR BLVD, BELLE GLADE 33430	
Inspection Date: 04/01/2021	Inspection Number: 1498788	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SEVILLA, FREDDY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
06-03-4	Marked exit is inaccessible. For reporting purposes only. Several windows cover with plywood East side of the building and rear of the building.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Palm Beach County

License Number: 6011218 R & D APARTMENTS
 License Type: Apartment 633 SW 8 ST, BELLE GLADE 33430

Inspection Date: 03/30/2021 Inspection Number: 1508140 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SEVILLA, FREDDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. North side of the building first floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
06-02-4	Door marked as an exit is blocked. For reporting purposes only. Apartment on the first floor South East side of the building Windows blocked by plywood .	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6000229 33 NE AVE C
 License Type: Apartment 33 NE AVE C, BELLE GLADE 33430-3153

Inspection Date: 03/30/2021 Inspection Number: 1491119 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SEVILLA, FREDDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
06-03-4	Marked exit is inaccessible. For reporting purposes only. Windows cover with plywood on apartment #6.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6004888 THOMAS APARTMENTS
 License Type: Apartment 584 SW 5 ST, BELLE GLADE 33430-3846

Inspection Date: 03/30/2021 Inspection Number: 1495988 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SEVILLA, FREDDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
06-03-4	Marked exit is inaccessible. For reporting purposes only. Windows are blocked by a metal wire mesh from the outside on west side corner of the building first floor apartment.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6012655

FAIRFIELD INN & SUITES JUPITER

License Type: Hotel

6748 INDIANTOWN RD, JUPITER 33458

Inspection Date: 04/02/2021

Inspection Number: 1158585

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 121021, 121022, 095111 all exp 03/15/2019
 Repeat Violation - From follow-up inspection 2021-04-02: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6013129

ELKWOOD APARTMENT DUPLEXES

License Type: Apartment

4800 32 DR S, WEST PALM BEACH 33461

Inspection Date: 03/31/2021

Inspection Number: 1503104

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: STEUBER, RYAN

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
 At unit 4822

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
 At unit 4802

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6203064		TRADEWINDS SANDPIPER BEACH RESORT	
License Type: Motel		6000 GULF BLVD, ST. PETE BEACH 33706	
Inspection Date: 03/31/2021	Inspection Number: 1215839	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: DAY-WALKER, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Yellow trouble light on lobby fire panel.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6200452		MONTEREY APTS	
License Type: Apartment		5701 N 21 AVE, ST PETERSBURG 337105044	
Inspection Date: 03/30/2021	Inspection Number: 1492964	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HOBBS, ANDREW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Near mail boxes	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6211956		KENWOOD INN	
License Type: Motel		451 34 ST N, ST. PETERSBURG 33713	
Inspection Date: 04/01/2021	Inspection Number: 1213833	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: HOBBS, ANDREW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. 246 - From follow-up inspection 2021-03-17: Extinguisher still in recharge zone **Time Extended** - From follow-up inspection 2021-04-01: Extinguisher still needs a recharge	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
01-05-4	- From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only. No strikers on any fire extinguishers. - From follow-up inspection 2021-03-17: No strikers observed **Time Extended** - From follow-up inspection 2021-04-01: No strikers present on locked boxes	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Pinellas County

License Number: 6207397

TAMARIND BAY, LLC

License Type: Apartment

11400 4 ST N, ST. PETERSBURG 33716

Inspection Date: 03/30/2021

Inspection Number: 1505779

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: LOZANO, KELVIN

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Unable to view due to fire extinguisher being turned around 1-113. Unable to view charge zone due to cover not being see-through 3-303 11-1101

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6200043

ORANGE MOTEL

License Type: Motel

1736 GULF TO BAY BLVD, CLEARWATER 33755

Inspection Date: 03/30/2021

Inspection Number: 1215257

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back - Complied

Inspector Name: BENEDICT, TRACY

Violation CodeObservationViolation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to unit 29 - From follow-up inspection 2021-03-30: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6204367

WISNIOWSKI

License Type: Apartment

304 S HERCULES AVE, CLEARWATER 33765

Inspection Date: 03/30/2021

Inspection Number: 1497782

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BENEDICT, TRACY

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Next to unit 2

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6900381

OPAL HOTEL & SUITES

License Type: Motel

230 W SR 436, ALTAMONTE SPRINGS 32714

Inspection Date: 04/01/2021

Inspection Number: 1214702

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MARTIN, LESLIE

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
 -extinguisher missing from box on 2nd level balcony by room 232.
 -extinguisher in guest laundry room not in designated location.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6903992

THE WESTIN LAKE MARY, ORLANDO NORTH

License Type: Hotel

2974 INTERNATIONAL PKWY, LAKE MARY 32746

Inspection Date: 04/01/2021

Inspection Number: 1158837

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GUTTERMAN, KENNETH

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6602284

MAINSTAY SUITES AT PGA VILLAGE PORT ST LUCIE

License Type: Hotel

85801 CHAMPION WAY, PORT ST LUCIE 34986

Inspection Date: 04/02/2021

Inspection Number: 1158914

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: HYNES, MONICA

Violation CodeObservationViolation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable.
For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6602518

HILTON GARDEN INN AT PGA VILLAGE

License Type: Hotel

8540 COMMERCE CENTRE DR, PORT ST LUCIE 34986

Inspection Date: 04/01/2021

Inspection Number: 1157823

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HYNES, MONICA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7401678		HERITAGE INN	
License Type: Motel		1100 S RIDGEWOOD AVE, DAYTONA BEACH 32114	
Inspection Date: 03/29/2021	Inspection Number: 1216726	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LARSON, SARAH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-03-4	Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Room 7.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7400051		DAYS INN SPEEDWAY	
License Type: Motel		2904 W INTL SPEEDWAY BLVD, DAYTONA BEACH 32124	
Inspection Date: 03/31/2021	Inspection Number: 1214135	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-04-4	Gas can and pressure cleaner with gas stored inside the building storage shop by electric panels .For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7400969		TRIANGLE MOTEL	
License Type: Motel		5080 S RIDGEWOOD AVE, PORT ORANGE 32127	
Inspection Date: 03/29/2021	Inspection Number: 1212950	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-04-4	Gas can with gas stored inside the water heater room. For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7406336		ASHTON POINT APARTMENTS	
License Type: Apartment		6305 WILLIAMSON BLVD, PORT ORANGE 32128	
Inspection Date: 03/29/2021	Inspection Number: 1509469	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Memory light on building 8. **Corrected On-Site**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Volusia County

License Number: 7403776

ALL SUITE MOTEL

License Type: Apartment

335 N RIDGEWOOD AVE, EDGEWATER 321321648

Inspection Date: 03/30/2021

Inspection Number: 1502678

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: PICHARDO, RENEE

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location guest laundry room. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406522

OM HOSPITALITY OF DELTONA LLC

License Type: Motel

481 DELTONA BLVD, DELTONA 32725

Inspection Date: 03/30/2021

Inspection Number: 1214956

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back - Complied

Inspector Name: ANGEL, TERRY

Violation CodeObservationViolation Citation

02-04-4

- From initial inspection : Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. Maintenance shop. - From follow-up inspection 2021-03-30: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.