

Alachua County

License Number: 1102962		AC HOTEL BY MARRIOTT GAINESVILLE	
License Type: Hotel		151 NW 14 ST, GAINESVILLE 32603	
Inspection Date: 04/15/2021	Inspection Number: 1157198	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CASEY, KEITH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-06-4	Combustibles stored in boiler room. For reporting purposes only. Observed 2 propane tanks in the downstairs boiler room. These were removed. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1100264		COLLEGE PARK APTS	
License Type: Apartment		1716 NW 3 AVE, GAINESVILLE 326031865	
Inspection Date: 04/15/2021	Inspection Number: 1504598	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: FRANCO, RICHARD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Fire extinguisher missing from fire extinguisher box in hallway of building with units 9-16.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1100198		COLLEGIATE COURTYARD	
License Type: Apartment		1710 NW 2 AVE, GAINESVILLE 326031879	
Inspection Date: 04/15/2021	Inspection Number: 1507077	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: FRANCO, RICHARD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Fire extinguishers missing from designated locations at entrance next to unit 5 and unit 25.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1100155		CLASSIC INN	
License Type: Motel		14925 NE US 301 S, WALDO 32694	
Inspection Date: 04/13/2021	Inspection Number: 1216495	Inspection Type: Complaint Full	Inspection Disposition: Call Back - Extension given, pending
Inspector Name: DOTY, JOSEPH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-05-4	- From initial inspection : No smoke detector provided in guest room/unit. For reporting purposes only. Person in charge tested smoke in room 1, smoke detector not working - From follow-up inspection 2021-04-13: At Callback: room 1 occupied until May 2, 2021 **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Brevard County

License Number: 1500173

INTERNATIONAL PALMS RESORT & CONFERENCE CENTER COCOA BEACH

License Type: Motel

1300 N ATLANTIC AVE, COCOA BEACH 32931

Inspection Date: 04/14/2021

Inspection Number: 1216067

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: HICKS, GEORGE RANDY

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By housekeeping room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1500324

MOTEL 6 #069

License Type: Motel

3701 N ATLANTIC AVE, COCOA BEACH 32931

Inspection Date: 04/16/2021

Inspection Number: 1215940

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HICKS, GEORGE RANDY

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher between 123-124

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1604617 GARSAM TERRACE APARTMENTS
 License Type: Apartment 701 NE 10 ST, HALLANDALE 33009-2540

Inspection Date: 04/16/2021 Inspection Number: 1490783 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: GANPAT, INDAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Next to unit 103 **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1600660 OCEANSIDE MOTEL
 License Type: Motel 315 CLEVELAND ST, HOLLYWOOD 33019

Inspection Date: 04/12/2021 Inspection Number: 1215684 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: LONDONO, GLORIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-03-4	Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Room 1409	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1602282 HOLLYWOOD BEACH HOTELS- SEAGUL
 License Type: Motel 1915 N OCEAN DR, HOLLYWOOD 33019

Inspection Date: 04/15/2021 Inspection Number: 1215688 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LONDONO, GLORIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-03-4	Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Room # 402	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620884 SEA TURTLE
 License Type: Motel 315 ROOSEVELT ST, HOLLYWOOD 33019

Inspection Date: 04/12/2021 Inspection Number: 1215703 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: LONDONO, GLORIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-03-4	Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. -Corridor and living room, unit # 102 - kitchen, and sleeping room, unit # 107	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620918 1901 DEWEY ST
 License Type: Apartment 1901 DEWEY ST, HOLLYWOOD 33020

Inspection Date: 04/12/2021 Inspection Number: 1491704 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SMITH, CORETTA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Between apt 3-4.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621163 SW - HOLLYWOOD LLC
 License Type: Apartment 1902 DEWEY ST, HOLLYWOOD 33020

Inspection Date: 04/13/2021 Inspection Number: 1496542 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTINEZ, RHEANNE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed at fire extinguisher across from unit #6.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621205 MOSAIC AT MIRAMAR TOWN CENTER
 License Type: Apartment 11575 CITY HALL PROMENADE SUITE 100, MIRAMAR 33025

Inspection Date: 04/15/2021 Inspection Number: 1511674 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: NEALY, VALENCIA Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. -Observed Fire extinguisher in recharge zone: Building 3, unit 513 -Building 3, Unit 412. -Observed Fire extinguisher in overcharge zone, building 4, across from unit 370.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1602179 FORT LAUDERDALE MARRIOTT POMPANO BEACH
 License Type: Hotel 1200-1208 N OCEAN BLVD, POMPANO BEACH 33062

Inspection Date: 04/14/2021 Inspection Number: 1158146 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: BURGRABE, BROCK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. At main panel and behind front desk office panel.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620672		AVANA BAYVIEW	
License Type: Apartment		1631 S FEDERAL HWY, POMPANO BEACH 33062	
Inspection Date: 04/14/2021	Inspection Number: 1492185	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, DENNIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1620722		BAYSHORE VILLAS	
License Type: Motel		538 BAYSHORE DR, FORT LAUDERDALE 33304	
Inspection Date: 04/14/2021	Inspection Number: 1216634	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SEVILLA, FREDDY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell right side of the building . For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1620869		TRANQUILO HOTEL	
License Type: Motel		725 N BIRCH RD, FORT LAUDERDALE 33304	
Inspection Date: 04/15/2021	Inspection Number: 1216411	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, DENNIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only. Fire extinguisher are expired	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1620878		TARA HOTEL	
License Type: Motel		524 BAYSHORE DR, FORT LAUDERDALE 33304	
Inspection Date: 04/14/2021	Inspection Number: 1216635	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SEVILLA, FREDDY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. North side of the building.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Broward County

License Number: 1620914 ROLO BEACH HOTEL
 License Type: Hotel 701-709 ORTON AVE, FORT LAUDERDALE 33304

Inspection Date: 04/15/2021 Inspection Number: 1158418 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only. fire extinguisher expired	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1604111 TRAVELODGE
 License Type: Motel 1251 E SUNRISE BLVD, FORT LAUDERDALE 33304-2810

Inspection Date: 04/14/2021 Inspection Number: 1215294 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: BRANN, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By unit 218.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1603330 BEACHSIDE VILLAGE RESORT
 License Type: Motel 4553 EL MAR DR, LAUDERDALE-BY-THE-SE 33308

Inspection Date: 04/14/2021 Inspection Number: 1216201 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: FEIGELES, MITCHELL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher across from Chatham Suite door pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1617062 PARK APTS
 License Type: Apartment 525 NW 2 AVE, FORT LAUDERDALE 33311

Inspection Date: 04/16/2021 Inspection Number: 1501395 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FEIGELES, MITCHELL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher across from apartment 123. Manager provided proof of contact to have extinguisher recharged. **Corrective Action Taken**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621254 BLU 84 LLC
 License Type: Apartment 1401 MARINA MILE BLVD, FORT LAUDERDALE 33315

Inspection Date: 04/16/2021 Inspection Number: 1494974 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: EVANS, EUGENE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By 304, manager replaced **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1617319 COURTYARD MARRIOTT
 License Type: Hotel 440 S SEABREEZE BLVD, FORT LAUDERDALE 33316

Inspection Date: 04/17/2021 Inspection Number: 1159012 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: EVANS, EUGENE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. All certificates expired 8/4/2019	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621370 SPECIAL K INVESTMENTS LLC
 License Type: Apartment 5941 NE 18 AVE, FORT LAUDERDALE 33334

Inspection Date: 04/15/2021 Inspection Number: 1491989 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GOODWIN, NICHOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Located outside of unit 1	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2101761

COMFORT INN & EXECUTIVE SUITES

License Type: Motel

3860 TOLL GATE BLVD, NAPLES 34114

Inspection Date: 04/16/2021

Inspection Number: 1214123

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: PICO, JORGE

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Observed boiler certificate expired
FL 055358. Exp. 01-08-2020 **Warning**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Columbia County

License Number: 2200384

DREAM INN

License Type: Motel

13771 S US HWY 441, LAKE CITY 32025

Inspection Date: 04/16/2021

Inspection Number: 1215115

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Between rooms 149 and 147. Back building. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328381

OCEAN MAR PARK APARTMENTS

License Type: Apartment

1200 W 25 PL, HIALEAH 33010

Inspection Date: 04/13/2021

Inspection Number: 1501446

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: PRIETO, EDGAR

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Building #1200 by apartment 3.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2324625

J X & SON'S LLC

License Type: Apartment

1127 NE 1 AVE, HOMESTEAD 33030

Inspection Date: 04/14/2021

Inspection Number: 1490848

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: AZPURUA, JULIO

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed trouble light at panel next to unit #5

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2307286

MARIA T ALVARADO

License Type: Apartment

1346 NW 6 ST, MIAMI 33125

Inspection Date: 04/02/2021

Inspection Number: 1511368

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Observed missing breaking device in fire extinguisher boxes at the right alley of the building.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330199

ANNE ENTERPRISES LLC

License Type: Apartment

254 NW 36 ST APT A, MIAMI 33127

Inspection Date: 04/14/2021

Inspection Number: 1494648

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher in needs of charge (fire extinguisher located on unit B)

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2301233		VILLA LOURDES	
License Type: Apartment		337 SW 5 AVENUE, MIAMI 33130	
Inspection Date: 04/13/2021	Inspection Number: 1502706	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CABANAS, NATALIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2316565		VILLA ELENA APARTMENTS	
License Type: Apartment		636 SW 6 STREET, MIAMI 33130	
Inspection Date: 04/15/2021	Inspection Number: 1507625	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. On 1st floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2330310		1134 APT LLC	
License Type: Apartment		1134 SW 4 ST, MIAMI 33130	
Inspection Date: 04/13/2021	Inspection Number: 1501965	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: VILCHEZ, NABEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Next to apartment 9 second floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2301745		1235 APARTMENTS	
License Type: Apartment		1235 SW 6 ST, MIAMI 331354053	
Inspection Date: 04/14/2021	Inspection Number: 1499843	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed missing breaking device in extinguisher box by unit 1.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2302791		1745 NW 1 PL LLC	
License Type: Apartment		1745 NW 1 PL, MIAMI 33136	
Inspection Date: 04/14/2021	Inspection Number: 1506286	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2303085		7ST LLC	
License Type: Apartment		1000 7 ST, MIAMI BEACH 33139	
Inspection Date: 04/13/2021	Inspection Number: 1508748	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Second floor. - From follow-up inspection 2021-04-13: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329420		NEW AGE 2012 LLC	
License Type: Hotel		807 ALTON RD, MIAMI BEACH 33139	
Inspection Date: 04/15/2021	Inspection Number: 1158398	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329460		17 WEST	
License Type: Hotel		1220 17TH STREET, MIAMI BEACH 33139	
Inspection Date: 04/12/2021	Inspection Number: 1158042	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329562		GINGER HOLDINGS320, LLC	
License Type: Apartment		320-330 84TH STREET, MIAMI BEACH 33141	
Inspection Date: 04/13/2021	Inspection Number: 1511806	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329990		THE MILE CORAL GABLES	
License Type: Apartment		3622 CORAL WAY, MIAMI 33145	
Inspection Date: 04/14/2021	Inspection Number: 1494944	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2301713		REALBIZ MANAGEMENT LLC	
License Type: Apartment		17080 NE 23 AVE, NORTH MIAMI BEACH 33160	
Inspection Date: 04/12/2021	Inspection Number: 1510088	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to apt 3.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Duval County

License Number: 2600296		MIDTOWN LODGE	
License Type: Motel		4141 PHILLIPS HWY, JACKSONVILLE 32207	
Inspection Date: 04/13/2021	Inspection Number: 1215296	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: JEFFERS, MARY-BETH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-03-4	- From initial inspection : Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Smoke detector in room #263 in disrepair/ unit damaged and appear to be inoperable - From follow-up inspection 2021-04-13: At callback still the same. Time needed to replace **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2600595		REGENCY INN	
License Type: Motel		6237 ARLINGTON EXPY, JACKSONVILLE 32211	
Inspection Date: 04/13/2021	Inspection Number: 1216839	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: THOMAS, PHILIP			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Fire extinguisher missing from marked fire box between rooms 103 and 104. Operator supplied extinguisher **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2603661		TRAVELODGE INN & SUITES	
License Type: Motel		1153 AIRPORT RD, JACKSONVILLE 32218	
Inspection Date: 04/15/2021	Inspection Number: 1216845	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: PERRY, DENNIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Missing by 116/118. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2603603		ONE OCEAN RESORT HOTEL & SPA	
License Type: Hotel		1 OCEAN BLVD, ATLANTIC BEACH 32233	
Inspection Date: 04/09/2021	Inspection Number: 1158422	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ESPINOSA-BECKERT, ILIANA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-04-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. 6 in maintenance shop	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Hendry County

License Number: 3600024

RELAX INN

License Type: Motel

820 E SUGARLAND HWY, CLEWISTON 33440

Inspection Date: 04/12/2021

Inspection Number: 1215430

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRADY, OSSIAN

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

Between units 107 and 108.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913977

OAKS AT UNIVERSITY APARTMENTS - PARCEL 2

License Type: Apartment

1514 EAST 140TH AVE, TAMPA 33613

Inspection Date: 04/12/2021

Inspection Number: 1511619

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: REGAS, ANTHONY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed at apartment 1513. Manager called for replacement. **Corrective Action Taken**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4602772 LAQUINTA INN & SUITES #2039
 License Type: Hotel 20091 SUMMERLIN RD, FORT MYERS 33908

Inspection Date: 04/15/2021 Inspection Number: 1159002 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: REED, RICARDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4701524

MELROSE APARTMENTS

License Type: Apartment

1533 S BRONOUGH ST, TALLAHASSEE 32301

Inspection Date: 04/12/2021

Inspection Number: 1499566

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GOSAI, MATT

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher in recharge zone. Outside unit E. Second floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4703181

CASANAS VILLAGE

License Type: Apartment

448 W GEORGIA ST, TALLAHASSEE 32301

Inspection Date: 04/12/2021

Inspection Number: 1492294

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation CodeObservationViolation Citation

04-07-4

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.
Fire panel shows trouble for battery charger to system.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4700428

TALLA VILLA APARTMENTS

License Type: Apartment

925 E MAGNOLIA DR, TALLAHASSEE 323016686

Inspection Date: 04/12/2021

Inspection Number: 1506176

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: GRODEWALD, PAUL

Violation CodeObservationViolation Citation

04-05-4

No smoke detector provided in guest room/unit. For reporting purposes only.
Smoke alarms missing from apartments P1 and K4.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400459

HAVANA CABANA

License Type: Motel

3420 N ROOSEVELT BLVD, KEY WEST 33040

Inspection Date: 04/13/2021

Inspection Number: 1213424

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Corrected On-Site****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5810574 TOWNEPLACE SUITES BY MARRIOTT
 License Type: Hotel 11801 HIGH TECH AVE, ORLANDO 328171490

Inspection Date: 04/14/2021 Inspection Number: 1158197 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: JENKINS, JOSHUA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
05-02-5	- From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. - From follow-up inspection 2021-04-14: Test button on detectors in rooms 315 316, 410 not working. Room 324 detectors not fully functional. **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5809167 LA QUINTA INN & SUITES UCS #180
 License Type: Hotel 11805 RESEARCH PKWY, ORLANDO 32826

Inspection Date: 04/16/2021 Inspection Number: 1158096 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: JENKINS, JOSHUA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
05-02-5	- From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. - From follow-up inspection 2021-04-16: Newly ordered hearing impaired smoke detector is missing wall outlet cord. Battery operation does work, however, strobe will not work without AC power, according to manufacturer. Recommend getting new detector with wall cord. **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900225

SERALAGO HOTEL AND SUITES MAINGATE EAST

License Type: Hotel

5678 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 04/13/2021

Inspection Number: 1158908

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: LORENZO, ANA

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. ****Repeat Violation**** - From follow-up inspection 2021-04-13: ****Time Extended****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5912072

WYNDHAM ORLANDO RESORT & CONFERENCE CENTER, CELEBRATION AREA

License Type: Hotel

3011 MAINGATE LN, KISSIMMEE 34747

Inspection Date: 04/14/2021

Inspection Number: 1158087

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: YOUNG, COLIN

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

133406, 098107 exp. 07/03/2020

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6201054		BROOKSIDE SQUARE APARTMENTS	
License Type: Apartment		200 72 AVE N, ST. PETERSBURG 33702	
Inspection Date: 04/15/2021	Inspection Number: 1508655	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LOZANO, KELVIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to 13-265	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6205544		TARA HOUSE APARTMENTS (THE)	
License Type: Apartment		484 N 75 AVE, ST. PETERSBURG 33702	
Inspection Date: 04/13/2021	Inspection Number: 1497264	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: LOZANO, KELVIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In front of unit 424-102 near stairway. Outside of office building 460	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6215820		BERKELEY BEACH CLUB LLC	
License Type: Hotel		109 8 AVE, ST PETE BEACH 33706	
Inspection Date: 04/14/2021	Inspection Number: 1158157	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: DAY-WALKER, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Yellow trouble light illuminated on fire panel.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6203219		SIRATA BEACH RESORT	
License Type: Motel		5300 GULF BLVD, ST.PETE BEACH 33706	
Inspection Date: 04/15/2021	Inspection Number: 1211891	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DAY-WALKER, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Yellow trouble lights illuminated on fire panel in front office.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Pinellas County

License Number: 6211956

KENWOOD INN

License Type: Motel

451 34 ST N, ST. PETERSBURG 33713

Inspection Date: 04/16/2021

Inspection Number: 1213833

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: HOBBS, ANDREW

Violation CodeObservationViolation Citation

01-05-4

- From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only. No strikers on any fire extinguishers. - From follow-up inspection 2021-03-17: No strikers observed **Time Extended** - From follow-up inspection 2021-04-01: No strikers present on locked boxes - From follow-up inspection 2021-04-16: No strikers on fire extinguisher boxes **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6204851

MADISYN ON PARK LLC

License Type: Apartment

1410 PARK ST, CLEARWATER 33755

Inspection Date: 04/12/2021

Inspection Number: 1495722

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: HIRST, DAN

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Extinguisher on first floor of second building between apartments 9 and 11.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216010

1 SHORE INVESTMENTS LLC

License Type: Apartment

1495 DREW ST, CLEARWATER 33755

Inspection Date: 04/12/2021

Inspection Number: 1494319

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: BENEDICT, TRACY

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215981

WINDTREE VILLAS

License Type: Apartment

15001A VERONA AVE, CLEARWATER 33760

Inspection Date: 04/12/2021

Inspection Number: 1493978

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WILMOT, TASHARA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
-at building 15016

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6214076		EXTENDED STAY HOTELS	
License Type: Motel		2311 ULMERTON RD, CLEARWATER 33762	
Inspection Date: 04/15/2021	Inspection Number: 1216259	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LANTIGUA, ROBERTO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 6214166		EXTENDED STAY AMERICA #303	
License Type: Hotel		3089 EXECUTIVE DR, CLEARWATER 33762	
Inspection Date: 04/15/2021	Inspection Number: 1158413	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LANTIGUA, ROBERTO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Facing elevator in 2nd floor	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 6215912		COURTYARD GARDENVIEW APARTMENTS	
License Type: Apartment		403-405 S CIRUS AVE, CLEARWATER 33765	
Inspection Date: 04/12/2021	Inspection Number: 1494596	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BENEDICT, TRACY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. All fire extinguisher on building 405 are covered and taped off	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Polk County

License Number: 6303266

IMPERIAL SWAN HOTEL & SUITES

License Type: Hotel

4141 S FLORIDA AVE, LAKELAND 33813

Inspection Date: 04/16/2021

Inspection Number: 1158469

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: BEAULIEU, STEPHANIE

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
074517 expired 5-14-2020. Front desk rep said inspector came by today and will certify boiler ****Repeat Violation**** - From follow-up inspection 2021-01-26:
****Time Extended**** - From follow-up inspection 2021-03-15: ****Time Extended****
- From follow-up inspection 2021-04-16: ****Time Extended****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Putnam County

License Number: 6400783

WOODLAND POINT APARTMENTS

License Type: Apartment

6710 ST JOHNS AVE, PALATKA 32177

Inspection Date: 04/12/2021

Inspection Number: 1506893

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: DOTY, JOSEPH

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
 Trouble light blinking on panel, building 5E.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6902128

HILTON ALTAMONTE

License Type: Hotel

350 S NORTHLAKE BLVD, ALTAMONTE SPRINGS 32701

Inspection Date: 04/12/2021

Inspection Number: 1158210

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MARTIN, LESLIE

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
-3 boiler certificates posted expired 1/23/21.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6902155

THE PARK AT RAVELLO

License Type: Apartment

401 W SEMINOLE BLVD, SANFORD 32771

Inspection Date: 04/16/2021

Inspection Number: 1501227

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: ANGEL, TERRY

Violation CodeObservationViolation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Building I. Notified Dan Taylor, Sanford Fire Inspector. 407-562-2788. Voice Mail. - From follow-up inspection 2021-02-16:
- From follow-up inspection 2021-04-16:

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Walton County

License Number: 7601853

WATERCOLOR INN AND RESORT

License Type: Hotel

34 GOLDENROD CIR, SANTA ROSA BEACH 32459

Inspection Date: 04/14/2021

Inspection Number: 1157915

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILSON, MISTY

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
135382 - 07-12-21 certification unavailable.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.