

Alachua County

License Number: 1100086

THE TOWERS

License Type: Apartment

207 NW 17 ST, GAINESVILLE 326031856

Inspection Date: 04/20/2021

Inspection Number: 1509509

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FRANCO, RICHARD

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
Missing hammer for locked fire extinguisher box at laundry room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bay County

License Number: 1300977

TURTLE LAKE APARTMENTS

License Type: Apartment

4324 W 20TH STREET, PANAMA CITY 32405

Inspection Date: 04/21/2021

Inspection Number: 1511757

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Outside unit L318

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620883		OCEAN POINTE HOLLYWOOD, LLC	
License Type: Motel		415 SOUTH OCEAN DRIVE, HOLLYWOOD 33019	
Inspection Date: 04/19/2021	Inspection Number: 1216081	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: KAMM, DARYL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
05-02-5	Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1621619		AOME #1	
License Type: Apartment		11401 NW 45TH ST., CORAL SPRINGS 33065	
Inspection Date: 04/20/2021	Inspection Number: 1512037	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MONTILLA, NATHALIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to apartment 11403	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1620706		BLUE PARROT INN	
License Type: Apartment		2617 NE 13 CT, FORT LAUDERDALE 33304	
Inspection Date: 04/19/2021	Inspection Number: 1504485	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: BRANN, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. NE corner by Apt 4.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1617319		COURTYARD MARRIOTT	
License Type: Hotel		440 S SEABREEZE BLVD, FORT LAUDERDALE 33316	
Inspection Date: 04/17/2021	Inspection Number: 1159012	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: EVANS, EUGENE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. All certificates expired 8/4/2019	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Broward County

License Number: 1621622

VILLA TERESA

License Type: Apartment

601-607 NE 29TH DR, WILTON MANORS 33334

Inspection Date: 04/21/2021

Inspection Number: 1511838

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BENJAMIN, ALEXANDER

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Building 607 next to unit 20

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2100395 BISCAYNE APARTMENTS
 License Type: Apartment 4960 BISCAYNE DR, NAPLES 34112

Inspection Date: 04/23/2021 Inspection Number: 1490821 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PICO, JORGE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher by apartment 4960 in the recharge zone	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2100965 TANY CO LLC
 License Type: Apartment 4058 BAYSHORE DR, NAPLES 34112

Inspection Date: 04/23/2021 Inspection Number: 1509121 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PICO, JORGE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed fire extinguisher at building 4060 by apartment 605, building 4062 by apartment 642, missing the hammer to break the glass	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2100215 PAL ENTERPRISES LLC
 License Type: Apartment 529 TALLWOOD ST, MARCO ISLAND 34145

Inspection Date: 04/22/2021 Inspection Number: 1508801 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CUDEMOS, VIRNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Near apartment #3. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2320673		BUDGET HOST INN	
License Type: Motel		815 N KROME AVE, FLORIDA CITY 33034	
Inspection Date: 04/22/2021	Inspection Number: 1216864	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: AZPURUA, JULIO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2330589		1940 WASHINGTON LLC	
License Type: Apartment		1940 WASHINGTON AVE, OPA-LOCKA 33054	
Inspection Date: 04/20/2021	Inspection Number: 1512019	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Missing fire extinguisher by unit 14.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329202		FAIRFIELD INN & SUITES MIAMI SOUTH	
License Type: Hotel		4101 NW 11 ST, MIAMI 33126	
Inspection Date: 04/22/2021	Inspection Number: 1157270	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: SANCHEZ, JAVIER			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2306501		LAS PALMAS APTS	
License Type: Apartment		501 SW 7 CT, MIAMI 33130	
Inspection Date: 04/12/2021	Inspection Number: 1493355	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: CABANAS, NATALIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2328824		HAVANA MIAMI APTS	
License Type: Apartment		826 SW 3 STREET, MIAMI 33130	
Inspection Date: 04/16/2021	Inspection Number: 1500304	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to apt under apt 5.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329832		WEST BRICKELL LODGING HOUSE	
License Type: Apartment		202 SW 7 AVE, MIAMI 33130	
Inspection Date: 04/23/2021	Inspection Number: 1508550	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CRUZ, EDGAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2324851		YVE HOTEL MIAMI	
License Type: Hotel		146 BISCAYNE BLVD, MIAMI 33132	
Inspection Date: 04/21/2021	Inspection Number: 1156860	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: PAGAN, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certification expired, 094175/094176 exp 5/8/20 **Repeat Violation** - From follow-up inspection 2021-04-21:	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2320639		DOUBLETREE GRAND HOTEL (THE)	
License Type: Hotel		1717 N BAYSHORE DR, MIAMI 331321180	
Inspection Date: 04/19/2021	Inspection Number: 1158612	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PAGAN, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329717

711 BEACOM APARTMENTS

License Type: Apartment

711 BEACOM BLVD, MIAMI 33135

Inspection Date: 04/19/2021

Inspection Number: 1505986

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Second and first floor extinguisher.
Repeat Violation **Admin Complaint**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2325586

GIBSON COVE PROPERTIES LLC

License Type: Apartment

1118 - 1126 NW 1 CT, MIAMI 33136

Inspection Date: 04/22/2021

Inspection Number: 1508994

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: TAYLOR, JOHN

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Located next to apt 2 in building 1118 and next to apt 2 and apt 5 in building 1126.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2305236

COLONY HOTEL

License Type: Hotel

736 OCEAN DRIVE, MIAMI BEACH 33139

Inspection Date: 04/20/2021

Inspection Number: 1158571

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: URIBE, GUISELLA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2305372

CHESTERFIELD / LEON / LILY HOTELS

License Type: Hotel

855 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 04/20/2021

Inspection Number: 1159030

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
Across from room 515 and 402

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2305624

THE STILES HOTEL

License Type: Hotel

1120 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 04/21/2021

Inspection Number: 1158722

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329301

HOTEL COLORETTA

License Type: Hotel

355 WASHINGTON, MIAMI BEACH 33139

Inspection Date: 04/21/2021

Inspection Number: 1156498

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329456 WEST AVENUE
 License Type: Hotel 1323-1327 WEST AVE, MIAMI BEACH 33139

Inspection Date: 04/19/2021 Inspection Number: 1157465 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed fire extinguisher missing near room 1 building 1323.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329573 WHITELAW HOTEL SOUTH BEACH LLC
 License Type: Apartment 820 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 04/20/2021 Inspection Number: 1498465 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2306670 SURFCOMBER HOTEL (THE)
 License Type: Hotel 1717 COLLINS AVE, MIAMI BEACH 331392081

Inspection Date: 04/14/2021 Inspection Number: 1158987 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel located behind front desk. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Exp. 07/19/2020 - From follow-up inspection 2021-04-14: Observed boiler jurisdiction number's 133023; 133024; 121685 All expir	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inpector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. Observed boiler jurisdiction number's 133023; 133024; 121685 All expired on 7/19/2020. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inpector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329265 NEW POINT MIAMI
 License Type: Hotel 5445 COLLINS AVE STE CU 15, MIAMI BEACH 33140

Inspection Date: 04/19/2021 Inspection Number: 1156923 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. One of the boiler has the certificate already expired since 3/6/2020.(FL 092741) - From follow-up inspection 2021-04-19:	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inpector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329399		DESIGN SUITES MIAMI BEACH	
License Type: Hotel		5445 COLLINS AVE STE CU14, MIAMI BEACH 33140	
Inspection Date: 04/19/2021	Inspection Number: 1156467	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. One of the boiler has the certificate already expired since 3/6/2020.(FL 092741) - From follow-up inspection 2021-04-19:	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2330598		PIERRE ON THE BAY APTS	
License Type: Apartment		2050-2070 BAY DR, MIAMI BEACH 33141	
Inspection Date: 04/23/2021	Inspection Number: 1512087	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Missing breaking device in fire extinguisher box by unit 305.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2306730		SHERRY FRONTENAC HOTEL	
License Type: Hotel		6565 COLLINS AVE, MIAMI BEACH 331414613	
Inspection Date: 04/20/2021	Inspection Number: 1159027	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2307661		VENUS MOTEL	
License Type: Motel		6891 SW 8 ST, MIAMI 331444742	
Inspection Date: 04/20/2021	Inspection Number: 1214757	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MARTINEZ, YANET			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Located on first floor between unit 6 and 5.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Highlands County

License Number: 3800126		HUNNEWELL'S COTTAGES ON LAKE BRENTWOOD	
License Type: Motel		2060 US HWY 27 NORTH, AVON PARK 33825	
Inspection Date: 04/23/2021	Inspection Number: 1215700	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: PETROW, MICHAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
05-02-5	Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 3800384		LAKESIDE VILLAS	
License Type: Apartment		1680 N DELAWARE AVE, AVON PARK 33825	
Inspection Date: 04/22/2021	Inspection Number: 1506038	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: PETROW, MICHAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-04-4	No portable fire extinguisher observed on the premises. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 3800928		LAKE ISIS VILLAS APTS	
License Type: Apartment		1536 DELAWARE AVE, AVON PARK 33825	
Inspection Date: 04/22/2021	Inspection Number: 1503705	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PETROW, MICHAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-04-4	No portable fire extinguisher observed on the premises. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 3801003		SO GOOD BEER GARDEN CAFE & MOTEL	
License Type: Apartment		1458 CUMMINGS AVE, AVON PARK 33825	
Inspection Date: 04/22/2021	Inspection Number: 1508769	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PETROW, MICHAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Hillsborough County

License Number: 3913978		HERON RESIDENCES	
License Type: Apartment		815 WATER ST, TAMPA 33602	
Inspection Date: 04/19/2021	Inspection Number: 1511099	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: COLEMAN, TONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
12-04-4	High Priority - Balcony collapsed.	61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.	

License Number: 3905758		RODEWAY INN AND SUITES	
License Type: Motel		2904 MELBOURNE BLVD, TAMPA 33605	
Inspection Date: 04/21/2021	Inspection Number: 1216367	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: LOZANO, KELVIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. No means to break glass next to room 318, 341, 340, 320	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 3912109		HILTON GARDEN INN - TAMPA YBOR HISTORIC DISTRICT	
License Type: Hotel		1700 E 9 AVE, TAMPA 33605	
Inspection Date: 04/22/2021	Inspection Number: 1159040	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LOZANO, KELVIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expiration 03/08/2020. Per operator new certificates have come in the mail but chief engineer has copies and is not present.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 3902786		TAMPA 8 INN	
License Type: Motel		4530 E COLUMBUS DR, TAMPA 336053235	
Inspection Date: 04/21/2021	Inspection Number: 1216349	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LOZANO, KELVIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Next to 108, no means to break glass.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Lee County

License Number: 4605688 DL PROPERTY FUNDING LLC
 License Type: Apartment 3236 DORA ST, FORT MYERS 33916

Inspection Date: 04/23/2021 Inspection Number: 1509883 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FREED, JOSEPH Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4700124		MAISON DEVILLE	
License Type: Apartment		504 BEVERLY ST, TALLAHASSEE 32301	
Inspection Date: 04/19/2021	Inspection Number: 1506163	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PERRY, DENNIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 4700600		WINDRUSH VILLAGE APARTMENTS	
License Type: Apartment		410 VICTORY GARDEN DR, TALLAHASSEE 32301	
Inspection Date: 04/19/2021	Inspection Number: 1503728	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: PERRY, DENNIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only. Missing in laundry room next to office.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
07-01-4	Damaged electrical wire(s). For reporting purposes only. Large main wire on side of building near unit 105. At end of inspection, inspector found two workers at site and were attempting to repair. **Corrective Action Taken**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 4703064		BLUE CASCADE	
License Type: Apartment		400 PUTNAM DR, TALLAHASSEE 32301	
Inspection Date: 04/22/2021	Inspection Number: 1494039	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: PERRY, DENNIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
07-01-4	Damaged electrical wire(s). For reporting purposes only. Wires hanging down by unit 1023.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Madison County

License Number: 5000144

MADISON SQUARE APARTMENTS

License Type: Apartment

643 W BASE ST, MADISON 32340

Inspection Date: 04/19/2021

Inspection Number: 1506521

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: JEFFERS, MARY-BETH

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.
Light fixture and wiring in disrepair near building 4 A-b

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811120

HILTON ORLANDO

License Type: Hotel

6001 DESTINATION PWKY, ORLANDO 32819

Inspection Date: 04/21/2021

Inspection Number: 1159004

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BACHOO, SAVITRI

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5800476

CONTEMPORARY RESORT HTL

License Type: Hotel

4600 N WORLD DR, BAY LAKE 32830

Inspection Date: 04/23/2021

Inspection Number: 1158800

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back - Extension given, pending

Inspector Name: BACHOO, SAVITRI

Violation CodeObservationViolation Citation

05-02-5

- From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Room 4904. - From follow-up inspection 2021-04-23: Room 4904 is occupied. Operator will have the room vacant 4/28/21. Time Extend

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5808761

FAIRFIELD INN & SUITES BY MARRIOTT ORLANDO LAKE BUENA VISTA

License Type: Hotel

12191 S APOPKA VINELAND RD, ORLANDO 32836

Inspection Date: 04/19/2021

Inspection Number: 1158960

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Boiler certification has expired 6/15/2020 135342,135341 **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6013279

COURTYARD BY MARRIOTT WEST PALM BEACH AIRPORT

License Type: Hotel

1800 CENTRE PARK DR E, WEST PALM BEACH 33401

Inspection Date: 04/19/2021

Inspection Number: 1158684

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: LANZALOTTO, JR

Violation CodeObservationViolation Citation

04-01-4

- From initial inspection : Observed: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Unit is giving trouble signs due to faulty equipment. Work order has been put in.
Priority: Reporting - From follow-up

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

- From initial inspection : Observed: Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Both boiler certificates expired on 1-10-2020 Priority: Reporting - From follow-up inspection 2021-04-19: Establishm

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6005016

TORRECILLA APARTMENTS

License Type: Apartment

300 NE 1 ST, BELLE GLADE 33430-3151

Inspection Date: 04/20/2021

Inspection Number: 1500735

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: SEVILLA, FREDDY

Violation CodeObservationViolation Citation

06-03-4

- From initial inspection : Marked exit is inaccessible. For reporting purposes only.
NW corner first floor apartment 6 window cover with plywood .
NE corner first floor apartment 9 window cover with plywood.
Windows are considered emergency exits.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6100017

SADDLEBROOK RESORTS CONDO

License Type: Vacation Rental - Condo

5700 SADDLEBROOK WAY, WESLEY CHAPEL 335434411

Inspection Date: 04/20/2021

Inspection Number: 1088432

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: COLE, GABRIELLE

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By Building 3, Room 352.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6214797 DARTMOOR HOUSE
 License Type: Apartment 471 9TH AVE NORTH, ST PETERSBURG 33701

Inspection Date: 04/22/2021 Inspection Number: 1502853 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: THORNCROFT, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher at apt 1 on the first floor	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216095 DOWNTOWN ST PETE APARTMENTS
 License Type: Apartment 535 2 ST N, ST. PETERSBURG 33701

Inspection Date: 04/22/2021 Inspection Number: 1506910 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: THORNCROFT, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Inside the hall way of 549#4 fire extinguisher is in the red	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
02-08-4	Pile of wood from repairs stored under the stairs in the back of building 549	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6205313 SSE APARTMENTS LLC
 License Type: Apartment 2827 DR. M.L.K. JR. STREET NORTH, SANT PETERSBURG 33704

Inspection Date: 04/20/2021 Inspection Number: 1492462 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LOZANO, KELVIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. No means to break glass sealing fire extinguisher next to unit 3 and 8.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6202405 SPENCER RECOVERY CENTER
 License Type: Apartment 601 71 AVE, ST PETERSBURG BCH 337063609

Inspection Date: 04/23/2021 Inspection Number: 1502627 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HARROD, JESSICA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Fire extinguisher on top floor	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6203632 SKYLARK MOTEL
 License Type: Motel 10149 GULF BLVD, TREASURE ISLAND 337064808

Inspection Date: 04/19/2021 Inspection Number: 1214132 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: DAY-WALKER, LISA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-02-4	- From initial inspection : Frayed electrical wire(s). For reporting purposes only. Frayed wires hanging from unit 1 light fixture. **Repeat Violation** - From follow-up inspection 2021-04-19: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6211956 KENWOOD INN
 License Type: Motel 451 34 ST N, ST. PETERSBURG 33713

Inspection Date: 04/19/2021 Inspection Number: 1213833 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: HOBBS, ANDREW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-05-4	- From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only. No strikers on any fire extinguishers. - From follow-up inspection 2021-03-17: No strikers observed **Time Extended** - From follow-up	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6212122 REGENCY OAKS
 License Type: Apartment 2751 REGENCY OAKS BLVD, CLEARWATER 33759

Inspection Date: 04/19/2021 Inspection Number: 1511147 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied
 Inspector Name: BENEDICT, TRACY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-04-4	- From initial inspection : Boiler certificate not posted in the boiler room. For reporting purposes only. Current boiler certification posted in boiler room are expired - From follow-up inspection 2021-04-19: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6210961

SUPER 8 - AIRPORT

License Type: Motel

13260 34TH STREET N, CLEARWATER 33762

Inspection Date: 04/19/2021

Inspection Number: 1216290

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: LANTIGUA, ROBERTO

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.
No sound

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216032

KEL PROPERTIES LLC

License Type: Apartment

614 BEVERLY AVE, LARGO 33770

Inspection Date: 04/22/2021

Inspection Number: 1496807

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: COLE, GABRIELLE

Violation CodeObservationViolation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6303266

IMPERIAL SWAN HOTEL & SUITES

License Type: Hotel

4141 S FLORIDA AVE, LAKE LAND 33813

Inspection Date: 04/21/2021

Inspection Number: 1159029

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BEAULIEU, STEPHANIE

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
 Certificate Expiration: 05/14/2020 **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Santa Rosa County

License Number: 6700995

PARK AVENUE APARTMENTS

License Type: Apartment

6593 PARK AVE, MILTON 32570

Inspection Date: 04/21/2021

Inspection Number: 1499433

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: ALBRITTON, GREGORY

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Building 6558
First Floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only.
Building 6548

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6701205

WILLOW TREE APARTMENTS

License Type: Apartment

6475 WILLOW TREE COURT, MILTON 32570

Inspection Date: 04/20/2021

Inspection Number: 1504423

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ALBRITTON, GREGORY

Violation CodeObservationViolation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only.
Building 6506

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.