

Bay County

License Number: 1303989

CASTLE MOTEL

License Type: Motel

20417 BACK BEACH RD, PANAMA CITY BCH 324133718

Inspection Date: 04/26/2021

Inspection Number: 1214006

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILSON, MISTY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1502671

ATLANTIC INN

License Type: Motel

2900 N HWY A1A, INDIALANTIC 329032145

Inspection Date: 04/29/2021

Inspection Number: 1215681

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: SCHOENLY, BARBARA

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.by room #106 -
From follow-up inspection 2021-04-29: Extinguisher still in recharge zone

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620908

NEPTUNE HOLLYWOOD BEACH HOTEL

License Type: Motel

310 MCKINLEY ST, HOLLYWOOD 33019

Inspection Date: 04/27/2021

Inspection Number: 1216905

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LONDONO, GLORIA

Violation CodeObservationViolation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.
Bedroom, unit 114

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable.
For reporting purposes only.
Living room , unit 114

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-01-4

Damaged electrical wire(s). For reporting purposes only.
Ceiling Lamp in dining room area, unit 114

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621626

MEDFORD N 17TH

License Type: Apartment

1720 N 17 AVE, HOLLYWOOD 33020

Inspection Date: 04/26/2021

Inspection Number: 1512108

Inspection Type: Lodging-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHRISTGEN, THOM

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes Fire extinguisher near unit 4.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2102728		925 CYPRESS DRIVE	
License Type: Apartment		2805 SHOREVIEW DR, NAPLES 34112	
Inspection Date: 04/28/2021	Inspection Number: 1493820	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: PICO, JORGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only. Observed no hammer to break the glass of the fire extinguisher box next to apartment 14.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2102729		BAYVIEW INN APARTMENTS	
License Type: Apartment		2800 BAYVIEW DR S, NAPLES 34112	
Inspection Date: 04/28/2021	Inspection Number: 1508328	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: PICO, JORGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed a fire extinguisher box without the hammer to break the glass between apartments 7 and 8	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2100020		CONTY'S MOTEL	
License Type: Motel		11238 E TAMIAMI TRAIL, NAPLES 34113	
Inspection Date: 04/29/2021	Inspection Number: 1214795	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: PICO, JORGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed the fire extinguisher box by room 3, missing the hammer to brake the glass.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2101713		NAPLES PLACE	
License Type: Apartment		6240-6256 RATTLESNAKE HAMMOCK RD, NAPLES 34113	
Inspection Date: 04/28/2021	Inspection Number: 1499340	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PICO, JORGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed fire extinguisher box by apartment 6242 , 6252, 6256 , missing the hammer to break the glass.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Collier County

License Number: 2102383

COLLEGE PARK APTS HOME

License Type: Apartment

6450 COLLEGE PK CIR, NAPLES 34113

Inspection Date: 04/28/2021

Inspection Number: 1495166

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: PICO, JORGE

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Observed fire extinguisher of building 6455 , near apartment 303 in the recharge zone

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Observed in building 6445, near apartment 102, no hammer to break the glass

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2308273		KULODEX CORPORATION	
License Type: Apartment		416 E 27 ST, HIALEAH 33013	
Inspection Date: 04/26/2021	Inspection Number: 1448343	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: PAGAN, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. - From follow-up inspection 2021-04-26: **Admin Complaint**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2310999		3800 INVESTMENTS LLC	
License Type: Apartment		3800 E 4 AVE, HIALEAH 33013	
Inspection Date: 04/29/2021	Inspection Number: 1480578	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: MASKASEM, SUPPACHAI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed on the 2nd floor by the unit #1. **Repeat Violation** - From follow-up inspection 2020-03-13: **Time Extended** - From follow-up inspection 2021-04-29: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2308699		MARTHAS APARTMENTS	
License Type: Apartment		2375 W. OKEECHOBEE RD, HIALEAH 33014	
Inspection Date: 04/30/2021	Inspection Number: 1512240	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VILCHEZ, NABEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By apartment #17 second floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329374		TOWNEPLACE SUITES MIAMI AIRPORT	
License Type: Hotel		4021 NW 11TH ST, MIAMI 33126	
Inspection Date: 04/26/2021	Inspection Number: 1157234	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: SANCHEZ, JAVIER			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2300977		VC 1050 LLC	
License Type: Apartment		1050 NW 2 ST, MIAMI 33128	
Inspection Date: 04/26/2021	Inspection Number: 1451747	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: PAGAN, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Next to unit #6 **Warning** - From follow-up inspection 2021-04-26: **Admin Complaint**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2330392		ADA ANTIGUA NO 1 LLC	
License Type: Apartment		129 NW 9 AVE, MIAMI 33128	
Inspection Date: 04/27/2021	Inspection Number: 1497347	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: PAGAN, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Missing breaking device on fire extinguisher box located in first floor. - From follow-up inspection 2021-04-27: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2310489		ALEXAS INVESTMENT	
License Type: Apartment		426 SW 3 ST, MIAMI 33130	
Inspection Date: 04/27/2021	Inspection Number: 1479435	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: PAGAN, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Fire extinguisher box in the third floor missing breaking device. - From follow-up inspection 2021-04-27: **Admin Complaint**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2312380		ROSA CHOIE DE OW APT	
License Type: Apartment		543 SW 4 ST, MIAMI 33130	
Inspection Date: 04/27/2021	Inspection Number: 1474493	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: PAGAN, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed fire extinguisher inside of the locked box at the first floor, missing breaking device. - From follow-up inspection 2021-04-27: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2312541 BUENA VISTA APARTMENTS
 License Type: Apartment 529 SW 4 ST, MIAMI 33130

Inspection Date: 04/30/2021 Inspection Number: 1500294 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher by unit 104. For reporting purposes only. - From follow-up inspection 2021-04-30: Portable fire extinguisher locked in a box with no means of access to the fire extinguisher by unit 104. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330310 1134 APT LLC
 License Type: Apartment 1134 SW 4 ST, MIAMI 33130

Inspection Date: 04/26/2021 Inspection Number: 1501965 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: VILCHEZ, NABEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Next to apartment 9 second floor. - From follow-up inspection 2021-04-26: Still observed **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2309459 LISMAR APTS
 License Type: Apartment 404 SW 6 ST, MIAMI 331302872

Inspection Date: 04/29/2021 Inspection Number: 1497497 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: URIBE, GUISELLA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By Unit 25, fourth floor. - From follow-up inspection 2021-04-29: Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By Unit 25, fourth floor. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2303085 7ST LLC
 License Type: Apartment 1000 7 ST, MIAMI BEACH 33139

Inspection Date: 04/27/2021 Inspection Number: 1483357 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. All extinguishers locked in a box. - From follow-up inspection 2021-04-27: On second floor **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2306098 1113 MERIDIAN AVE
 License Type: Apartment 1113 MERIDIAN AVE, MIAMI BEACH 33139

Inspection Date: 04/26/2021 Inspection Number: 1455394 Inspection Type: Routine - Lodging Inspection Disposition: Call Back -
 Inspector Name: PAGAN, VICTOR Complied

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. - From follow-up inspection 2021-04-26: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2320150 CATALINA HOTEL
 License Type: Hotel 1720-1756 COLLINS AVENUE, BUILDINGS 1720,1732, 1756, MIAMI BEACH 33139

Inspection Date: 04/28/2021 Inspection Number: 1159053 Inspection Type: Complaint Full Inspection Disposition: Inspection
 Inspector Name: HODGE, KRISTEN Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel located behind front desk. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328176 TOWNHOUSE HOTEL
 License Type: Hotel 150 20 ST, MIAMI BEACH 33139

Inspection Date: 04/29/2021 Inspection Number: 1157765 Inspection Type: Routine - Lodging Inspection Disposition: Call Back -
 Inspector Name: HODGE, KRISTEN Complied

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel located behind front desk. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2021-04-29: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2322781 FOUR GIRLS APTS
 License Type: Apartment 227 1 ST, MIAMI BEACH 331397325

Inspection Date: 04/27/2021 Inspection Number: 1473166 Inspection Type: Routine - Lodging Inspection Disposition: Call Back -
 Inspector Name: WILLIAMS, ALFREDA Admin. complaint recommended

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. On second floor. - From follow-up inspection 2021-04-27: No access door locked. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329408		EVEN MIAMI AIRPORT HOTEL	
License Type: Hotel		3499 NW 25 ST, MIAMI 33142	
Inspection Date: 04/30/2021	Inspection Number: 1157413	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificate 314081 and 314082 expired on 01-01-2020. - From follow-up inspection 2021-04-30: Boiler certificates not provided **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2304560		PROSPER APTS	
License Type: Apartment		3210 NW 22 AVE, MIAMI 331428588	
Inspection Date: 04/26/2021	Inspection Number: 1441694	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: PAGAN, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. - From follow-up inspection 2021-04-26: **Admin Complaint**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329270		GRAND BEACH HOTEL SURFSIDE	
License Type: Hotel		9449 COLLINS AVE, SURFSIDE 33154	
Inspection Date: 04/27/2021	Inspection Number: 1157302	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2307510		KN APT	
License Type: Apartment		1555 NE 125 TERR, NORTH MIAMI 33161	
Inspection Date: 04/29/2021	Inspection Number: 1505352	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: SUAREZ, LEOPOLDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2021-04-29: On 4/29/21 at the time of callback inspection observed Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329173 BEST WESTERN HOTEL & SUITES
 License Type: Hotel 8560 SW 124 AVE, MIAMI 33183

Inspection Date: 04/28/2021 Inspection Number: 1158219 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: ELDER, AUDREY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed on fourth floor near room 416. - From follow-up inspection 2021-04-28: Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed on fourth floor near room 416. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Highlands County

License Number: 3800892

BREEZEWAY

License Type: Apartment

1000 S LAKE ANOKA BLVD, AVON PARK 33825

Inspection Date: 04/26/2021

Inspection Number: 1494480

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation CodeObservationViolation Citation

01-04-4

No portable fire extinguisher observed on the premises. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3800766

EWING APTS

License Type: Apartment

1202 W STRATFORD RD, AVON PARK 33825-9526

Inspection Date: 04/26/2021

Inspection Number: 1508942

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation CodeObservationViolation Citation

01-04-4

No portable fire extinguisher observed on the premises. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3902452		TIMBERFALLS APARTMENTS	
License Type: Apartment		2600 E 113TH AVE, TAMPA 33612	
Inspection Date: 04/26/2021	Inspection Number: 1512137	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MCINTYRE, REGIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. In laundry room 2610 4 and in laundry room 2600 4. Operator had employee place fire extinguishers in laundry rooms. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 3913881		THE RETREAT AT TAMPA	
License Type: Apartment		11326 N 46TH ST, TAMPA 33617	
Inspection Date: 04/27/2021	Inspection Number: 1511653	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: REGAS, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 3910857		COURTYARD BY MARRIOTT TAMPA NORTH/I-75	
License Type: Hotel		13575 CYPRESS GLEN LN, TAMPA 33637	
Inspection Date: 04/27/2021	Inspection Number: 1159025	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: REGAS, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-07-4	Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 3912329		HILTON GARDEN INN TAMPA NORTH	
License Type: Hotel		13305 TAMPA OAKS BLVD, TEMPLE TERRACE 33637	
Inspection Date: 04/29/2021	Inspection Number: 1157506	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Extension given, pending
Inspector Name: REGAS, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2021-01-28: **Time Extended** - From follow-up inspection 2021-03-30: **Time Extended** - From follow-up inspection 2021-04-29: From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2021-01-28: - From follow-up inspection 2021-03-30: -From follow up inspection 2021-04-29: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Hillsborough County

License Number: 3910558

TAMPA PALMS GOLF & CC

License Type: Motel

5811 TAMPA PALMS BLVD, TAMPA 336471090

Inspection Date: 04/27/2021

Inspection Number: 1216194

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: POWELL, DAVID

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler inspection certificate to have expired on 1/3/2021

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4700602

VILLA LUCIA LLC

License Type: Apartment

1845 BELLE VUE WAY, TALLAHASSEE 32304

Inspection Date: 04/27/2021

Inspection Number: 1503704

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JEFFERS, MARY-BETH

Violation Code

Observation

Violation Citation

07-04-4

Electrical outlet damaged to indicate a malfunction. For reporting purposes only.
Small electrical box separating from wall near apt #162

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5403191

CASA MARINA A WALDORF ASTORIA RESORT

License Type: Hotel

1500 REYNOLDS ST, KEY WEST 33040

Inspection Date: 04/27/2021

Inspection Number: 1158294

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: DEMARTINI, JOSEPH

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Located in the office of the main building nearby the front desk.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only. Observed FL124944, expires 8/28/20; FL124945, expires 8/28/20 FL055829 expires 8/28/20, FL055830 expires 08/28/20 posted new certificates in the both boiler rooms: FL 124944, expires 09/23/22; FL 124945, expires 09/23/22; FL 055829, expires 09/23/22; FL 055830, expires 09/23/22 **Corrected On-Site**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Nassau County

License Number: 5500967

SPRINGHILL SUITES AMELIA ISLAND

License Type: Hotel

2700 ATLANTIC AVE STE 2, AMELIA ISLAND 32034

Inspection Date: 04/27/2021

Inspection Number: 1158628

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Inspection
Completed - No Further Action

Inspector Name: NEVILLE, DAVID

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
Hot water heaters are 500,000 BTU, 160 gallons, and 210°F per the data plate

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5500968

COURTYARD AMELIA ISLAND

License Type: Hotel

2700 ATLANTIC AVE STE 1, AMELIA ISLAND 32034

Inspection Date: 04/27/2021

Inspection Number: 1158629

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Inspection
Completed - No Further Action

Inspector Name: NEVILLE, DAVID

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
Hot water heaters are 500,000 BTU, 160 gallons, and 210°F per the data plate

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5603261

HEROS LANDING APARTMENTS

License Type: Apartment

1005 MARTIN LUTHER KING JR AVE, CRESTVIEW 32536

Inspection Date: 04/26/2021

Inspection Number: 1509718

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: STEINMAN, MARC

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Bld D located between units 5 and 6

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811348		NOVEL LUCERNE	
License Type: Apartment		733 MAIN LN, ORLANDO 32801	
Inspection Date: 04/26/2021	Inspection Number: 1499588	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Extension given, pending
Inspector Name: MONTESANO, MISTI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - main building first floor, Earthfair Panel - From follow-up inspection 2021-04-26: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 5811328		THE TIFFANY AT MAITLAND WEST	
License Type: Apartment		9301 SUMMIT CENTRE WAY, ORLANDO 32810	
Inspection Date: 04/27/2021	Inspection Number: 1499496	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Extension given, pending
Inspector Name: THORNCROFT, ROBERT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. System in trouble - From follow-up inspection 2021-04-27: System in trouble **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 5805932		INTOWN SUITES ORLANDO SOUTH LLC	
License Type: Hotel		1951 CENTRAL FLORIDA PKWY, ORLANDO 32837	
Inspection Date: 04/26/2021	Inspection Number: 1158696	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ALVIS, DAVID			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. -122593 9-18-2020	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 5811127		MARRIOTT'S LAKESHORE RESERVE	
License Type: Hotel		11248 LAKESHORE RESERVE DR, ORLANDO 32837	
Inspection Date: 04/26/2021	Inspection Number: 1158715	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ALVIS, DAVID			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Orange County

License Number: 5801553

DAYS INN ORLANDO

License Type: Motel

2500 W 33 ST, ORLANDO 32839

Inspection Date: 04/26/2021

Inspection Number: 1214370

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PASIECKI, VICTORIA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
#5311561C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5800462

DAYS INN MIDTOWN

License Type: Motel

3300 S ORANGE BLOSSOM TRL, ORLANDO 328398968

Inspection Date: 04/30/2021

Inspection Number: 1216918

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: PASIECKI, VICTORIA

Violation CodeObservationViolation Citation

01-06-4

- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
Outside room 165/163
Outside Room 264/262 - From follow-up inspection 2021-04-30: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
Outside room 165/163
Outside Room 264/262

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810924

FAIRFIELD INN & SUITES ORLANDO/OCOEE

License Type: Hotel

10971 W COLONIAL DR, OCOEE 34761

Inspection Date: 04/28/2021

Inspection Number: 1156914

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: GREENE, MARVIN

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.
Room 202.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5912068

MM LAKE HOTEL LLC

License Type: Hotel

4944 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 04/27/2021

Inspection Number: 1159049

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LORENZO, ANA

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900879

THE GRAND ORLANDO RESORT AT CELEBRATION

License Type: Hotel

2900 PKWY BLVD, KISSIMMEE 34747

Inspection Date: 04/29/2021

Inspection Number: 1159060

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: YOUNG, COLIN

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Room 2101
Maintenance manager will call for service

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Chris the maintenance manager advised they just had their inspection and the current certificates are expired. He advised that they should receive the certificates shortly

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014232

CLPF NORTH BOCA VILLAGE LLC

License Type: Apartment

7801 N FEDERAL HWY, BOCA RATON 33487

Inspection Date: 04/28/2021

Inspection Number: 1512176

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Warning
Issued

Inspector Name: GOODWIN, NICHOLAS

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In building 13 outside of unit 107, in building 22 outside of unit 111, in building 22 outside of elevator machine room, building 22 outside of unit 507, building 19 outside of unit 101

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215529		COFFEE POT BAYOU REALTY	
License Type: Apartment		300 34 AVE N, ST. PETERSBURG 33704	
Inspection Date: 04/29/2021	Inspection Number: 1505221	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LOZANO, KELVIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. In front of unit 8. Glass partially broken but no means to break the rest of the glass.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6204782		BREEZEWAY APARTMENTS	
License Type: Apartment		11875 3 ST E, TREASURE ISLAND 337064578	
Inspection Date: 04/26/2021	Inspection Number: 1500162	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
07-01-4	Damaged electrical wire(s). For reporting purposes only . Light hanging by wires and exposed wires by apartment 3.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6212890		JOLLY ROGER APTS	
License Type: Apartment		145 116 AVE, TREASURE ISLAND 337064583	
Inspection Date: 04/26/2021	Inspection Number: 1495422	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. System trouble and and alarm 1 and 2 lights on.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6212290		ANCHOR APARTMENTS	
License Type: Apartment		10225 GULF BLVD, TREASURE ISLAND 337064810	
Inspection Date: 04/28/2021	Inspection Number: 1502638	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-03-4	Battery missing at smoke detector room 3. For reporting purposes only. Do not rent room 3 until smoke detector is fully functioning. Manager replaced battery. **Corrected On-Site**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Pinellas County

License Number: 6215955

TGM IBIS WALK

License Type: Apartment

871 IBIS WALK PL N, ST. PETERSBURG 33716

Inspection Date: 04/26/2021

Inspection Number: 1494321

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: LOZANO, KELVIN

Violation CodeObservationViolation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In front of 3307. In front of 3407. In front of 5209 - From follow-up inspection 2021-04-26: In front of 3307, 5209

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215772

INTOWN SUITES

License Type: Hotel

2833 ROOSEVELT BLVD, CLEARWATER 33760

Inspection Date: 04/28/2021

Inspection Number: 1158425

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WILMOT, TASHARA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
-hearing impaired smoke detector needs to be mounted to wall
Light not flashing only sound **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6201176

MAGNUSON HOTEL

License Type: Motel

21252 US HWY 19 N, CLEARWATER 33765

Inspection Date: 04/27/2021

Inspection Number: 1216891

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BENEDICT, TRACY

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
Fire extinguisher missing from box in between rooms 256 and 257, operator put fire extinguisher in box **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Santa Rosa County

License Number: 6700011

HOSPITALITY INN APTS

License Type: Apartment

6436 HWY 90, MILTON 325704527

Inspection Date: 04/26/2021

Inspection Number: 1492993

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: ALBRITTON, GREGORY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Apartment 61/63.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. Next to apartment 69/71.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6804742

TROPICAL SANDS ACCOMMODATIONS, LLC

License Type: Motel

5830 MIDNIGHT PASS RD, SARASOTA 34242

Inspection Date: 04/28/2021

Inspection Number: 1215161

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: HOWARTH, ROSALIE

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher out of green range, located in Tower 2 Room 704. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6903889

ARBOR LAKES CONDOMINIUMS

License Type: Apartment

100 ARBOR LAKES CIR, SANFORD 32771

Inspection Date: 04/27/2021

Inspection Number: 1508859

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

01-03-4

- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
Garages. - From follow-up inspection 2021-04-27:

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406543

GOOD SAMARITAN SOCIETY DAYTONA BEACH

License Type: Apartment

340 S RIDGEWOOD AVE, DAYTONA BEACH 32114

Inspection Date: 04/29/2021

Inspection Number: 1505767

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: LARSON, SARAH

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2021-04-29:

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.