

Bay County

License Number: 1301324 GULF AVENUE APTS INC
 License Type: Apartment 1400 GULF AVE, PANAMA CITY 32401

Inspection Date: 05/06/2021 Inspection Number: 1500495 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LYNN, NICKOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Between front doors of units 2 and 3 **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1305240 CABANA WEST
 License Type: Apartment 302 CABANA BLVD, PANAMA CITY BEACH 32407

Inspection Date: 05/04/2021 Inspection Number: 1503635 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: HAASE, TINA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed fire extinguisher missing next to G37 in back of property.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1300032 BANANA PEEL RESORT
 License Type: Motel 12830 W FRONT BEACH RD, PANAMA CITY BCH 324073312

Inspection Date: 05/04/2021 Inspection Number: 1212653 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: HAASE, TINA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. Observed no smoke detector in room 103.	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1604142 PIERCE APARTMENT CONDOMINIUM ASSOCIATION
 License Type: Apartment 2750 PIERCE ST, HOLLYWOOD 33020

Inspection Date: 05/06/2021 Inspection Number: 1501011 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: GANPAT, INDAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
06-02-4	Some windows are blocked with ply wood, east of property. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621379 CURTIS INN AND SUITES
 License Type: Apartment 1730 MAYO ST, HOLLYWOOD 33020

Inspection Date: 05/06/2021 Inspection Number: 1508921 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: CHRISTGEN, THOM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed on extinguisher at front door of unit.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1610903 HOTEL POMPANO BEACH
 License Type: Motel 1201 NW 31ST AVE, POMPANO BEACH 33069

Inspection Date: 05/03/2021 Inspection Number: 1216191 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: PITRE, ASTRID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2021-05-03: No Boiler certificate. **Admin Complaint**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2102388

SADDLEBROOK VILLAGE APARTMENTS

License Type: Apartment

8685 SADDLEBROOK CIR, NAPLES 34104

Inspection Date: 05/06/2021

Inspection Number: 1508686

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DILLON, TIMOTHY

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed several missing hammers for the locked fire extinguisher box. Specifically Building 8625, Apartment 1208, 1106 and 1104.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2305469

SHELBORNE SOUTH BEACH

License Type: Hotel

1801 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 04/30/2021

Inspection Number: 1157778

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: HODGE, KRISTEN

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 055333; 055334 All expired 4/28/2019
- From follow-up inspection 2021-04-30: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2600027

RIVERBANK

License Type: Apartment

1591 LANE AVE S, JACKSONVILLE 32210

Inspection Date: 03/29/2021

Inspection Number: 1512366

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: MERCER, THOMAS

Violation Code

Observation

Violation Citation

04-05-4

Priority: Reporting

Observed: No smoke detector provided in guest room/unit. For reporting purposes only.

No smoke detector in apartment LL 121 and LL 119. Maintenance employee installed during inspection. ****Corrected On-Site****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hamilton County

License Number: 3400163

MUSTANG INN

License Type: Motel

8055 SR 6 W, JASPER 32052

Inspection Date: 05/07/2021

Inspection Number: 1216960

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Between 156 and 157 rooms.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hernando County

License Number: 3700051

RIDGE MANOR MOTEL

License Type: Motel

5205 TREIMAN BLVD, RIDGE MANOR 33523

Inspection Date: 05/04/2021

Inspection Number: 1216165

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: POWELL, DAVID

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Observed the hearing impaired device not operating when tested audible works but light does not flash.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3902852

GODFREY HOTELS & CABANAS

License Type: Hotel

7700 W CAMPBELL CSWY, TAMPA 33607

Inspection Date: 05/05/2021

Inspection Number: 1158609

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CANNELLA, MARK

Violation Code Observation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Violation Citation

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913912

TOWN WESTSHORE

License Type: Apartment

5001 BRIDGE ST, TAMPA 33611

Inspection Date: 05/03/2021

Inspection Number: 1509159

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: KLUSENDORF, JEANNE

Violation Code Observation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Violation Citation

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3900493

THE RIVIERA AT 8412

License Type: Apartment

8412 RIO BRAVO COURT, TAMPA 33617

Inspection Date: 05/03/2021

Inspection Number: 1512056

Inspection Type: Lodging-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: REGAS, ANTHONY

Violation Code Observation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Unit 1402 building 14, buildings 27, 5, and 27 all are missing fire extinguishers.

Violation Citation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3901729

ALEXANDRIA GARDEN

License Type: Apartment

3814 W EUCLID AVE, TAMPA 33629

Inspection Date: 05/07/2021

Inspection Number: 1509287

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MCINTYRE, REGIS

Violation Code Observation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Across from apartment 13.

Violation Citation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Indian River County

License Number: 4101361

REGENCY PARK OF VERO BEACH

License Type: Apartment

910 REGENCY SQUARE, VERO BEACH 32967

Inspection Date: 05/04/2021

Inspection Number: 1499717

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: SCHUCK, GREGORY

Violation Code

Observation

Violation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2021-05-04:
Time Extended

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4703094 WOODSPRING SUITES TALLAHASSEE NORTHWEST
 License Type: Hotel 5344 W TENNESSEE ST, TALLAHASSEE 32304

Inspection Date: 05/03/2021 Inspection Number: 1158639 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ADAMSON, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Upon inspection observed fire extinguisher in recharge zone on first floor next to room 118.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4703116 THE OSCEOLA
 License Type: Apartment 500 CHAPEL DR, 420-1, 420-2, TALLAHASSEE 32304

Inspection Date: 05/07/2021 Inspection Number: 1491651 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: GRODEWALD, PAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Fire extinguisher missing from box in front of apartment 336. Manager had employee place fire extinguisher in box	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4702292 SOUTHGATE CAMPUS CENTRE
 License Type: Apartment 675 W JEFFERSON ST, TALLAHASSEE 32304-8013

Inspection Date: 05/03/2021 Inspection Number: 1501654 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: MERCER, THOMAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. All six boiler certification expired on 3/15/2020	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5103072

HOLIDAY INN EXPRESS & SUITES BRADENTON WEST

License Type: Hotel

4450 47 ST W, BRADENTON 34210

Inspection Date: 05/05/2021

Inspection Number: 1156810

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: HICKS, GEORGE RANDY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5402993

BATES B & B

License Type: Bed and Breakfast

84791 OLD HWY, ISLAMORADA, VLG OF I 33036

Inspection Date: 05/04/2021

Inspection Number: 1094024

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

03-01-4

- From initial inspection : No fire sprinkler system installed in a transient lodging establishment three stories or more in height, or over 75 feet in height. For reporting purposes only. - From follow-up inspection 2021-05-04: No fire sprinkler sy

509.215 and 509.032(2)(d) FS Reporting: 509.215 Any public lodging establishment, as defined in this chapter, which is of three stories or more, or over 75 feet in height shall be equipped with an automatic sprinkler system installed in compliance with the provisions prescribed in the National Fire Protection Association publication NFPA No. 13 "Standards for the Installation of Sprinkler Systems. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5603605

ARIUM EMERALD ISLE APARTMENTS

License Type: Apartment

921 DENTON BLVD NW, FORT WALTON BEACH 32547

Inspection Date: 05/05/2021

Inspection Number: 1494681

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: STEINMAN, MARC

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Build 3 unit 703, Build 5 unit 1505

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5603621

ARIUM EMERALD ISLE APARTMENTS

License Type: Apartment

214 RACETRACK ROAD NW, FORT WALTON BEACH 32547

Inspection Date: 05/05/2021

Inspection Number: 1509170

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: STEINMAN, MARC

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5800312

MAGNOLIA TOWERS

License Type: Apartment

100 E ANDERSON ST, ORLANDO 328013756

Inspection Date: 04/15/2021

Inspection Number: 1490488

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: MONTESANO, MISTI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900682

SUPER 8 MOTEL MAINGATE

License Type: Motel

5875 W IRLO BRONSON HWY, KISSIMMEE 34746

Inspection Date: 05/06/2021

Inspection Number: 1215149

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FERTIL, SYLVERST

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificate expired 1/10/2020 - JN 131433 and 131532.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6010088

6575 JUPITER GARDENS LLC

License Type: Apartment

6575 JUPITER GARDENS BLVD, JUPITER 33458

Inspection Date: 05/03/2021

Inspection Number: 1512298

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code

Observation

Violation Citation

07-04-4

Electrical outlet damaged to indicate a malfunction. For reporting purposes only by apts #6 and #13.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6100329

LA CASA INN

License Type: Motel

6523 US HWY 19, NEW PORT RICHEY 34652

Inspection Date: 05/05/2021

Inspection Number: 1216919

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: DAHL, MICHELE

Violation Code

Observation

Violation Citation

06-01-4

Path to door marked as an exit is blocked. For reporting purposes only. Blocked by laundry cart and bags of trash **Corrected On-Site**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6205494 FAIR OAKS APARTMENTS
 License Type: Apartment 720 8TH ST N, ST. PETERSBURG 33701

Inspection Date: 05/05/2021 Inspection Number: 1501488 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WOOD, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. -Upstairs between unit 6 and 7 inside marked box -downstairs between units 2 and 3 inside marked box	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216171 ANDERSON HOUSE HOTEL
 License Type: Apartment 424 2ND STREET NORTH, ST. PETERSBURG 33701

Inspection Date: 05/04/2021 Inspection Number: 1489115 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VILLEGAS, TATTYANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
05-02-5	Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Please provide a working hearing impaired smoke detector with a functioning light.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6204220 SAND DUNE APARTMENTS LLC
 License Type: Apartment 8012 BLIND PASS RD, ST.PETE BEACH 33706

Inspection Date: 05/05/2021 Inspection Number: 1508756 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: THORNCROFT, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-08-4	2 motorcycles stored under the stairwell	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6211956 KENWOOD INN
 License Type: Motel 451 34 ST N, ST. PETERSBURG 33713

Inspection Date: 05/03/2021 Inspection Number: 1213833 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: HOBBS, ANDREW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-05-4	- From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only. No strikers on any fire extinguishers. - From follow-up inspection 2021-03-17: No strikers observed **Time Extended** - From follow-up	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6202471

ISLAND CAY AT CLEARWATER BEACH

License Type: Motel

648 POINSETTIA AVE, CLEARWATER BEACH 33767

Inspection Date: 05/03/2021

Inspection Number: 1214778

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: KOUSTIS, TIMOTHY

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Room 119.

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Santa Rosa County

License Number: 6700027

EMERALD SANDS INN

License Type: Motel

6436 W HWY 90, MILTON 325704527

Inspection Date: 05/03/2021

Inspection Number: 1216504

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ALBRITTON, GREGORY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to room 209.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6904062

VUE ON LAKE MONROE

License Type: Apartment

800 MARBELLA LN, SANFORD 32771

Inspection Date: 05/05/2021

Inspection Number: 1512335

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Notified Dan Taylor, Sanford Fire Inspector. 407-562-2788. Voice Message.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.