

**Alachua County**

License Number: 1100727

ECONO LODGE

License Type: Motel

2649 SW 13 ST, GAINESVILLE 32608

Inspection Date: 05/12/2021

Inspection Number: 1216961

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: PACE, PATRICK

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.  
Missing next to room 126

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-03-4

- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.  
Missing next to room 126 - From follow-up inspection 2021-05-13:

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1103077

LIV PLUS GAINESVILLE

License Type: Apartment

1900 SW 13TH ST, GAINESVILLE 32608

Inspection Date: 05/13/2021

Inspection Number: 1512255

Inspection Type: Lodging-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PACE, PATRICK

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.  
Missing next to unit 320

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Bay County**

License Number: 1301433		ST ANDREWS TOWERS	
License Type: Apartment		24 HARRISON AVE, PANAMA CITY 324012744	
Inspection Date: 05/14/2021	Inspection Number: 1496245	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: DESHAZIER, ERNEST			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired 8-8-17, For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 1304141		COMET VILLA APARTMENTS	
License Type: Apartment		132 -138 N COMET AVE, CALLAWAY 32404	
Inspection Date: 05/11/2021	Inspection Number: 1501846	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DESHAZIER, ERNEST			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. Observed a gas grill with 20lbs tank on the second floor unit 3 building 138.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 1300935		AZTEC VILLA APARTMENTS	
License Type: Apartment		3913 PIZA DR, PANAMA CITY 32405-3452	
Inspection Date: 05/13/2021	Inspection Number: 1490751	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LYNN, NICKOLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-04-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. Unit I-1, porch closet door missing, tank in closet, visible from exterior.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Bradford County**

License Number: 1400018

BUDGET INN OF LAWTEY

License Type: Motel

23670 US HWY 301 N, LAWTEY 32058

Inspection Date: 05/13/2021

Inspection Number: 1216497

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DOTY, JOSEPH

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
Fire extinguisher near room 118

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Brevard County**

License Number: 1501012

COCOA AFFORDABLE LIVING CENTER

License Type: Motel

900 FRIDAY RD, COCOA 32926

Inspection Date: 05/14/2021

Inspection Number: 1215697

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: WILSON, LANETTE

Violation CodeObservationViolation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Between units 219 and 217 - From follow-up inspection 2021-03-15: \*\*Time Extended\*\* - From foll

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1502749

DAYS INN

License Type: Motel

5600 SR 524, COCOA 32926

Inspection Date: 05/14/2021

Inspection Number: 1215701

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: WILSON, LANETTE

Violation CodeObservationViolation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Between 103 & 104 - From follow-up inspection 2021-05-14: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1620846

DOUBLETREE BY HILTON SUNRISE - SAWGRASS MILLS

License Type: Hotel

13400 W SUNRISE BLVD, SUNRISE 33323

Inspection Date: 05/12/2021

Inspection Number: 1159093

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: GRAY, ANTHONY

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Calhoun County**

License Number: 1700094

BENCHMARK APARTMENTS

License Type: Apartment

247 E FANNIN AVE, BLOUNTSTOWN 32424

Inspection Date: 05/06/2021

Inspection Number: 1507104

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WRIGHT, JACOB

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.

No fire extinguishers in designated areas on front of each building. Storage casing is installed but no extingui

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Collier County**

License Number: 2102710

SREIT TUSCAN ISLE

License Type: Apartment

8650 WEIR DR, NAPLES 34104

Inspection Date: 05/12/2021

Inspection Number: 1506987

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DILLON, TIMOTHY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed the fire panel is showing trouble on the panel.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2312596

DAYS INN MIAMI INTERNATIONAL AIRPORT HOTEL-NEW

License Type: Motel

7250 NW 11 ST, MIAMI 331261903

Inspection Date: 05/14/2021

Inspection Number: 1216991

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FL 097556, expired 09/21/20.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329257

ALOFT MARY BRICKELL

License Type: Hotel

1001 SW 2 AVE, MIAMI 33130

Inspection Date: 05/14/2021

Inspection Number: 1157828

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back - Extension given, pending

Inspector Name: MASKASEM, SUPPACHAI

Violation CodeObservationViolation Citation

08-04-4

- From initial inspection : Boiler certificate not posted in the boiler room. For reporting purposes only. - From follow-up inspection 2021-05-14: \*\*Time Extended\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330159

MONARC AT MET

License Type: Apartment

201 SE 2 AVE, MIAMI 33131

Inspection Date: 05/14/2021

Inspection Number: 1501761

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 10-04-2020

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2306734		SAN JUAN HOTEL	
License Type: Hotel		1680 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 05/14/2021	Inspection Number: 1158595	Inspection Type: Complaint Full	Inspection Disposition: Call Back - Complied
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Fire panel located in front desk office, trouble light illuminated. - From follow-up inspection 2021-05-14: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329312		CLAREMONT HOTEL	
License Type: Hotel		1700 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 05/14/2021	Inspection Number: 1157714	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). Observed empty fire extinguisher box located on the 3rd floor near room number 325. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2301114		LA FLORA HOTEL	
License Type: Hotel		1238 COLLINS AVE, MIAMI BEACH 331394607	
Inspection Date: 05/10/2021	Inspection Number: 1157933	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2021-05-10: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Dade County**

License Number: 2304620

HOTEL BELLAMAR

License Type: Hotel

220 31 ST, MIAMI BEACH 33140

Inspection Date: 05/11/2021

Inspection Number: 1158737

Inspection Type: Lodging-Licensing  
InspectionInspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device for extinguisher located in the stairs between 1 st and second floor building 230.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Building 230 .

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329463

DCROSS MANAGEMENT

License Type: Hotel

5445 COLLINS AVENUE UNIT C17, MIAMI BEACH 33140

Inspection Date: 05/12/2021

Inspection Number: 1158116

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. One of the boiler has the certificate already expired since 3/6/2020.( FL 092741) - From follow-up inspection 2021-05-12:  
\*\*T

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329326

HOLIDAY INN EXPRESS AND SUITES MIAMI ARPT AND INTERMODAL AREA

License Type: Hotel

2601 NW 42 AVE, MIAMI 33142

Inspection Date: 05/07/2021

Inspection Number: 1157083

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. 499900 btu, 575.64 gl water, \*\*Repeat Violation\*\* - From follow-up inspection 2021-05-07: \*\*Time Extended\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2603661

TRAVELODGE INN & SUITES

License Type: Motel

1153 AIRPORT RD, JACKSONVILLE 32218

Inspection Date: 05/14/2021

Inspection Number: 1216989

Inspection Type: Complaint Full

Inspection Disposition: Administrative complaint recommended

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only.  
Missing by rooms 117 and 315.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only.  
In room 122.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3911502 EXTENDED STAY AMERICA #9643  
 License Type: Motel 330 GRAND REGENCY BLVD, BRANDON 33510

Inspection Date: 05/13/2021 Inspection Number: 1216121 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: THORNCROFT, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Only one certificate is available , operator looked up the email information on the inspection and the email from CNA described the servicing of 2 units	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913532 LA QUINTA INN # 965  
 License Type: Hotel 310 GRAND REGENCY BLVD, BRANDON 33510

Inspection Date: 05/13/2021 Inspection Number: 1158314 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: THORNCROFT, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 132744 1/31/21 expired , 132767 1/31/21 expired	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913547 GIBTOWN INN  
 License Type: Motel 11545 S US HWY 41, GIBSONTON 33534

Inspection Date: 05/13/2021 Inspection Number: 1216179 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: THORNCROFT, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Red fire extinguisher box is empty at room 12	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3911366 RUSKIN INN  
 License Type: Motel 3113 E COLLEGE AVE, RUSKIN 33570

Inspection Date: 05/11/2021 Inspection Number: 1216159 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: THORNCROFT, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Unit is in trouble	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3909771		COMFORT INN	
License Type: Motel		718 CYPRESS VILLAGE BLVD, SUN CITY CENTER 335736800	
Inspection Date: 05/12/2021	Inspection Number: 1214191	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: THORNCROFT, ROBERT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. System is in trouble	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 3913626		HILTON GARDEN INN TAMPA SOUTHEAST	
License Type: Hotel		4328 GARDEN VISTA DR, RIVERVIEW 33578	
Inspection Date: 05/10/2021	Inspection Number: 1158304	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: ANGEL, TERRY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Notified Fire Inspector, Jason Castro, 813-233-3366. Voice message.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 3902625		BELARA LAKES APARTMENTS	
License Type: Apartment		8402 WATERFORD AVE, TAMPA 33604	
Inspection Date: 05/14/2021	Inspection Number: 1512437	Inspection Type: Complaint Full	Inspection Disposition: Administrative complaint recommended
Inspector Name: ZHANG, JACKY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By building 13 unit T4.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 3910141		GARDEN VILLAS APARTMENTS	
License Type: Apartment		8731 N 30 ST UNIT A, TAMPA 33604	
Inspection Date: 05/14/2021	Inspection Number: 1504074	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
07-01-4	Orange cord hooked up to box on side of building running around building and into wall on other side of building. For reporting purposes only. Manager believes it's from the cable company. States new tenant moved in yesterday. Building 8749	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Hillsborough County**

License Number: 3905670 EMBASSY SUITES BY HILTON TAMPA AIRPORT WESTSHORE  
 License Type: Hotel 555 N WESTSHORE BLVD, TAMPA 33609

Inspection Date: 05/10/2021 Inspection Number: 1159088 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: KLUSENDORF, JEANNE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3900493 THE RIVIERA AT 8412  
 License Type: Apartment 8412 RIO BRAVO COURT, TAMPA 33617

Inspection Date: 05/13/2021 Inspection Number: 1512435 Inspection Type: Complaint Full Inspection Disposition: Warning Issued  
 Inspector Name: REGAS, ANTHONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed missing fire extinguishers at buildings 5, 14,22 and 27.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3901892 RANCH HOUSE MOTEL  
 License Type: Motel 2909 S 50 ST, TAMPA 336196045

Inspection Date: 05/12/2021 Inspection Number: 1215834 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: KLUSENDORF, JEANNE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Next to room 18	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-05-4	No smoke detector provided in guest room/unit. For reporting purposes only. Operator replaced smoke detector room 7 **Corrective Action Taken**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3911569

PARK DEL MAR APTS

License Type: Apartment

19411 VIA DEL MAR, TAMPA 33647

Inspection Date: 05/10/2021

Inspection Number: 1490406

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: POWELL, DAVID

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed fire extinguisher missing by 11-104

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Lee County**

License Number: 4602988

COURTYARD FORT MYERS CAPE CORAL

License Type: Hotel

4455 METRO PARKWAY, FORT MYERS 33916

Inspection Date: 05/12/2021

Inspection Number: 1156675

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: FREED, JOSEPH

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Leon County**

License Number: 4703166

THE DECK/ THE COURT

License Type: Apartment

699 W GAINES ST, TALLAHASSEE 32304

Inspection Date: 05/11/2021

Inspection Number: 1506331

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRODEWALD, PAUL

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
Fire extinguisher in front of apartment 412.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.  
Fire extinguisher box in parking garage in front of parking spot 116.  
Fire extinguisher box next to apartment 432

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Okaloosa County**

License Number: 5602816

BRADFORD APTS

License Type: Apartment

800 BRADFORD PLACE, FT WALTON BCH 325473209

Inspection Date: 05/11/2021

Inspection Number: 1502592

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BURROUGHS, RICHARD

Violation Code

Observation

Violation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only.  
 - 2806, apartment 2: propane gas grill with tank attached under stairwell.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5811348

NOVEL LUCERNE

License Type: Apartment

733 MAIN LN, ORLANDO 32801

Inspection Date: 05/12/2021

Inspection Number: 1499588

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: MONTESANO, MISTI

Violation CodeObservationViolation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
 - main building first floor, Earthfair Panel - From follow-up inspection  
 2021-04-26: \*\*Time Extended\*\* - From follow-up ins

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5809848

SUNSTYLE SUITES

License Type: Motel

7209 ORANGE BLOSSOM TRAIL, ORLANDO 32809

Inspection Date: 05/11/2021

Inspection Number: 1211456

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: PASIECKI, VICTORIA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
 Outside room 218

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810954

HERITAGE HOTEL

License Type: Motel

7900 S ORANGE BLOSSOM TRAIL, ORLANDO 32809

Inspection Date: 05/10/2021

Inspection Number: 1213363

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: FRANZ, LISA

Violation CodeObservationViolation Citation

01-03-4

- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.  
 - by room 2018 - From follow-up inspection 2021-05-10: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 51981 and 122138 expired 7/19/2018 -  
 From follow-up inspection 2021-05-10: \*\*Time Extended\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5808506

COURTYARD BY MARRIOTT

License Type: Hotel

12000 COLLEGIATE WAY, ORLANDO 32817

Inspection Date: 05/13/2021

Inspection Number: 1159086

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: JENKINS, JOSHUA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5801553

DAYS INN ORLANDO

License Type: Motel

2500 W 33 ST, ORLANDO 32839

Inspection Date: 05/12/2021

Inspection Number: 1214370

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: PASIECKI, VICTORIA

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.  
 #53115 - From follow-up inspection 2021-05-12: \*\*Time Extended\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC LODGING ESTABLISHMENTS - WEEK ENDING 5/15/2021

www.MyFloridaLicense.com/dbpr/hr/

**Osceola County**

License Number: 5900225

SERALAGO HOTEL AND SUITES MAINGATE EAST

License Type: Hotel

5678 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 05/10/2021

Inspection Number: 1159037

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: FERTIL, SYLVERST

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificates expired 12/10/2020.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900708

PARADISE INN

License Type: Motel

4501 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746-5416

Inspection Date: 05/11/2021

Inspection Number: 1212121

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: FERTIL, SYLVERST

Violation CodeObservationViolation Citation

07-01-4

Electrical outlet cover is missing in room 221.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6005960		SUPER 8 MOTEL	
License Type: Motel		4112 W BLUE HERON BLVD, RIVIERA BEACH 33404-4855	
Inspection Date: 05/14/2021	Inspection Number: 1215154	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: PETROW, MICHAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2021-05-14: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 6011917		RESIDENCE INN WEST PALM BEACH	
License Type: Hotel		2461 METROCENTRE BLVD, WEST PALM BEACH 33407	
Inspection Date: 05/14/2021	Inspection Number: 1157835	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: PETROW, MICHAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-03-4	- From initial inspection : Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only.  Room 211 - hard wired hearing impaired smoke detection device test button inoperable. - From follow-up inspection	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 6004110		1031 SOUTH WOOSTER LTD	
License Type: Motel		1901 PALM BEACH LAKES BLVD., WEST PALM BEACH 33409	
Inspection Date: 05/14/2021	Inspection Number: 1215172	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: ROTONDI, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-04-4	- From initial inspection : Boiler certificate not posted in the boiler room. For reporting purposes only. - From follow-up inspection 2021-05-14: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 6008599		LAQUINTA INN	
License Type: Motel		34 FISHERMANS WHARF, JUPITER 33477	
Inspection Date: 05/11/2021	Inspection Number: 1216647	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: PETROW, MICHAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
06-03-4	- From initial inspection : Marked exit is inaccessible. For reporting purposes only.no emergency exit sign/diagram/fire evacuation floor plan posted on door.#308,#215,#200. - From follow-up inspection 2021-05-11: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Pasco County**

License Number: 6100216

TWILITE MOTEL

License Type: Motel

4040 GALL BLVD, ZEPHYRHILLS 33542

Inspection Date: 05/14/2021

Inspection Number: 1216276

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: POWELL, DAVID

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. When hearing impaired device is plugged in, the unit does not function when test button is pressed.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6215804

TREASURE BAY RESORT &amp; MARINA

License Type: Hotel

11125 GULF BLVD, TREASURE ISLAND 33706

Inspection Date: 05/11/2021

Inspection Number: 1158441

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: DAY-WALKER, LISA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. trouble yellow light illuminated in lobby fire panel.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6201091

BETTY LANE APARTMENTS

License Type: Apartment

311 S BETTY LANE, CLEARWATER 33756

Inspection Date: 05/13/2021

Inspection Number: 1497043

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: LANTIGUA, ROBERTO

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.  
By unit 34

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215883

INDIAN OAKS VILLAS

License Type: Apartment

2704 SECOND ST, INDIAN ROCKS BEACH 33785

Inspection Date: 05/10/2021

Inspection Number: 1509066

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Location laundry room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Sarasota County**

License Number: 6804762

MAGNOLIA POINTE

License Type: Hotel

5965 BROOKHILL BLVD, SARASOTA 34232

Inspection Date: 05/10/2021

Inspection Number: 1158162

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HELGESON, ERIC

Violation CodeObservationViolation Citation

02-04-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only.  
Observed 2 20lb LP tanks in mechanical room.  
Employee removed tanks.  
As a repeat violation the importance of following proper p

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6804763

ART OVATION HOTEL

License Type: Hotel

1255 N PALM AVE, SARASOTA 34236

Inspection Date: 05/14/2021

Inspection Number: 1158449

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: WICK, JENNIFER

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.