

**Broward County**

License Number: 1618200 ROYAL BEACH PALACE HOTEL  
 License Type: Hotel 3711 N OCEAN BLVD, FORT LAUDERALE 33308

Inspection Date: 05/14/2021 Inspection Number: 1159107 Inspection Type: Complaint Full Inspection Disposition: Warning Issued  
 Inspector Name: BENJAMIN, ALEXANDER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Zone 3 on panel	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Inspection Date: 05/17/2021 Inspection Number: 1159107 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied  
 Inspector Name: BENJAMIN, ALEXANDER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Zone 3 on panel - From follow-up inspection 2021-05-17: Observed same **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1607221 FORT LAUDERDALE GRAND HOTEL  
 License Type: Hotel 4900 POWERLINE ROAD, OAKLAND PARK 33309

Inspection Date: 05/17/2021 Inspection Number: 1159117 Inspection Type: Complaint Full Inspection Disposition: Warning Issued  
 Inspector Name: BENJAMIN, ALEXANDER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2308299		PARK MOTEL	
License Type: Motel		600 S KROME AVE, HOMESTEAD 33030	
Inspection Date: 05/20/2021	Inspection Number: 1216019	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: ORDONEZ, CATALINA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Between room 18 and 19. <b>**Repeat Violation**</b> - From follow-up inspection 2021-05-20: Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Between room 18 and 19. <b>**Time Extended**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2320327		FAIRWAY INN	
License Type: Motel		100 U S 1, FLORIDA CITY 33034	
Inspection Date: 05/18/2021	Inspection Number: 1215438	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: LODENQUAI, BARRINGTON			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. As per operator, matter is being addressed. <b>**Repeat Violation**</b> <b>**Warning**</b> - From follow-up inspection 2021-05-18: As per operator still being worked on. <b>**Time Extended**</b>	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2330271		5805 NW 7 LLC	
License Type: Apartment		5805 NW 7 PLACE, MIAMI 33127	
Inspection Date: 05/17/2021	Inspection Number: 1511646	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329257		ALOFT MARY BRICKELL	
License Type: Hotel		1001 SW 2 AVE, MIAMI 33130	
Inspection Date: 05/21/2021	Inspection Number: 1157828	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: MASKASEM, SUPPACHAI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-04-4	- From initial inspection : Boiler certificate not posted in the boiler room. For reporting purposes only. - From follow-up inspection 2021-05-14: <b>**Time Extended**</b> - From follow-up inspection 2021-05-21: <b>**Time Extended**</b>	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Dade County**

License Number: 2330365 CAOBA MIAMI WORLDCENTER  
 License Type: Apartment 698 NE 1 AVE, MIAMI 33132

Inspection Date: 05/20/2021 Inspection Number: 1492270 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied  
 Inspector Name: PAGAN, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2021-05-20: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-04-4	- From initial inspection : Boiler certificate not posted in the boiler room. For reporting purposes only. - From follow-up inspection 2021-05-20: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2309756 SEVEN SEAS MOTEL  
 License Type: Motel 5940 BISCAYNE BLVD, MIAMI 331372296

Inspection Date: 05/18/2021 Inspection Number: 1217015 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SEYBA, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Between 210 and 211.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328949 RIVERSIDE HOTEL  
 License Type: Motel 498 NE 78 ST, MIAMI 33138

Inspection Date: 05/19/2021 Inspection Number: 1213872 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied  
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2021-03-18: Observed fire alarm panel turned off **Time Extended** - From follow-up inspection 2021-05-19: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2328823 GENEVA HOTEL  
 License Type: Hotel 1520 COLLINS AVENUE, MIAMI BEACH 33139

Inspection Date: 05/18/2021 Inspection Number: 1156982 Inspection Type: Routine - Lodging Inspection Disposition: Call Back -  
 Inspector Name: UNZAGA, MILADYS Complied

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge located next to room number 2, on the 1st floor. For reporting purposes only. - From follow-up inspection 2021-05-18: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel located at hallway area on 1st floor. For reporting purposes only. - From follow-up inspection 2021-05-18: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2309749 EDEN ROC  
 License Type: Hotel 4525 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 05/19/2021 Inspection Number: 1156463 Inspection Type: Routine - Lodging Inspection Disposition: Call Back -  
 Inspector Name: UNZAGA, MILADYS Extension given, pending

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Main panel located next to Inez Cafe. **Repeat Violation** - From follow-up inspection 2021-05-19: Fire alarm company is working on the building **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed 1 new boiler that replaced the old one and will be inspected this year when renewing the other ones. - From follow-up inspection 2021-05-19: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329221 SOHO HOUSE  
 License Type: Hotel 4385 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 05/17/2021 Inspection Number: 1156676 Inspection Type: Routine - Lodging Inspection Disposition: Call Back -  
 Inspector Name: UNZAGA, MILADYS Complied

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Establishment unable to show the certificates for boilers FL 099975, 004875, 099979, 004874. - From follow-up inspection 2021-05-17: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329277		HILTON CABANA MIAMI BEACH	
License Type: Hotel		6261 COLLINS AVE, MIAMI BEACH 33140	
Inspection Date: 05/17/2021	Inspection Number: 1156705	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light illuminated on panel located behind concierge desk. - From follow-up inspection 2021-05-17: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2329307		AC HOTEL MIAMI BEACH	
License Type: Hotel		2912 COLLINS AVE, MIAMI BEACH 33140	
Inspection Date: 05/18/2021	Inspection Number: 1159119	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light flashing ( panel located by the front desk) **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2319158		LA QUINTA INN 667	
License Type: Motel		7401 NW 36 ST, MIAMI 33166	
Inspection Date: 05/18/2021	Inspection Number: 1217004	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed extinguisher located between room 117 and 119.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed extinguisher in recharge zone located between rooms 307 and 309.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	



**Duval County**

License Number: 2600005

VILLAS ON THE HILL 1131

License Type: Apartment

1131- 1137 WOODRUFF AVE, JACKSONVILLE 32205

Inspection Date: 05/18/2021

Inspection Number: 1512470

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation CodeObservationViolation Citation

04-05-4

No smoke detector provided in guest room/unit. For reporting purposes only. Apt  
1137-23

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2602643

SCOTTISH INN

License Type: Motel

2300 PHILLIPS HWY, JACKSONVILLE 322073548

Inspection Date: 05/20/2021

Inspection Number: 1217019

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: YOUNG, JENNIFER

Violation CodeObservationViolation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable.  
For reporting purposes only.  
Smoke alarm is hanging on wall in room 224

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Escambia County**

License Number: 2702586

DEVILLIERS GARDENS

License Type: Apartment

501 N DEVILLIERS ST, PENSACOLA 32501

Inspection Date: 05/19/2021

Inspection Number: 1500354

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: ALBRITTON, GREGORY

Violation CodeObservationViolation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2705809

APARTMENT

License Type: Apartment

5708 N PALAFOX HWY, PENSACOLA 32503

Inspection Date: 05/19/2021

Inspection Number: 1507841

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: ALBRITTON, GREGORY

Violation CodeObservationViolation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2700357

PARK PLACE APARTMENTS

License Type: Apartment

2275 SCENIC HWY, PENSACOLA 325036680

Inspection Date: 05/19/2021

Inspection Number: 1490407

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: ALBRITTON, GREGORY

Violation CodeObservationViolation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only.  
Stairway next to apartment 104 and 105.  
Stairway next to apartment 101 and 116.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Hillsborough County**

License Number: 3902625

BELARA LAKES APARTMENTS

License Type: Apartment

8402 WATERFORD AVE, TAMPA 33604

Inspection Date: 05/21/2021

Inspection Number: 1512437

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Complied

Inspector Name: ZHANG, JACKY

Violation CodeObservationViolation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
By building 13 unit T4. - From follow-up inspection 2021-05-21: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3900494

THE MIRASOL

License Type: Apartment

84 DAVIS BLVD, TAMPA 33606

Inspection Date: 05/17/2021

Inspection Number: 1512447

Inspection Type: Lodging-Licensing  
InspectionInspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: MCINTYRE, REGIS

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to apartment 409. Next to apartment 203.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3904663

MARRIOTT TAMPA WESTSHORE

License Type: Hotel

1001 N WESTSHORE BLVD, TAMPA 33607

Inspection Date: 05/21/2021

Inspection Number: 1158493

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: DODGE, DAVID

Violation CodeObservationViolation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.  
Operator has a scheduled boiler inspection scheduled for this week \*\*Corrective Action Taken\*\* \*\*Repeat Violation\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Leon County**

License Number: 4700582 THE SUMMIT AT CAMPUS EDGE  
 License Type: Apartment 630 W VIRIGINA ST, TALLAHASSEE 32304

Inspection Date: 05/19/2021 Inspection Number: 1491975 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended  
 Inspector Name: GRODEWALD, PAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher in front of apartment 308.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4703205 DOLGEN APARTMENTS  
 License Type: Apartment 1413 MCCAULEY RD, TALLAHASSEE 32308

Inspection Date: 05/21/2021 Inspection Number: 1512416 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SMITH, PAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Fire extinguisher on ground by apt A.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Manatee County**

License Number: 5105092		RIVERSONG APARTMENTS	
License Type: Apartment		606 3 AVE W, BRADENTON 34205	
Inspection Date: 05/21/2021	Inspection Number: 1492514	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ANGEL, TERRY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Notified Bradenton Fire Inspector, Massey, 941-932-9600. Left Voice Message.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5100375		MICHIANA MOTEL	
License Type: Motel		3235 14 ST W, BRADENTON 342056298	
Inspection Date: 05/20/2021	Inspection Number: 1212596	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: NIEVES, RAFAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-06-4	Combustibles stored in boiler room. For reporting purposes only. Observed a wood pallet stored in boiler room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5100097		DESOTO TOWERS	
License Type: Apartment		1523 W 6 AVE, BRADENTON 342056717	
Inspection Date: 05/20/2021	Inspection Number: 1507425	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: FRANZ, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5103072		HOLIDAY INN EXPRESS & SUITES BRADENTON WEST	
License Type: Hotel		4450 47 ST W, BRADENTON 34210	
Inspection Date: 05/12/2021	Inspection Number: 1159092	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: CARMASSI, BRADLEY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Manatee County**

License Number: 5105068

NORTHLAND YACHT CLUB LLC

License Type: Apartment

6510 ANCHOR LOOP, BRADENTON 34212

Inspection Date: 05/20/2021

Inspection Number: 1502127

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FRANZ, LISA

Violation Code

Observation

Violation Citation

07-01-4

Exposed electrical wire(s). For reporting purposes only.  
Building 14

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Martin County**

License Number: 5300336

DAYS INN

License Type: Motel

1200 SE FEDERAL HWY, STUART 34994

Inspection Date: 05/18/2021

Inspection Number: 1215753

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: KAMM, DARYL

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By room 210. -  
From follow-up inspection 2021-05-18: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Monroe County**

License Number: 5400573

AMARA CAY RESORT

License Type: Hotel

80001 OVERSEAS HWY, ISLAMORADA 33036

Inspection Date: 05/21/2021

Inspection Number: 1156721

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.  
2- new 360,000 BTU WATER heaters with 600 Gal. Holding tank.  
As per chief engineer, certificate not required due to under 400,000 BTU - From follow-up inspection 2021-05-21: No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.  
No engineer available at time of inspection. \*\*Time Extended\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Okaloosa County**

License Number: 5603309

INNTOWN APARTMENTS

License Type: Apartment

795 N WILSON ST, CRESTVIEW 32536

Inspection Date: 05/19/2021

Inspection Number: 1504322

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BURROUGHS, RICHARD

Violation CodeObservationViolation Citation

07-01-4

Damaged electrical fuse box. For reporting purposes only.  
 - apartment 157F: electrical circuit breaker panel under carport has the cover hanging by one screw exposing the interior wiring.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5602925

SHANGRA WOODS APTS

License Type: Apartment

940 ASHLEY LN, FT WALTON BCH 325476798

Inspection Date: 05/20/2021

Inspection Number: 1507479

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: STEINMAN, MARC

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
 Between units I and J

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5603602

CORVET APTS

License Type: Apartment

406- 408-410 CORVET ST, FORT WALTON BEACH 32548

Inspection Date: 05/21/2021

Inspection Number: 1500405

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ADAMSON, ROBERT

Violation CodeObservationViolation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.  
 Low hanging wires on right exterior second story wall leading to utility pole.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Orange County**

License Number: 5811292

WYNDHAM BONNET CREEK RESORT

License Type: Vacation Rental - Condo

9560 VIA ENCINAS, ORLANDO 32830

Inspection Date: 05/18/2021

Inspection Number: 1088441

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.  
Observed expired boiler certification 1/08/2021 in tower 3, called boiler safety office in Tallahassee pending status.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

License Number: 5908014

THE ANICETTE INN

License Type: Motel

4657 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 05/17/2021

Inspection Number: 1216994

Inspection Type: Complaint Full

Inspection Disposition: Administrative complaint recommended

Inspector Name: FERTIL, SYLVERST

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed the smoke alarm in room # 3 in disrepair on the floor. Advised operator to to repair or replace before making the room available for service.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6014445

WPB HOLDINGS 2 LLC

License Type: Apartment

1000 W LAKEWOOD RD, WEST PALM BEACH 33405

Inspection Date: 05/19/2021

Inspection Number: 1512495

Inspection Type: Lodging-Licensing  
Inspection

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SEVILLA, FREDDY

Violation Code

Observation

Violation Citation

06-03-4

Marked exit is inaccessible. For reporting purposes only.  
Observed apartment 4 window East side blocked with a sheet of plastic .  
Observed apartment 6 window East side blocked with a sheet of plywood.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pasco County**

License Number: 6100017

SADDLEBROOK RESORTS CONDO

License Type: Vacation Rental - Condo

5700 SADDLEBROOK WAY, WESLEY CHAPEL 335434411

Inspection Date: 05/20/2021

Inspection Number: 1088432

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: COLE, GABRIELLE

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By Building 3, Room 352. - From follow-up inspection 2021-05-20: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6205451

HARLOW AT GATEWAY

License Type: Apartment

509 77 AVE N, ST. PETERSBURG 33702

Inspection Date: 05/18/2021

Inspection Number: 1497239

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: LOZANO, KELVIN

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. 1-308

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to 01-308

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. No means to break glass 12-106

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6203125

SAHARA MOTEL

License Type: Motel

10910 GANDY BLVD, ST PETERSBURG 337021430

Inspection Date: 05/18/2021

Inspection Number: 1216296

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: LOZANO, KELVIN

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Gentex hearing impaired smoke alarm has to be hard wired into room to function and be tested \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6200856

AZALEA COURT

License Type: Motel

8210 N 4 ST, ST PETERSBURG 337023606

Inspection Date: 05/20/2021

Inspection Number: 1216245

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: LOZANO, KELVIN

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. No means to break glass next to room 10

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6201541

EMPRESS APT MOTEL

License Type: Motel

1501 N 9 ST, ST PETERSBURG 337044201

Inspection Date: 05/17/2021

Inspection Number: 1216264

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: LOZANO, KELVIN

Violation CodeObservationViolation Citation

06-01-4

Path to door marked as an exit is blocked. For reporting purposes only. Blocked by mattresses and other discarded equipment near room 112

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FL123630 expired 12/05/2020. Operator provided new boiler certificate and posted during inspection. FL \*\*Corrected On-Site\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6202970

LANDMARK MOTEL

License Type: Motel

1930 N 4 ST, ST PETERSBURG 337044396

Inspection Date: 05/19/2021

Inspection Number: 1216261

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: LOZANO, KELVIN

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Next to room 108. No means to break glass

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216066

LULA REALTY CORP

License Type: Apartment

4190 58 ST N, KENNETH CITY 33709

Inspection Date: 05/18/2021

Inspection Number: 1501921

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HOBBS, ANDREW

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Near unit 46

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6201537 PARK HOUSE APARTMENTS  
 License Type: Apartment 3980 64 ST N, ST. PETERSBURG 33709

Inspection Date: 05/18/2021 Inspection Number: 1497376 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: HOBBS, ANDREW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Near unit 37	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6211956 KENWOOD INN  
 License Type: Motel 451 34 ST N, ST. PETERSBURG 33713

Inspection Date: 05/13/2021 Inspection Number: 1213833 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Admin. complaint recommended  
 Inspector Name: HOBBS, ANDREW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-05-4	- From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only. No strikers on any fire extinguishers. - From follow-up inspection 2021-03-17: No strikers observed **Time Extended** - From follow-up inspection 2021-04-01: No strikers present on locked boxes - From follow-up inspection 2021-04-16: No strikers on fire extinguisher boxes **Time Extended** - From follow-up inspection 2021-04-19: **Time Extended** - From follow-up inspection 2021-05-03: - From follow-up inspection 2021-05-13: Several boxes require strikers	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Inspection Date: 05/17/2021 Inspection Number: 1213833 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Admin. complaint recommended  
 Inspector Name: HOBBS, ANDREW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-05-4	- From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only. No strikers on any fire extinguishers. - From follow-up inspection 2021-03-17: No strikers observed **Time Extended** - From follow-up inspection 2021-04-01: No strikers present on locked boxes - From follow-up inspection 2021-04-16: No strikers on fire extinguisher boxes **Time Extended** - From follow-up inspection 2021-04-19: **Time Extended** - From follow-up inspection 2021-05-03: - From follow-up inspection 2021-05-13: Several boxes require strikers - From follow-up inspection 2021-05-17: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Polk County**

License Number: 6300996

QUALITY INN & SUITES WINTER HAVEN

License Type: Motel

5651 CYPRESS GARDENS BLVD, WINTER HAVEN 33884

Inspection Date: 05/21/2021

Inspection Number: 1217030

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JACKSON, SHARON

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 03/01/2021

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Santa Rosa County**

License Number: 6700912

THACKER 2 APARTMENTS

License Type: Apartment

6126 PINE BLOSSOM RD, MILTON 32570

Inspection Date: 05/20/2021

Inspection Number: 1506848

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: ALBRITTON, GREGORY

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6701096

THACKER 1 APARTMENTS

License Type: Apartment

6407 NORTH HWY 87, MILTON 32570

Inspection Date: 05/20/2021

Inspection Number: 1506648

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: ALBRITTON, GREGORY

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.