

Bay County

License Number: 1303872

TWIN OAKS APTS

License Type: Apartment

6201 CHERRY STREET, CALLAWAY 32404

Inspection Date: 05/24/2021

Inspection Number: 1490902

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: DESHAZIER, ERNEST

Violation Code ObservationViolation Citation

01-03-4 Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1304002

IDO SHANY RENTALS

License Type: Apartment

2223 JOAN AVE, PANAMA CITY BEACH 32408

Inspection Date: 05/24/2021

Inspection Number: 1504342

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: LYNN, NICKOLAS

Violation Code ObservationViolation Citation

02-08-4 Propane (LP gas) tank having a water capacity greater than 2.7 lbs stored under a stairwell. For reporting purposes only. In front of 121.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621113

LEHMAN PROPERTY MANAGEMENT INC

License Type: Apartment

1903 THOMAS ST, HOLLYWOOD 33020

Inspection Date: 05/25/2021

Inspection Number: 1503366

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHRISTGEN, THOM

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed on the West side of unit 8.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2305709		HIALEAH AIRPORT MOTEL	
License Type: Motel		131-161 W OKEECHOBEE RD, HIALEAH 33010	
Inspection Date: 05/24/2021	Inspection Number: 1216104	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: PRIETO, EDGAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Room #316. **Repeat Violation** - From follow-up inspection 2021-05-24: During the time of the callback inspection observed portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Room #316. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329403		GUILD (THE)	
License Type: Hotel		230 NE 4 ST, MIAMI 33128	
Inspection Date: 05/24/2021	Inspection Number: 1156979	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation** **Warning** - From follow-up inspection 2021-05-24: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2330626		VILLA PINA APARTMENTS	
License Type: Apartment		619 SW 2 STREET, MIAMI 33130	
Inspection Date: 05/28/2021	Inspection Number: 1512619	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CONCEPCION, ADRIEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm and silence alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2301265		THERESA APTS	
License Type: Apartment		127 SW 16 AVE, MIAMI 331352192	
Inspection Date: 05/26/2021	Inspection Number: 1512627	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329260 MERIDIAN HOUSE
 License Type: Hotel 1816 MERIDIAN AVE, MIAMI BEACH 33139

Inspection Date: 05/24/2021 Inspection Number: 1158697 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. Observed no smoke detector inside room number 1, located on the 1st floor.	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2319938 LEXINGTON BY HOTEL RL MIAMI BEACH
 License Type: Hotel 4299 COLLINS AVE, MIAMI BEACH 331403290

Inspection Date: 05/26/2021 Inspection Number: 1158181 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificate expired on 2/11/2021. - From follow-up inspection 2021-05-26: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-04-4	- From initial inspection : Boiler certificate not posted in the boiler room. For reporting purposes only. No boiler certificate was posted. - From follow-up inspection 2021-05-26: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329293 THE NEW CASABLANCA ON THE OCEAN
 License Type: Hotel 6345 COLLINS AVE, MIAMI BEACH 33141

Inspection Date: 05/28/2021 Inspection Number: 1158241 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: PRIETO, VICENTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2021-05-28: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329481 RADISSON RED MIAMI AIRPORT
 License Type: Hotel 3401 NW 25 ST, MIAMI 33142

Inspection Date: 05/27/2021 Inspection Number: 1151411 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection
 Inspector Name: CRUZ, EDGAR Inspection Completed - No Further Action

Violation Code ObservationViolation Citation

08-03-4 No boiler certificate or insurance inspector's boiler report available.
 For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330625 FLM MIAMI PROPERTIES
 License Type: Apartment 1864 NW 24TH ST, MIAMI 33142

Inspection Date: 05/28/2021 Inspection Number: 1512032 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection
 Inspector Name: HODGE, KRISTEN Inspection Completed - No Further Action

Violation Code ObservationViolation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access
 to the fire extinguisher. For reporting purposes only. Observed fire
 extinguisher located on the 1st and 2nd floor no breaking device
 observed, boxes are locked. As indicated on box, front plastic panel
 must be broken to access fire extinguisher.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2323582 RODEWAY INN SOUTH MIAMI - CORAL GABLES
 License Type: Hotel 5959 SW 71 ST, MIAMI 33143

Inspection Date: 05/25/2021 Inspection Number: 1157113 Inspection Type: Routine - Lodging Inspection Disposition: Call Back -
 Inspector Name: MASKASEM, SUPPACHAI Complied

Violation Code ObservationViolation Citation

04-02-4 - From initial inspection : No smoke detector provided in guest
 room/unit. For reporting purposes only.
 Observed the smoke detector of room 407 without the battery .
 Observed smoke detector of room 410 missing. - From follow-up
 inspection 2021-05-25: **Time Extended**

509.215(1) and (2) and 509.032(2)(d) FS Reporting:
 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2318561

SUNSET WAY

License Type: Apartment

15385 SW 73 TER CIR, MIAMI 33193

Inspection Date: 05/26/2021

Inspection Number: 1512557

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ELDER, AUDREY

Violation Code Observation

Violation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
Observed no breaking device provided to access fire extinguisher at building 15331 near unit 3.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2603121		APM INN AND SUITES JACKSONVILLE	
License Type: Motel		510 LN AVE S, JACKSONVILLE 32254	
Inspection Date: 05/25/2021	Inspection Number: 1217018	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MERCER, THOMAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher by room 302 has gauge needle in red recharge area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2608861		BEST STAY INN	
License Type: Motel		8220 DIX ELLIS TRAIL, JACKSONVILLE 32256	
Inspection Date: 05/26/2021	Inspection Number: 1217047	Inspection Type: Complaint Full	Inspection Disposition: Administrative complaint recommended
Inspector Name: VILBRUN, JOSUE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher in leasing office next to employee restroom is in the Red	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2600171		MIRAMAR	
License Type: Apartment		5736 TALL PINE LN, JACKSONVILLE 32277	
Inspection Date: 05/28/2021	Inspection Number: 1512633	Inspection Type: Complaint Full	Inspection Disposition: Call Back - Extension given, pending
Inspector Name: THOMAS, PHILIP			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-04-4	- From initial inspection : No portable fire extinguisher present on the premises. For reporting purposes only. Fire extinguishers missing from the following locations including but not limited to 5756 unit 2, 3134 unit 5, 3032 unit 5, 3114 unit 2. - From follow-up inspection 2021-05-28: Fire extinguishers still missing from locations. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only. Fire extinguishers missing from the following locations including but not limited to 5756 unit 2, 3134 unit 5, 3032 unit 5, 3114 unit 2.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Escambia County

License Number: 2705842

SAVOY PLACE

License Type: Apartment

301 N DEVILLIERS ST, PENSACOLA 32501

Inspection Date: 05/27/2021

Inspection Number: 1512604

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ALBRITTON, GREGORY

Violation Code ObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
First floor next to entrance.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2705837

CROW ROAD APARTMENTS

License Type: Apartment

260 CROW RD, PENSACOLA 32506

Inspection Date: 05/26/2021

Inspection Number: 1509165

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: RUSSELL, SARAH

Violation Code ObservationViolation Citation

07-02-4 Exposed electrical wire(s). On back porch of build 380 unit d . For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913671 CONCORD HOSPITALITY ENTERPRISES
License Type: Hotel 3650 MIDTOWN DR, TAMPA 33607

Inspection Date: 05/27/2021 Inspection Number: 1157235 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KLUSENDORF, JEANNE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Control panel by Market by front desk	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3906037 CHASE SUITE HOTEL BY WOODFIN
License Type: Hotel 3075 ROCKY POINT DR, TAMPA 336071439

Inspection Date: 05/26/2021 Inspection Number: 1158405 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
Inspector Name: KLUSENDORF, JEANNE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. By office	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4605574 MAPLE CREST APARTMENTS
 License Type: Apartment 3607 CRESTWOOD LAKE AVE, FORT MYERS 33901

Inspection Date: 05/27/2021 Inspection Number: 1491248 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WALTER, KAYLA

Violation Code ObservationViolation Citation

01-03-4 Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed missing fire extinguisher in building 1-3268 near unit 107.
 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4605674 2145 PROPERTIES
 License Type: Apartment 2145 CANAL ST, FORT MYERS 33901

Inspection Date: 05/27/2021 Inspection Number: 1495001 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PFENNING, BRUNO

Violation Code ObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge across from unit #4. . For reporting purposes only.
 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4601820 HARBOR PALMS
 License Type: Apartment 4100 EDGEWOOD AVE, FORT MYERS 33916

Inspection Date: 05/26/2021 Inspection Number: 1500873 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PFENNING, BRUNO

Violation Code ObservationViolation Citation

01-03-4 Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed fire extinguisher broken off wall on ground on unit #83.
 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4702105

CLAY STREET APARTMENTS

License Type: Apartment

1305 CLAY ST, TALLAHASSEE 323041957

Inspection Date: 05/26/2021

Inspection Number: 1506179

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: LYNN, NICKOLAS

Violation Code ObservationViolation Citation

01-03-4 Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Missing on front side of 7.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4701445

QUALITY INN & SUITES

License Type: Motel

6737 MAHAN DR, TALLAHASSEE 32308

Inspection Date: 05/28/2021

Inspection Number: 1215103

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CHARLES, BRENDA

Violation Code ObservationViolation Citation

01-01-4 Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged: in between room 119 and 120. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5300333

SANDPIPER

License Type: Apartment

555 NE OCEAN BLVD, STUART 34996

Inspection Date: 05/27/2021

Inspection Number: 1512434

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Warning
Issued

Inspector Name: ROTONDI, VICTOR

Violation Code ObservationViolation Citation04-02-4 No smoke detector provided in guest room/unit. For reporting
purposes only. **Warning**509.215(1) and (2) and 509.032(2)(d) FS Reporting:
509.215(1) Each guest room shall be equipped with an
approved listed single-station smoke detector meeting
the minimum requirements of NFPA-74 Standards for
the Installation, Maintenance and Use of Household Fire
Warning Equipment. (2) The building has smoke
detectors in each guest room individually annunciating
to a panel at a supervised location. 509.032(2)(d) The
division, or its agent, shall notify the local firesafety
authority or the State Fire Marshal of any readily
observable violation of a rule adopted under chapter 633
which relates to public lodging establishments or public
food establishments, and the identification of such
violation does not require any firesafety inspection
certification. For reporting purposes only.

License Number: 5300742

HUTCHINSON ISLAND MARRIOTT BEACH RESORT & MARINA

License Type: Hotel

555 NE OCEAN BLVD, STUART 34996

Inspection Date: 05/27/2021

Inspection Number: 1159109

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Warning
Issued

Inspector Name: ROTONDI, VICTOR

Violation Code ObservationViolation Citation04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For
reporting purposes only.man lobby/office509.032(2)(d) FS Reporting: The division, or its agent,
shall notify the local firesafety authority or the State Fire
Marshal of any readily observable violation of a rule
adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

Monroe County

License Number: 5400985 TRUMAN HOTEL
 License Type: Motel 611 TRUMAN AVE, KEY WEST 33040

Inspection Date: 05/24/2021 Inspection Number: 1216368 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTINEZ, YANET

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Located outside room 110.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5402153 BARBARY BEACH HOUSE KEY WEST
 License Type: Hotel 2001 ROOSEVELT BLVD, KEY WEST 33040

Inspection Date: 05/24/2021 Inspection Number: 1159140 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied
 Inspector Name: ENDERS, PAMELA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. From follow-up inspection 2021-05-24: Provided information to obtain reports. **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5600131 HOLLAND TOWNHOUSE APARTMENTS
 License Type: Apartment 201 TAYLOR CR, FT WALTON BCH 325472696

Inspection Date: 05/21/2021 Inspection Number: 1508470 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: BURROUGHS, RICHARD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-01-4	Damaged electrical wire(s). For reporting purposes only. - building 2: on the backside at several locations where light fixtures are missing from there is exposed electrical wiring.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5602927 WESVUE APTS
 License Type: Apartment 951 MCFARLAN AVE, FT WALTON BCH 325473822

Inspection Date: 05/24/2021 Inspection Number: 1502593 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BURROUGHS, RICHARD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs stored under a stairwell. For reporting purposes only. - middle stairwell outside apartments 31/32.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-01-4	Damaged electrical wire(s). For reporting purposes only. - apartment 12: backside exterior light hanging from wires.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5603524 GREGG CHAPEL APARTMENTS
 License Type: Apartment 116 MCGRIF ST, FT WALTON BCH 32548

Inspection Date: 05/25/2021 Inspection Number: 1500146 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: ADAMSON, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-01-4	Damaged electrical wire(s). For reporting purposes only. Upon inspection observed low hanging wire from single apartment unit not connected to other apartments (not identified by number or letter) to utility pole.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5600190

AMBASSADOR HOUSE APARTMENTS

License Type: Apartment

18 WRIGHT PKWY, FT WALTON BEACH 32548

Inspection Date: 05/26/2021

Inspection Number: 1500357

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: ADAMSON, ROBERT

Violation Code Observation

Violation Citation

07-01-4 Damaged electrical wire(s). For reporting purposes only.
 Upon inspection observed low hanging wires to utility pole right side of building.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811348 NOVEL LUCERNE
 License Type: Apartment 733 MAIN LN, ORLANDO 32801

Inspection Date: 05/26/2021 Inspection Number: 1499588 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: MONTESANO, MISTI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - main building first floor, Earthfair Panel - From follow-up inspection 2021-04-26: **Time Extended** - From follow-up inspection 2021-05-12: contruction going on in the connected businesses causing the trouble alarm to show. **Time Extended** - From follow-up inspection 2021-05-26: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811386 CITI TOWER APARTMENTS
 License Type: Apartment 101 LAKE AVE, ORLANDO 32801

Inspection Date: 05/27/2021 Inspection Number: 1512489 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MONTESANO, MISTI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inpector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810555 CROWNE PLAZA ORLANDO UNIVERSAL
 License Type: Hotel 7800 UNIVERSAL BLVD, ORLANDO 32819

Inspection Date: 05/24/2021 Inspection Number: 1159125 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BACHOO, SAVITRI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificates or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inpector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5805932

INTOWN SUITES ORLANDO SOUTH LLC

License Type: Hotel

1951 CENTRAL FLORIDA PKWY, ORLANDO 32837

Inspection Date: 05/27/2021

Inspection Number: 1159143

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ALVIS, DAVID

Violation Code Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
 -122593 9-18-2020 ****Repeat Violation****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014061

RESIDENCE INN WEST PALM BEACH DOWNTOWN

License Type: Hotel

455 HIBISCUS ST, WEST PALM BEACH 33401

Inspection Date: 05/26/2021

Inspection Number: 1157990

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: MCCARTHY, RAMONA

Violation Code ObservationViolation Citation

08-01-4 - From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2021-05-26: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6013457

HAMPTON INN WEST PALM BEACH FLORIDA TURNPIKE

License Type: Hotel

2025 VISTA PKWY, WEST PALM BEACH 33411

Inspection Date: 05/27/2021

Inspection Number: 1158902

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: DE JESUS, ARLENNY

Violation Code ObservationViolation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
095172 expiration date 04/30/2021

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6209371

LA QUINTA INN #638

License Type: Motel

7500 HWY 19 N, PINELLAS PARK 33781

Inspection Date: 05/25/2021

Inspection Number: 1216327

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: RANVILLE, AMANDA

Violation Code ObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Fire panel reads NAC EXTENDER BLDG B/C SIG 5 SIGNAL CIRCUIT OPEN CKT TROUBLE.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215975

BOARDWALK APARTMENTS

License Type: Apartment

6401 102 AVE N, PINELLAS PARK 33782

Inspection Date: 05/28/2021

Inspection Number: 1512688

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation Code ObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Near unit 4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6804742

TROPICAL SANDS ACCOMMODATIONS, LLC

License Type: Motel

5830 MIDNIGHT PASS RD, SARASOTA 34242

Inspection Date: 05/28/2021

Inspection Number: 1215161

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back - Admin. complaint recommended

Inspector Name: HOWARTH, ROSALIE

Violation Code Observation

Violation Citation

01-02-4 - From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher out of green range, located in Tower 2 Room 704. ****Repeat Violation**** - From follow-up inspection 2021-05-28: ****Time Extended****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6900032

RAMADA

License Type: Motel

150 DOUGLAS AVE, ALTAMONTE SPRINGS 32714

Inspection Date: 05/25/2021

Inspection Number: 1215153

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: MARTIN, LESLIE

Violation Code Observation

Violation Citation

08-01-4 - From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
-Per State Fire Marshall website boiler 094799 is still active but no boiler certificate available. Per operator only one certificate is provided for both boilers if inspection is satisfactory. - From follow-up inspection 2021-05-25: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501614

ECONO LODGE / ZEN LIVING

License Type: Motel

2535 SR-16 E, SAINT AUGUSTINE 32092

Inspection Date: 05/28/2021

Inspection Number: 1217055

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: GOSAI, MATT

Violation Code Observation

Violation Citation

07-02-4 Dangling connected power outlet on floor under Air conditioner unit in 251.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.