

Alachua County

License Number: 1103014

GNV CITY CENTER LLC - THE PALMS

License Type: Apartment

230 SW 2 AVE, GAINESVILLE 32601

Inspection Date: 06/11/2021

Inspection Number: 1512690

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: PACE, PATRICK

Violation Code

Observation

Violation Citation

04-06-4

Fire alarm control panel emitting an audible alarm. For reporting purposes only.
From riser room on back side of building. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1505854

825 EAST UNIVERSITY BLVD

License Type: Apartment

825 E UNIVERSITY BLVD, MELBOURNE 32901

Inspection Date: 06/11/2021

Inspection Number: 1512642

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: QUINONES, ANTONIO

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher between unit 103&104

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1607221

FORT LAUDERDALE GRAND HOTEL

License Type: Hotel

4900 POWERLINE ROAD, OAKLAND PARK 33309

Inspection Date: 06/09/2021

Inspection Number: 1159204

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BENJAMIN, ALEXANDER

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2309300		LUCKY SEABASS, LLC	
License Type: Apartment		1915 NW 19 AVE, MIAMI 33125	
Inspection Date: 06/10/2021	Inspection Number: 1512800	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed extinguisher without braking device located on second floor between Units 4 and 5.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2305567		LEAMINGTON HOTEL	
License Type: Hotel		307 NE 1 ST, MIAMI 33132	
Inspection Date: 06/07/2021	Inspection Number: 1158183	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: PAGAN, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2021-06-07: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2328062		PARK PLACE BY THE BAY	
License Type: Apartment		915 NW 1 AVE, MIAMI 33136	
Inspection Date: 06/08/2021	Inspection Number: 1502681	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2302499		ZENWOTEL	
License Type: Apartment		1385 NE 105TH ST., MIAMI 33138	
Inspection Date: 06/11/2021	Inspection Number: 1512213	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PAGAN, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2305308		CAVALIER HOTEL	
License Type: Hotel		1320 OCEAN DR, MIAMI BEACH 33139	
Inspection Date: 06/11/2021	Inspection Number: 1158518	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329233		WALDORF TOWERS HOTEL	
License Type: Hotel		860 OCEAN DR, MIAMI BEACH 33139	
Inspection Date: 06/10/2021	Inspection Number: 1158666	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Near room 102.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329239		SLS SOUTH BEACH	
License Type: Hotel		1701 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 06/11/2021	Inspection Number: 1159152	Inspection Type: Complaint Full	Inspection Disposition: Call Back - Complied
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2021-06-11: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329270		REAL PROPERTIES LENOX LLC	
License Type: Apartment		1611 LENOX AVE, MIAMI BEACH 33139	
Inspection Date: 06/04/2021	Inspection Number: 1503420	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-04-4	- From initial inspection : Fire alarm control panel has no power. For reporting purposes only. - From follow-up inspection 2021-06-04: Panel has power, but trouble alarm light on. **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Duval County

License Number: 2609702

COUNTRY INN & SUITES JACKSONVILLE SOUTH I-95

License Type: Hotel

4690 SALISBURY RD, JACKSONVILLE 32256

Inspection Date: 06/07/2021

Inspection Number: 1159180

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: VILBRUN, JOSUE

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Jurisdiction 133133 exp 7-14-19 & Jurisdiction 099841 exp 7-14-19
Operator stated already had inspection completed but has not received new certification and

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2600171

MIRAMAR

License Type: Apartment

5736 TALL PINE LN, JACKSONVILLE 32277

Inspection Date: 06/07/2021

Inspection Number: 1512633

Inspection Type: Complaint Full

Inspection Disposition: Call Back - Complied

Inspector Name: THOMAS, PHILIP

Violation CodeObservationViolation Citation

01-04-4

- From initial inspection : No portable fire extinguisher present on the premises. For reporting purposes only.
Fire extinguishers missing from the following locations including but not limited to 5756 unit 2, 3134 unit 5, 3032 unit 5, 3114 unit 2. -

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613445

JUSTINA COURT APARTMENTS

License Type: Apartment

5844 JUSTINA CT, JACKSONVILLE 32277

Inspection Date: 06/11/2021

Inspection Number: 1509686

Inspection Type: Lodging-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THOMAS, PHILIP

Violation CodeObservationViolation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only.
Propane tank stored under interior stairwell between units 1 and 9.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2702778

KEY WEST INN

License Type: Motel

6900 PENSACOLA BLVD, PENSACOLA 32505

Inspection Date: 06/08/2021

Inspection Number: 1212857

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: RUSSELL, SARAH

Violation CodeObservationViolation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Smoke alarm missing on room 123. **Repeat Violation**

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2705820

SUBURBAN EXTENDED STAY PENSACOLA

License Type: Hotel

3984 BARRANCAS AVE, PENSACOLA 32507

Inspection Date: 06/09/2021

Inspection Number: 1159162

Inspection Type: Complaint Partial

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: RUSSELL, SARAH

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Panel beeping stating fire. Written Sign on panel states damaged from hurricane.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hamilton County

License Number: 3400112

BUDGET INN OF JASPER

License Type: Motel

8182 SR 6 W, JASPER 32052

Inspection Date: 06/07/2021

Inspection Number: 1217098

Inspection Type: Complaint Full

Inspection Disposition: Administrative complaint recommended

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Between rooms 304 and 305. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3900037

TAMPA INN

License Type: Motel

2901 E BUSCH BLVD, TAMPA 33612

Inspection Date: 06/07/2021

Inspection Number: 1217067

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JAIME, ANTONY

Violation Code Observation

Violation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed by room 354.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4600947

PARKER HOUSE PROPERTIES

License Type: Apartment

808 MIRAMAR ST, CAPE CORAL 33904

Inspection Date: 06/08/2021

Inspection Number: 1491231

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: SOMMERS, KARA

Violation Code

Observation

Violation Citation

01-01-4 - From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Extinguisher between Units 8 & 9. - From follow-up inspection 2021-06-08:

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4700634

AOTD HOLDINGS, LLC

License Type: Apartment

1698 STUCKEY AVE, TALLAHASSEE 32310

Inspection Date: 06/09/2021

Inspection Number: 1512613

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: STESLOW, KEVIN

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.

Observed exposed electrical wires on the south end of building.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5401502

OCEAN KEY RESORT

License Type: Hotel

ZERO DUVAL ST, KEY WEST 33040

Inspection Date: 06/10/2021

Inspection Number: 1158785

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. By Hot Tin roof, second floor.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811205		HOLIDAY INN EXPRESS - ORLANDO - SOUTH PARK	
License Type: Hotel		2776 DESTINATION PKWY, ORLANDO 32819	
Inspection Date: 06/09/2021	Inspection Number: 1159205	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KOSTELNY, ROGER			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Room 521 on the panel behind the front desk. Operator is aware and they are waiting for part and room will not be rented until part is fixed.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 5811116		FAIRFIELD INN & SUITES ORLANDO AT SEAWORLD	
License Type: Hotel		10815 INTERNATIONAL DR, ORLANDO 32821	
Inspection Date: 06/07/2021	Inspection Number: 1158755	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ALVIS, DAVID			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 5800051		CYPRESS POINTE RESORT	
License Type: Vacation Rental - Condo		8651 TREASURE CAY LN, ORLANDO 328366437	
Inspection Date: 06/11/2021	Inspection Number: 1088478	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: SPEIGHTS, BLANCHIE MACHELLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed 8/25/2019 expired in building 8.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Osceola County

License Number: 5913650

STUDIO 6 #6050

License Type: Motel

5733 W IRLON BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 06/08/2021

Inspection Number: 1215403

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: ALVIS, DAVID

Violation CodeObservationViolation Citation

08-01-4 - From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. For one boiler -
From follow-up inspection 2021-06-08: Time extended until next unannounced inspection **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900643

QUALITY INN & SUITES BY THE LAKE KISSIMMEE

License Type: Motel

7785 W US 192, KISSIMMEE 34747

Inspection Date: 06/09/2021

Inspection Number: 1215070

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: FERTIL, SYLVERST

Violation CodeObservationViolation Citation

08-01-4 - From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2021-06-09: Operator states inspection is scheduled for Tomorrow. Violation will be verified durin

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6002361

AQUA MOTEL

License Type: Motel

7802 S DIXIE HWY, WEST PALM BEACH 33405-4820

Inspection Date: 06/08/2021

Inspection Number: 1216742

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: SINGH, GAJENDRA

Violation Code

Observation

Violation Citation

01-02-4 - From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge in guest laundry room. For reporting purposes only. - From follow-up inspection 2021-06-08: Same **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215790 600 COREY
 License Type: Apartment 600 COREY AVE, SAINT PETERSBURG BCH 33706

Inspection Date: 06/09/2021 Inspection Number: 1512759 Inspection Type: Lodging-Licensing Inspection Disposition: Administrative
 Inspector Name: DAY-WALKER, LISA Inspection complaint recommended

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher in recharge zone near unit 127.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215957 CZYSZCZON VENTURES LLC
 License Type: Apartment 4209 GULF BLVD, ST.PETE BEACH 33706

Inspection Date: 05/28/2021 Inspection Number: 1496376 Inspection Type: Routine - Lodging Inspection Disposition: Inspection
 Inspector Name: KOUSTIS, TIMOTHY Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Observed: Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Near unit 4 Priority: Reporting	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6209700 QUALITY INN & SUITES
 License Type: Motel 3655 HOSPITALITY LN, CLEARWATER 33762

Inspection Date: 06/07/2021 Inspection Number: 1216145 Inspection Type: Routine - Lodging Inspection Disposition: Call Back -
 Inspector Name: LANTIGUA, ROBERTO Complied

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2021-06-07: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6201823 SEASIDE INN & SUITES
 License Type: Motel 401 S GULFVIEW BLVD, CLEARWATER BEACH 33767

Inspection Date: 06/07/2021 Inspection Number: 1217103 Inspection Type: Complaint Full Inspection Disposition: Inspection
 Inspector Name: KOUSTIS, TIMOTHY Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to room 217	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6213566

133LASPALMAS, LLC

License Type: Apartment

11916 133 AVE, LARGO 33778

Inspection Date: 06/11/2021

Inspection Number: 1489971

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BEACHAM, MICHELLE

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher
is in need of recharge. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its
agent, shall notify the local firesafety authority or the
State Fire Marshal of any readily observable violation of
a rule adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

Sarasota County

License Number: 6804746

MORRILL INVESTMENTS LLC

License Type: Apartment

308 OHIO PLACE, SARASOTA 34236

Inspection Date: 06/10/2021

Inspection Number: 1498469

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MCKEON, MICHAEL

Violation Code

Observation

Violation Citation

01-04-4 No portable fire extinguisher present on the premises. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400673

BEST WESTERN DAYTONA INN SEABREEZE

License Type: Motel

730 N ATLANTIC AVE, DAYTONA BCH 321183805

Inspection Date: 06/07/2021

Inspection Number: 1217094

Inspection Type: Complaint Full

Inspection Disposition: Administrative
complaint recommended

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4 - From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

- From follow-up inspection 2021-06-10: -control panel showing trouble on 6-10-2021

License Number: 7406455

SMRYNA FISH BED AND BREAKFAST

License Type: Bed and Breakfast

6108 S ATLANTIC AVE, NEW SMYRNA BEACH 32169

Inspection Date: 06/11/2021

Inspection Number: 1094044

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PICHARDO, RENEE

Violation CodeObservationViolation Citation

01-04-4 No portable fire extinguisher present on the premises. For reporting purposes only. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-02-4 No smoke detector provided in guest room/unit. For reporting purposes only. 3rd floor unit

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.