

Brevard County

License Number: 1500173

INTERNATIONAL PALMS RESORT & CONFERENCE CENTER COCOA BEACH

License Type: Motel

1300 N ATLANTIC AVE, COCOA BEACH 32931

Inspection Date: 06/17/2021

Inspection Number: 1216067

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: FRANZ, LINDA

Violation Code

Observation

Violation Citation

01-02-4 - From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By housekeeping room. - From follow-up inspection 2021-06-17: ****Time Extended****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1604152 1129 NW 3RD STREET, LLC
 License Type: Apartment 2019 JACKSON ST, HOLLYWOOD 33020

Inspection Date: 06/18/2021 Inspection Number: 1512929 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CHRISTGEN, THOM Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed on Fire Extinguisher on a Third floor South end.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620899 CIRC BY SONDER
 License Type: Hotel 1780 POLK ST, HOLLYWOOD 33020

Inspection Date: 06/15/2021 Inspection Number: 1158134 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: BARTON, GEOFFREY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Boilers recertified Hartford Steam Boiler June 2020. No current certificate available. **Repeat Violation** - From follow-up inspection 2021-06-15: Observed at callback inspection same. **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1602179 FORT LAUDERDALE MARRIOTT POMPANO BEACH
 License Type: Hotel 1200-1208 N OCEAN BLVD, POMPANO BEACH 33062

Inspection Date: 06/15/2021 Inspection Number: 1158146 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: BURGGRAVE, BROCK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. At main panel and behind front desk office panel. - From follow-up inspection 2021-06-15: Trouble light observed on. **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1610903 HOTEL POMPANO BEACH
 License Type: Motel 1201 NW 31ST AVE, POMPANO BEACH 33069

Inspection Date: 06/16/2021 Inspection Number: 1217122 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: BURGGRABE, BROCK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. At laundry room fire extinguisher.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620706 BLUE PARROT INN
 License Type: Apartment 2617 NE 13 CT, FORT LAUDERDALE 33304

Inspection Date: 06/18/2021 Inspection Number: 1504485 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: BRANN, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. NE corner by Apt 4. - From follow-up inspection 2021-06-18: Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. NE corner by Apt 4. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1604111 TRAVELODGE
 License Type: Motel 1251 E SUNRISE BLVD, FORT LAUDERDALE 33304-2810

Inspection Date: 06/16/2021 Inspection Number: 1215294 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: BRANN, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By unit 218. - From follow-up inspection 2021-06-16: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Columbia County

License Number: 2200160

BAYMONT INN

License Type: Motel

3598 W US HWY 90, LAKE CITY 32055

Inspection Date: 06/16/2021

Inspection Number: 1217137

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BAILEY, KIMBERLY

Violation Code Observation

Violation Citation

04-02-4 No smoke detector provided in guest room/unit. For reporting purposes only. Room 118, operator placed fire detector in correct location in room. ****Corrected On-Site****

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329137 HOLIDAY INN EXPRESS
 License Type: Hotel 35200 SOUTH DIXIE HWY, FLORIDA CITY 33034

Inspection Date: 06/18/2021 Inspection Number: 1157897 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: LODENQUAI, BARRINGTON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2021-06-18: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328390 SAGAMORE MIAMI BEACH
 License Type: Hotel 1671 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 06/14/2021 Inspection Number: 1159207 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel due to phone line, which engineering is the process of repairing . For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329347 1355 DREXEL AVENUE LLC
 License Type: Hotel 1355 57 DREXEL AVE, 440 14 ST, MIAMI BEACH 33139

Inspection Date: 06/15/2021 Inspection Number: 1159089 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-04-4	Fire alarm control panel has no power. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328318 BEST WESTERN PLUS ATLANTIC BEACH RRSORT
 License Type: Hotel 4101 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 06/18/2021 Inspection Number: 1159227 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed inspection for boilers was conducted on 6/3/2021, but certificates are not ready. Pending action observed.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2303707 SUNSET CLUB APTS
 License Type: Apartment 6267 SUNSET DR, SOUTH MIAMI 331438833

Inspection Date: 06/18/2021 Inspection Number: 1512640 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PICO, JORGE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed the fire extinguisher near apartment E7, on the second floor of building 6265, in the recharge zone	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed the fire extinguisher on the third floor of building 6265, near the apartment E-13, without the glass breaking hammer.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2309567 CORAL HAVEN APARTMENTS
 License Type: Apartment 10255 CORAL WAY, MIAMI 33165

Inspection Date: 06/16/2021 Inspection Number: 1512975 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: AZPURUA, JULIO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed box missing breaking device next to apartments #462 and #151.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329376

WOODSPRING SUITES MIAMI SOUTHWEST

License Type: Hotel

16055 SW 117 AVE, MIAMI 33177

Inspection Date: 06/18/2021

Inspection Number: 1158674

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330629

MAX'S LANDING

License Type: Apartment

8905 SW 169 CT, MIAMI 33196

Inspection Date: 06/14/2021

Inspection Number: 1511096

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ELDER, AUDREY

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913532

LA QUINTA INN # 965

License Type: Hotel

310 GRAND REGENCY BLVD, BRANDON 33510

Inspection Date: 06/15/2021

Inspection Number: 1158314

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: HALILOVIC, ALEKSANDAR

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 132744 1/31/21 expired , 132767 1/31/21 expired - From follow-up inspection 2021-06-15: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3910982

RAMADA WEST SHORE TAMPA

License Type: Hotel

1200 North WESTSHORE BLVD, TAMPA 33607

Inspection Date: 06/16/2021

Inspection Number: 1159212

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CANNELLA, MARK

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3901853

PACIFICA FOXCROFT LLC

License Type: Apartment

3807 TOWER RD, TAMPA 33614

Inspection Date: 06/16/2021

Inspection Number: 1512946

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ZHANG, JACKY

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Both 1st floor and 2nd floor of building 3831, 3832 and building 3914.
2nd floor of building 3838.
1st floor of building 3918.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

No portable fire extinguisher present on the premises. For reporting purposes only.
Building 3832, 3903 and 3914.

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
1st floor of building 3838. **Repeat Violation**

Hillsborough County

License Number: 3905638 TUSCANY POINTE II (M-O) OWNER LLC
 License Type: Apartment 3350 WEST HILLSBOROUGH AVENUE, TAMPA 33614

Inspection Date: 06/15/2021 Inspection Number: 1512940 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: ZHANG, JACKY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Next to unit 118.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3900493 THE RIVIERA AT 8412
 License Type: Apartment 8412 RIO BRAVO COURT, TAMPA 33617

Inspection Date: 06/14/2021 Inspection Number: 1512435 Inspection Type: Complaint Full Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: REGAS, ANTHONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed missing fire extinguishers at buildings 5, 14,22 and 27. - From follow-up inspection 2021-06-14: Missing at buildings 5, 14,22, and 27. still. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Indian River County

License Number: 4100157

ISLANDER INN RESORT (THE)

License Type: Motel

3101 OCEAN DR, VERO BEACH 32963

Inspection Date: 06/15/2021

Inspection Number: 1216927

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SCHUCK, GREGORY

Violation Code

Observation

Violation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. Behind office under stairwell

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4605078

INTOWN SUITES FORT MYERS

License Type: Hotel

7071 LAKERIDGE CT SW, FORT MYERS 33907

Inspection Date: 06/16/2021

Inspection Number: 1159200

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ORDONEZ, ADADBELLA

Violation Code

Observation

Violation Citation

07-04-4

Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Observed damaged outlet in kitchen in room 111

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5103072

HOLIDAY INN EXPRESS & SUITES BRADENTON WEST

License Type: Hotel

4450 47 ST W, BRADENTON 34210

Inspection Date: 06/14/2021

Inspection Number: 1156810

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: CARMASSI, BRADLEY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2021-06-14: Technicians were on site to repair trouble alarm at time of inspection. **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2021-06-14: Technicians were on site to repair trouble alarm at time of inspection. **Admin Complaint**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5200203

DAYS INN OCALA NORTH SPACE COAST HOSPITALITY LLC

License Type: Motel

3811 NW BLITCHON RD, OCALA 34482

Inspection Date: 06/17/2021

Inspection Number: 1217153

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DRIGGERS, MANDY

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested.
For reporting purposes only.
Smoke detector light is not working.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5603637

SOMERSET BEACHSIDE APARTMENTS WEST BUILDING

License Type: Apartment

480 SANTA ROSA BLVD, FORT WALTON BEACH 32548

Inspection Date: 06/15/2021

Inspection Number: 1511651

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ADAMSON, ROBERT

Violation Code

Observation

Violation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside between units 211-210.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5800312

MAGNOLIA TOWERS

License Type: Apartment

100 E ANDERSON ST, ORLANDO 328013756

Inspection Date: 06/16/2021

Inspection Number: 1490488

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: MONTESANO, MISTI

Violation CodeObservationViolation Citation

08-01-4 - From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2021-06-16: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5801277

COCO KEY HOTEL AND WATER RESORT ORLANDO

License Type: Motel

7400 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 06/15/2021

Inspection Number: 1217132

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BACHOO, SAVITRI

Violation CodeObservationViolation Citation

08-01-4 Boiler certificates or insurance inspector's boiler report expired. For reporting purposes only. Boiler have been inspected.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810948

VENTERRA REALTY

License Type: Apartment

4902 MILLENIA BLVD, ORLANDO 32839

Inspection Date: 06/18/2021

Inspection Number: 1492537

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PASIECKI, VICTORIA

Violation CodeObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Building 4473 outside apartment 103

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900225

SERALAGO HOTEL AND SUITES MAINGATE EAST

License Type: Hotel

5678 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 06/14/2021

Inspection Number: 1159195

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FERTIL, SYLVERST

Violation Code

Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

103024- 12/10/20, 092576- 12/10/20, 092581-12/10/20, 070715-12/10/20 - Operator is working on scheduling all inspections.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6203064		TRADEWINDS SANDPIPER BEACH RESORT	
License Type: Motel		6000 GULF BLVD, ST. PETE BEACH 33706	
Inspection Date: 06/16/2021	Inspection Number: 1217143	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DAY-WALKER, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Yellow trouble light illuminated in front lobby. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6204808		THE BEACHCOMBER BEACH RESORT HOTEL	
License Type: Motel		6200 GULF BLVD, ST.PETE BEACH 33706	
Inspection Date: 06/15/2021	Inspection Number: 1212282	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: HOBBS, ANDREW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6215962		600 COREY	
License Type: Apartment		600 COREY AVE STE 3, ST.PETE BEACH 33706	
Inspection Date: 06/09/2021	Inspection Number: 1513010	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Administrative complaint recommended
Inspector Name: DAY-WALKER, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Observed: Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher in recharge zone near unit 127. Priority: Reporting	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6216188		SNLE INVESTMENTS	
License Type: Apartment		140 112TH AVE, TREASURE ISLAND 33706	
Inspection Date: 06/18/2021	Inspection Number: 1513005	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DAY-WALKER, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher near unit 3 is in recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Pinellas County

License Number: 6211956 KENWOOD INN
 License Type: Motel 451 34 ST N, ST. PETERSBURG 33713

Inspection Date: 06/17/2021 Inspection Number: 1213833 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: HOBBS, ANDREW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-05-4	- From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only. No strikers on any fire extinguishers. - From follow-up inspection 2021-03-17: No strikers observed **Time Extended** - From follow-up inspection 2021-04-01: No strikers present on locked boxes - From follow-up inspection 2021-04-16: No strikers on fire extinguisher boxes **Time Extended** - From follow-up inspection 2021-04-19: **Time Extended** - From follow-up inspection 2021-05-03: - From follow-up inspection 2021-05-13: Several boxes require strikers - From follow-up inspection 2021-05-17: **Time Extended** - From follow-up inspection 2021-06-17:	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215692 BEATRICE PROPERTIES LLC
 License Type: Apartment 600 S BETTY LN, CLEARWATER 33756

Inspection Date: 06/18/2021 Inspection Number: 1512888 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LANTIGUA, ROBERTO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. West stairwell.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216132 MONTEGO BAY VILLAS
 License Type: Apartment 401 1 AVE NE, LARGO 33770

Inspection Date: 06/18/2021 Inspection Number: 1512967 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: LANTIGUA, ROBERTO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By unit 409 A.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400921 SR OLEANDER LLC
 License Type: Apartment 2525 N OLEANDER AVE, DAYTONA BEACH 32118

Inspection Date: 06/15/2021 Inspection Number: 1512953 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WOOD, JUSTIN Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. -propane tank next to grill outside unit 102. Underneath stairwell/platform	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406424 NEWPORT SOUND
 License Type: Apartment 10101 NEWPORT SOUND PLACE, NEW SMYRNA BEACH 32168

Inspection Date: 06/14/2021 Inspection Number: 1512944 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended
 Inspector Name: PICHARDO, RENEE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2021-06-15: **Time Extended** - From follow-up inspection 2021-06-18: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2021-06-15: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.