

Broward County

License Number: 1602282 HOLLYWOOD BEACH HOTELS- SEAGUL
 License Type: Motel 1915 N OCEAN DR, HOLLYWOOD 33019

Inspection Date: 06/24/2021 Inspection Number: 1217177 Inspection Type: Complaint Full
 Inspector Name: LONDONO, GLORIA

Inspection Disposition: Inspection Completed - No Further Action

Violation Code ObservationViolation Citation

04-03-4 Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Unit # 602

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1610903 HOTEL POMPANO BEACH
 License Type: Motel 1201 NW 31ST AVE, POMPANO BEACH 33069

Inspection Date: 06/21/2021 Inspection Number: 1217122 Inspection Type: Complaint Full
 Inspector Name: BURGGRABE, BROCK

Inspection Disposition: Call Back - Extension given, pending

Violation Code ObservationViolation Citation

01-02-4 - From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. At laundry room fire extinguisher. - From follow-up inspection 2021-06-21: Fire extinguisher in laun

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4 - From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2021-06-21: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1604728 PULSO MIAMI LLC
 License Type: Apartment 901 NE 16TH AVE, FORT LAUDERDALE 33304

Inspection Date: 06/24/2021 Inspection Number: 1513054 Inspection Type: Routine - Lodging
 Inspector Name: BRANN, JUSTIN

Inspection Disposition: Inspection Completed - No Further Action

Violation Code ObservationViolation Citation

07-04-4 Electrical outlet damaged - wires hanging out of outlet next to left side washer/dryer unit. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1601872

SEA CLUB OCEAN RESORT HOTEL

License Type: Hotel

619 N ATLANTIC BLVD, FORT LAUDERDALE 33304-4127

Inspection Date: 06/23/2021

Inspection Number: 1159245

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation Code ObservationViolation Citation

01-03-4 Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. 5th Floor hose box by Room 510. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1608850

PULSO MIAMI LLC

License Type: Apartment

1401 NE 17TH CT, FORT LAUDERDALE 33305

Inspection Date: 06/24/2021

Inspection Number: 1513109

Inspection Type: Lodging-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation Code ObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By Apt 212.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1610943

PULSO MIAMI LLC

License Type: Apartment

1151 NE 17TH CT, FORT LAUDERDALE 33305

Inspection Date: 06/25/2021

Inspection Number: 1513063

Inspection Type: Lodging-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation Code ObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. 2 extinguishers on East and NE sides.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-03-4 Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Top of rear NE stairs.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620883

WOODSPRING SUITES FORT LAUDERDALE

License Type: Hotel

5700 REESE RD, DAVIE 33314

Inspection Date: 06/21/2021

Inspection Number: 1158922

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BARTON, GEOFFREY

Violation Code Observation

Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed yellow trouble light indicator for smoke detector issue in Room 409

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2102315

THE POINT AT NAPLES

License Type: Apartment

2155 GREAT BLUE DR, NAPLES 34112

Inspection Date: 06/22/2021

Inspection Number: 1499196

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: GRAVES, PETER

Violation Code Observation

Violation Citation

01-05-4 - From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Observed fire extinguisher at building 3, in front of apart 103, Building 5 near apartment 103, 204,203,107, 208, Building 6 near apartment 306

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4 - From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2021-06-22: Observed trouble light illuminated on the fire control panel. ****Time Extended****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2300139		ANHINGA MOTEL	
License Type: Motel		250 S KROME AVE, HOMESTEAD 33030	
Inspection Date: 06/21/2021	Inspection Number: 1217127	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: LEIDECKER, EDILMA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-03-4	Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Observed smoke detector in room 2 damaged.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2330635		ROBERT KING HIGH, LLC	
License Type: Apartment		1407 NW 7 ST, MIAMI 33125	
Inspection Date: 06/25/2021	Inspection Number: 1513026	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2330633		ZOI HOUSE	
License Type: Apartment		2900 SW 28 LN, SUITE E203, MIAMI 33133	
Inspection Date: 06/21/2021	Inspection Number: 1512955	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MASKASEM, SUPPACHAI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329301		HOTEL COLORETTA	
License Type: Hotel		355 WASHINGTON, MIAMI BEACH 33139	
Inspection Date: 06/23/2021	Inspection Number: 1156498	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2021-06-23: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2309749 EDEN ROC
 License Type: Hotel 4525 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 06/22/2021 Inspection Number: 1156463 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: SUAREZ, LEOPOLDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Main panel located next to Inez Cafe. **Repeat Violation** - From follow-up inspection 2021-05-19: Fire alarm company is working	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed 1 new boiler that replaced the old one and will be inspected this year when renewing the other ones. - From foll	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330587 MSFLJ LLC
 License Type: Apartment 3039-3045 NW 21 CT, MIAMI 33142

Inspection Date: 06/25/2021 Inspection Number: 1513083 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONCEPCION, ADRIEL Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-02-4	Frayed/Exposed electrical wire(s) located above unit 2 in building 3045 under upstairs platform.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2302711

NEWPORT BEACHSIDE HOTEL & RESORT

License Type: Motel

16701 COLLINS AVE, SUNNY ISLES BEACH 33160

Inspection Date: 06/24/2021

Inspection Number: 1217181

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HODGE, KRISTEN

Violation Code Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed all boiler certificates Expired as of, 097488 (MAIN BLDG) Expired 9/24/2020, 055203 (BLR RM) Expired 9/24/2020, 015014 (KITCHEN) Expired 11/04/2020.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-04-4 Boiler certificate not posted in the boiler room. For reporting purposes only. Observed boiler certificates not kept posted inside boiler room. Provided emailed copies of boiler jurisdiction number's 097488, 055203 and 015014 to Director of Facilities, C

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5810954

HERITAGE HOTEL

License Type: Motel

7900 S ORANGE BLOSSOM TRAIL, ORLANDO 32809

Inspection Date: 06/22/2021

Inspection Number: 1216643

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: PASIECKI, VICTORIA

Violation Code ObservationViolation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5808315

CARIBE ROYALE RESORT SUITES

License Type: Hotel

8101 WORLD CENTER DRIVE, ORLANDO 32821

Inspection Date: 06/22/2021

Inspection Number: 1157154

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: IRVEN, RYAN

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811139

KEY SUITES

License Type: Hotel

4855 S ORANGE BLOSSOM TRL, ORLANDO 32839

Inspection Date: 06/22/2021

Inspection Number: 1158797

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PASIECKI, VICTORIA

Violation Code ObservationViolation Citation01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Outside room 206

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Hotel

7769 W. IRLO BRONSON MEMORIAL HWY., KISSIMMEE 34747

Inspection Date: 06/21/2021

Inspection Number: 1159236

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: IRVEN, RYAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only by 446.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By room 554	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Panel in trouble. Engineering stated they are the middle of inspection.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6100017

SADDLEBROOK RESORTS CONDO

License Type: Vacation Rental - Condo

5700 SADDLEBROOK WAY, WESLEY CHAPEL 335434411

Inspection Date: 06/22/2021

Inspection Number: 1088432

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: COLE, GABRIELLE

Violation Code Observation

Violation Citation

01-02-4 - From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By Building 3, Room 352. - From follow-up inspection 2021-05-20: ****Time Extended**** - From follo

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6900385

ALTAMONTE SPRINGS HOTEL & SUITES

License Type: Motel

450 DOUGLAS RD, ALTAMONTE SPRINGS 32714

Inspection Date: 06/21/2021

Inspection Number: 1217133

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MARTIN, LESLIE

Violation Code Observation

Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406424

NEWPORT SOUND

License Type: Apartment

10101 NEWPORT SOUND PLACE, NEW SMYRNA BEACH 32168

Inspection Date: 06/25/2021

Inspection Number: 1512944

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: ANGEL, TERRY

Violation Code Observation

Violation Citation

04-01-4 - From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2021-06-15: **Time Extended** - From follow-up inspection 2021-06-18: **Time Extended** -

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.