

Broward County

License Number: 1620706 BLUE PARROT INN
 License Type: Apartment 2617 NE 13 CT, FORT LAUDERDALE 33304

Inspection Date: 06/29/2021 Inspection Number: 1504485 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: BRANN, JUSTIN

Violation Code ObservationViolation Citation

01-02-4 - From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
 NE corner by Apt 4. - From follow-up inspection 2021-06-18: Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
 NE corner by Apt 4. **Time Extended** - From follow-up inspection 2021-06-29: Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
 NE corner by Apt 4. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1601872 SEA CLUB OCEAN RESORT HOTEL
 License Type: Hotel 619 N ATLANTIC BLVD, FORT LAUDERDALE 33304-4127

Inspection Date: 06/29/2021 Inspection Number: 1159215 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied
 Inspector Name: BRANN, JUSTIN

Violation Code ObservationViolation Citation

01-03-4 - From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
 Hose box on landing of 5th floor leading to room 510 - From follow-up inspection 2021-06-29: Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
 Hose box on landing of 5th floor leading to room 510 **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1619051 HOMETOWNE STUDIOS - FORT LAUDERDALE 3512
 License Type: Hotel 3031 W COMMERCIAL BLVD, FORT LAUDERDALE 33309

Inspection Date: 07/01/2021 Inspection Number: 1159271 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: BENJAMIN, ALEXANDER

Violation Code ObservationViolation Citation

08-06-4 Combustibles stored in boiler room. For reporting purposes only.
 Cardboard boxes

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620846

DOUBLETREE BY HILTON SUNRISE - SAWGRASS MILLS

License Type: Hotel

13400 W SUNRISE BLVD, SUNRISE 33323

Inspection Date: 07/02/2021

Inspection Number: 1161528

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: BRADY, OSSIAN

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Observed certificates 098676 expired 02/19/21 and 098655 expired 02/19/21.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Charlotte County

License Number: 1800152

SUNNYBROOK EFFICIENCES

License Type: Apartment

27100 SUNNYBROOK RD, HARBOUR HEIGHTS 33983

Inspection Date: 07/03/2021

Inspection Number: 1528119

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: SAYED, MOHAMMED

Violation Code Observation

Violation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed between units 4 and 5. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2324625 J X & SON'S LLC
 License Type: Apartment 1127 NE 1 AVE, HOMESTEAD 33030

Inspection Date: 06/29/2021 Inspection Number: 1490848 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: AZPURUA, JULIO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light at panel next to unit #5 - From follow-up inspection 2021-06-29: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light at panel next to unit #5 **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2309901 GOLD WAYNE APARTMENTS
 License Type: Apartment 344 NW 2 AVE, HOMESTEAD 330305865

Inspection Date: 07/01/2021 Inspection Number: 1525216 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: LEIDECKER, EDILMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed a portable fire extinguisher locked in box next to unit 2 (building 344) **Warning**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329463 EL CORTIJO LLC
 License Type: Apartment 935 NW 37 AVE, MIAMI 33125

Inspection Date: 07/02/2021 Inspection Number: 1521086 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device on extinguisher located between Apartments 11 and 12.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330639 550 LEJEUNE
 License Type: Apartment 4227 NW 5 ST, MIAMI 33126

Inspection Date: 06/30/2021 Inspection Number: 1512862 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTINEZ, YANET

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Located on 1 floor by unit 2.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328422 VILLAS OF HAVANA LLC
 License Type: Apartment 717 SW 11 AVE, MIAMI 33130

Inspection Date: 06/30/2021 Inspection Number: 1501171 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: AZPURUA, JULIO

Violation Code ObservationViolation Citation

04-01-4 - From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2021-06-30: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Ground fault 0220 Observed. **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2308026 GONZALEZ APTS
 License Type: Apartment 1380 SW 6 ST, MIAMI 331353930

Inspection Date: 07/02/2021 Inspection Number: 1520412 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GARCIA, B OSCAR

Violation Code ObservationViolation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329337 THE ABBEY HOTEL
 License Type: Hotel 300 21 ST, MIAMI BEACH 33139

Inspection Date: 06/30/2021 Inspection Number: 1159244 Inspection Type: Lodging-Licensing Inspection Disposition: Warning Issued
 Inspector Name: HODGE, KRISTEN

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329377 7320 BYRON
 License Type: Hotel 7320 BYRON AVE, MIAMI BEACH 33141

Inspection Date: 06/28/2021 Inspection Number: 1158604 Inspection Type: Lodging-Licensing Inspection Disposition: Warning Issued
 Inspector Name: PRIETO, VICENTE

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328881 THE DEED LLC
 License Type: Bed and Breakfast 11298 SW 155 LN, MIAMI 33157

Inspection Date: 06/30/2021 Inspection Number: 1094294 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: AZPURUA, JULIO Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329442 WYNDHAM GARDEN MIAMI INTERNATIONAL AIRPORT
 License Type: Hotel 4909 NW 36 ST, MIAMI SPRINGS 33166

Inspection Date: 07/02/2021 Inspection Number: 1160354 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, ERIK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed Extinguisher overcharge located between rooms 411 and 412.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2700357

PARK PLACE APARTMENTS

License Type: Apartment

2275 SCENIC HWY, PENSACOLA 325036680

Inspection Date: 05/19/2021

Inspection Number: 1490407

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: MONROE, JANIE

Violation Code ObservationViolation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs stored under a stairwell. For reporting purposes only.
Stairway next to apartment 104 and 105.
Stairway next to apartment 101 and 116.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2702778

KEY WEST INN

License Type: Motel

6900 PENSACOLA BLVD, PENSACOLA 32505

Inspection Date: 07/01/2021

Inspection Number: 1217208

Inspection Type: Complaint Full

Inspection Disposition: Administrative
complaint recommended

Inspector Name: ADAMSON, ROBERT

Violation Code ObservationViolation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.
Upon inspection observed no smoke detector on wall and was located in left upper kitchen cabinet in room 218 and in no smoke detector in room 508. Operator replaced smoke detectors during inspection. **Corrected On-Site**

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3910558

TAMPA PALMS GOLF & CC

License Type: Motel

5811 TAMPA PALMS BLVD, TAMPA 336471090

Inspection Date: 06/29/2021

Inspection Number: 1216194

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: POWELL, DAVID

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler inspection certificate to have expired on 1/3/2021 - From follow-up inspection 2021-06-29: Certification not completed. Must be completed by next inspection **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5102536 SUNRISE INN
License Type: Motel 668 67 ST CIRCLE E, BRADENTON 34208

Inspection Date: 07/02/2021 Inspection Number: 1219478 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CATTLEY, RAYMOND

Violation Code Observation

Violation Citation

04-02-4 No smoke detector provided in guest room/unit. For reporting purposes only. Observed smoke detector in disrepair in room 303.

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5100174 TALTY'S SUN RAY COURT
License Type: Apartment 905 E 30 AVE, BRADENTON 342083947

Inspection Date: 07/01/2021 Inspection Number: 1513171 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CATTLEY, RAYMOND

Violation Code Observation

Violation Citation

07-01-4 Damaged electrical wire(s). For reporting purposes only. Observed unit 929 with wires cut before going into house. Maintenance said that unit is not being rented.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5200159

SILVER RIVER INN

License Type: Motel

5565 E SILVER SPRINGS BLVD, SILVER SPRINGS 34488

Inspection Date: 06/28/2021

Inspection Number: 1217186

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: FIGUEROA-ROBLES, TATIANA

Violation Code Observation

Violation Citation

01-05-4 Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Missing breaking bar on fire extinguishers near room 107 and 104.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400621

LA SIESTA RESORT & MARINA

License Type: Motel

80241 OVERSEAS HWY, ISLAMORADA 33036

Inspection Date: 07/01/2021

Inspection Number: 1217116

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation Code Observation

Violation Citation

04-07-4 Trouble/alarm light illuminated on the smoke detector panel
connected to the fire alarm system. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5603524

GREGG CHAPEL APARTMENTS

License Type: Apartment

116 MCGRIFF ST, FT WALTON BCH 32548

Inspection Date: 05/25/2021

Inspection Number: 1500146

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: MONROE, JANIE

Violation Code Observation

Violation Citation

07-01-4 Damaged electrical wire(s). For reporting purposes only.
 Upon inspection observed low hanging wire from single apartment unit not connected to other apartments (not identified by number or letter) to utility pole.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5808326

GRATIGNY APARTMENTS OF HIALEAH INC

License Type: Apartment

1811 - 1833 BLOSSOM TER, ORLANDO 32839

Inspection Date: 06/30/2021

Inspection Number: 1493350

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PASIECKI, VICTORIA

Violation Code Observation

Violation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Hotel

7769 W. IRLO BRONSON MEMORIAL HWY., KISSIMMEE 34747

Inspection Date: 06/28/2021

Inspection Number: 1159255

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation Code Observation

Violation Citation

01-01-4 Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. By room 643

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014057

COURTYARD BY MARRIOTT JUPITER ABACO

License Type: Hotel

4800 MAIN ST, JUPITER 33458

Inspection Date: 07/02/2021

Inspection Number: 1160747

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: ROTONDI, VICTOR

Violation Code ObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.050731, 050732, 122695 exp 08/08/2020

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6212890

JOLLY ROGER APTS

License Type: Apartment

145 116 AVE, TREASURE ISLAND 337064583

Inspection Date: 06/29/2021

Inspection Number: 1495422

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: DAY-WALKER, LISA

Violation Code ObservationViolation Citation

04-01-4 - From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
System trouble and and alarm 1 and 2 lights on. - From follow-up inspection 2021-06-03: Lights illuminated on fire panel system trouble and alarm 1&2. ****Time Extended**** - From follow-up inspection 2021-06-29: ****Time Extended****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6212290

ANCHOR APARTMENTS

License Type: Apartment

10225 GULF BLVD, TREASURE ISLAND 337064810

Inspection Date: 06/29/2021

Inspection Number: 1502638

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: DAY-WALKER, LISA

Violation Code ObservationViolation Citation

04-03-4 - From initial inspection : Battery missing at smoke detector room 3. For reporting purposes only.
Do not rent room 3 until smoke detector is fully functioning. Manager replaced battery. ****Corrected On-Site**** - From follow-up inspection 2021-06-29: Room occupied ****Time Extended****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215772

INTOWN SUITES

License Type: Hotel

2833 ROOSEVELT BLVD, CLEARWATER 33760

Inspection Date: 06/28/2021

Inspection Number: 1158425

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: WILMOT, TASHARA

Violation Code ObservationViolation Citation

04-01-4 - From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
-hearing impaired smoke detector needs to be mounted to wall
Light not flashing only sound ****Repeat Violation**** - From follow-up inspection 2021-06-28:
hearing impaired smoke detector has a battery connected, but the device isn't flashing. ****Time Extended****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6304815

JJ'S MOTEL

License Type: Motel

6480 MIAMI DR, INDIAN LAKE ESTATES 33855

Inspection Date: 07/02/2021

Inspection Number: 1217199

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: WHITE, CHERYL

Violation Code Observation

Violation Citation

07-03-4	Scorch marks around an electrical outlet. For reporting purposes only. Room 103 by bathroom door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-04-4	Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Room 103 by bed	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406415

HAMPTON INN DAYTONA SPEEDWAY AIRPORT

License Type: Hotel

1715 W INTERNATIONAL SPEEDWAY BLVD, DAYTONA BEACH 32114

Inspection Date: 06/30/2021

Inspection Number: 1159266

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LARSON, SARAH

Violation Code ObservationViolation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401104

LA QUINTA INN & SUITES

License Type: Motel

816 N ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 07/01/2021

Inspection Number: 1218664

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400087

PELICAN CONDOMINIUM (THE)

License Type: Vacation Rental - Condo

2401 S ATLANTIC AVE, NEW SMYRNA BCH 321693467

Inspection Date: 06/29/2021

Inspection Number: 1088490

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: OCASIO-LOPEZ, LISA

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.