

Brevard County

License Number: 1502506 HILTON MELBOURNE BEACH OCEANFRONT
 License Type: Hotel 3003 N HWY A1A, MELBOURNE 32903

Inspection Date: 07/16/2021 Inspection Number: 1160540 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SCHOENLY, BARBARA

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
 On for supervisory working on **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1502461 CLEAR POND ESTATES
 License Type: Apartment 811 CRESTVIEW DR, COCOA 32922

Inspection Date: 07/14/2021 Inspection Number: 1526609 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: WILSON, LANETTE

Violation Code ObservationViolation Citation

01-05-4 Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
 Trash bag hanging from extinguisher case

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1505840 GO BUILDING LLC
 License Type: Apartment 1711-1723 DIXON BLVD, COCOA 32922

Inspection Date: 07/13/2021 Inspection Number: 1517761 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: WILSON, LANETTE

Violation Code ObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Bldg 1717

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1505842 KRAVEN ALBA INVESTMENTS LLC
 License Type: Apartment 1711-1723 DIXON BLVD, COCOA 32922

Inspection Date: 07/13/2021 Inspection Number: 1527060 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: WILSON, LANETTE

Violation Code ObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. 1717 bldg

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620902 SPRINGHILL SUITES FT LAUD MIRAMAR
 License Type: Hotel 10880 MARKS WAY, MIRAMAR 33025

Inspection Date: 07/16/2021 Inspection Number: 1161419 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: NEALY, VALENCIA

Violation Code ObservationViolation Citation

01-01-4 Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
 -Fire extinguisher near room 601.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620846 DOUBLETREE BY HILTON SUNRISE - SAWGRASS MILLS
 License Type: Hotel 13400 W SUNRISE BLVD, SUNRISE 33323

Inspection Date: 07/15/2021 Inspection Number: 1161528 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied
 Inspector Name: BRADY, OSSIAN

Violation Code ObservationViolation Citation

08-01-4 - From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Observed certificates 098676 expired 02/19/21 and 098655 expired 02/19/21. - From follow-up inspection 2021-07-15: Per maintenance supervisor, boiler inspector schedule to come out on Wednesday July 21st to issue boiler certification. **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Clay County

License Number: 2000674

ZEN LIVING SUITES

License Type: Motel

150 PARK AVE, ORANGE PARK 32073

Inspection Date: 07/12/2021

Inspection Number: 1219700

Inspection Type: Complaint Full

Inspection Disposition: Administrative complaint recommended

Inspector Name: BIAVA, GRANT

Violation Code Observation

Violation Citation

08-04-4 Boiler certificate not posted in the boiler room. For reporting purposes only.
No certification in boiler room, manager has copy on his phone.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2325181 1200 SW 3RD ST., LLC
 License Type: Apartment 1200 SW 3 ST, HOMESTEAD 33030

Inspection Date: 07/16/2021 Inspection Number: 1532347 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: GONZALEZ, ALEJANDRO

Violation Code ObservationViolation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed at buildings 1241 and 1261(first and second floor). **Repeat Violation** **Warning**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330483 EMILY INVESTMENTS
 License Type: Apartment 435 SW 9 AVE, HOMESTEAD 33030

Inspection Date: 07/13/2021 Inspection Number: 1529443 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: LEIDECKER, EDILMA

Violation Code ObservationViolation Citation

01-03-4 Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed portable fire extinguisher missing located between unit 208 and 209.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2304734 NOELA APARTMENTS LLC
 License Type: Apartment 3633 NW 9 ST, MIAMI 33125

Inspection Date: 07/09/2021 Inspection Number: 1526191 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: UNZAGA, MILADYS

Violation Code ObservationViolation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device on extinguishers located by unit 11 and also missing by unit 7.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2311173 ROMERZAL 1259 APTS
 License Type: Apartment 1259 NW 4 ST, MIAMI 33125

Inspection Date: 07/14/2021 Inspection Number: 1527944 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, ERIK

Violation Code ObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed extinguisher in recharge zone located on second floor between units 5 and 6.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328942		FOUR SEASONS HOTEL MIAMI	
License Type: Hotel		1435 BRICKELL AVE, MIAMI 33131	
Inspection Date: 07/16/2021	Inspection Number: 1161649	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FL 57334, expiration date 02/04/21; FL 13404 expiration date 02/04/21, expiration date 02/04/21, FL96424 02/04/21, FL 96425 expiration date 02/04/21, 7th floor. FI 017975, expires 07/24/20; FL 017974, expires 05/23/20, 18th floor. FI 057332 expires 2/4/21. FI 134041 2/4/21. FI 134042 2nd floor	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2316091		HOLIDAY INN DOWNTOWN PORT OF MIAMI	
License Type: Hotel		340 BISCAYNE BLVD, MIAMI 33132	
Inspection Date: 07/08/2021	Inspection Number: 1161545	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PAGAN, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329207		SPRINGHILL SUITES BY MARRIOTT	
License Type: Hotel		1311 NW 10TH AVE, MIAMI 33136	
Inspection Date: 07/12/2021	Inspection Number: 1160309	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed by the office, trouble light flashing. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329432		AC HOTEL MIAMI MIDTOWN	
License Type: Hotel		3400 BISCAYNE BLVD, MIAMI 33137	
Inspection Date: 07/16/2021	Inspection Number: 1160957	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SEYBA, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light on indicating room #317 is out of order. Manager cleared trouble light during inspection. **Corrected On-Site**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2302009		THE ALEXANDER HOTEL	
License Type: Hotel		5225 COLLINS AVE, MIAMI BEACH 33140	
Inspection Date: 07/16/2021	Inspection Number: 1161689	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed expired certificates for FL 097316 and 097305 exp 9/17/2020. As per Chief Engineer those boilers were replaced for new units 136650 and 136651. Observed letter stating that Fire Marshal was already notified to get the registration for the new boilers.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2308460		MONTEGO APARTMENTS	
License Type: Apartment		4044 N MERIDIAN AVE, MIAMI BEACH 33140	
Inspection Date: 07/12/2021	Inspection Number: 1522599	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light illuminated (panel located on the garage, next to the laundry)	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329185		CARILLON HOTEL AND SPA	
License Type: Hotel		6801 COLLINS AVENUE, MIAMI BEACH 33141	
Inspection Date: 07/14/2021	Inspection Number: 1161374	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2306730		SHERRY FRONTENAC HOTEL	
License Type: Hotel		6565 COLLINS AVE, MIAMI BEACH 331414613	
Inspection Date: 07/13/2021	Inspection Number: 1161456	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed expiration date on 07/09/2021 for boilers with jurisdiction numbers: 059292 and 057119	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2311910		E D REAL ESTATE INVESTMENT GROUP LLC	
License Type: Apartment		2179 NW 23 ST, MIAMI 33142	
Inspection Date: 07/12/2021	Inspection Number: 1528804	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CONCEPCION, ADRIEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2313718		15390 APARTMENTS LLC	
License Type: Apartment		15390 NE 6 AVE, NORTH MIAMI 33162	
Inspection Date: 07/13/2021	Inspection Number: 1532257	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: STUBBS, CHRISTINE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed no access to fire extinguisher next to apartment #406	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329252		ALOFT DORAL	
License Type: Hotel		3265 NW 107 AVE, DORAL 33172	
Inspection Date: 07/14/2021	Inspection Number: 1161024	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: ALVAREZ, MARGARET			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2321528

LAKESIDE VILLAS APARTMENTS

License Type: Apartment

15410 SW 75 CIRCLE LN, MIAMI 33193

Inspection Date: 07/16/2021

Inspection Number: 1530668

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ELDER, AUDREY

Violation Code Observation

Violation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
Observed no breaking device provided at fire extinguisher box located at building 7 near unit 203.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2609107

DAYS INN JACKSONVILLE AIRPORT

License Type: Hotel

1170 AIRPORT RD, JACKSONVILLE 32218

Inspection Date: 07/15/2021

Inspection Number: 1161531

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: PERRY, DENNIS

Violation Code ObservationViolation Citation

07-01-4 Damaged electrical wire(s). For reporting purposes only.
Wires hanging from exit sign by room 223.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613248

FOUR POINTS BY SHERATON BAYMEADOWS

License Type: Hotel

8520 BAYMEADOWS RD, JACKSONVILLE 32256

Inspection Date: 07/15/2021

Inspection Number: 1159962

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VILBRUN, JOSUE

Violation Code ObservationViolation Citation

01-01-4 Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
Fire extinguisher in the red is in front entrance of housekeeping room stored on floor on right side of the door ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613204

THOMAS CHASE APARTMENTS

License Type: Apartment

4901 SUNBEAM RD, JACKSONVILLE 32257

Inspection Date: 07/12/2021

Inspection Number: 1532246

Inspection Type: Lodging-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JEFFERS, MARY-BETH

Violation Code ObservationViolation Citation

07-01-4 Damaged electrical wire(s). For reporting purposes only.
Hallway light at building #4 hanging from electrical wires/ in disrepair

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2700898

GARDEN INN & SUITES

License Type: Motel

8500 PINE FOREST RD, PENSACOLA 32534

Inspection Date: 07/13/2021

Inspection Number: 1219736

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARDNER, GREGORY

Violation Code ObservationViolation Citation

04-03-4	Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. In room 142 smoke detector was down and in tv stand	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.06/11/2021	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hamilton County

License Number: 3400163

MUSTANG INN

License Type: Motel

8055 SR 6 W, JASPER 32052

Inspection Date: 07/15/2021

Inspection Number: 1219287

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BAILEY, KIMBERLY

Violation Code Observation

Violation Citation

01-03-4 Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Between 156 and 157.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lake County

License Number: 4502671

DAYS INN & SUITES

License Type: Hotel

20390 US HWY 27, CLERMONT 34715

Inspection Date: 07/14/2021

Inspection Number: 1161651

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FREY, RANDY

Violation Code Observation

Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4601057

GOLF MEADOW APARTMENTS

License Type: Apartment

1852 GOLFOVIEW AVE, FORT MYERS 33901

Inspection Date: 07/09/2021

Inspection Number: 1527033

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: WALTER, KAYLA

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed fire extinguisher missing on first floor, near intersection of Kelly st and Hill Ave.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4703112

HYATT HOUSE TALLAHASSEE CAPITOL - UNIVERSITY

License Type: Hotel

1100 RAILROAD AVE, TALLAHASSEE 32310

Inspection Date: 07/13/2021

Inspection Number: 1160920

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: STESLOW, KEVIN

Violation Code Observation

Violation Citation

08-04-4 Boiler certificate not posted in the boiler room. For reporting purposes only.

Observed no Boiler certificate posted in boiler room

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400347

FISHER INN RESORTS & MARINA

License Type: Motel

84951 OVERSEAS HWY, ISLAMORADA 33036

Inspection Date: 07/16/2021

Inspection Number: 1219211

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: WHITEHURST, SCOTT

Violation Code ObservationViolation Citation

02-04-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs stored inside the building. For reporting purposes only. In maintenance room with propane hot water heaters.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
03-01-4	No fire sprinkler system installed in a transient lodging establishment three stories or more in height, or over 75 feet in height. For reporting purposes only.	509.215 and 509.032(2)(d) FS Reporting: 509.215 Any public lodging establishment, as defined in this chapter, which is of three stories or more, or over 75 feet in height shall be equipped with an automatic sprinkler system installed in compliance with the provisions prescribed in the National Fire Protection Association publication NFPA No. 13 "Standards for the Installation of Sprinkler Systems. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5402962

HAMPTON INN KEY LARGO

License Type: Motel

102400 OVERSEAS HWY, KEY LARGO 33037

Inspection Date: 07/14/2021

Inspection Number: 1218478

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, RICARDO

Violation Code ObservationViolation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	---

Okaloosa County

License Number: 5603204

REGENCY INN

License Type: Motel

349 MIRACLE STRIP PKWY SW, FORT WALTON BEACH 32548

Inspection Date: 07/16/2021

Inspection Number: 1219779

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ADAMSON, ROBERT

Violation Code Observation

Violation Citation

04-02-4 No smoke detector provided in guest room/unit. For reporting purposes only. Room 108.

509.215(1) and (2) and 509.032(2)(d) FS Reporting:
 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811136

THE ALFOND INN

License Type: Hotel

300 E NEW ENGLAND AVE, WINTER PARK 32789

Inspection Date: 07/13/2021

Inspection Number: 1159781

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MONTGOMERY, DOREEN

Violation Code ObservationViolation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only, two boilers on roof, one certificate expired 2/20/20 **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5803221

INDIGO WINTER PARK

License Type: Apartment

220 S SEMORAN BLVD, WINTER PARK 32792

Inspection Date: 07/15/2021

Inspection Number: 1532317

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MONTGOMERY, DOREEN

Violation Code ObservationViolation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Certificate expired 2/10/18 # 139434 room #4
Certificate expired 2 10/18 # 230908 room #5
No certificate for room #1
Certificate expired 2/10/18 #200600 room #2
Certificate expired 2/10/18 #137015 room #3

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-03-4 No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

No certificate for boiler in room #1

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5809848

SUNSTYLE SUITES

License Type: Motel

7209 ORANGE BLOSSOM TRAIL, ORLANDO 32809

Inspection Date: 07/12/2021

Inspection Number: 1211456

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back - Complied

Inspector Name: PASIECKI, VICTORIA

Violation Code ObservationViolation Citation

01-02-4 - From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Outside room 218 - From follow-up inspection 2021-07-12:
Time Extended

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5810332 FAIRFIELD INN AND SUITES ORLANDO
 License Type: Hotel 5614 VINELAND RD, ORLANDO 32819

Inspection Date: 07/14/2021 Inspection Number: 1160658 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: KOSTELNY, ROGER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FL 134712 exp 6/12/21	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811176 HOLIDAY INN EXPRESS LAKE BUENA VISTA
 License Type: Hotel 11409 MARBELLA PALMS CT, ORLANDO 32836

Inspection Date: 07/12/2021 Inspection Number: 1160575 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed fire alarm panel has trouble light showing spoke to Engineering is aware of the problem, will notify monitoring company.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900220 LAMBERT INN
 License Type: Motel 410 W VINE ST, KISSIMMEE 347414200

Inspection Date: 07/13/2021 Inspection Number: 1218464 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: NIEVES, RAFAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-01-4	Damaged electrical wire(s). For reporting purposes only. Observed in laundry room on ceiling over washer and dryers.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900225 SERALAGO HOTEL AND SUITES MAINGATE EAST
 License Type: Hotel 5678 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 07/12/2021 Inspection Number: 1159268 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FERTIL, SYLVERST

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Seralago Hotel Boilers 103024- 12/10/20, 092576- 12/10/20, 092581-12/10/20, 070715-12/10/20, 122658- 12/27/21, Operator states the boiler inspections will be scheduled as soon as possible.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900708 PARADISE INN
 License Type: Motel 4501 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746-5416

Inspection Date: 07/14/2021 Inspection Number: 1212121 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: FERTIL, SYLVERST

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-01-4	- From initial inspection : Electrical outlet cover is missing in room 221. - From follow-up inspection 2021-07-14: Operator is working on replacing the outlet cover. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6211956

KENWOOD INN

License Type: Motel

451 34 ST N, ST. PETERSBURG 33713

Inspection Date: 07/16/2021

Inspection Number: 1219776

Inspection Type: Complaint Full

Inspection Disposition: Administrative
complaint recommended

Inspector Name: HOBBS, ANDREW

Violation Code ObservationViolation Citation

01-05-4 Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Enclosed fire extinguisher boxes have no strikers
Repeat Violation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-06-4 Smoke alarm emitting an audible alarm. For reporting purposes only. Room 230 smoke detector low battery chirping

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6211194

MARRIOTT SANDKEY

License Type: Hotel

1201 GULF BLVD, CLEARWATER BCH 33767

Inspection Date: 07/12/2021

Inspection Number: 1161282

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation Code ObservationViolation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 3 out of 4 certificates expired. FL134097, FL134099, FL134100 all expired 9/12/2020, FL134098 expires 9/23/2022. Paperwork submitted. **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6600336

DAYS INN

License Type: Hotel

3224 S US HWY #1, FT PIERCE 34982

Inspection Date: 07/13/2021

Inspection Number: 1160820

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HARROD, JESSICA

Violation Code ObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In between rooms 242&244, 252&254,

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6602457

HAMPTON INN & SUITES

License Type: Hotel

155 SW PEACOCK BLVD, PORT ST. LUCIE 34986

Inspection Date: 07/15/2021

Inspection Number: 1160788

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HYNES, MONICA

Violation Code ObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Floor 3.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7401692

BRADDOCK APARTMENTS

License Type: Apartment

624 BRADDOCK AVE, DAYTONA BEACH 32118

Inspection Date: 07/15/2021

Inspection Number: 1524121

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back - Admin. complaint recommended

Inspector Name: WOOD, JUSTIN

Violation Code Observation

Violation Citation

07-01-4 - From initial inspection : Damaged electrical wire(s). For reporting purposes only.

Coming from box near unit 11 upstairs - From follow-up inspection 2021-07-15:

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Walton County

License Number: 7600597

HILTON SANDESTIN

License Type: Hotel

4000 SANDESTIN BLVD S, MIRAMAR BEACH 32550

Inspection Date: 07/11/2021

Inspection Number: 1161557

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILSON, MISTY

Violation Code Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
081414 - 04-12-21

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.