

Alachua County

License Number: 1103014

GNV CITY CENTER LLC - THE PALMS

License Type: Apartment

230 SW 2 AVE, GAINESVILLE 32601

Inspection Date: 07/21/2021

Inspection Number: 1512690

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: PACE, PATRICK

Violation Code

Observation

Violation Citation

04-06-4

- From initial inspection : Fire alarm control panel emitting an audible alarm. For reporting purposes only.
From riser room on back side of building. ****Repeat Violation**** -
From follow-up inspection 2021-07-21: No change

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bay County

License Number: 1305240 CABANA WEST
 License Type: Apartment 302 CABANA BLVD, PANAMA CITY BEACH 32407

Inspection Date: 07/22/2021 Inspection Number: 1532406 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HAASE, TINA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. observed fire extinguisher missing next to garage G37.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1305850 SHORES OF PANAMA COMMERCIAL LLC
 License Type: Vacation Rental - Condo 9900 S THOMAS DR, PANAMA CITY BEACH 32408

Inspection Date: 07/17/2021 Inspection Number: 1088501 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LYNN, NICKOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-03-4	Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Smoke alarm in master bedroom and hallway, flashing red lights.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1501954

THE PARK AT PARMA

License Type: Apartment

500 N WICKHAM RD, MELBOURNE 32935

Inspection Date: 07/22/2021

Inspection Number: 1515149

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MITTEN, JAMES

Violation Code Observation

Violation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Extinguisher by office

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620698		COURTYARD BY MARRIOTT	
License Type: Hotel		400 GULF STREAM WAY, DANIA 33004	
Inspection Date: 07/23/2021	Inspection Number: 1160421	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LONDONO, GLORIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1613800		PALM CREST APARTMENTS	
License Type: Apartment		9900 RIVERSIDE DR, CORAL SPRINGS 33071-8808	
Inspection Date: 07/23/2021	Inspection Number: 1518790	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: BRADY, OSSIAN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler jurisdiction 122617 expired 03/20/2020.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1620916		HYATT CENTRIC LAS OLAS FORT LAUDERDALE	
License Type: Hotel		100 E LAS OLAS BLVD, FORT LAUDERDALE 33301	
Inspection Date: 07/20/2021	Inspection Number: 1160613	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANN, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1606413		1300 LAS OLAS PLACE	
License Type: Apartment		1300 SE 1 ST, FORT LAUDERDALE 33301-3973	
Inspection Date: 07/23/2021	Inspection Number: 1525784	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANN, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs stored under a stairwell (next to stairwell on second floor BBQ area). For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Broward County

License Number: 1603330 BEACHSIDE VILLAGE RESORT
 License Type: Motel 4553 EL MAR DR, LAUDERDALE-BY-THE-SE 33308

Inspection Date: 07/21/2021 Inspection Number: 1216201 Inspection Type: Routine - Lodging Inspection Disposition: Call Back -
 Inspector Name: DEJONG, STEVEN Complied

Violation Code ObservationViolation Citation

01-02-4 - From initial inspection : Portable fire extinguisher across from Chatham Suite door pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
 - From follow-up inspection 2021-06-16: Fire extinguisher across fro

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1619051 HOMETOWNE STUDIOS - FORT LAUDERDALE 3512
 License Type: Hotel 3031 W COMMERCIAL BLVD, FORT LAUDERDALE 33309

Inspection Date: 07/20/2021 Inspection Number: 1161714 Inspection Type: Complaint Full Inspection Disposition: Warning
 Inspector Name: SEWELL, SANGAY Issued

Violation Code ObservationViolation Citation

08-04-4 Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620922 AC HOTEL SAWGRASS MILLS
 License Type: Hotel 1870 SAWGRASS MILLS CIR, SUNRISE 33323

Inspection Date: 07/16/2021 Inspection Number: 1161491 Inspection Type: Routine - Lodging Inspection Disposition: Inspection
 Inspector Name: BRADY, OSSIAN Completed - No Further Action

Violation Code ObservationViolation Citation

08-03-4 No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Observed 2 boilers at 8th floor at Max 800,000 BTU/hr input rating and tanks supporting 500 Gallons. No boiler certifications available at time of inspe

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2101614

HAMPTON INN

License Type: Hotel

3210 N TAMIAMI TRAIL, NAPLES 34103

Inspection Date: 07/21/2021

Inspection Number: 1160590

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PENN, BRIAN

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329245 MEDINA DIAZ APTS INC
 License Type: Apartment 305 SW 4 AVE, HOMESTEAD 33030

Inspection Date: 07/21/2021 Inspection Number: 1518612 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEIDECKER, EDILMA

Violation Code ObservationViolation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed two fire extinguisher locked in a boxes between unit 1 and 2 and between unit 5 and 6, second floor. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329242 COURTYARD BY MARRIOTT SOUTH HOMESTEAD
 License Type: Hotel 2905 NE 9 ST, HOMESTEAD 33033

Inspection Date: 07/19/2021 Inspection Number: 1159613 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, RICARDO

Violation Code ObservationViolation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

130160 12/06/20. 130161 12/06/20

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328266 EXTENDED STAY AMERICA #1600
 License Type: Hotel 8655 NW 21 TERRACE, MIAMI 33122

Inspection Date: 07/23/2021 Inspection Number: 1160546 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SANCHEZ, JAVIER

Violation Code ObservationViolation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FL97596 expired 01/16/17, FL 97595 expired 01/16/17.. ****Repeat Violation****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329187 HILTON GARDEN INN MIAMI AIRPORT WEST
 License Type: Hotel 3550 NW 74 AVE, MIAMI 33122

Inspection Date: 07/19/2021 Inspection Number: 1159624 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SANCHEZ, JAVIER

Violation Code ObservationViolation Citation

02-04-4 Propane (LP gas) tank having a water capacity greater than 2.7 lbs stored inside the building. For reporting purposes only. Inside of the water heater room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2300278 JORGE PEREZ
 License Type: Apartment 144 NW 26 AVE, MIAMI 33125

Inspection Date: 07/20/2021 Inspection Number: 1519441 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, ERIK

Violation Code ObservationViolation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed extinguisher without braking device located on second floor by unit 10.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2316091 HOLIDAY INN DOWNTOWN PORT OF MIAMI
 License Type: Hotel 340 BISCAYNE BLVD, MIAMI 33132

Inspection Date: 07/20/2021 Inspection Number: 1161079 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CUDEMOS, VIRNA

Violation Code ObservationViolation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 059005 exp 4/22/2021

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2320639 DOUBLETREE GRAND HOTEL (THE)
 License Type: Hotel 1717 N BAYSHORE DR, MIAMI 331321180

Inspection Date: 07/22/2021 Inspection Number: 1159831 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CUDEMOS, VIRNA

Violation Code ObservationViolation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 082468/082469 expired 04/11/2021**Repeat Violation** **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2308454 YURIANI INVESTMENTS LLC
 License Type: Apartment 1421 SW 6 ST, MIAMI 33135

Inspection Date: 07/19/2021 Inspection Number: 1532354 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: GARCIA, B OSCAR

Violation Code ObservationViolation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. **Warning**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2308026		GONZALEZ APTS	
License Type: Apartment		1380 SW 6 ST, MIAMI 331353930	
Inspection Date: 07/19/2021	Inspection Number: 1532356	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. **Warning**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2305198		200 COLLINS AVENUE	
License Type: Apartment		200 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 07/23/2021	Inspection Number: 1532418	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. On 1st and 2nd floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2309536		BELAZDAN HOLDING CORPORATION	
License Type: Apartment		626 -650 JEFFERSON AVE, MIAMI BEACH 33139	
Inspection Date: 07/21/2021	Inspection Number: 1516419	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. 650 building 2nd floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329285		LORD BALFOUR HOTEL	
License Type: Hotel		350 OCEAN DR, MIAMI BEACH 33139	
Inspection Date: 07/23/2021	Inspection Number: 1161796	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329467 THE GOODTIME HOTEL
 License Type: Hotel 601 WASHINGTON AVE, MIAMI BEACH 33139

Inspection Date: 07/22/2021 Inspection Number: 1159797 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed water heater maximum states 499,900 maximum btu	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310682 LISI APTS
 License Type: Apartment 729 EUCLID AVE, MIAMI BEACH 331396134

Inspection Date: 07/23/2021 Inspection Number: 1527407 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. On 1st floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2303627 YESORA APTS
 License Type: Apartment 761 JEFFERSON AVE, MIAMI BEACH 331398568

Inspection Date: 07/21/2021 Inspection Number: 1525254 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. On second floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-04-4	Fire alarm control panel has no power. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2323354

THE MANSION LC

License Type: Apartment

1001 W 46 ST, MIAMI BEACH 33140

Inspection Date: 07/19/2021

Inspection Number: 1525637

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: UNZAGA, MILADYS

Violation Code ObservationViolation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device on extinguisher located on the backside of the building.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330587

MSFLJ LLC

License Type: Apartment

3039-3045 NW 21 CT, MIAMI 33142

Inspection Date: 07/16/2021

Inspection Number: 1532352

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: HODGE, KRISTEN

Violation Code ObservationViolation Citation

07-02-4 Frayed electrical wire(s), located above unit 2 in building 3045 under upstairs platform. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2308500

AVALON APTS

License Type: Apartment

2251 NE 170 ST, NORTH MIAMI BEACH 33160

Inspection Date: 07/16/2021

Inspection Number: 1518493

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TAYLOR, JOHN

Violation Code ObservationViolation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to Apt 202 & 209.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2303148 168 STREET PROPERTY COMPANY
 License Type: Apartment 1985 NE 168TH ST, NORTH MIAMI BEACH 33162

Inspection Date: 07/19/2021 Inspection Number: 1532330 Inspection Type: Lodging-Licensing Inspection Disposition: Warning
 Inspector Name: STUBBS, CHRISTINE Inspection Issued

Violation Code ObservationViolation Citation

01-05-4 Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Missing hammers at apartments #6 & #8.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-05-4 - From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Missing hammers at apartments #6 & #8. - From follow-up inspection 2021-07-21: At time of call back inspection observed portable fire extin

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2321990 QUALITY INN MIAMI AIRPORT
 License Type: Hotel 3959 NW 79 AVE, MIAMI 33166

Inspection Date: 07/19/2021 Inspection Number: 1160599 Inspection Type: Routine - Lodging Inspection Disposition: Warning
 Inspector Name: GONZALEZ, ERIK Inspection Issued

Violation Code ObservationViolation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed 080920, 123866, Expiration 11/27/2020.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2313311 PORTOFINO AT BISCAYNE
 License Type: Apartment 14000 BISCAYNE BLVD, NORTH MIAMI 33181

Inspection Date: 07/22/2021 Inspection Number: 1532367 Inspection Type: Complaint Full Inspection Disposition: Administrative
 Inspector Name: SUAREZ, LEOPOLDO complaint recommended

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Buildings 14020 and 1430

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2702778

KEY WEST INN

License Type: Motel

6900 PENSACOLA BLVD, PENSACOLA 32505

Inspection Date: 07/19/2021

Inspection Number: 1219778

Inspection Type: Complaint Full

Inspection Disposition: Administrative
complaint recommended

Inspector Name: RUSSELL, SARAH

Violation Code ObservationViolation Citation04-02-4 No smoke detector provided in guest room/unit. For reporting
purposes only. In room 116.509.215(1) and (2) and 509.032(2)(d) FS Reporting:
509.215(1) Each guest room shall be equipped with an
approved listed single-station smoke detector meeting
the minimum requirements of NFPA-74 Standards for
the Installation, Maintenance and Use of Household Fire
Warning Equipment. (2) The building has smoke
detectors in each guest room individually annunciating
to a panel at a supervised location. 509.032(2)(d) The
division, or its agent, shall notify the local firesafety
authority or the State Fire Marshal of any readily
observable violation of a rule adopted under chapter 633
which relates to public lodging establishments or public
food establishments, and the identification of such
violation does not require any firesafety inspection
certification. For reporting purposes only.

License Number: 2705355

MELEI RENTALS

License Type: Apartment

3543 MOBILE HWY, PENSACOLA 32505

Inspection Date: 07/19/2021

Inspection Number: 1532359

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: RUSSELL, SARAH

Violation Code ObservationViolation Citation06-03-4 Marked exit is inaccessible. For reporting purposes only. Every
building on property has multiple windows boarded up no longer
accessible for use.509.032(2)(d) FS Reporting: The division, or its agent,
shall notify the local firesafety authority or the State Fire
Marshal of any readily observable violation of a rule
adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

Hillsborough County

License Number: 3911768 COURTYARD BY MARRIOTT
 License Type: Hotel 102 E CASS ST, TAMPA 33602

Inspection Date: 07/23/2021 Inspection Number: 1161208 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: COLEMAN, TONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only. Expired Boiler certificate posted in the boiler room	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3900493 THE RIVIERA AT 8412
 License Type: Apartment 8412 RIO BRAVO COURT, TAMPA 33617

Inspection Date: 07/20/2021 Inspection Number: 1512435 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied
 Inspector Name: MOULDER, BRITTANY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed missing fire extinguishers at buildings 5, 14,22 and 27. - From follow-up inspection 2021-06-14: Mi	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Indian River County

License Number: 4100229

PRESTIGE HOTEL VERO BEACH

License Type: Motel

1526 OCEAN DR, VERO BEACH 32963

Inspection Date: 07/22/2021

Inspection Number: 1218248

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHUCK, GREGORY

Violation Code Observation

Violation Citation

02-08-4 Propane (LP gas) tank having a water capacity greater than 2.7 lbs stored under a stairwell. For reporting purposes only. 3 propane tanks ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4600683

FOUNTAIN COTTAGES INN

License Type: Motel

14621 MCGREGOR BLVD, FORT MYERS 33908

Inspection Date: 07/19/2021

Inspection Number: 1217017

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: SOMMERS, KARA

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. Extinguisher near Unit 2. For reporting purposes only. - From follow-up inspection 2021-07-19:

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5402153

BARBARY BEACH HOUSE KEY WEST

License Type: Hotel

2001 ROOSEVELT BLVD, KEY WEST 33040

Inspection Date: 07/19/2021

Inspection Number: 1160223

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MARTINEZ, YANET

Violation Code Observation

Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5603610

TOWNEPLACE SUITES BY MARRIOTT

License Type: Hotel

843 EGLIN PKWY, FORT WALTON BEACH 32547

Inspection Date: 07/21/2021

Inspection Number: 1159635

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BURROUGHS, RICHARD

Violation Code Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
 - all three certificates expired by over 20 months.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5809236

HOMEWOOD SUITES BY HILTON ORLANDO INTERNATIONAL DRIVE

License Type: Hotel

8745 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 07/20/2021

Inspection Number: 1159958

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BACHOO, SAVITRI

Violation Code ObservationViolation Citation

08-03-4 No boiler certificates or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5807829

HAMPTON INN ORLANDO - INTERNATIONAL AIRPORT

License Type: Hotel

5767 T G LEE BLVD, ORLANDO 32822

Inspection Date: 07/21/2021

Inspection Number: 1161347

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LORENZO, ANA

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only./ observed trouble light at main fire panel

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5809011

HOMETOWNE STUDIOS ORLANDO UCF AREA 3513

License Type: Hotel

12350 E COLONIAL DR, ORLANDO 32826

Inspection Date: 07/19/2021

Inspection Number: 1160855

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: JENKINS, JOSHUA

Violation Code ObservationViolation Citation05-02-5 Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.
One portable hearing impaired smoke detector not functioning when tested. Two hard-wired in rooms; one room unoccupied and unit functional, other room is occupi

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5913658

UNNO BOUTIQUE HOTEL

License Type: Motel

2095 E IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34744

Inspection Date: 07/21/2021

Inspection Number: 1218709

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BORRERO, AUDREY

Violation Code Observation

Violation Citation

04-02-4 No smoke detector provided in guest room/unit. For reporting purposes only. In room 153, per manager they are changing the detectors

509.215(1) and (2) and 509.032(2)(d) FS Reporting:
 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014096 KINGS LODGE
License Type: Apartment 2715 BROADWAY, WEST PALM BEACH 33407

Inspection Date: 07/21/2021 Inspection Number: 1523619 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MCCARTHY, RAMONA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6005016 SUBU HOLDINGS INC
License Type: Apartment 300 NE 1 ST, BELLE GLADE 33430

Inspection Date: 07/20/2021 Inspection Number: 1532377 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SEVILLA, FREDDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
06-03-4	Marked exit is inaccessible. For reporting purposes only. Windows on back of apartment 9 north east corner blocked by plywood. Windows on back of apartment 6 north west corner blocked by plywood.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6012655 FAIRFIELD INN & SUITES JUPITER
License Type: Hotel 6748 INDIANTOWN RD, JUPITER 33458

Inspection Date: 07/16/2021 Inspection Number: 1161083 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
Inspector Name: ROTONDI, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 121021, 121022, 095111 all exp 03/15/2019 **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6002274 700 SOUTH BROADWAY LLC
License Type: Apartment 700 S BROADWAY, LANTANA 33462

Inspection Date: 07/23/2021 Inspection Number: 1519215 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PITRE, ASTRID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged, next to unit 9. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6003850 JUPITER BEACH RESORT
 License Type: Motel 5 N A1A, JUPITER 33477

Inspection Date: 07/22/2021 Inspection Number: 1218938 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ROTONDI, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.main lobby.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.099577, 099578, 098381, all exp 5/20/2021.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6203125 SAHARA MOTEL
 License Type: Motel 10910 GANDY BLVD, ST PETERSBURG 337021430

Inspection Date: 07/21/2021 Inspection Number: 1216296 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: LOZANO, KELVIN

Violation Code ObservationViolation Citation

05-02-5 - From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Gentex hearing impaired smoke alarm has to be hard wired into room to function and be tested ****Repeat Violation**** - From follow-

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6200856 AZALEA COURT
 License Type: Motel 8210 N 4 ST, ST PETERSBURG 337023606

Inspection Date: 07/21/2021 Inspection Number: 1216245 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: LOZANO, KELVIN

Violation Code ObservationViolation Citation

01-06-4 - From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. No means to break glass next to room 10 - From follow-up inspection 2021-07-21:

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215804 TREASURE BAY RESORT & MARINA
 License Type: Hotel 11125 GULF BLVD, TREASURE ISLAND 33706

Inspection Date: 07/19/2021 Inspection Number: 1160243 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DAY-WALKER, LISA

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Trouble light illuminated on fire panel. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6201537 PARK HOUSE APARTMENTS
 License Type: Apartment 3980 64 ST N, ST. PETERSBURG 33709

Inspection Date: 07/20/2021 Inspection Number: 1497376 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: RANVILLE, AMANDA

Violation Code ObservationViolation Citation

01-02-4 - From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Near unit 37 - From follow-up inspection 2021-07-20:

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6211956 KENWOOD INN
 License Type: Motel 451 34 ST N, ST. PETERSBURG 33713

Inspection Date: 07/19/2021 Inspection Number: 1219776 Inspection Type: Complaint Full
 Inspector Name: HOBBS, ANDREW

Inspection Disposition: Call Back -
 Admin. complaint recommended

Violation Code ObservationViolation Citation

01-05-4 - From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Enclosed fire extinguisher boxes have no strikers ****Repeat Violation**** - From follow-up inspection 2021-07-19: ****Time Extended****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6201823 SEASIDE INN & SUITES
 License Type: Motel 401 S GULFVIEW BLVD, CLEARWATER BEACH 33767

Inspection Date: 07/20/2021 Inspection Number: 1219788 Inspection Type: Complaint Full
 Inspector Name: KOUSTIS, TIMOTHY

Inspection Disposition: Administrative
 complaint recommended

Violation Code ObservationViolation Citation

01-01-4 Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Next to room 108.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6201831 MAGNUSON HOTEL
 License Type: Motel 421 S GULFVIEW BLVD, CLEARWATER BEACH 33767

Inspection Date: 07/20/2021 Inspection Number: 1218927 Inspection Type: Routine - Lodging
 Inspector Name: KOUSTIS, TIMOTHY

Inspection Disposition: Administrative
 complaint recommended

Violation Code ObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to room 435. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-03-4 Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Next to room 336.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

06-01-4 Path to door marked as an exit is blocked. For reporting purposes only.
 City of Clearwater has closed the north stairwell for use due to spalling concrete and rebar. 9 rooms closed off by City of Clearwater. Operator has closed off this stairwell, not

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6204341

BOYER STREET LLC

License Type: Apartment

442 JAMES ST, DUNEDIN 34698

Inspection Date: 07/23/2021

Inspection Number: 1523920

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PEARCE, LAURA

Violation Code Observation

Violation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Missing tool at locked fire extinguisher cabinets throughout property

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6300029

ECONOMY SUITES

License Type: Motel

1901 CYPRESS GARDENS BLVD, WINTER HAVEN 33884

Inspection Date: 07/20/2021

Inspection Number: 1219772

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JACKSON, SHARON

Violation Code Observation

Violation Citation

04-05-4 No smoke detector provided in guest room/unit. For reporting purposes only. Room 23,24,

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6903990

WOODSPRING SUITES ORLANDO SANFORD

License Type: Hotel

2727 S ORLANDO DR, SANFORD 32773

Inspection Date: 07/21/2021

Inspection Number: 1161673

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation Code Observation

Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Unit is in trouble 2

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6602260

SPRINGHILL SUITES BY MARRIOTT

License Type: Hotel

2000 NW COURTYARD CIR, PORT ST LUCIE 34986

Inspection Date: 07/21/2021

Inspection Number: 1161078

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: HYNES, MONICA

Violation Code Observation

Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406520

EXTENDED STAY AMERICA #9512

License Type: Hotel

275 INTERCHANGE BLVD, ORMOND BEACH 32174

Inspection Date: 07/20/2021

Inspection Number: 1160384

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: RUTLEDGE, REBECCA

Violation Code Observation

Violation Citation

08-04-4 Boiler certificate not posted in the boiler room. For reporting purposes only. Provided initial boiler inspection.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.