

**Alachua County**

License Number: 1103014

GNV CITY CENTER LLC - THE PALMS

License Type: Apartment

230 SW 2 AVE, GAINESVILLE 32601

Inspection Date: 07/21/2021

Inspection Number: 1531379

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: PACE, PATRICK

Violation Code    Observation

Violation Citation

04-06-4    Fire alarm control panel emitting an audible alarm. For reporting purposes only.  
 Room on back side of property labeled as FACP emitting an alarm.  
 \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Bay County**

License Number: 1305147

PALM GROVE

License Type: Motel

14513 FRONT BEACH RD, PANAMA CITY BEACH 32413

Inspection Date: 07/29/2021

Inspection Number: 1219907

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code    Observation

Violation Citation

01-01-4    Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Outside 5201.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1620865 HYATT PLACE FT LAUDERDALE AIRPORT & CRUISE PORT  
 License Type: Hotel 91 SW 18 AVE, DANIA BEACH 33004

Inspection Date: 07/28/2021 Inspection Number: 1160496 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: LONDONO, GLORIA

Violation Code    ObservationViolation Citation

01-02-4      Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. 6th floor  
 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1606048 ELEA HOLDINGS LLC  
 License Type: Apartment 5912 MAYO ST, HOLLYWOOD 33023

Inspection Date: 07/29/2021 Inspection Number: 1518899 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GANPAT, INDAR

Violation Code    ObservationViolation Citation

01-02-4      Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By unit #2  
 \*\*Repeat Violation\*\*  
 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1618849 HAMPTON INN PEMBROKE PINES  
 License Type: Hotel 1900 NW 150 AVE, PEMBROKE PINES 33028

Inspection Date: 07/28/2021 Inspection Number: 1159873 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: NEALY, VALENCIA

Violation Code    ObservationViolation Citation

06-02-4      Door marked as an exit is blocked. For reporting purposes only.  
 -Observed behind stairwell exit door blocked by discarded boxes, 5th level, next to room 524.  
 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1600334 THE RIVERSIDE HOTEL  
 License Type: Hotel 620 E LAS OLAS BLVD, FORT LAUDERDALE 33301

Inspection Date: 07/27/2021 Inspection Number: 1160145 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BRANN, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-04-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs stored inside the building. Approximately 21 tanks stored on 7th level parking garage. Inspector will forward inspection to Fire Marshall for review. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. 120384 exp 7-24-2021, 120383 exp 7-24-2021 For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1606802 BROWARD GARDENS APARTMENTS  
 License Type: Apartment 2960 NW 19 ST, FORT LAUDERDALE 33311

Inspection Date: 07/29/2021 Inspection Number: 1532488 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BRANN, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621271 JOMY ZACHARIAS  
 License Type: Apartment 6354 6398 NW 26 ST, SUNRISE 33313

Inspection Date: 07/30/2021 Inspection Number: 1524116 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SMITH, CORETTA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. Observed fire extinguisher by apt 6394. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1603798

LANDMARK TOWERS

License Type: Apartment

601 NW 42 AVE, PLANTATION 33317

Inspection Date: 07/30/2021

Inspection Number: 1515177

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: NEALY, VALENCIA

Violation Code    Observation

Violation Citation

01-02-4    Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
 -Observed fire extinguisher in need of charge in level 5 laundry room, building 551.  
 -Observed missing extinguisher across from unit

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Clay County**

License Number: 2000674

ZEN LIVING SUITES

License Type: Motel

150 PARK AVE, ORANGE PARK 32073

Inspection Date: 07/26/2021

Inspection Number: 1219700

Inspection Type: Complaint Full

Inspection Disposition: Call Back - Admin. complaint recommended

Inspector Name: BIAVA, GRANT

Violation Code    Observation

Violation Citation

08-04-4    - From initial inspection : Boiler certificate not posted in the boiler room. For reporting purposes only.  
 No certification in boiler room, manager has copy on his phone.    -  
 From follow-up inspection 2021-07-26: \*\*Time Extended\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2313279 DANATAP APTS  
 License Type: Apartment 1952 NW 22 CT, MIAMI 331251352

Inspection Date: 07/27/2021 Inspection Number: 1518122 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: UNZAGA, MILADYS

Violation Code    ObservationViolation Citation

01-06-4    Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device on fire extinguisher located next to unit 2 , building 1920.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329191 W MIAMI HOTEL  
 License Type: Hotel 485 BRICKELL AVE, MIAMI 33131

Inspection Date: 07/30/2021 Inspection Number: 1160782 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: HENLEY, LATONYA

Violation Code    ObservationViolation Citation

08-01-4    Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FL 123105, Expired on 07/06/2018; FI 123107 Expired on 07/06/2018

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2307318 RALGO 1 APARTMENTS  
 License Type: Apartment 534 SW 13 AVE, MIAMI 33135

Inspection Date: 07/29/2021 Inspection Number: 1519907 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GARCIA, B OSCAR

Violation Code    ObservationViolation Citation

01-06-4    Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2304079 CIMA APTS  
 License Type: Apartment 1950 SW 2 ST, MIAMI 331351733

Inspection Date: 07/26/2021 Inspection Number: 1515724 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GARCIA, B OSCAR

Violation Code    ObservationViolation Citation

06-01-4    Path to door marked as an exit is blocked. For reporting purposes only. (Furniture second floor) \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2307527 800 PENNSYLVANIA AVE LLC  
 License Type: Apartment 800 PENNSYLVANIA AVE, MIAMI BEACH 33139

Inspection Date: 07/27/2021 Inspection Number: 1524866 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. On second floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2327652 GOTHAM PLAZA  
 License Type: Apartment 735 EUCLID AVE, MIAMI BEACH 33139

Inspection Date: 07/26/2021 Inspection Number: 1527575 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Located near apartment 14 and near apartment 7.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328230 ROYAL HOTEL  
 License Type: Hotel 763 PENNSYLVANIA AVE, MIAMI BEACH 33139

Inspection Date: 07/27/2021 Inspection Number: 1159621 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329337 THE ABBEY HOTEL  
 License Type: Hotel 300 21 ST, MIAMI BEACH 33139

Inspection Date: 07/26/2021 Inspection Number: 1159244 Inspection Type: Lodging-Licensing Inspection Inspection Disposition: Call Back - Complied  
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2021-07-26: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2309047		TOBA APTS	
License Type: Apartment		1023 PENNSYLVANIA AVE, MIAMI BEACH 331394933	
Inspection Date: 07/27/2021	Inspection Number: 1522751	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. On 1st floor	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2301381		GAYLE APARTMENTS	
License Type: Apartment		720 JEFFERSON AVE, MIAMI BEACH 331398547	
Inspection Date: 07/29/2021	Inspection Number: 1525090	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2300796		SEACOAST SUITE	
License Type: Apartment		5101 COLLINS AVE, MIAMI BEACH 33140	
Inspection Date: 07/28/2021	Inspection Number: 1528965	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificates expired on 4/8/2021.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2306125		1150 APARTMENTS, LLC	
License Type: Apartment		1150 71ST STREET, MIAMI BEACH 33141	
Inspection Date: 07/26/2021	Inspection Number: 1517691	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-07-4	Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only. Observed sounding audible alarm in unit 5.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Dade County**

License Number: 2310421		IGAL MIAMI LLC	
License Type: Apartment		2285 NE 172 ST, NORTH MIAMI BEACH 33160	
Inspection Date: 07/28/2021	Inspection Number: 1516954	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329451		RAMADA PLAZA MARCO POLO BEACH RESORT	
License Type: Hotel		19201 COLLINS AVENUE, SUNNY ISLES BEACH 33160	
Inspection Date: 07/27/2021	Inspection Number: 1161821	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
03-05-4	Fire sprinkler head rusted. Located in room 409. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2301455		DAYS INN MIAMI AIRPORT NORTH	
License Type: Motel		4767 NW 36 ST, MIAMI SPRINGS 33166	
Inspection Date: 07/26/2021	Inspection Number: 1219857	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed extinguisher located by room 415.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2313311		PORTOFINO AT BISCAYNE	
License Type: Apartment		14000 BISCAYNE BLVD, NORTH MIAMI 33181	
Inspection Date: 07/26/2021	Inspection Number: 1532447	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: SUAREZ, LEOPOLDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Buildings 1420, 14040, 1430.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Duval County**

License Number: 2612657

JACKSONVILLE SPRINGHILL SUITES

License Type: Hotel

4385 SOUTHSIDE BLVD, JACKSONVILLE 32216

Inspection Date: 07/27/2021

Inspection Number: 1160111

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: ARMSTRONG, RICO

Violation Code   ObservationViolation Citation

08-01-4      Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.  
135005 6/06/21  
135006 6/06/21

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612609

INTOWN SUITES

License Type: Hotel

3162 ST JOHNS BLUFF RD S, JACKSONVILLE 32246

Inspection Date: 07/27/2021

Inspection Number: 1161795

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: THOMAS, PHILIP

Violation Code   ObservationViolation Citation

01-01-4      Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.  
FE on 3rd floor just outside elevator and maintenance closet in overcharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Escambia County**

License Number: 2705820

SUBURBAN EXTENDED STAY PENSACOLA

License Type: Hotel

3984 BARRANCAS AVE, PENSACOLA 32507

Inspection Date: 07/28/2021

Inspection Number: 1161818

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RUSSELL, SARAH

Violation Code    Observation

Violation Citation

04-01-4    Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Panel beeping stating fire. Hotel currently on fire watch per fire inspectors. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3913678

HYATT PLACE / HYATT HOUSE TAMPA DOWNTOWN

License Type: Hotel

325 N FLORIDA AVE, TAMPA 33602

Inspection Date: 07/26/2021

Inspection Number: 1160921

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: COLEMAN, TONYA

Violation Code   ObservationViolation Citation

04-01-4      Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3906225

FOUR POINTS SHERATON TAMPA AIRPORT WESTSHORE

License Type: Hotel

4400 W CYPRESS ST, TAMPA 33607

Inspection Date: 07/26/2021

Inspection Number: 1161084

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CANNELLA, MARK

Violation Code   ObservationViolation Citation

08-01-4      Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3905827

MACDILL MOTEL

License Type: Motel

6227 S DALE MABRY HWY, TAMPA 33611-4807

Inspection Date: 07/26/2021

Inspection Number: 1217272

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KLUSENDORF, JEANNE

Violation Code   ObservationViolation Citation

04-02-4      No smoke detector provided in guest room/unit. For reporting purposes only. Room 110

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3902452

TIMBERFALLS APARTMENTS

License Type: Apartment

2600 E 113TH AVE, TAMPA 33612

Inspection Date: 07/29/2021

Inspection Number: 1532482

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JAIME, ANTONY

Violation Code

Observation

Violation Citation

12-04-4

High Priority - Balcony//platform underneath rotted on multiple units on property.

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

**Lee County**

License Number: 4602525

RED ROOF INN WATERFRONT / DOWNTOWN

License Type: Motel

13000 N. CLEVELAND AVE, NORTH FORT MYERS 33903

Inspection Date: 07/29/2021

Inspection Number: 1219910

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: FREED, JOSEPH

Violation Code    Observation

Violation Citation

01-02-4    Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher in laundry room in recharge zone. Notified housekeeping manager. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Leon County**

License Number: 4703214

OAK PARK APARTMENT HOMES

License Type: Apartment

214 COLUMBIA DR, TALLAHASSEE 32304

Inspection Date: 05/21/2021

Inspection Number: 1532462

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: MERCER, THOMAS

Violation Code

Observation

Violation Citation

01-02-4

OBSERVED PORTABLE FIRE EXTINGUISHER PRESSURE GAUGE INDICATES THE EXTINGUISHER IS IN NEED OF RECHARGE. FOR REPORTING PURPOSES ONLY. EXTINGUISHER AT APARTMENT 18 HAS GUAGE IN RED AREA FOR RECHARGE. PRIORITY: REPORTING

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Monroe County**

License Number: 5400666 HOLIDAY INN KEY LARGO RESORT & MARINA  
 License Type: Motel 99701 OVERSEAS HWY, KEY LARGO 33037

Inspection Date: 07/27/2021 Inspection Number: 1218236 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GONZALEZ, RICARDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-01-4	Damaged electrical wire(s). For reporting purposes only. Observed exposed electrical wiring at above canopy at the entrance to building 4.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5400696 HAWKS CAY RESORT  
 License Type: Hotel 61 HAWKS CAY BLVD, DUCK KEY 33050

Inspection Date: 07/27/2021 Inspection Number: 1160874 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: WHITEHURST, SCOTT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. The new boiler has no certificate at time of inspection.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Nassau County**

License Number: 5500303

DIXIE MOTEL

License Type: Motel

551664 US HWY 1, HILLIARD 32046

Inspection Date: 07/28/2021

Inspection Number: 1219908

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROZIER, TORRANCE

Violation Code    Observation

Violation Citation

04-02-4    No smoke detector provided in guest room/unit. For reporting purposes only.  
 No smoke detector in room 17

509.215(1) and (2) and 509.032(2)(d) FS Reporting:  
 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5811157

FAIRFIELD INN AND SUITES

License Type: Hotel

3420 LAKE LYNDA DR, ORLANDO 32817

Inspection Date: 07/27/2021

Inspection Number: 1160501

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: JENKINS, JOSHUA

Violation Code    ObservationViolation Citation

04-01-4      Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
Repair crew on site working on the problem. **\*\*Corrective Action Taken\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811106

PLACE ON MILLENIA

License Type: Apartment

5215 MILLENIA BLVD, ORLANDO 32839

Inspection Date: 07/27/2021

Inspection Number: 1526671

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: PASIECKI, VICTORIA

Violation Code    ObservationViolation Citation

01-02-4      Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

Outside 23208 fire extinguisher used, in recharge zone,  
Maintenance replaced extinguisher with a new unused extinguisher  
**\*\*Correc**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Hotel

7769 W. IRLO BRONSON MEMORIAL HWY., KISSIMMEE 34747

Inspection Date: 07/26/2021

Inspection Number: 1161738

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation Code    Observation

Violation Citation

04-01-4      Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4      Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5912073

WOODSPRING SUITES ORLANDO KISSIMMEE

License Type: Hotel

7727 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34747

Inspection Date: 07/27/2021

Inspection Number: 1160936

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: IRVEN, RYAN

Violation Code    Observation

Violation Citation

04-01-4      Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6005456		MARRIOTT WEST PALM BEACH HOTEL	
License Type: Hotel		1001 OKEECHOBEE BLVD, WEST PALM BEACH 33401	
Inspection Date: 07/28/2021	Inspection Number: 1161823	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DE JESUS, ARLENNY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6014468		RESIDENCES UPTOWN BOCA	
License Type: Apartment		20940 UPTOWN AVE, BOCA RATON 33428	
Inspection Date: 07/29/2021	Inspection Number: 1532410	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CUDEMOS, HAIDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed next to apartment 317 of building #20940	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6008599		LAQUINTA INN	
License Type: Motel		34 FISHERMANS WHARF, JUPITER 33477	
Inspection Date: 07/30/2021	Inspection Number: 1219927	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ROTONDI, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.086671 exp 4/15/2017	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6013901		RESIDENCE INN DELRAY BEACH	
License Type: Hotel		1111 E ATLANTIC AVE, DELRAY BEACH 33483	
Inspection Date: 07/30/2021	Inspection Number: 1160741	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GOODWIN, NICHOLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign/box present indicating designated location). For reporting purposes only. Located on floor 2 at turn. Operator put back up in. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	



**Pinellas County**

License Number: 6200856 AZALEA COURT  
 License Type: Motel 8210 N 4 ST, ST PETERSBURG 337023606

Inspection Date: 07/27/2021 Inspection Number: 1219889 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended  
 Inspector Name: LOZANO, KELVIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Fire extinguisher next to room 11 is sealed with glass cover and no means to crack glass	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. Room 1, 3, and 8	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-04-4	No power to left side of building. Duke energy will be shutting off power to entire establishment until building is brought up to code.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-03-4	Scorch marks around an electrical outlet. For reporting purposes only. Fire damage on wall of room 8 next to Ac unit and fuse box close to water heater room	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215772 INTOWN SUITES  
 License Type: Hotel 2833 ROOSEVELT BLVD, CLEARWATER 33760

Inspection Date: 07/30/2021 Inspection Number: 1158425 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied  
 Inspector Name: WILMOT, TASHARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. -hearing impaired smoke detector needs to be mounted to wall Light not flashing only sound **Repeat Violation** - From follow-up	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6201823 SEASIDE INN & SUITES  
 License Type: Motel 401 S GULFVIEW BLVD, CLEARWATER BEACH 33767

Inspection Date: 07/29/2021 Inspection Number: 1219892 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended  
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. Room 204 building 1.	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6209371 LA QUINTA INN #638  
 License Type: Motel 7500 HWY 19 N, PINELLAS PARK 33781

Inspection Date: 07/27/2021 Inspection Number: 1216327 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied  
 Inspector Name: RANVILLE, AMANDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Fire panel reads NAC EXTENDER BLDG B/C SIG 5 SIGNAL CIRCUIT OPEN CKT TROUBLE. - From follow-up inspection 2021-07-27:	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Sarasota County**

License Number: 6804742

TROPICAL SANDS ACCOMMODATIONS, LLC

License Type: Motel

5830 MIDNIGHT PASS RD, SARASOTA 34242

Inspection Date: 07/28/2021

Inspection Number: 1215161

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: HOWARTH, ROSALIE

Violation Code    Observation

Violation Citation

01-02-4    - From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher out of green range, located in Tower 2 Room 704. **\*\*Repeat Violation\*\***    -

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**St. Lucie County**

License Number: 6600043

HOLIDAY VIL.OF SANDPIPER HOTEL

License Type: Hotel

3500 MORNINGSIDE BLVD, PORT ST LUCIE 349526116

Inspection Date: 07/29/2021

Inspection Number: 1161602

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: HYNES, MONICA

Violation Code   ObservationViolation Citation

08-01-4      Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Dates on certificates in boiler room 3-7-05

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6602510

PEACOCK RUN

License Type: Apartment

5502 NW E. TORRENO PKWY, PORT ST LUCIE 34986

Inspection Date: 07/28/2021

Inspection Number: 1516019

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HYNES, MONICA

Violation Code   ObservationViolation Citation

04-01-4      Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7400500

PERRY'S OCEAN EDGE RESORT

License Type: Motel

2209 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 07/27/2021

Inspection Number: 1217601

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: WOOD, JUSTIN

Violation Code   ObservationViolation Citation07-04-4      Electrical outlet damaged to indicate a malfunction. For reporting  
purposes only.

South tower, near indoor pool area door hallway, closest to unit 45

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-04-4      - From initial inspection : Electrical outlet damaged to indicate a  
malfunction. For reporting purposes only.South tower, near indoor pool area door hallway, closest to unit 45  
- From follow-up inspection 2021-07-28: **\*\*Time Extended\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406502

HAMPTON INN &amp; SUITES

License Type: Hotel

20 SUMMIT OAK PL, DELAND 32720

Inspection Date: 07/26/2021

Inspection Number: 1161044

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: OCASIO-LOPEZ, LISA

Violation Code   ObservationViolation Citation04-01-4      Trouble/alarm light illuminated on the fire alarm control panel. For  
reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.