

Baker County

License Number: 1200123

TRAVELODGE

License Type: Motel

1651 S 6TH STREET, MACCLENNY 32063

Inspection Date: 08/05/2021

Inspection Number: 1219923

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: DOTY, JOSEPH

Violation Code Observation

Violation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher near room 111	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Fire extinguisher near room 123	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1500173

INTERNATIONAL PALMS RESORT & CONFERENCE CENTER COCOA BEACH

License Type: Motel

1300 N ATLANTIC AVE, COCOA BEACH 32931

Inspection Date: 08/03/2021

Inspection Number: 1219816

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: HICKS, GEORGE RANDY

Violation Code Observation

Violation Citation

01-01-4 - From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. By housekeeping room . - From follow-up inspection 2021-08-03: missing from location **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-04-4 - From initial inspection : Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Outlet missing cover by room 242. - From follow-up inspection 2021-08-03: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620867		CAMBRIA SUITES FT LAUDERDALE	
License Type: Hotel		141 SW 19 CT, DANIA 33004	
Inspection Date: 08/02/2021	Inspection Number: 1161010	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LONDONO, GLORIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. E paired on December 2020	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1620861		FOUR POINT BY SHERATON FORT LAUDERDALE AIRPORT-DANIA BEACH	
License Type: Hotel		1900 STIRLING RD, DANIA BEACH 33004	
Inspection Date: 08/04/2021	Inspection Number: 1161168	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LONDONO, GLORIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1621547		KINGDOM FUND 2 LLC	
License Type: Apartment		2519 PIERCE ST, HOLLYWOOD 33020	
Inspection Date: 08/02/2021	Inspection Number: 1524780	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHRISTGEN, THOM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed on the extinguisher on the East side of 2519C.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1620901		FAIRFIELD INN & SUITES FORT LAUDERDALE DOWNTOWN/LAS OLAS	
License Type: Hotel		30 S FEDERAL HWY, FORT LAUDERDALE 33301	
Inspection Date: 08/04/2021	Inspection Number: 1159458	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: BRANN, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. Per operator a pipe burst. Alarm company was notified and repairs are underway. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Broward County

License Number: 1604688 THE WESTIN BEACH RESORT FORT LAUDERDALE
 License Type: Hotel 303 N FORT LAUDERDALE BEACH BLVD, FORT LAUDERDALE 33304

Inspection Date: 08/06/2021 Inspection Number: 1160217 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: BRANN, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. Inspector will forward inspection report to Fire Marshall for review. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1609861 THE WESTIN BEACH RESORT FORT LAUDERDALE
 License Type: Hotel 321 N FORT LAUDERDALE BEACH BLVD, FORT LAUDERDALE 33304

Inspection Date: 08/06/2021 Inspection Number: 1159644 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: BRANN, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. Inspector will forward inspection report to Fire Marshall for review. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Clay County

License Number: 2000955

INTOWN SUITES

License Type: Hotel

442 BLANDING BLVD, ORANGE PARK 32073

Inspection Date: 08/04/2021

Inspection Number: 1161909

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: BIAVA, GRANT

Violation Code Observation

Violation Citation

08-01-4 - From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Both boiler certifications expired on 7/18/2021 - From follow-up inspection 2021-08-04: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Both boiler certifications expired on 7/18/2021

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Columbia County

License Number: 2200535

DAYS INN

License Type: Motel

3430 US HWY 441, LAKE CITY 32055

Inspection Date: 08/02/2021

Inspection Number: 1217831

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BAILEY, KIMBERLY

Violation Code Observation

Violation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. On left side of building.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2317292 HOLIDAY INN
 License Type: Hotel 7707 NW 103 ST, HIALEAH GARDENS 33016

Inspection Date: 08/06/2021 Inspection Number: 1159706 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: CRUZ, EDGAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed certificate 099297 dated 10/14/2020 **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329827 THE BUSH INVESTMENT SVCS
 License Type: Apartment 314 SW 3 AVE, HOMESTEAD 33030

Inspection Date: 08/02/2021 Inspection Number: 1526550 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEIDECKER, EDILMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed portable fire extinguisher locked in a box located next to unit 9 second floor. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2317719 BISCAYNE BAY MARRIOTT HOTEL
 License Type: Hotel 1633 N BAYSHORE DR, MIAMI 331321261

Inspection Date: 08/02/2021 Inspection Number: 1161226 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CUDEMOS, VIRNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 135641, 135640, 135644, 133546, 135645, 135637. Expiration date 02/20/21.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329749		MULTICOW, LLC	
License Type: Apartment		1265 SW 6 ST., MIAMI 33135	
Inspection Date: 08/06/2021	Inspection Number: 1519225	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Located next to apt 10.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2330648		SMATHERS PRESERVATION PHASE ONE LLC	
License Type: Apartment		935 SW 30 AVE, MIAMI 33135	
Inspection Date: 08/03/2021	Inspection Number: 1532540	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2309316		935 JEFFERSON INVESTMENT INC	
License Type: Apartment		935 JEFFERSON AVE, MIAMI BEACH 33139	
Inspection Date: 08/02/2021	Inspection Number: 1519047	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Near apartment 8/9.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329469		MOXY SOUTH BEACH	
License Type: Hotel		915-955 WASHINGTON AVE, MIAMI BEACH 33139	
Inspection Date: 07/30/2021	Inspection Number: 1160387	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2300927

SARA APARTMENTS

License Type: Apartment

745 JEFFERSON AVENUE, MIAMI BEACH 331398562

Inspection Date: 08/02/2021

Inspection Number: 1520478

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILLIAMS, ALFREDA

Violation Code ObservationViolation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. On 1st and 2nd floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2300796

SEACOAST SUITE

License Type: Apartment

5101 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 08/03/2021

Inspection Number: 1532529

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: UNZAGA, MILADYS

Violation Code ObservationViolation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificates expired FL 075375 and 075376 exp 4/8/2021.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2304675

MARSEILLES ENTERPRISES INC

License Type: Apartment

1725 MARSEILLES DR, MIAMI BEACH 33141

Inspection Date: 08/03/2021

Inspection Number: 1520814

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PRIETO, VICENTE

Violation Code ObservationViolation Citation

01-05-4 Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed no breaking device in fire extinguisher box between 3 and 4 units.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2309424

PALM GARDEN APARTMENTS

License Type: Apartment

17271 NE 23 AVE, NORTH MIAMI BEACH 331602902

Inspection Date: 07/29/2021

Inspection Number: 1527390

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TAYLOR, JOHN

Violation Code ObservationViolation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to apt 1 in building 17291 & 17271.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2319921

COURTYARD BY MARRIOTT HOTEL

License Type: Hotel

3929 NW 79 AVE, MIAMI 33166

Inspection Date: 08/05/2021

Inspection Number: 1159444

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: GONZALEZ, ERIK

Violation Code ObservationViolation Citation

05-02-5 Hearing-impaired smoke detector is not functioning when tested.
For reporting purposes only. Observed bell not functioning at Room
235.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2316403

CUTLER MANOR APARTMENTS

License Type: Apartment

10875 SW 216 ST, MIAMI 331703103

Inspection Date: 08/02/2021

Inspection Number: 1529817

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LEIDECKER, EDILMA

Violation Code ObservationViolation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access
to the fire extinguisher. For reporting purposes only. Observed all of
portable fire extinguishers locked no means of access. **Repeat
Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328337

INTERNATIONAL CLUB APARTMENTS

License Type: Apartment

1900 SW 122 AVE, MIAMI 33175

Inspection Date: 08/05/2021

Inspection Number: 1519794

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: AZPURUA, JULIO

Violation Code ObservationViolation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access
to the fire extinguisher. For reporting purposes only.
Observed fire extinguisher missing breaking device. Next to unit
#116

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2600619 GOLDEN SHORES JACKSONVILLE (JASPER)
 License Type: Apartment 7703 HARE AVE, JACKSONVILLE 32211

Inspection Date: 08/06/2021 Inspection Number: 1532586 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: THOMAS, PHILIP

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only. Missing Fire extinguishers from wall boxes located next to units including but not limited to unit 144, 150, and 176	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612030 SPINNAKER REACH APARTMENTS
 License Type: Apartment 3875 SAN PABLO RD S, JACKSONVILLE 32224

Inspection Date: 08/06/2021 Inspection Number: 1532588 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended
 Inspector Name: THOMAS, PHILIP

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only. No fire extinguisher in fire box located inside laundry room	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2610443 ST JOHNS FOREST
 License Type: Apartment 7925 MERRILL RD, JACKSONVILLE 32277

Inspection Date: 08/05/2021 Inspection Number: 1532558 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: THOMAS, PHILIP

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher next to outdoor grill area near pool and front office is in recharge zone. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2700898

GARDEN INN & SUITES

License Type: Motel

8500 PINE FOREST RD, PENSACOLA 32534

Inspection Date: 08/03/2021

Inspection Number: 1219925

Inspection Type: Complaint Full

Inspection Disposition: Administrative complaint recommended

Inspector Name: GARDNER, GREGORY

Violation Code Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hamilton County

License Number: 3400014 AMERICAN INN
 License Type: Motel 8072 SR 6 W, JASPER 32052

Inspection Date: 08/06/2021 Inspection Number: 1217589 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BAILEY, KIMBERLY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. Room 10 and 16 smoke alarms in drawers, not in place on wall.	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3400112 BUDGET INN OF JASPER
 License Type: Motel 8182 SR 6 W, JASPER 32052

Inspection Date: 08/06/2021 Inspection Number: 1217911 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BAILEY, KIMBERLY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Between 304 and 305. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3900493

THE RIVIERA AT 8412

License Type: Apartment

8412 RIO BRAVO COURT, TAMPA 33617

Inspection Date: 07/30/2021

Inspection Number: 1532426

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: REGAS, ANTHONY

Violation Code Observation

Violation Citation

01-03-4 Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed fire extinguisher missing at building 1 and 27. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5603626

RESIDENCE INN BY MARRIOTT

License Type: Hotel

2 MIRACLE STRIP PKWY SE, FORT WALTON BEACH 32548

Inspection Date: 08/04/2021

Inspection Number: 1159542

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ADAMSON, ROBERT

Violation Code Observation

Violation Citation

08-03-4 No boiler certificate or insurance inspector's boiler report available.
For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5809882

COURTYARD ORLANDO LK BUENA VISTA

License Type: Hotel

8623 VINELAND AVE, ORLANDO 32821

Inspection Date: 08/03/2021

Inspection Number: 1160686

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: YOUNG, COLIN

Violation Code ObservationViolation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5800779

B RESORT

License Type: Hotel

1905 HOTEL PLAZA BLVD, LAKE BUENA VISTA 32830

Inspection Date: 07/30/2021

Inspection Number: 1159365

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

Violation Code ObservationViolation Citation04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed trouble signal on the fire alarm panel for the Hotel, per Engineering company will be replacing the system.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5903723

GOOD SAMARITAN VILLAS WEST

License Type: Apartment

4260 VILLAGE DR, KISSIMMEE 347466480

Inspection Date: 08/06/2021

Inspection Number: 1526983

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: FERTIL, SYLVERST

Violation Code ObservationViolation Citation

08-03-4 No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Observed 2 water heaters on site - 1 on the left is 375,000BTU AND THE 1 on the right is 500,000BTU. A boiler certificate is needed for the unit on the

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900695

HERITAGE CREEKSIDE

License Type: Apartment

1550 ALDERSGATE DIRVE, KISSIMMEE 34746-6573

Inspection Date: 08/06/2021

Inspection Number: 1518681

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: FERTIL, SYLVERST

Violation Code ObservationViolation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed the following certificates: 050046-6/15/2017 050047-6/15/2017

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5912065

FAIRFIELD INN SUITES BY MARRIOTT

License Type: Hotel

6073 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34747

Inspection Date: 08/03/2021

Inspection Number: 1160633

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6008599

LAQUINTA INN

License Type: Motel

34 FISHERMANS WHARF, JUPITER 33477

Inspection Date: 08/05/2021

Inspection Number: 1217518

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code Observation

Violation Citation

07-04-4 Electrical outlet damaged to indicate a malfunction. For reporting purposes only.1st floor /by room#119/117/outlet cover missing.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6202334 AVALON GARDEN APTS
 License Type: Apartment 210 SW JEFFERSON CIR N, ST PETERSBURG 337031322

Inspection Date: 08/02/2021 Inspection Number: 1523033 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILMOT, TASHARA

Violation Code ObservationViolation Citation

01-01-4 Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. -adjacent of unit 1 **Repeat Violation**
 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6213380 TAHITIAN RESORT
 License Type: Motel 11320 GULF BLVD, TREASURE ISLAND 33706

Inspection Date: 08/06/2021 Inspection Number: 1219991 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DAY-WALKER, LISA

Violation Code ObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher near unit 152,153 is showing in the red recharge zone.
 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6200407 IMPERIAL GARDEN APTS
 License Type: Apartment 2100 NURSERY RD, CLEARWATER 33764

Inspection Date: 08/05/2021 Inspection Number: 1523077 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: WILMOT, TASHARA

Violation Code ObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. -at unit 4 building K **Repeat Violation**
 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215803 OPAL SANDS RESORT
 License Type: Hotel 430 S GULFVIEW BLVD, CLEARWATER 33767

Inspection Date: 08/03/2021 Inspection Number: 1160242 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KOUSTIS, TIMOTHY

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6602518

HILTON GARDEN INN AT PGA VILLAGE

License Type: Hotel

8540 COMMERCE CENTRE DR, PORT ST LUCIE 34986

Inspection Date: 08/05/2021

Inspection Number: 1160040

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HYNES, MONICA

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6602525

SLEEP INN OF PORT ST LUCIE

License Type: Hotel

8501 CHAMPION WAY, PORT ST LUCIE 34986

Inspection Date: 08/05/2021

Inspection Number: 1160867

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HYNES, MONICA

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-03-4 No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406168 KHEMARA HOLDINGS LLC
 License Type: Apartment 421 SILVER BEACH AVE, DAYTONA BEACH 32118

Inspection Date: 08/03/2021 Inspection Number: 1519937 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WOOD, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. -inside laundry room	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401756 ECONO INN
 License Type: Motel 1567 N US 1, ORMOND BEACH 32174

Inspection Date: 08/06/2021 Inspection Number: 1218936 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: RUTLEDGE, REBECCA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-03-4	Smoke detector/alarm in guest room/unit 112 has audible low battery signal.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406512 LOTUS INN & SUITES
 License Type: Motel 505 S ATLANTIC AVE, ORMOND BEACH 32176

Inspection Date: 08/05/2021 Inspection Number: 1219430 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RUTLEDGE, REBECCA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.