

Alachua County

License Number: 1101058		FAIRVIEW APTS	
License Type: Apartment		1615 NE 16 AVE, GAINESVILLE 326014672	
Inspection Date: 08/27/2021	Inspection Number: 1513189	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CASEY, KEITH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed the fire extinguisher between 6 and 7 is visually obstructed by the bush and the buttress.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1103078		VARSITY HOUSE GAINESVILLE	
License Type: Apartment		1720 SW 37TH ST, GAINESVILLE 32607	
Inspection Date: 08/24/2021	Inspection Number: 1532725	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: CASEY, KEITH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher in the recharge zone, 3rd floor 1720, in a storage room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed the fire alarm digital screen at the entrance to the office, has trouble indicated, alarm is silenced.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1102627		EXTENDED STAY AMERICA #381	
License Type: Motel		3600 SW 42 ST, GAINESVILLE 32608	
Inspection Date: 08/24/2021	Inspection Number: 1218002	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PACE, PATRICK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher in laundry slightly into recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Alachua County

License Number: 1102475

CHELSEA APARTMENTS

License Type: Apartment

2510 NE 9 ST, GAINESVILLE 32609

Inspection Date: 08/27/2021

Inspection Number: 1516777

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: CASEY, KEITH

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed trouble lights by 310.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1101899

NEWBERRY PLACE APARTMENTS

License Type: Apartment

25415 NW 7 AVE, NEWBERRY 32669

Inspection Date: 08/24/2021

Inspection Number: 1528661

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: TORRES, WILLIAM

Violation CodeObservationViolation Citation

01-03-4

Observed two Portable fire extinguisher missing from it's designated location (sign present indicating designated location) between units three and four , as well as between units eight and nine. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Baker County

License Number: 1200123

TRAVELODGE

License Type: Motel

1651 S 6TH STREET, MACCLENNY 32063

Inspection Date: 08/25/2021

Inspection Number: 1220174

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In front of room 111. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1505695 EXTENDED STAY AMERICA #9505
 License Type: Hotel 4835 HELEN HAUSER BLVD, TITUSVILLE 32780

Inspection Date: 08/23/2021 Inspection Number: 1160906 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILSON, LANETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Couldn't locate . Both tanks say 500,000 btu	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1505860 CYPRESS BAY
 License Type: Apartment 3656 VERDI CIRCLE, PALM BAY 32909

Inspection Date: 08/26/2021 Inspection Number: 1512990 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SCHOENLY, BARBARA Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620926 AC HOTELS BY MARRIOTT FT. LAUDERDALE AIRPORT
 License Type: Hotel 154 N COMPASS WAY, DANIA BEACH 33004

Inspection Date: 08/25/2021 Inspection Number: 1159202 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LONDONO, GLORIA Inspection

Violation Code ObservationViolation Citation

08-03-4 No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. 2 boilers with 600.000 BTUs capacity.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620927 MARRIOTT FT. LAUDERDALE AIRPORT
 License Type: Hotel 166 N COMPASS WAY, DANIA BEACH 33004

Inspection Date: 08/25/2021 Inspection Number: 1159203 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LONDONO, GLORIA Inspection

Violation Code ObservationViolation Citation

08-03-4 No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. 2 boilers with 600 BTUs capacity

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621011 POMPANO PALMS APARTMENT
 License Type: Apartment 300 NW 34 ST, POMPANO BEACH 33064

Inspection Date: 08/27/2021 Inspection Number: 1532769 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: GOODWIN, NICHOLAS

Violation Code ObservationViolation Citation

01-01-4 Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Unit 205 400

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1610903		HOTEL POMPANO BEACH	
License Type: Motel		1201 NW 31ST AVE, POMPANO BEACH 33069	
Inspection Date: 08/27/2021	Inspection Number: 1217122	Inspection Type: Complaint Full	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: STEUBER, RYAN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2021-06-21: **Time Extended** - From follow-up inspection 2021-08-27:	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1600852		1414 NE 4 ST APARTMENTS	
License Type: Apartment		1414 NE 4 ST, FORT LAUDERDALE 33301	
Inspection Date: 08/23/2021	Inspection Number: 1518980	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANN, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
07-01-4	Damaged electrical wire(s). For reporting purposes only. Wires on West side of property are on the ground. Inspector contacted property manager and will forward inspection report to Fire Marshall.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1621472		VICTORIA PARK INVESTMENTS LLC	
License Type: Apartment		1120 N VICTORIA PARK RD, FORT LAUDERDALE 33304	
Inspection Date: 08/27/2021	Inspection Number: 1514934	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANN, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. By Apts 1A and 7.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1610291		CASA ESPANOLA APTS	
License Type: Apartment		2221 NW 58 TER, LAUDERHILL 33313-3124	
Inspection Date: 08/23/2021	Inspection Number: 1523673	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SMITH, CORETTA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-04-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs stored inside the building. For reporting purposes only. Observed on second floor on bldg 2220	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Broward County

License Number: 1621683 4TH AVE LAND HOLDINGS, LLC
 License Type: Apartment 3890 DAVIE RD, DAVIE 33314

Inspection Date: 08/27/2021 Inspection Number: 1532709 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BARTON, GEOFFREY Inspection

Violation Code ObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. On column in garage at handicap spot closest to Commercial Suite 111 back door. 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1612534 PFL VII LLC
 License Type: Hotel 400 CORPORATE DR, FORT LAUDERDALE 33334

Inspection Date: 08/20/2021 Inspection Number: 1160877 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: BENJAMIN, ALEXANDER

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1615157 BEST WESTERN HOTEL
 License Type: Hotel 1050 E NEWPORT CENTER DR, DEERFIELD BEACH 33442-7723

Inspection Date: 08/25/2021 Inspection Number: 1159354 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, DENNIS

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Supervisor back flow alarm 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2307080		ST THOMAS APTS	
License Type: Apartment		4385 NW 9 ST, MIAMI 331263583	
Inspection Date: 08/20/2021	Inspection Number: 1529770	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed by unit 4 and on second floor by unit 14. Priority: Reporting **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329384		HYATT CENTRIC BRICKELL	
License Type: Hotel		1102 BRICKELL BAY DR, MIAMI 33131	
Inspection Date: 08/23/2021	Inspection Number: 1160567	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed the trouble light illuminated on the first floor by the entrance. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2316381		ERNESTO MOTEL	
License Type: Motel		4001 W FLAGLER ST, MIAMI 33134	
Inspection Date: 08/24/2021	Inspection Number: 1219522	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ALEJANDRO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
07-04-4	Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Office.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2323053		HAMILTON ON THE BAY	
License Type: Apartment		555 NE 34 ST, MIAMI 33137	
Inspection Date: 08/24/2021	Inspection Number: 1532738	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: SEYBA, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. On west end of hallway on floor 24.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light on "smoke evac fans"	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2307154		JEFFERSON TERRACE APTS	
License Type: Apartment		840 16 ST, MIAMI BEACH 331392882	
Inspection Date: 08/20/2021	Inspection Number: 1529772	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge located next to unit 13. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2328969		CADILLAC HOTEL & BEACH CLUB, AUTOGRAPH COLLECTION	
License Type: Hotel		3925 COLLINS AVE, MIAMI BEACH 33140	
Inspection Date: 08/24/2021	Inspection Number: 1159880	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329208		GRAND BEACH HOTEL	
License Type: Hotel		4835 COLLINS AVE, MIAMI BEACH 33140	
Inspection Date: 08/26/2021	Inspection Number: 1161051	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329321		L HOTEL	
License Type: Hotel		4121 INDIAN CREEK DR, MIAMI BEACH 33140	
Inspection Date: 08/26/2021	Inspection Number: 1159934	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed in main panel located in the front desk office.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2309627		SHANTI HOUSE	
License Type: Apartment		1940 BAY DR #11, MIAMI BEACH 33141	
Inspection Date: 08/23/2021	Inspection Number: 1518640	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2310348		SUNSET SQUARE APTS	
License Type: Apartment		5950 SW 74 ST, SOUTH MIAMI 33143	
Inspection Date: 08/25/2021	Inspection Number: 1531541	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PICO, JORGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed a fire extinguisher missing at the parking lot area, next to the laundry room location.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2303092	HOLIDAY INN HOTEL		
License Type: Motel	1111 S ROYAL POINCIANA, MIAMI SPGS 331667318		
Inspection Date: 08/27/2021	Inspection Number: 1217221	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed extinguisher with no braking device located by ice machine on 2nd floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2326874	EXTENDED STAY AMERICA #9639		
License Type: Hotel	8720 NW 33RD ST, MIAMI 33172		
Inspection Date: 08/27/2021	Inspection Number: 1162226	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ALVAREZ, MARGARET			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2323902	HAMMOCKS PLACE		
License Type: Apartment	15280 SW 104 ST, MIAMI 33196		
Inspection Date: 08/23/2021	Inspection Number: 1528917	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: ELDER, AUDREY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device near unit 7110.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Duval County

License Number: 2602493		EASTSIDE TERRACE APARTMENTS	
License Type: Apartment		1230 E 7 ST, JACKSONVILLE 322064839	
Inspection Date: 08/27/2021	Inspection Number: 1532605	Inspection Type: Complaint Full	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: PERRY, DENNIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Panel in laundry area shows trouble. - From follow-up inspection 2021-08-13: Panel in laundry area still showing trouble alert.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2608615		MOTEL 6 JACKSONVILLE ORANGE PARK	
License Type: Motel		6107 YOUNGERMAN CIR, JACKSONVILLE 32244	
Inspection Date: 08/24/2021	Inspection Number: 1220155	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BELLEMARE, RYAN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Missing outside of 134, 142	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2613193		FAIRFIELD INN & SUITES	
License Type: Hotel		1616 1 ST N, JACKSONVILLE BEACH 32250	
Inspection Date: 08/27/2021	Inspection Number: 1160971	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: GONZALEZ, MAYRA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificate expired 06/06/2021 for boiler number 098188, 098189	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Hillsborough County

License Number: 3900493 THE RIVIERA AT 8412
 License Type: Apartment 8412 RIO BRAVO COURT, TAMPA 33617

Inspection Date: 08/27/2021 Inspection Number: 1532426 Inspection Type: Complaint Full Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: REGAS, ANTHONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed fire extinguisher missing at building 1 and 27. **Repeat Violation** - F	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3903555 RIVERSIDE PALMS APARTMENTS
 License Type: Apartment 5008 SIERRA PL, TAMPA 33617

Inspection Date: 08/27/2021 Inspection Number: 1532763 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: REGAS, ANTHONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
12-04-4	High Priority - Balcony/starway/platform collapsed. The balcony at building 5002 unit 357 is being held upright by jacks. **Repeat Violation**	61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

Monroe County

License Number: 5400641

CONCH KEY FISHING LODGE & MARINA

License Type: Motel

3 N CONCH AVE, MARATHON 33050

Inspection Date: 08/27/2021

Inspection Number: 1217710

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation Code Observation

Violation Citation

04-02-4 No smoke detector provided in guest room/unit. For reporting purposes only. Unit 5 has no smoke detector.

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5603600

EMERALD GRANDE

License Type: Hotel

10 HARBOR BLVD, DESTIN 32541

Inspection Date: 08/23/2021

Inspection Number: 1161865

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: STEINMAN, MARC

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available.
 For reporting purposes only.
 2 New Boilers installed
 3rd boiler off line

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 63 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5801661

LA QUINTA INN

License Type: Motel

5825 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 08/26/2021

Inspection Number: 1219614

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Observed boiler certification has expired F1130055 5/16/2020 spoke to General Manager.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6009061

PALM BEACH GARDENS MARRIOTT

License Type: Hotel

4000 RCA BLVD, PALM BEACH GARDENS 33410

Inspection Date: 08/26/2021

Inspection Number: 1159447

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GOLDMAN, BARRY

Violation Code ObservationViolation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. J# 135773, 135774 - 05/2021 expired. Inspection conducted waiting on Certificates. **Corrective Action Taken**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6014310

THE HAMPTONS AT PALM BEACH GARDENS

License Type: Apartment

4045 CENTRAL GARDENS WAY, PALM BEACH GARDENS 33418

Inspection Date: 08/27/2021

Inspection Number: 1526456

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: KAMM, DARYL

Violation Code ObservationViolation Citation

04-07-4 Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6014069

AXIS DELRAY

License Type: Apartment

1495 SPRING HARBOR DR, DELRAY BEACH 33445

Inspection Date: 08/26/2021

Inspection Number: 1532755

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: GOODWIN, NICHOLAS

Violation Code ObservationViolation Citation

01-01-4 Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Located outside of Apt F2095

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

02-04-4 Propane (LP gas) tank having a water capacity greater than 2.7 lbs stored inside the building. For reporting purposes only. LP gas tank stored on patio of 2nd floor u it or building 1505. NW side of building

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6206343 EVEREST AUTUMN CHASE HOLDINGS TWO LLC
 License Type: Apartment 2200 GLADYS ST, LARGO 33774

Inspection Date: 08/23/2021 Inspection Number: 1532542 Inspection Type: Lodging-Licensing Inspection Disposition: Call Back -
 Inspector Name: LOZANO, KELVIN Inspection Extension given, pending

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
12-04-4	- From initial inspection : High Priority - Platform with rotted wood. Unit 1307 **Warning** - From follow-up inspection 2021-08-23: Per maintenance parts have been ordered for repairs and they are waiting for delivery **Time Extended** **Corrective	61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

License Number: 6215012 MP & BT LLC
 License Type: Apartment 4951 N 87 AVE, PINELLAS PARK 33782

Inspection Date: 08/24/2021 Inspection Number: 1524172 Inspection Type: Routine - Lodging Inspection Disposition: Inspection
 Inspector Name: WILMOT, TASHARA Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6306553

LAKELAND COURTYARD BY MARRIOTT

License Type: Hotel

3725 HARDEN BLVD, LAKELAND 33803

Inspection Date: 08/24/2021

Inspection Number: 1162129

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BEAULIEU, STEPHANIE

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. System trouble light on.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. System trouble light on. - From follow-up inspection 2021-08-27: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7401645		PALM COVE	
License Type: Apartment		886 S NOVA RD, DAYTONA BEACH 32114	
Inspection Date: 08/23/2021	Inspection Number: 1532657	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ANGEL, TERRY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Laundry Room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7400715		GRAND PRIX MOTEL	
License Type: Motel		2015 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118	
Inspection Date: 08/23/2021	Inspection Number: 1218366	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: WOOD, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. -upstairs next to 38	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7401460		MAKAI BEACH RESORT	
License Type: Motel		707 S ATLANTIC AVE, ORMOND BEACH 32176	
Inspection Date: 08/26/2021	Inspection Number: 1220173	Inspection Type: Complaint Full	Inspection Disposition: Call Back - Extension given, pending
Inspector Name: RUTLEDGE, REBECCA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. From follow-up inspection 2021-08-26:	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	