

**Alachua County**

License Number: 1100335

SUNNY SOUTH MOTEL

License Type: Motel

105 SW 250TH ST, NEWBERRY 32669

Inspection Date: 09/07/2021

Inspection Number: 1219309

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TORRES, WILLIAM

Violation Code    Observation

Violation Citation

04-02-4    No smoke detector provided in guest room/unit. For reporting purposes only.  
Observed smoke detector disconnected in room 103.

509.215(1) and (2) and 509.032(2)(d) FS Reporting:  
509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Bay County**

License Number: 1302937

ECONOLOGDE

License Type: Motel

4411 W HWY 98, PANAMA CITY 324011024

Inspection Date: 09/07/2021

Inspection Number: 1218652

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code    Observation

Violation Citation

01-01-4    Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Outside room 212.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Broward County**

License Number: 1602464 ST MAURICE BEACH INN  
 License Type: Motel 310 MICHIGAN ST, HOLLYWOOD 33019

Inspection Date: 09/10/2021 Inspection Number: 1218540 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: MARTINEZ, RHEANNE

Violation Code ObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed mini extinguisher on maintenance shed in red reading "Empty". Operator replaced with new mini extinguisher backup from offi  
 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1611722 SUPER 8 MOTEL POMPANO BEACH  
 License Type: Hotel 2300 NE 10 ST, POMPANO BEACH 33062-4104

Inspection Date: 09/08/2021 Inspection Number: 1162385 Inspection Type: Complaint Full Inspection Disposition: Warning Issued  
 Inspector Name: BURGGRABE, BROCK

Violation Code ObservationViolation Citation

04-02-4 No smoke detector provided in guest room/unit. For reporting purposes only. Manager took room out of service to have smoke detector on shelf reinstalled.  
 509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620956 GOLDEN VILLA APARTMENTS  
 License Type: Apartment 1325 NW 18 DR, POMPANO BEACH 33069

Inspection Date: 09/09/2021 Inspection Number: 1516290 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BURGGRABE, BROCK

Violation Code ObservationViolation Citation

04-06-4 Fire alarm control panel emitting an audible alarm. For reporting purposes only. At building 1341/205 breezeway panel/room.  
 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621688 VICTORIA628 LLC  
 License Type: Apartment 628 NE 8TH AVE., FORT LAUDERDALE 33304

Inspection Date: 09/07/2021 Inspection Number: 1512330 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BRANN, JUSTIN

Violation Code ObservationViolation Citation

07-01-4 Two light fixtures on exterior of laundry room with exposed electrical wire(s) and alongside Unit 1, parking side, outlet with no cover. For reporting purposes only.  
 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1606784

4 PCMK DAVIE INC

License Type: Apartment

4931 SW 65 AVE, DAVIE 33314

Inspection Date: 09/09/2021

Inspection Number: 1531537

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BARTON, GEOFFREY

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2325795 EXECUTIVE PALACE HOTEL  
 License Type: Hotel 2125 W OKEECHOBEE RD, HIALEAH 33010

Inspection Date: 09/07/2021 Inspection Number: 1159633 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PRIETO, EDGAR

Violation Code    ObservationViolation Citation

04-01-4    Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2325394 BARBARA APARTMENTS  
 License Type: Apartment 6030 W 22 CT, HIALEAH 33016

Inspection Date: 09/08/2021 Inspection Number: 1520157 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: CRUZ, EDGAR

Violation Code    ObservationViolation Citation

04-01-4    Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2320362 2225 BUILDING  
 License Type: Apartment 2225 W 60 ST, HIALEAH 330164476

Inspection Date: 09/07/2021 Inspection Number: 1525155 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied  
 Inspector Name: CRUZ, EDGAR

Violation Code    ObservationViolation Citation

01-06-4    - From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.  
 Observed no glass breaking devices on fire extinguisher by elevators. **\*\*Repeat Violation\*\*** - From fo

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329343 SLS BRICKELL HOTEL  
 License Type: Hotel 1300 S MIAMI AVE, MIAMI 33130

Inspection Date: 09/09/2021 Inspection Number: 1160317 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: CABANAS, NATALIE

Violation Code    ObservationViolation Citation

04-01-4    Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329470

HOTEL INDIGO MIAMI BRICKELL / ATWELL SUITES MIAMI BRICKELL

License Type: Hotel

145 SW 11 ST, MIAMI 33130

Inspection Date: 09/08/2021

Inspection Number: 1160860

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CABANAS, NATALIE

Violation Code   ObservationViolation Citation

08-03-4      No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.  
At the time of the inspection observed two boilers with 700,000 btu, No boiler certificate provided establishment is in process to get certified.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329214

THE GABRIEL HOTEL MIAMI

License Type: Hotel

1100 BISCAYNE BLVD, MIAMI 33132

Inspection Date: 09/07/2021

Inspection Number: 1160742

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CUDEMOS, VIRNA

Violation Code   ObservationViolation Citation

04-07-4      Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329407

GLOBAL GRAND MANAGEMENT

License Type: Hotel

1717 N BAYSHORE DR STE 240, MIAMI 33132

Inspection Date: 09/08/2021

Inspection Number: 1161157

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CUDEMOS, VIRNA

Violation Code   ObservationViolation Citation

08-01-4      Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328267

WYNTOWN APARTMENTS LLC

License Type: Apartment

1720 NW 1 PL, MIAMI 33136

Inspection Date: 09/10/2021

Inspection Number: 1532918

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: HENLEY, LATONYA

Violation Code   ObservationViolation Citation

01-06-4      Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By unit 1, building 1720.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329171

Z OCEAN

License Type: Hotel

1437 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 09/08/2021

Inspection Number: 1159311

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: HODGE, KRISTEN

Violation Code   ObservationViolation Citation

04-01-4      Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2300796

SEACOAST SUITE

License Type: Apartment

5101 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 09/08/2021

Inspection Number: 1528965

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back - Extension given, pending

Inspector Name: UNZAGA, MILADYS

Violation Code   ObservationViolation Citation

08-01-4      - From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificates expired on 4/8/2021. - From follow-up inspection 2021-09-08: Boilers were inspected , but still w

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329678

REGAL APARTMENTS LLC

License Type: Apartment

6020 NW 13 AVE, MIAMI 33142

Inspection Date: 09/07/2021

Inspection Number: 1532820

Inspection Type: Complaint Full

Inspection Disposition: Administrative complaint recommended

Inspector Name: CONCEPCION, ADRIEL

Violation Code   ObservationViolation Citation

01-06-4      Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.

Observed missing breaking device on fire extinguisher located next unit 23 on 3rd floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2306103

SEA VIEW HOTEL (THE)

License Type: Hotel

9909 COLLINS AVE, MIAMI BEACH 331541808

Inspection Date: 09/07/2021

Inspection Number: 1160400

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PRIETO, VICENTE

Violation Code    Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. <b>**Repeat Violation**</b>	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed 5 boilers with expired certificates.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Escambia County**

License Number: 2705813

MARGARITAVILLE BEACH HOTEL

License Type: Hotel

165 FORT PICKENS RD, PENSACOLA BEACH 32561

Inspection Date: 09/07/2021

Inspection Number: 1161278

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ALBRITTON, GREGORY

Violation Code    Observation

Violation Citation

01-06-4    Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.  
 3-1 next to room 328.  
 7-1 next to room 728.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Lee County**

License Number: 4600947 PARKER HOUSE PROPERTIES  
 License Type: Apartment 808 MIRAMAR ST, CAPE CORAL 33904

Inspection Date: 09/10/2021 Inspection Number: 1491231 Inspection Type: Routine - Lodging Inspection Disposition: Call Back -  
 Inspector Name: SOMMERS, KARA Complied

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Extinguisher between Units 8 & 9. - From follow-up inspection 2021-06-08: - From follow-up inspection 20	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4604656 LAGO DEL SOL APARTMENTS  
 License Type: Apartment 10770 CLEAR LAKE LOOP, FORT MYERS 33908

Inspection Date: 09/10/2021 Inspection Number: 1503246 Inspection Type: Routine - Lodging Inspection Disposition: Call Back -  
 Inspector Name: SOMMERS, KARA Admin. complaint recommended

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-06-4	- From initial inspection : Fire alarm control panel emitting an audible alarm. For reporting purposes only. Buildings 15061 and 15101. - From follow-up inspection 2021-06-02: - From follow-up inspection 2021-07-08: - From follow-up inspectio	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-01-4	- From initial inspection : Damaged electrical wire(s). For reporting purposes only. Observed emergency lights detached and hanging by wires, 2nd and 3rd floor, Building 15061. **Repeat Violation** - From follow-up inspection 2021-06-02: - From f	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Marion County**

License Number: 5200061 SANCHEZ APARTMENTS  
 License Type: Apartment 221 SE SANCHEZ AVE, OCALA 34471

Inspection Date: 08/31/2021 Inspection Number: 1517508 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GARNER, DHANIQUA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher on second floor in need of recharge.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5200101 QUEEN'S GARDENS RESORT  
 License Type: Motel 3330 S PINE AVE, OCALA 34471

Inspection Date: 08/30/2021 Inspection Number: 1218598 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: GARNER, DHANIQUA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed no breaking bar attached to fire extinguisher located between room 110 and room 111.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5200252 DIXIE MOTEL  
 License Type: Motel 1539 S PINE AVE, OCALA 34471

Inspection Date: 09/08/2021 Inspection Number: 1219464 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: GARNER, DHANIQUA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher next to room 11.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-03-4	Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Observed smoke detector cover missing on smoke alarm on wall in room 2.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Okaloosa County**

License Number: 5600787

WYNDHAM GARDENS

License Type: Motel

573 SANTA ROSA BLVD, FT WALTON BCH 32548

Inspection Date: 09/09/2021

Inspection Number: 1220350

Inspection Type: Complaint Full

Inspection Disposition: Administrative complaint recommended

Inspector Name: ADAMSON, ROBERT

Violation Code    Observation

Violation Citation

08-01-4    Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **\*\*Repeat Violation\*\***

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Hotel

7769 W. IRLO BRONSON MEMORIAL HWY., KISSIMMEE 34747

Inspection Date: 09/08/2021

Inspection Number: 1220353

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation Code    Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. <b>**Repeat Violation**</b>	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-03-4	Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only room 544 and 538	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
05-02-5	Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. In room 544	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Palm Beach County**

License Number: 6012655

FAIRFIELD INN &amp; SUITES JUPITER

License Type: Hotel

6748 INDIANTOWN RD, JUPITER 33458

Inspection Date: 09/10/2021

Inspection Number: 1161083

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: ROTONDI, VICTOR

Violation Code    ObservationViolation Citation

08-01-4    - From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 121021, 121022, 095111 all exp 03/15/2019 \*\*Repeat Violation\*\* - From follow-up inspection 2021-09-10: No proof of current boil

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4    Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 121021, 121022, / all exp 3/15/2019. \*\*Repeat Violation\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6014336

CASPIAN

License Type: Apartment

190 SE 5 AVE, DELRAY BEACH 33483

Inspection Date: 09/10/2021

Inspection Number: 1526668

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation Code    ObservationViolation Citation

04-01-4    Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Main FACP located next to leasing office has trouble sign illuminated \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6216107

R ST PETE LLC

License Type: Apartment

550 50 AVE N, ST PETERSBURG 33703

Inspection Date: 09/07/2021

Inspection Number: 1517616

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILMOT, TASHARA

Violation Code    Observation

Violation Citation

01-02-4    Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
 -next to unit 40 \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Seminole County**

License Number: 6903585

HILTON GARDEN INN ORLANDO NORTH-LAKE MARY FL

License Type: Hotel

705 CURRENCY CIR, LAKE MARY 32746

Inspection Date: 09/09/2021

Inspection Number: 1161296

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation Code    Observation

Violation Citation

04-01-4            Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**St. Lucie County**

License Number: 6602528

LIVE OAKS VILLAS

License Type: Apartment

919 S 25 ST, FORT PIERCE 34947

Inspection Date: 09/10/2021

Inspection Number: 1520941

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HARROD, JESSICA

Violation Code    ObservationViolation Citation

04-01-4    Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Troubled file panel.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6602521

RESIDENCE INN BY MARRIOTT PORT ST LUCIE

License Type: Hotel

1920 SW FOUNTAINVIEW BLVD, PORT ST LUCIE 34986

Inspection Date: 09/07/2021

Inspection Number: 1160043

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HYNES, MONICA

Violation Code    ObservationViolation Citation

08-01-4    Boiler certificate or insurance inspector's boiler report expired. Certificate that is posted in boiler room is dated 2015. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Suwannee County**

License Number: 7100152

ECONO LODGE

License Type: Motel

6811 N US 129, LIVE OAK 32060

Inspection Date: 09/10/2021

Inspection Number: 1217984

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BAILEY, KIMBERLY

Violation Code    Observation

Violation Citation

02-04-4    Propane (LP gas) tank having a water capacity greater than 2.7 lbs stored inside the building. For reporting purposes only. Inside storage room/breakfast room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7401243 SPARHAWK PROPERTIES LLC  
 License Type: Apartment 515 SILVER BEACH AVE, DAYTONA BEACH 32118

Inspection Date: 09/09/2021 Inspection Number: 1526122 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: WOOD, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-08-4	Motorcycle stored under a stairwell. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406495 HOLIDAY INN DAYTONA BEACH LPGA  
 License Type: Hotel 137 AUTOMALL CIR, DAYTONA BEACH 32124

Inspection Date: 09/07/2021 Inspection Number: 1162202 Inspection Type: Complaint Full Inspection Disposition: Warning Issued  
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. System trouble and system silence	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.