

Alachua County

License Number: 1102123		BAYMONT INN & SUITES	
License Type: Motel		6901 NW 4 BLVD, GAINESVILLE 32607	
Inspection Date: 10/05/2021	Inspection Number: 1218386	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: CASEY, KEITH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed the fire extinguisher at the North stairwell is indicated in the recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed the boiler certificate for 087938 expired on 8-15-2020.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 1100727		ECONO LODGE	
License Type: Motel		2649 SW 13 ST, GAINESVILLE 32608	
Inspection Date: 10/05/2021	Inspection Number: 1220702	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: PACE, PATRICK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-05-4	No smoke detector provided in guest room/unit. For reporting purposes only. Missing in unit 212	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
04-05-4	- From initial inspection : No smoke detector provided in guest room/unit. For reporting purposes only. Missing in unit 212 - From follow-up inspection 2021-10-08: No smoke detector in room 212. **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 1102323		TRAVELODGE ALACHUA	
License Type: Motel		15920 NW US 441, ALACHUA 32615	
Inspection Date: 10/04/2021	Inspection Number: 1218330	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Extension given, pending
Inspector Name: CASEY, KEITH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
05-02-5	- From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Observed the hearing impaired smoke detectors in 102 and 103 are not functioning. - From follow-up inspection 2021-10-04: Only 1 functioning hearing impaired smoke detector. **Time Extended** **Corrective Action Taken**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Bay County

License Number: 1301607

SUNSET INN

License Type: Motel

8109 SURF DR, PANAMA CITY 32408

Inspection Date: 10/04/2021

Inspection Number: 1218815

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside room 219.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1304002

KAPALUA APARTMENTS

License Type: Apartment

2223 JOAN AVE, PANAMA CITY BEACH 32408

Inspection Date: 06/15/2021

Inspection Number: 1533163

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: LYNN, NICKOLAS

Violation CodeObservationViolation Citation

02-08-4

OBSERVED PROPANE (LP GAS) TANK HAVING A WATER CAPACITY GREATER THAN 2.7LBS STORED UNDER STAIRWELL, IN FRONT OF UNIT 117. PRIORITY: REPORTING

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Inspection Date: 10/07/2021

Inspection Number: 1533035

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside 105.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs stored under a stairwell. For reporting purposes only. In front of 117. Manager removed tanks at time of inspection. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1612878		HOTOLOS HOLLYWOOD	
License Type: Motel		2520 STIRLING RD, HOLLYWOOD 33019	
Inspection Date: 10/04/2021	Inspection Number: 1217771	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: CHRISTGEN, THOM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed on extinguisher between rooms 335 and 337 and on extinguisher between 235 and 237. - From follow-up inspection 2021-10-04: Observed same at fire extinguisher by room 235. Observed same at fire extinguisher by room 335. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1603513		RASCAL HOLLYWOOD LLC	
License Type: Apartment		1500 S 20 AVE, HOLLYWOOD 33020	
Inspection Date: 10/06/2021	Inspection Number: 1533137	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHRISTGEN, THOM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed at the extinguisher between units 12 and 15.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1604979		WILLIAM HERSHEY REVOCABLE TRUST	
License Type: Apartment		1649 DEWEY ST, HOLLYWOOD 33020	
Inspection Date: 10/06/2021	Inspection Number: 1519012	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHRISTGEN, THOM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed on the extinguisher to the right of Unit 7.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1615065		LAKES AT PEMBROKE	
License Type: Apartment		9900 SHERIDAN ST, PEMBROKE PINES 33024	
Inspection Date: 10/06/2021	Inspection Number: 1525927	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LONDONO, GLORIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In front of unit 101, building 9840.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Broward County

License Number: 1607536		BRC PROPERTIES INC	
License Type: Apartment		600 SE 23 AVE, POMPANO BEACH 33062	
Inspection Date: 10/06/2021	Inspection Number: 1516930	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BURGGRABE, BROCK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. At 1st floor fire extinguisher.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1607221		FORT LAUDERDALE GRAND HOTEL	
License Type: Hotel		4900 POWERLINE ROAD, OAKLAND PARK 33309	
Inspection Date: 10/07/2021	Inspection Number: 1161439	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SEWELL, SANGAY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed certificate expired 10/24/2019	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1619671		COMFORT SUITES	
License Type: Hotel		2201 N COMMERCE PKWY, WESTON 33326	
Inspection Date: 10/08/2021	Inspection Number: 1159300	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MUIR, TRICIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
07-04-4	Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Observed outlet damaged in 120 Operator called maintenance for repair.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Broward County

License Number: 1611978

DOUBLETREE BY HILTON DEERFIELD BEACH - BOCA RATON

License Type: Hotel

100 FAIRWAY DR, DEERFIELD BEACH 33441

Inspection Date: 10/08/2021

Inspection Number: 1154053

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: KHATOON, BEGUM

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2325181 1200 SW 3RD ST., LLC
 License Type: Apartment 1200 SW 3 ST, HOMESTEAD 33030

Inspection Date: 10/06/2021 Inspection Number: 1532347 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: LEIDECKER, EDILMA

Violation Code ObservationViolation Citation

01-06-4 - From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed at buildings 1241 and 1261(first and second floor). **Repeat Violation** **Warning** - From follow-up inspection 2021-10-06: Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed at buildings 1241 and 1261(first and second floor). **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330156 X MIAMI
 License Type: Apartment 230 NE 4 ST, MIAMI 33132

Inspection Date: 10/04/2021 Inspection Number: 1524270 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: CUDEMOS, VIRNA

Violation Code ObservationViolation Citation

08-01-4 - From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2021-10-04: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330669 1442 NEW MIAMI COURT LLC
 License Type: Apartment 1442 NE MIAMI CT, MIAMI 33132

Inspection Date: 10/06/2021 Inspection Number: 1533074 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CUDEMOS, VIRNA

Violation Code ObservationViolation Citation

04-07-4 Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2308798 SUNSHINE INN OF MIAMI LLC
 License Type: Motel 4871 W FLAGLER ST, CORAL GABLES 33134

Inspection Date: 10/08/2021 Inspection Number: 1219172 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, ALEJANDRO

Violation Code ObservationViolation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2327192		RED SOUTH BEACH	
License Type: Hotel		3010 COLLINS AVE, MIAMI BEACH 33140	
Inspection Date: 10/04/2021	Inspection Number: 1162812	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2329307		AC HOTEL MIAMI BEACH	
License Type: Hotel		2912 COLLINS AVE, MIAMI BEACH 33140	
Inspection Date: 10/04/2021	Inspection Number: 1159921	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2329398		GENERATOR	
License Type: Hotel		3120 COLLINS AVENUE, MIAMI BEACH 33140	
Inspection Date: 10/06/2021	Inspection Number: 1161384	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329482		CASTLE BEACH HOTEL	
License Type: Hotel		5445 COLLINS AVE CU 4, MIAMI BEACH 33140	
Inspection Date: 10/06/2021	Inspection Number: 1161657	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329220		THE LANDON	
License Type: Hotel		9660 E BAY HARBOR DR, BAY HARBOR ISLANDS 33154	
Inspection Date: 10/06/2021	Inspection Number: 1160436	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2319158		LA QUINTA INN 667	
License Type: Motel		7401 NW 36 ST, MIAMI 33166	
Inspection Date: 10/06/2021	Inspection Number: 1217545	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed extinguisher in recharge zone located between rooms 307 and 309. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed fire extinguishers with no braking device located between rooms 329 and 331, and rooms 339 and 341.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2307288

MIAMI SPRINGS INN

License Type: Motel

661 EAST DRIVE, MIAMI SPRINGS 33166

Inspection Date: 10/08/2021

Inspection Number: 1218818

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed extinguisher with no braking device located between rooms 107 and 108.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2319611

MIAMI SPRINGS INN

License Type: Motel

4585 NW 36 ST, MIAMI SPRINGS 33166

Inspection Date: 10/08/2021

Inspection Number: 1217594

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed extinguishers with no braking device located between rooms 204 and 205, 218 and 219.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329376

WOODSPRING SUITES MIAMI SOUTHWEST

License Type: Hotel

16055 SW 117 AVE, MIAMI 33177

Inspection Date: 10/07/2021

Inspection Number: 1160859

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LODENQUAI, BARRINGTON

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble lights illuminated on fire panel located at the front desk. **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2600150

BEACHWOOD APTS

License Type: Apartment

2931 BEACHWOOD BLVD, JACKSONVILLE 32246

Inspection Date: 10/07/2021

Inspection Number: 1530217

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: FICHTER, GARRICK

Violation Code

Observation

Violation Citation

02-04-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs stored inside the building. For reporting purposes only.
 15 lbs propane tank stored under stairwell outside unit C115.
 Manager removed propane tank from property **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2700272

MAYFAIR MOTEL

License Type: Motel

4540 MOBILE HWY, PENSACOLA 32506

Inspection Date: 10/08/2021

Inspection Number: 1217842

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: GARDNER, GREGORY

Violation Code

Observation

Violation Citation

06-03-4

Marked exit is inaccessible. All guest rooms rear windows in motel complex boarded up. For reporting purposes only. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3911404

EXTENDED STAY AMERICA

License Type: Hotel

5401 BEAUMONT CTR BLVD E, TAMPA 33634

Inspection Date: 10/06/2021

Inspection Number: 1161021

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ZHANG, JACKY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4601286

BRAMAN TERRACE APTS

License Type: Apartment

2055 BRAMAN AVE, FORT MYERS 33901

Inspection Date: 10/07/2021

Inspection Number: 1527228

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WALTER, KAYLA

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed first floor fire extinguisher closest to unit 1 in overcharge one.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Levy County

License Number: 4800428

BRONSON COUNTRY INN

License Type: Motel

315 N HATHAWAY AVE, BRONSON 32621

Inspection Date: 10/04/2021

Inspection Number: 1217756

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TORRES, WILLIAM

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.
Observe no smoke detector in guest room two or in guestroom 12

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5201916

SERENITY GARDENS AT BELLEVIEW

License Type: Apartment

5836 SE DREW RD, BELLEVIEW 34420

Inspection Date: 10/06/2021

Inspection Number: 1533114

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: FIGUEROA-ROBLES, TATIANA

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Extinguisher located between unit A4-A5 and A8-A9

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5402705

DOUBLETREE GRAND KEY RESORT

License Type: Hotel

3990 S ROOSEVELT BLVD, KEY WEST 33040

Inspection Date: 10/04/2021

Inspection Number: 1160484

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ORDONEZ, CATALINA

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Nassau County

License Number: 5500078

TROPIC MOTEL

License Type: Motel

850427 US HWY 17, YULEE 32097

Inspection Date: 10/06/2021

Inspection Number: 1219224

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROZIER, TORRANCE

Violation Code

Observation

Violation Citation

02-04-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs stored inside the building. For reporting purposes only.
Propane grill stored in front of door 5

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811138

GDC ORLANDO HOTEL OWNER LLC

License Type: Hotel

500 S ORANGE AVE, ORLANDO 32801

Inspection Date: 10/07/2021

Inspection Number: 1159525

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: JENKINS, JOSHUA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Boiler certificate expired in 2019. Boiler certificates not posted in room.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 63 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811121

SIGNIA BY HILTON ORLANDO BONNET CREEK

License Type: Hotel

14100 BONNET CREEK RESORT LN, ORLANDO 32821

Inspection Date: 10/08/2021

Inspection Number: 1160818

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: NIEVES, RAFAEL

Violation CodeObservationViolation Citation

08-04-4

Current boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 63 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811184

JW MARRIOTT ORLANDO BONNET CREEK HOTEL

License Type: Hotel

14900 CHELONIA PKWY, ORLANDO 32821

Inspection Date: 10/04/2021

Inspection Number: 1159521

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: NIEVES, RAFAEL

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Observed 3 boilers with the BTU of 1,501,000 without a boiler inspection or certificate.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 63 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811106

LAXMI AUGUSTA NATIONAL HOTEL II LTD

License Type: Hotel

5828 HAZELTINE NATIONAL DR, ORLANDO 32822

Inspection Date: 10/06/2021

Inspection Number: 1160339

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LORENZO, ANA

Violation Code

Observation

Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only./ system trouble at main panel

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5903723

GOOD SAMARITAN VILLAS WEST

License Type: Apartment

4260 VILLAGE DR, KISSIMMEE 347466480

Inspection Date: 10/05/2021

Inspection Number: 1526983

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: FERTIL, SYLVERST

Violation CodeObservationViolation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Observed 2 water heaters on site - 1 on the left is 375,000BTU AND THE 1 on the right is 500,000BTU. A boiler certificate is needed for the unit on the right. - From follow-up inspection 2021-10-05: Operator is waiting for the inspection to be conducted. Violation will be verified during the next unannounced inspection. **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900695

HERITAGE CREEKSIDE

License Type: Apartment

1550 ALDERSGATE DIRVE, KISSIMMEE 34746-6573

Inspection Date: 10/05/2021

Inspection Number: 1518681

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: FERTIL, SYLVERST

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed the following certificates: 050046-6/15/2017 050047-6/15/2017 - From follow-up inspection 2021-10-05: Operator is waiting on boiler inspectors to conduct inspection. Violation will be verified during the next unannounced inspection. **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Hotel

7769 W. IRLO BRONSON MEMORIAL HWY., KISSIMMEE 34747

Inspection Date: 10/05/2021

Inspection Number: 1162766

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2021-10-05: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-03-4	- From initial inspection : Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Room 552 - From follow-up inspection 2021-10-05: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-03-4	Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Room 552	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5912071

MARGARITAVILLE RESORT ORLANDO

License Type: Hotel

8000 FINS UP CIR, KISSIMMEE 34747

Inspection Date: 10/05/2021

Inspection Number: 1160594

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	---

Pinellas County

License Number: 6202349		NAUTICA APARTMENTS	
License Type: Apartment		5700 6 AVE N, ST. PETERSBURG 33710	
Inspection Date: 10/05/2021	Inspection Number: 1514661	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HOBBS, ANDREW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Building C near unit 30	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6205493		COSMO CASTLE	
License Type: Apartment		3000 70 LANE N, ST. PETERSBURG 33710	
Inspection Date: 10/07/2021	Inspection Number: 1525613	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HOBBS, ANDREW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Near unit 203	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6215858		PINE COVE VILLAS	
License Type: Apartment		1824 VILLAS DR #22, CLEARWATER 33760	
Inspection Date: 10/07/2021	Inspection Number: 1525793	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILMOT, TASHARA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. -at building 1836 (first floor) **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Pinellas County

License Number: 6216152

1717 PASADENA

License Type: Apartment

1717 PASADENA DRIVE, DUNEDIN 34698

Inspection Date: 10/06/2021

Inspection Number: 1531990

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PEARCE, LAURA

Violation Code

Observation

Violation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only.
Smoke detector and battery removed from ceiling and located on top of stairway in hallway

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6804758

THE WESTIN SARASOTA

License Type: Hotel

1175 N GULFSTREAM AVE, SARASOTA 34236

Inspection Date: 10/06/2021

Inspection Number: 1159677

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MCKEON, MICHAEL

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Establishment has 4:boilers and only the certificate for one of them.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6903762

SPRINGHILL SUITES SANFORD

License Type: Motel

201 N TOWNE RD, SANFORD 32771

Inspection Date: 10/07/2021

Inspection Number: 1218089

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Notified Sanford Fire Inspector, Dan Taylor. 407-562-2788.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6602352 PALM RIDGE APARTMENTS
 License Type: Apartment 2905 N US HWY 1, FT. PIERCE 34946

Inspection Date: 10/07/2021 Inspection Number: 1527127 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DAVIS, DIANNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-04-4	Extension Electrical corned strung around laundry room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6602535 THE BRENNITY AT TRADITION
 License Type: Apartment 10685 SW STONY CREEK WAY, PORT ST LUCIE 34987

Inspection Date: 10/04/2021 Inspection Number: 1524465 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: HYNES, MONICA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Suwannee County

License Number: 7100008

STEAMBOAT DIVE INN

License Type: Motel

503 US HWY 27, BRANFORD 32008

Inspection Date: 10/06/2021

Inspection Number: 1217660

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: TORRES, WILLIAM

Violation Code

Observation

Violation Citation

04-02-4	- From initial inspection : No smoke detector provided in guest room/unit. For reporting purposes only. Observed no smoke detector in Guestroom two or guestroom five. - From follow-up inspection 2021-10-06: No change **Time Extended**	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 63: which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. Observed no smoke detector in Guestroom two or guestroom five.	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 63: which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400500

PERRY'S OCEAN EDGE RESORT

License Type: Motel

2209 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 10/08/2021

Inspection Number: 1217601

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

07-04-4

- From initial inspection : Electrical outlet damaged to indicate a malfunction. For reporting purposes only.

South tower, near indoor pool area door hallway, closest to unit 45

- From follow-up inspection 2021-07-28: ****Time Extended**** -

From follow-up inspection 2021-10-08: ****Time Extended****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.