

Broward County

License Number: 1600660

OCEANSIDE MOTEL

License Type: Motel

315 CLEVELAND ST, HOLLYWOOD 33019

Inspection Date: 10/19/2021

Inspection Number: 1217333

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: MARTINEZ, RHEANNE

Violation Code ObservationViolation Citation

04-02-4

No smoke detector provided in guest room/unit. Observed in room #1408. Operator sent in work order for maintenance to set up smoke detector in unit. For reporting purposes only. **Corrective Action Taken**

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620324

RESIDENCE INN BY MARRIOTT FT LAUDERDALE POMPANO BEACH OCEANFRONT

License Type: Hotel

1350 N OCEAN BLVD, POMPANO BEACH 33062

Inspection Date: 10/19/2021

Inspection Number: 1159492

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BURGGRABE, BROCK

Violation Code ObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. At main panel.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1617554

ST ANDREWS AT PALM AIRE LLC

License Type: Apartment

1000 SW 46 AVE, POMPANO BEACH 33069

Inspection Date: 10/18/2021

Inspection Number: 1530610

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BURGGRABE, BROCK

Violation Code ObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. At building 1050/103-106 breezeway in meter room. Building 1060 103-106 breezeway meter room.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620856

PELICAN GRAND BEACH RESORT

License Type: Hotel

2000 N OCEAN BLVD, FORT LAUDERDALE 33305

Inspection Date: 10/15/2021

Inspection Number: 1159322

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BENJAMIN, ALEXANDER

Violation Code ObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620919

CAMBRIA HOTEL FORT LAUDERDALE BEACH

License Type: Hotel

2231 N OCEAN BLVD, FORT LAUDERDALE 33305

Inspection Date: 10/15/2021

Inspection Number: 1161192

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BENJAMIN, ALEXANDER

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1609984

COLLEGE SQUARE

License Type: Apartment

6600 SW 39 ST, DAVIE 33314

Inspection Date: 10/18/2021

Inspection Number: 1526141

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BARTON, GEOFFREY

Violation Code ObservationViolation Citation01-01-4 Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
Upstairs between units B4 & B5 bldg

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1602792

B OCEAN FORT LAUDERDALE

License Type: Hotel

1140 SEABREEZE BLVD, FORT LAUDERDALE 33316

Inspection Date: 10/18/2021

Inspection Number: 1162337

Inspection Type: Lodging-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: EVANS, EUGENE

Violation Code ObservationViolation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

088783: 088782 exp 5/20/2021

STower 074395:088710 exp 5/20/21

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1609354

B OCEAN FORT LAUDERDALE

License Type: Hotel

1136 HOLIDAY DR, FORT LAUDERDALE 33316

Inspection Date: 10/18/2021

Inspection Number: 1162336

Inspection Type: Lodging-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: EVANS, EUGENE

Violation Code ObservationViolation Citation

08-03-4 No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

134147:134148: 136206 installed 2/18/2021

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1619117

EXTENDED STAY AMERICA SUITES #1561

License Type: Hotel

1450 SE 17 ST CSWY, FORT LAUDERDALE 33316

Inspection Date: 10/21/2021

Inspection Number: 1160518

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: EVANS, EUGENE

Violation Code ObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to rm 208

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1618409

EXTENDED STAY AMERICA SUITES #328

License Type: Hotel

1200 FAU RESEARCH PARK BLVD, DEERFIELD BEACH 33441

Inspection Date: 10/19/2021

Inspection Number: 1160803

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KHATOON, BEGUM

Violation Code ObservationViolation Citation

04-02-4 smoke detector not functioning in guest room/unit. For reporting purposes only. All inspected room.

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1601523

ROYAL PALMS MOTEL

License Type: Motel

10 NE 20 AVE, DEERFIELD BEACH 33441-4591

Inspection Date: 10/20/2021

Inspection Number: 1217720

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, DENNIS

Violation Code ObservationViolation Citation

01-04-4 No portable fire extinguisher present on the premises. For reporting purposes only. Found a couple but expired

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2102700

WOODSPRING SUITES NAPLES

License Type: Hotel

3786 WHITELAKE BLVD, NAPLES 34117

Inspection Date: 10/19/2021

Inspection Number: 1161407

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: DILLON, TIMOTHY

Violation Code Observation

Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed the fire panel is showing trouble.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2305718

UNIQUE MOTEL

License Type: Motel

511-555 E OKEECHOBEE RD, HIALEAH 33010

Inspection Date: 10/19/2021

Inspection Number: 1219668

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PRIETO, EDGAR

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2304761

NEXX MOTEL

License Type: Motel

841 N KROME AVE, HOMESTEAD 33030

Inspection Date: 10/18/2021

Inspection Number: 1219214

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: LEIDECKER, EDILMA

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2320410

DELUXE INN MOTEL

License Type: Motel

28475 S DIXIE HWY, MIAMI 33033

Inspection Date: 10/18/2021

Inspection Number: 1217263

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GONZALEZ, RICARDO

Violation Code ObservationViolation Citation01-05-4 Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Breaking device missing on extinguisher by room 15. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2309092

MABEN INVESTMENTS INC

License Type: Apartment

739 NW 3 ST, MIAMI 33128

Inspection Date: 10/22/2021

Inspection Number: 1528058

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: CUDEMOS, VIRNA

Violation Code ObservationViolation Citation12-04-4 High Priority - Starway/platform collapsed. Near apartments #1
Warning

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

Dade County

License Number: 2308601		THE NEW YORKER	
License Type: Motel		6500 BISCAYNE BLVD, MIAMI 33138	
Inspection Date: 10/21/2021	Inspection Number: 1220651	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SEYBA, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. In front of room 106.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2330173		NORTH BEACH PROPERTIES II	
License Type: Apartment		6755 HARDING AVE, MIAMI BEACH 33141	
Inspection Date: 10/21/2021	Inspection Number: 1517270	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2310930		PONS FRANCISCO	
License Type: Apartment		2923 NW 22 AVE, MIAMI 33142	
Inspection Date: 10/19/2021	Inspection Number: 1516166	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CRUZ, EDGAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed by unit 5. Glass breaking device missing.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2302711		NEWPORT BEACHSIDE HOTEL & RESORT	
License Type: Motel		16701 COLLINS AVE, SUNNY ISLES BEACH 33160	
Inspection Date: 10/18/2021	Inspection Number: 1219132	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. All as of 9/24/20.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2321990

QUALITY INN MIAMI AIRPORT

License Type: Hotel

3959 NW 79 AVE, MIAMI 33166

Inspection Date: 10/22/2021

Inspection Number: 1160599

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: GONZALEZ, ERIK

Violation Code Observation

Violation Citation

08-01-4 - From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed 080920, 123866, Expiration 11/27/2020. - From follow-up inspection 2021-09-21: At time of callback inspection observe

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2600595

REGENCY INN

License Type: Motel

6237 ARLINGTON EXPY, JACKSONVILLE 32211

Inspection Date: 10/21/2021

Inspection Number: 1218355

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: THOMAS, PHILIP

Violation Code ObservationViolation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Boiler certificate expired July 2021. Operator placed call to have recertification completed.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2610113

PORTOFINO CLUB

License Type: Apartment

3333 MONUMENT RD, JACKSONVILLE 32225

Inspection Date: 10/20/2021

Inspection Number: 1531999

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: THOMAS, PHILIP

Violation Code ObservationViolation Citation

12-04-4 High Priority - Balcony/starway/platform collapsed.
Broken step on stairway between units 502 and 510. Third Step is starting to sag and collapse in the center with stress cracks visible that move when pressure is applied.
Operator had area marked with

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

Escambia County

License Number: 2705383

HAMPTON INN P'COLA AIRPORT

License Type: Hotel

2187 AIRPORT BLVD, PENSACOLA 32504

Inspection Date: 10/19/2021

Inspection Number: 1160398

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WRIGHT, JACOB

Violation Code Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Boiler Certificate reads - 099678 4/24/2021

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3901979

QUALITY INN

License Type: Hotel

2701 E FOWLER AVE, TAMPA 33612

Inspection Date: 10/22/2021

Inspection Number: 1162521

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: SANDERS, CLEVELAND

Violation Code ObservationViolation Citation

08-01-4 - From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. #124663
04/17/2021 expired. - From follow-up inspection 2021-10-22: Still observed **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3900493

THE RIVIERA AT 8412

License Type: Apartment

8412 RIO BRAVO COURT, TAMPA 33617

Inspection Date: 10/21/2021

Inspection Number: 1533226

Inspection Type: Complaint Full

Inspection Disposition: Administrative
complaint recommended

Inspector Name: REGAS, ANTHONY

Violation Code ObservationViolation Citation

01-03-4 Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
Portable fire extinguisher missing from building #1.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3906758

THE DAWSON

License Type: Apartment

15501 BRUCE B DOWNS BLVD, TAMPA 33647

Inspection Date: 10/22/2021

Inspection Number: 1514170

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: POWELL, DAVID

Violation Code ObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed the fire extinguisher on the second floor of building 22 in the recharge range.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-04-4 No portable fire extinguisher present on the premises. For reporting purposes only. On first floor of building 2

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913697 COLONIAL GRAND AT HAMPTON PRESERVE
 License Type: Apartment 6398 COLONIAL GRAND DR, TAMPA 33647

Inspection Date: 10/22/2021 Inspection Number: 1529123 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: POWELL, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed the fire extinguisher in the kitchen cabinet of 17-108 meter registers in the recharge red area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3912414 ANDOVER PLACE AT CROSS CREEK
 License Type: Apartment 10328 VENITIA REAL AVE, TAMPA 33647-4052

Inspection Date: 10/19/2021 Inspection Number: 1532712 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied
 Inspector Name: POWELL, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-01-4	- From initial inspection : Damaged electrical wire(s). For reporting purposes only. Observed the outlet loose and wires exposed by the air conditioning units between units 110 and 105 in building 10319 - From follow-up inspection 2021-10-19: Observe	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4601856 COLFOSCO LLC
 License Type: Apartment 4021 SE 12 AVE, CAPE CORAL 33904

Inspection Date: 10/22/2021 Inspection Number: 1527292 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SOMMERS, KARA

Violation Code ObservationViolation Citation

01-01-4 Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Extinguisher between Units 1 &2. 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4602603 PINE MEADOWS APARTMENTS
 License Type: Apartment 15025 PINE MEADOWS DRIVE SW, FORT MYERS 33908

Inspection Date: 10/22/2021 Inspection Number: 1515538 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SOMMERS, KARA

Violation Code ObservationViolation Citation

01-01-4 Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Extinguisher near Unit 2, Building 15055. 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4603054 SANIBEL HARBOUR RESORT & SPA
 License Type: Hotel 17260 HARBOUR POINTE DR, FT MYERS 33908

Inspection Date: 10/18/2021 Inspection Number: 1160424 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SOMMERS, KARA

Violation Code ObservationViolation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5200088

SILVER SPRINGS BUDGET MOTEL

License Type: Motel

4121 E SILVER SPGS BLVD, OCALA 344705003

Inspection Date: 10/21/2021

Inspection Number: 1221010

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: DRIGGERS, MANDY

Violation Code ObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested.
For reporting purposes only.
Light is flashing with no sign.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5201735

SOUTH PINE APARTMENTS

License Type: Apartment

3501 S PINE AVE, OCALA 34471

Inspection Date: 10/21/2021

Inspection Number: 1518660

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: FIGUEROA-ROBLES, TATIANA

Violation Code ObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access
to the fire extinguisher. For reporting purposes only.
Between unit 3-4 and 9-10, fire extinguisher locked, no breaking bar

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400141

LOOE KEY REEF RESORT & DIVE CENTER

License Type: Motel

27340 OVERSEAS HWY, RAMROD KEY 33042

Inspection Date: 10/19/2021

Inspection Number: 1220939

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: HENLEY, LATONYA

Violation Code Observation

Violation Citation

07-03-4 Scorch marks around an electrical outlet. For reporting purposes only. Observed the cord for the window ac unit wrapped with black tape on the cord nearby the plug in the wall in room 25.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-04-4 Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Observed the outlet damaged in room 25 by the bathroom.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811267 CENTRAL ON ORANGE
 License Type: Apartment 480 N ORANGE AVE, ORLANDO 32801

Inspection Date: 10/22/2021 Inspection Number: 1533110 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: JENKINS, JOSHUA Inspection

Violation Code Observation

08-04-4 Boiler certificate not posted in the boiler room. For reporting purposes only. ****Corrected On-Site****

Violation Citation

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5800094 WESTGATE LAKES RESORT AND SPA
 License Type: Vacation Rental - Condo 10000 TURKEY LAKE RD, ORLANDO 32819

Inspection Date: 10/22/2021 Inspection Number: 1089301 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied
 Inspector Name: BACHOO, SAVITRI

Violation Code Observation

08-04-4 - From initial inspection : Boiler certificate not posted in the boiler room. For reporting purposes only. - From follow-up inspection 2021-10-22: ****Time Extended****

Violation Citation

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5805056 RED ROOF PLUS
 License Type: Hotel 8342 JAMAICAN CT, ORLANDO 32819

Inspection Date: 10/19/2021 Inspection Number: 1160377 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: KOSTELNY, ROGER

Violation Code Observation

08-01-4 - From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 4/26/21 - From follow-up inspection 2021-10-19: ****Time Extended****

Violation Citation

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5809300 LQ MANAGEMENT LLC
 License Type: Hotel 8504 UNIVERSAL BLVD, ORLANDO 32819

Inspection Date: 10/21/2021 Inspection Number: 1160016 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: QUINONES, ANTONIO

Violation Code Observation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - Line fault signal

Violation Citation

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5805916 HOLIDAY INN RESORT LAKE BUENA VISTA
 License Type: Hotel 13351 SR 535, ORLANDO 32821

Inspection Date: 10/21/2021 Inspection Number: 1160487 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: NIEVES, RAFAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5806250 FOUR POINTS BY SHERATON
 License Type: Hotel 6435 WESTWOOD BLVD, ORLANDO 32821

Inspection Date: 10/18/2021 Inspection Number: 1160201 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: NIEVES, RAFAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. For FL131953, expired on 04/03/21 and for FL131952, expired on 04/03/21. - From follow-up inspection 2021-10-18: **Time Exte	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5809649 BEST WESTERN PLUS
 License Type: Hotel 6301 WESTWOOD BLVD, ORLANDO 32821

Inspection Date: 10/18/2021 Inspection Number: 1159281 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: NIEVES, RAFAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-06-4	Combustibles stored in gas water heater room. For reporting purposes only. Observed boxes of linen stored in gas water heater room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6001611 BOCA WINDS APT
 License Type: Apartment 541 NE 42 ST, BOCA RATON 33431-4556

Inspection Date: 10/21/2021 Inspection Number: 1516451 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CUDEMOS, HAIDA

Violation Code ObservationViolation Citation

01-01-4 Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed between apartment # 108 and 109. Observed between apartment # 202 and 203.
 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6002323 CORNER HOUSE
 License Type: Apartment 3763 NW 4 AVE, BOCA RATON 33431-5744

Inspection Date: 10/20/2021 Inspection Number: 1518877 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CUDEMOS, HAIDA

Violation Code ObservationViolation Citation

01-01-4 Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed in rear of building.
 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6002517 CAMINO REAL CONDOMINIUM
 License Type: Apartment 450 CAMINO REAL, BOCA RATON 33432

Inspection Date: 10/21/2021 Inspection Number: 1530820 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: STEUBER, RYAN

Violation Code ObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Between units 208 and 209
 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6009658 BOCA PALMS 2
 License Type: Apartment 20 SE 14 ST, BOCA RATON 33432

Inspection Date: 10/20/2021 Inspection Number: 1521548 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: STEUBER, RYAN

Violation Code ObservationViolation Citation

02-08-4 Propane (LP gas) tank having a water capacity greater than 2.7 lbs stored under a stairwell. For reporting purposes only. At west stairwell
 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6003623

CYNTHIA GARDENS

License Type: Apartment

1675 NW 4 AVE, BOCA RATON 33432-1538

Inspection Date: 10/22/2021

Inspection Number: 1518885

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: STEUBER, RYAN

Violation Code ObservationViolation Citation

01-03-4 Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Next to 310 in building at street next to building 1

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6000789

POINCIANA APARTMENTS

License Type: Apartment

233 ROYAL POINCIANA PLZ WAY, PALM BEACH 33480-4046

Inspection Date: 10/20/2021

Inspection Number: 1518787

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: AHLE, ROBERT

Violation Code ObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed apt 7 **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6012372

SPRINGHILL SUITES

License Type: Hotel

5130 NW 8 AVE, BOCA RATON 33487

Inspection Date: 10/22/2021

Inspection Number: 1161017

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Trouble light illuminated at main panel at front desk

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6209282 CRESCENT LANE APARTMENTS
 License Type: Apartment 2000 GANDY BLVD N, ST. PETERSBURG 33702

Inspection Date: 10/20/2021 Inspection Number: 1528893 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LOZANO, KELVIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher next unit 33 **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6205545 MARISOL VISTA APARTMENTS
 License Type: Apartment 1280 N 102 AVE, ST. PETERSBURG 33716

Inspection Date: 10/20/2021 Inspection Number: 1533192 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied
 Inspector Name: LOZANO, KELVIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher near unit 5-203 - From follow-up inspection 2021-10-20:	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-02-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher next to unit 5-203 - From follow-up inspection 2021-10-20:	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6201831 MAGNUSON HOTEL
 License Type: Motel 421 S GULFVIEW BLVD, CLEARWATER BEACH 33767

Inspection Date: 10/18/2021 Inspection Number: 1218927 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
06-01-4	- From initial inspection : Path to door marked as an exit is blocked. For reporting purposes only. City of Clearwater has closed the north stairwell for use due to spalling concrete and rebar. 9 rooms closed off by City of Clearwater. Operator has clo	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215507 BLUE MOON INN
 License Type: Motel 2920 N ALT 19 N, DUNEDIN 34698

Inspection Date: 10/20/2021 Inspection Number: 1217566 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PEARCE, LAURA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge opposite laundry room . For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6209012 MEASE MANOR
 License Type: Apartment 700 MEASE PLZ, DUNEDIN 346986680

Inspection Date: 10/20/2021 Inspection Number: 1526735 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PEARCE, LAURA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. Parts are on order . For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6801281

HYATT REGENCY SARASOTA

License Type: Hotel

1000 BLVD OF THE ARTS, SARASOTA 34236

Inspection Date: 10/21/2021

Inspection Number: 1160247

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: MCKEON, MICHAEL

Violation Code Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Expired 6/25/21

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6602479

BELLA VISTA APARTMENTS

License Type: Apartment

1900 BELLA VISTA WAY, PORT SAINT LUCIE 34952

Inspection Date: 10/18/2021

Inspection Number: 1520717

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HYNES, MONICA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Taylor County

License Number: 7200027

SKYLARK MOTEL

License Type: Motel

317 N BYRON BUTLER PKWY, PERRY 32347

Inspection Date: 10/22/2021

Inspection Number: 1218199

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SMITH, PAUL

Violation Code Observation

Violation Citation

01-03-4 Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Between unit 3 & 4.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400945

QUALITY INN OCEANFRONT

License Type: Motel

295 S. ATLANTIC AVE, ORMOND BEACH 32176

Inspection Date: 10/20/2021

Inspection Number: 1217469

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: RUTLEDGE, REBECCA

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-06-4 Combustibles stored in boiler room. For reporting purposes only.
Corrected On-Site

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401413

TROPICAL APTS & MARINA

License Type: Motel

1485 LAKEVIEW DR, DELAND 327203033

Inspection Date: 10/19/2021

Inspection Number: 1219599

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: OCASIO-LOPEZ, LISA

Violation Code ObservationViolation Citation05-02-5 Hearing-impaired smoke detector is not functioning when tested.
Repeat Violation **Warning**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.