

Alachua County

License Number: 1100353

KAMPUS INN

License Type: Motel

2820 NW 13 ST, GAINESVILLE 326092832

Inspection Date: 11/03/2021

Inspection Number: 1219321

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CASEY, KEITH

Violation Code Observation

Violation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
 Observed the fire extinguisher on the laundry is nothing fully charged.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bay County

License Number: 1305244

SPRINGHILL SUITES PANAMA CITY BEACH BEACHFRONT

License Type: Hotel

12513 FRONT BEACH RD, PANAMA CITY BEACH 32407

Inspection Date: 11/01/2021

Inspection Number: 1160382

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code Observation

Violation Citation

08-03-4 No boiler certificate or insurance inspector's boiler report available.
For reporting purposes only. 4 water heaters exceed 400,000 btu.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1504985

HAMPTON INN

License Type: Hotel

3425 N ATLANTIC AVE, COCOA BCH 32931

Inspection Date: 11/04/2021

Inspection Number: 1161222

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HICKS, GEORGE RANDY

Violation Code Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 4/17/21, operator states inspected March 2021, awaiting certificate.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621709 HIJI LLC
 License Type: Apartment 219 - 223 S 17 AVE, HOLLYWOOD 33020

Inspection Date: 11/05/2021 Inspection Number: 1533374 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CHRISTGEN, THOM Inspection

Violation Code ObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed on the first floor of the 221 building. 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620848 HILTON FT LAUDERDALE BEACH RESORT
 License Type: Hotel 505 N FT LAUDERDALE BEACH BLVD, FORT LAUDERDALE 33304

Inspection Date: 11/02/2021 Inspection Number: 1159334 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRANN, JUSTIN

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Inspector will email inspection report to Fire Marshall for review. 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Kitchen 125012 exp 9-27-2021; 125016 exp 9-27-2021 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620921 COURTYARD FORT LAUDERDALE DOWNTOWN
 License Type: Hotel 721 N FEDERAL HWY, FORT LAUDERDALE 33304

Inspection Date: 11/03/2021 Inspection Number: 1160102 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: BARTON, GEOFFREY

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Trouble light indicator on panel. 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621708

BELL SUNRISE

License Type: Apartment

1020 NE 12 AVE, FT. LAUDERDALE 33304

Inspection Date: 11/02/2021

Inspection Number: 1533352

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Bldg 1201.
Inspector will email inspection report to Fire Marshall for review.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2101627

MARCO ISLAND LAKESIDE INN

License Type: Motel

155 FIRST AVE, MARCO ISLAND 34145

Inspection Date: 10/29/2021

Inspection Number: 1218224

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRAVES, PETER

Violation Code Observation

Violation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed the fire extinguisher near the office door has no implement for breaking the glass.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2312295 CHAPLE APTS
 License Type: Apartment 1085 W 27 ST, HIALEAH 33010

Inspection Date: 11/05/2021 Inspection Number: 1517787 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: PRIETO, EDGAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2312644 GARDEN INN HOMESTEAD
 License Type: Motel 51 SOUTH HOMESTEAD BLVD, HOMESTEAD 33030

Inspection Date: 10/29/2021 Inspection Number: 1218649 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEIDECKER, EDILMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. One located next to room 234.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2320327 FAIRWAY INN
 License Type: Motel 100 U S 1, FLORIDA CITY 33034

Inspection Date: 11/01/2021 Inspection Number: 1218442 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEIDECKER, EDILMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329564 ORCHID GROVE
 License Type: Apartment 750 NW 8 ST, FLORIDA CITY 33034

Inspection Date: 11/01/2021 Inspection Number: 1518860 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEIDECKER, EDILMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble/alarm light illuminated on the fire alarm control panel located in building 2.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-06-4	Fire alarm control panel emitting an audible alarm. For reporting purposes only. At control panel located in building 2.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329417 MR C
 License Type: Hotel 2988 MCFARLANE RD, MIAMI 33133

Inspection Date: 11/02/2021 Inspection Number: 1161848 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MASKASEM, SUPPACHAI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boilers certificates 135906, 135907, 135908 expired 09/05/2021	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2305469 SHELBORNE SOUTH BEACH
 License Type: Hotel 1801 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 11/03/2021 Inspection Number: 1161458 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler jurisdiction number's 055333; 055334 all expired on 04/28/2019. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329233

WALDORF TOWERS HOTEL

License Type: Hotel

860 OCEAN DR, MIAMI BEACH 33139

Inspection Date: 11/03/2021

Inspection Number: 1160444

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WILLIAMS, ALFREDA

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329281

THE LESLIE HOTEL

License Type: Hotel

1244 OCEAN DR, MIAMI BEACH 33139

Inspection Date: 11/03/2021

Inspection Number: 1160757

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WILLIAMS, ALFREDA

Violation Code ObservationViolation Citation01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
Observed fire extinguisher locked on 3rd and 1st floor.
Also in laundry area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2307184

STARLITE APARTMENTS

License Type: Hotel

750 OCEAN DR, MIAMI BEACH 33139-6294

Inspection Date: 11/02/2021

Inspection Number: 1159670

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WILLIAMS, ALFREDA

Violation Code ObservationViolation Citation01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Located near room 111.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2305010

BALTIC HOTEL

License Type: Hotel

7643 HARDING AVE, MIAMI BEACH 33141

Inspection Date: 10/29/2021

Inspection Number: 1163162

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PRIETO, VICENTE

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light on.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2307484

DICKENS COURT APTS 700-710

License Type: Apartment

700 77 ST, MIAMI BEACH 331412229

Inspection Date: 10/29/2021

Inspection Number: 1529777

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PRIETO, VICENTE

Violation Code ObservationViolation Citation01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking devices in fire extinguisher boxes by units 4 and 5.
****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2306628

7600 DICKERS APT

License Type: Apartment

7600 DICKENS AVE, MIAMI BEACH 331412239

Inspection Date: 10/29/2021

Inspection Number: 1522739

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PRIETO, VICENTE

Violation Code ObservationViolation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device in fire extinguisher box by unit 6.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329270

GRAND BEACH HOTEL SURFSIDE

License Type: Hotel

9449 COLLINS AVE, SURFSIDE 33154

Inspection Date: 11/02/2021

Inspection Number: 1162306

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PRIETO, VICENTE

Violation Code ObservationViolation Citation04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-04-4 Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2327022

HOLIDAY INN MIAMI/DORAL AREA

License Type: Hotel

3255 NW 87 AVE, MIAMI 33172

Inspection Date: 11/05/2021

Inspection Number: 1160070

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back - Complied

Inspector Name: ALVAREZ, MARGARET

Violation Code ObservationViolation Citation08-04-4 - From initial inspection : Boiler certificate not posted in the boiler room. For reporting purposes only. - From follow-up inspection 2021-11-05: ****Time Extended****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2327881

STAYBRIDGE SUITES MIAMI/DORAL

License Type: Hotel

3265 NW 87 AVE, MIAMI 33172

Inspection Date: 11/05/2021

Inspection Number: 1161172

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back - Complied

Inspector Name: ALVAREZ, MARGARET

Violation Code ObservationViolation Citation08-04-4 - From initial inspection : Boiler certificate not posted in the boiler room. For reporting purposes only. - From follow-up inspection 2021-11-05: ****Time Extended****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330251

CASA VERA

License Type: Apartment

8881 SW 172 AVE, MIAMI 33196

Inspection Date: 11/02/2021

Inspection Number: 1531521

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ELDER, AUDREY

Violation Code Observation

Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Located at building 3900.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dixie County

License Number: 2500003

SUWANNEE GABLES MOTEL AND MARINA

License Type: Motel

27659 SE HWY 19 ALT 27, OLD TOWN 32680

Inspection Date: 11/01/2021

Inspection Number: 1217318

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: TORRES, WILLIAM

Violation Code Observation

Violation Citation

01-01-4 - From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
Observed overcharge fire extinguisher by room 108 - From follow-up inspection 2021-11-01: No change **Time E

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-04-4 - From initial inspection : Electrical outlet damaged to indicate a malfunction. For reporting purposes only.
Observed missing outlet cover behind nightstand in room 105 -
From follow-up inspection 2021-11-01: No change **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613252 HYATT PLACE JACKSONVILLE AIRPORT
 License Type: Hotel 14565 DUVAL RD, JACKSONVILLE 32218

Inspection Date: 11/02/2021 Inspection Number: 1160593 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-06-4	Combustibles stored in hot water heater room. For reporting purposes only. Gas powered pressure washer inside hot water heater room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2609446 WEST CREEK II APARTMENTS
 License Type: Apartment 5601 CALIFORNIA AVE-OFFIC, JACKSONVILLE 32244

Inspection Date: 11/01/2021 Inspection Number: 1526206 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BELLEMARE, RYAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-04-4	For reporting purposes only. Extension cords running from building 1 to building 2. Cords are running through trees and tied to the roof ends of the buildings. Powering security cameras. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613195 SEA WALK HOTEL
 License Type: Motel 117 1 AVE N, JACKSONVILLE BEACH 32250

Inspection Date: 11/01/2021 Inspection Number: 1218896 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: GONZALEZ, MAYRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-04-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs stored inside the building. For reporting purposes only. 15 lbs propane tank stored inside building near employee restrooms by lobby area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
02-04-4	- From initial inspection : Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. 15 lbs propane tank stored inside building near employee restrooms by lobby area. - From follow-u	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2705841

VISTA 17 AT CERVANTES APARTMENTS

License Type: Apartment

1717 W CERVANTES STREET, PENSACOLA 32501

Inspection Date: 10/29/2021

Inspection Number: 1517798

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ALBRITTON, GREGORY

Violation Code Observation

Violation Citation

01-03-4 Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. At front entrance.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Flagler County

License Number: 2800514

GOLDEN MAGNOLIA RESORT

License Type: Bed and Breakfast

1104 S OCEAN SHORE BLVD, FLAGLER BEACH 32136

Inspection Date: 11/01/2021

Inspection Number: 1094384

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BADDING, MELANIE

Violation Code Observation

Violation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher by the reach in freezer undercharged.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Fire extinguisher by the spa is in break glass casing, no hammer available.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3902027 SHERATON TAMPA RIVERWALK
 License Type: Hotel 200 N ASHLEY DR, TAMPA 33602

Inspection Date: 11/02/2021 Inspection Number: 1159930 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: EHLERS, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside 630.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913671 ALOFT/ELEMENT
 License Type: Hotel 3650 MIDTOWN DR, TAMPA 33607

Inspection Date: 11/02/2021 Inspection Number: 1161426 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: CANNELLA, MARK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Unable to determine if boilers . **Repeat Violation** - From follow-up inspection 2021-11-02: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Indian River County

License Number: 4100043

SUNQUEST APARTMENTS

License Type: Apartment

1725 6 AVE STE 1, VERO BEACH 32960

Inspection Date: 11/03/2021

Inspection Number: 1517946

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAVIS, DIANNA

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location.
Hook in laundry room missing extinguisher.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4603748

LOST TREE VILLAGE

License Type: Apartment

15105-15156 PINE MEADOWS DR, FORT MYERS 33908

Inspection Date: 10/29/2021

Inspection Number: 1530721

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: SOMMERS, KARA

Violation Code

Observation

Violation Citation

12-04-4

High Priority - Fence/platform railing broken in front of Unit 3, Building 15146. ****Warning****

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

Leon County

License Number: 4700267

BUDGET INN

License Type: Motel

1402 W TENNESSEE ST, TALLAHASSEE 323043403

Inspection Date: 11/01/2021

Inspection Number: 1221125

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: TRUESDALE, CHRIS

Violation Code ObservationViolation Citation

04-03-4 Smoke detector/alarm in guest room/unit 103 damaged as to appear to be inoperable. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4702890

CHERRY LAUREL

License Type: Apartment

1009 CONCORD RD, TALLAHASSEE 32308

Inspection Date: 11/01/2021

Inspection Number: 1519049

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHARLES, BRENDA

Violation Code ObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge next to unit 333. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5300019

JUPITER ISL CLB HOTEL

License Type: Hotel

JUPITER ISLAND, HOBE SOUND 33455

Inspection Date: 10/29/2021

Inspection Number: 1161289

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code Observation

Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.main lobby

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400696

HAWKS CAY RESORT

License Type: Hotel

61 HAWKS CAY BLVD, DUCK KEY 33050

Inspection Date: 10/29/2021

Inspection Number: 1160874

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: WHITEHURST, SCOTT

Violation Code Observation

Violation Citation

04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2021-10-29: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5603590

WINGATE INN

License Type: Hotel

117 PALM ST, DESTIN 32541

Inspection Date: 11/05/2021

Inspection Number: 1161478

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WILSON, MISTY

Violation Code ObservationViolation Citation

07-04-4 Electrical outlet damaged to indicate a malfunction. For reporting purposes only.
319 - Outlet has signs of burnage.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5603287

COUNTRY LANE APARTMENTS

License Type: Apartment

1185 FOREST HEIGHTS DR, FORT WALTON BEACH 32547

Inspection Date: 10/29/2021

Inspection Number: 1517720

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BURROUGHS, RICHARD

Violation Code ObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
- building 1: downstairs.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5603352

UNION VILLAGE APARTMENTS

License Type: Apartment

515 UNION ST (515-517), FT WALTON BCH 32547

Inspection Date: 10/29/2021

Inspection Number: 1518349

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BURROUGHS, RICHARD

Violation Code ObservationViolation Citation

02-08-4 Propane (LP gas) tank having a water capacity greater than 2.7 lbs stored under a stairwell. For reporting purposes only.
- building 1: outside apartment A underneath stairs leading up to apartment C.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5809303		LA QUINTA INN AND SUITES	
License Type: Hotel		5621 MAJOR BLVD, ORLANDO 32819	
Inspection Date: 11/03/2021	Inspection Number: 1160095	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: KOSTELNY, ROGER			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. On 2nd floor by the elevator across from room 206.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5809563		THE FLORIDIAN HOTEL AND SUITES	
License Type: Hotel		7531 CANADA AVE, ORLANDO 32819	
Inspection Date: 11/02/2021	Inspection Number: 1160915	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KOSTELNY, ROGER			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. When entering the lobby. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5800155		BLUEGREEN VACATIONS UNLIMITED INC	
License Type: Vacation Rental - Condo		12400 INTERNATIONAL DRIVE, ORLANDO 32821	
Inspection Date: 11/05/2021	Inspection Number: 1089327	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: NIEVES, RAFAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. For boilers over 400, 000 BTU located in building 9. Boilers are 499, 000 BTU.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5810901		WINGATE INN @ ORLANDO INT'L AIRPORT	
License Type: Hotel		5750 HAZELTINE NATIONAL DR, ORLANDO 32822	
Inspection Date: 11/02/2021	Inspection Number: 1159665	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: LORENZO, ANA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only./ Trouble at main fire panel	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Orange County

License Number: 5808789

INDIGO WEST APARTMENTS

License Type: Apartment

6101 RALEIGH ST, ORLANDO 32835

Inspection Date: 10/29/2021

Inspection Number: 1522420

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: LUI, SUK HAN

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only./no portable fire extinguisher in apartment 508.
Corrected On-Site

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6000898

QUEENS LODGE

License Type: Motel

3712 BROADWAY, WEST PALM BEACH 33407-4399

Inspection Date: 11/01/2021

Inspection Number: 1218830

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MCCARTHY, RAMONA

Violation Code Observation

Violation Citation

05-02-5 Hearing-impaired smoke detector is not functioning when tested.
For reporting purposes only.
Strobe not flashing.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6013457

HAMPTON INN WEST PALM BEACH FLORIDA TURNPIKE

License Type: Hotel

2025 VISTA PKWY, WEST PALM BEACH 33411

Inspection Date: 11/05/2021

Inspection Number: 1160934

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SEVILLA, FREDDY

Violation Code Observation

Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6213911

GULF BREEZE INN

License Type: Apartment

2008 GULF BLVD, INDIAN ROCKS BEACH 33785

Inspection Date: 10/29/2021

Inspection Number: 1526301

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation Code Observation

Violation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Located in back of unit next to washer and dryer.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6301081 RELAX INN
 License Type: Motel 1433 LAKELAND HILLS BLVD, LAKELAND 33805

Inspection Date: 11/01/2021 Inspection Number: 1217329 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ROBERSON, JAMAL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-05-4	No smoke detector provided in guest room/unit. For reporting purposes only. Observed in unit 135 , 122.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6304242 SURESTAY HOTEL BY BEST WESTERN CLERMONT THEME PARK WEST
 License Type: Motel 9240 US HWY 192, CLERMONT 34714

Inspection Date: 11/04/2021 Inspection Number: 1218950 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: JACKSON, SHARON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-07-4	Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6804704 HOLIDAY INN EXPRESS & SUITES SARASOTA EAST/I-75
 License Type: Hotel 5730 GANTT RD, SARASOTA 34233

Inspection Date: 10/29/2021 Inspection Number: 1161371 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: CATTLEY, RAYMOND

Violation Code ObservationViolation Citation

07-04-4 Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Observed outlet cover missing outside west side of building near entrance door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6800192 BAYMONT INN AND SUITES
 License Type: Motel 1425 S TAMIAMI TRAIL, SARASOTA 34239

Inspection Date: 11/02/2021 Inspection Number: 1219016 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: CATTLEY, RAYMOND

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed Fire System Silent Knight with 2 warnings, system trouble and system silence.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6800033 HORIZONS WEST
 License Type: Vacation Rental - Condo 6140 MIDNIGHT PASS RD, SARASOTA 342422210

Inspection Date: 11/04/2021 Inspection Number: 1089325 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: CATTLEY, RAYMOND

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed Silent Knight Honeywell trouble cnt #1.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6903930

CHARLESTON CLUB APTS

License Type: Apartment

500 FOX QUARRY LN, SANFORD 32773

Inspection Date: 10/29/2021

Inspection Number: 1520186

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation Code Observation

Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.trouble bld 1101

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Taylor County

License Number: 7200002

REGENCY INN

License Type: Motel

2277 S BYRON BUTLER PKWY, PERRY 32348

Inspection Date: 10/29/2021

Inspection Number: 1219637

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SMITH, PAUL

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406519

HAWAIIAN INN BEACH RESORT

License Type: Hotel

2301 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 11/05/2021

Inspection Number: 1160665

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code ObservationViolation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400969

TRIANGLE MOTEL

License Type: Motel

5080 S RIDGEWOOD AVE, PORT ORANGE 32127

Inspection Date: 10/29/2021

Inspection Number: 1221101

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code ObservationViolation Citation

07-01-4	Damaged electrical wire(s). For reporting purposes only. -bellsouth phone box on backside of property facing residential street	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	---