

**Alachua County**

License Number: 1102961

DRURY INN & SUITES- GAINESVILLE

License Type: Hotel

4000 SW 40 BLVD, GAINESVILLE 32608

Inspection Date: 11/19/2021

Inspection Number: 1160830

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TORRES, WILLIAM

Violation Code    Observation

Violation Citation

08-03-4    No boiler certificate or insurance inspector's boiler report available.  
 For reporting purposes only.  
 Observed no boiler certificate posted in boiler room and no current  
 boiler certificate available during inspection

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is  
 required annually for power boilers and high  
 pressure/high temperature boilers and biannually for low  
 pressure steam or vapor heating boilers. 509.032(2)(d)  
 The division, or its agent, shall notify the local firesafety  
 authority or the State Fire Marshal of any readily  
 observable violation of a rule adopted under chapter 633  
 which relates to public lodging establishments or public  
 food establishments, and the identification of such  
 violation does not require any firesafety inspection  
 certification. For reporting purposes only.

**Bay County**

License Number: 1303765

HOLIDAY INN RESORT

License Type: Motel

11127 W FRONT BCH RD, PANAMA CITY BCH 324073529

Inspection Date: 11/19/2021

Inspection Number: 1218438

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILSON, MISTY

Violation Code    Observation

Violation Citation

08-04-4    Boiler certificate not posted in the boiler room. For reporting purposes only. Front desk brought them over. **\*\*Corrected On-Site\*\***

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Brevard County**

License Number: 1505699

EXTENDED STAY AMERICA #9511

License Type: Hotel

4450 HOLLYWOOD BLVD, MELBOURNE 32904

Inspection Date: 11/19/2021

Inspection Number: 1161191

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: VAUGHAN, COURTNEY

Violation Code   ObservationViolation Citation08-04-4      Boiler certificate not posted in the boiler room. For reporting  
purposes only.61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1505848

THE CARLTON OF WEST MELBOURNE

License Type: Apartment

4152 MERRILLVILLE DR, WEST MELBOURNE 32904

Inspection Date: 11/15/2021

Inspection Number: 1522512

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: DAVIS, DIANNA

Violation Code   ObservationViolation Citation02-08-4      Propane (LP gas) assumed in building with grill on balcony.  
Building 5 Unable to see if the tank was on or off the unit.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1602151

ROYAL INN MOTEL

License Type: Motel

1610 N FEDERAL HWY, HOLLYWOOD 33020-2824

Inspection Date: 11/19/2021

Inspection Number: 1219423

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHRISTGEN, THOM

Violation Code    ObservationViolation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed on the North side of the building.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	---

License Number: 1600152

HILLSBORO CLUB

License Type: Hotel

901 HILLSBORO MILE (A1A), HILLSBORO BEACH 33062

Inspection Date: 11/15/2021

Inspection Number: 1159862

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BURGGRAVE, BROCK

Violation Code    ObservationViolation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. At main panel near dining room.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	---

License Number: 1602179

FORT LAUDERDALE MARRIOTT POMPANO BEACH

License Type: Hotel

1200-1208 N OCEAN BLVD, POMPANO BEACH 33062

Inspection Date: 11/19/2021

Inspection Number: 1159987

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BURGGRAVE, BROCK

Violation Code    ObservationViolation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 124039 and 124040 both expire on 12/19/2021.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1602342	TRANQUILO HOTEL		
License Type: Apartment	2831 VISTA MAR ST, FORT LAUDERDALE	33304	
Inspection Date: 11/16/2021	Inspection Number: 1530659	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANN, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
07-04-4	Electrical outlet damaged to indicate a malfunction. For reporting purposes only. On staircase next to 6108 and in front of 6107. Repair service showed up during inspection. **Corrective Action Taken**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 1620869	TRANQUILO HOTEL		
License Type: Motel	725 N BIRCH RD, FORT LAUDERDALE	33304	
Inspection Date: 11/16/2021	Inspection Number: 1218564	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANN, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
07-04-4	Electrical outlet (light fixture outlet) with exposed wiring to indicate a malfunction. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 1620856	PELICAN GRAND BEACH RESORT		
License Type: Hotel	2000 N OCEAN BLVD, FORT LAUDERDALE	33305	
Inspection Date: 11/15/2021	Inspection Number: 1159322	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: BENJAMIN, ALEXANDER			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
05-02-5	- From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. - From follow-up inspection 2021-11-15: Observed same **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Charlotte County**

License Number: 1801531

EXTENDED STAY AMERICA SUITES 9504

License Type: Hotel

24100 BEATRIX BLVD, PORT CHARLOTTE 33954

Inspection Date: 11/16/2021

Inspection Number: 1161452

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: KEATING, PATRICK

Violation Code    Observation

Violation Citation

08-03-4    No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed no boiler certificate \*\*Repeat Violation\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2308499		RODRIGUEZ APTS	
License Type: Apartment		74 W 12 ST, HIALEAH 330103992	
Inspection Date: 11/18/2021	Inspection Number: 1513240	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, EDGAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Between units #2 and #3.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329040		BENTLEY BEACH HOTEL	
License Type: Hotel		101 OCEAN DRIVE, MIAMI BEACH 33139	
Inspection Date: 11/16/2021	Inspection Number: 1160410	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. <b>**Repeat Violation**</b>	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329392		FAIRWIND HOTEL	
License Type: Hotel		1000-1030 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 11/17/2021	Inspection Number: 1159703	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. <b>**Repeat Violation**</b>	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2310328		TRIO APARTMENTS	
License Type: Apartment		626 EUCLID AVE, MIAMI BEACH 331398632	
Inspection Date: 11/16/2021	Inspection Number: 1513261	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. All 3 buildings.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Dade County**

License Number: 2327192 RED SOUTH BEACH  
 License Type: Hotel 3010 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 11/15/2021 Inspection Number: 1162812 Inspection Type: Complaint Full Inspection Disposition: Call Back - Extension given, pending  
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2021-11-15: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329277 HILTON CABANA MIAMI BEACH  
 License Type: Hotel 6261 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 11/15/2021 Inspection Number: 1161042 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Extension given, pending  
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificate FL 130895, 132921 and 132922, all expired on 4/24/2021. - From follow-up inspection 2021-11-15:	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330692 DORIAN GARDENS  
 License Type: Apartment 13201 MEMORIAL HWY, NORTH MIAMI 33161

Inspection Date: 11/18/2021 Inspection Number: 1533479 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SUAREZ, LEOPOLDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2323902 CORTLAND AT THE HAMMOCKS  
 License Type: Apartment 15280 SW 104 ST, MIAMI 33196

Inspection Date: 11/15/2021 Inspection Number: 1528917 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied  
 Inspector Name: ELDER, AUDREY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device near unit 7110. - From follow-up inspection 2021-11-15: Portable fire ex	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Duval County**

License Number: 2602255 THE VILLAS  
 License Type: Apartment 1251 KINGS RD, JACKSONVILLE 32204

Inspection Date: 11/15/2021 Inspection Number: 1533454 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: ESPINOSA-BECKERT, ILIANA Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By apt 27	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Brake bar is gone by apt 3 and 27	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2611854 OAK HAMMOCK APARTMENTS  
 License Type: Apartment 500 ACME ST, JACKSONVILLE 32211

Inspection Date: 11/16/2021 Inspection Number: 1533425 Inspection Type: Lodging-Licensing Inspection Disposition: Warning Issued  
 Inspector Name: THOMAS, PHILIP Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
12-04-4	High Priority - Balcony/starway/platform collapsed. Building 6 has collapsed landing between first and second floor. Entire landing has fallen 6 feet and is resting on ground. Stairs leading down from second floor end with 6 foot drop. Landing between 2	61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.
12-04-4	- From initial inspection : High Priority - Balcony/starway/platform collapsed. Building 6 has collapsed landing between first and second floor. Entire landing has fallen 6 feet and is resting on ground. Stairs leading down from second floor end with 6	61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

License Number: 2612227 LA QUINTA INN #969  
 License Type: Hotel 4686 LENOIR AVE S, JACKSONVILLE 32216

Inspection Date: 11/18/2021 Inspection Number: 1160984 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: VILBRUN, JOSUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. One of boiler certificate shows expired on boiler site but operator has inspection card showing completed. Jurisdiction #133177 expiration	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2613278 HOME2 SUITES BY HILTON JACKSONVILLE AIRPORT  
 License Type: Hotel 13475 RANCH RD, JACKSONVILLE 32218

Inspection Date: 11/18/2021 Inspection Number: 1159774 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Panel near front entrance shows "general trouble".	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2609386 SHAKIR ECONOMY MOTEL  
 License Type: Motel 7992 NEW KINGS RD, JACKSONVILLE 322193631

Inspection Date: 11/16/2021 Inspection Number: 1219551 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BELLEMARE, RYAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. Smoke detector missing from unit 4, person in charge stated they are going replace it.	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Escambia County**

License Number: 2705472

HOME STAY LODGE

License Type: Motel

9357 N DAVIS HWY, PENSACOLA 32514

Inspection Date: 11/16/2021

Inspection Number: 1221356

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: ADAMSON, ROBERT

Violation Code

Observation

Violation Citation

12-04-4

High Priority - Balcony/starway/platform.  
Upon inspection observed 2 columns on first level facing middle parking lot on right side in disrepair.

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

**Flagler County**

License Number: 2800564

SI COMO NO INN

License Type: Motel

2480 N OCEANSHORE BLVD, FLAGLER BEACH 32136

Inspection Date: 11/15/2021

Inspection Number: 1217636

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: BADDING, MELANIE

Violation Code    ObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested.  
For reporting purposes only.  
At the time of inspection, hearing impaired smoke alarm is only  
making audible warning when tested, no flashing light.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2800024

BEACH FRONT MOTEL

License Type: Motel

1544 S HWY A1A, FLAGLER BCH 321363805

Inspection Date: 11/15/2021

Inspection Number: 1218287

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: BADDING, MELANIE

Violation Code    ObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested.  
For reporting purposes only.  
At the time of inspection, hearing impaired smoke alarm is not  
flashing, only audible warning.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3906179

RODEWAY INN

License Type: Motel

2307 E BUSCH BLVD, TAMPA 33612

Inspection Date: 11/18/2021

Inspection Number: 1221434

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: CESAR, RACHEL

Violation Code    ObservationViolation Citation

01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Several fire extinguishers missing from designated locations.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-03-4	Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. ADA room hearing impaired smoke detector not working.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
05-02-5	Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Hearing impaired smoke detector in ADA room #150 not working .	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-04-4	Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Electrical plates missing , exposed wiring. Room 212, 150, 118, 204	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3912086

CFOC TAMPA FL LLC

License Type: Hotel

6800 WOODSTORK RD, TAMPA 33637

Inspection Date: 11/19/2021

Inspection Number: 1160616

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back - Complied

Inspector Name: REGAS, ANTHONY

Violation Code    ObservationViolation Citation

08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2021-11-19: Boiler certificate is expired. **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	---

**Hillsborough County**

License Number: 3911835

PORTOFINO APARTMENTS

License Type: Apartment

8702 NEW TAMPA BLVD, TAMPA 33647

Inspection Date: 11/16/2021

Inspection Number: 1529995

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: POWELL, DAVID

Violation Code

Observation

Violation Citation

01-02-4 - From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed 2 fire extinguisher that appear to be in the recharge zone. Verify that all fire extinguishers

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-06-4 - From initial inspection : Fire alarm control panel emitting an audible alarm. For reporting purposes only. Observed an audible alarm from the fire control box @6-8636 - From follow-up inspection 2021-11-16: Observed an audible alarm from the fire c

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Indian River County**

License Number: 4100003

OYSTER BAY

License Type: Vacation Rental - Condo

1614 N CENTRAL, SEBASTIAN 329583808

Inspection Date: 11/18/2021

Inspection Number: 1089373

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHUCK, GREGORY

Violation Code    Observation

Violation Citation

01-02-4    Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Pool deck next to restrooms

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Lee County**

License Number: 4605213 TH PALMS OF MONTERREY  
 License Type: Apartment 15250 SONOMA DR, FORT MYERS 33908

Inspection Date: 11/16/2021 Inspection Number: 1521296 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SOMMERS, KARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. Extinguisher next to Unit 302, Building 7. For reporting purposes only. <b>**Repeat Violation**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4604781 DIAMONDHEAD BEACH RESORT LLC  
 License Type: Hotel 2000 ESTERO BLVD, FT MYERS BCH 33931

Inspection Date: 11/18/2021 Inspection Number: 1160141 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GONDERMANN, FRANK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificate on site expired on 04/27/2019	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Manatee County**

License Number: 5102177

COURTYARD BY MARRIOTT BRADENTON

License Type: Motel

100 RIVERFRONT DR, BRADENTON 34205

Inspection Date: 11/17/2021

Inspection Number: 1218637

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BECHTOLD, NEIL

Violation Code    ObservationViolation Citation

04-01-4      Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
Observed 001 trouble smoke room 302. Operator stated that the occupants had vaped in the room.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5100673

SILVER SURF MOTEL

License Type: Motel

1301 N GULF DR, BRADENTON BCH 342172519

Inspection Date: 11/17/2021

Inspection Number: 1217593

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HELGESON, ERIC

Violation Code    ObservationViolation Citation

02-08-4      Propane (LP gas) tank having a water capacity greater than 2.7 lbs stored under a stairwell. For reporting purposes only.  
Observed several 20lb propane cylinders under stairwell below unit #300.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Marion County**

License Number: 5201373

COURTYARD OCALA

License Type: Hotel

3712 SW 38 AVE, OCALA 34474

Inspection Date: 11/16/2021

Inspection Number: 1163397

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARNER, DHANIQUA

Violation Code    Observation

Violation Citation

08-01-4    Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed Boiler certificates with expiration date 10/31/21 both in office and Boiler Room. Operator has log for checks done twice per day, check for 11/16 don

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Martin County**

License Number: 5301475 RIO PORCHES  
 License Type: Apartment 1440 NE DIXIE HWY, JENSEN BEACH 34957

Inspection Date: 11/18/2021 Inspection Number: 1533500 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PETROW, MICHAEL Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-04-4	No portable fire extinguisher observed on the premises. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5301461 THE HAMMOCK AT STUART VILLA RENTALS  
 License Type: Apartment 701 SE MARTIN LUTHER KING JR BLVD, STUART 34994

Inspection Date: 11/18/2021 Inspection Number: 1519171 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PETROW, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-04-4	No portable fire extinguisher observed on the premises. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Monroe County**

License Number: 5400289

RIPTIDE RV PARK & MOTEL

License Type: Motel

97680 OVERSEAS HWY, KEY LARGO 33037

Inspection Date: 11/17/2021

Inspection Number: 1218222

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: GONZALEZ, RICARDO

Violation Code    Observation

Violation Citation

05-02-5    Hearing-impaired smoke detector is not functioning when tested.  
For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5810324

EXTENDED STAY AMERICA #9841

License Type: Hotel

8750 UNIVERSAL BLVD, ORLANDO 32819

Inspection Date: 11/16/2021

Inspection Number: 1160811

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BACHOO, SAVITRI

Violation Code    Observation

Violation Citation

05-02-5    Hearing-impaired smoke detector is not functioning when tested.  
For reporting purposes only.Room233.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

License Number: 5900225

SERALAGO HOTEL AND SUITES MAINGATE EAST

License Type: Hotel

5678 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 11/18/2021

Inspection Number: 1163302

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FERTIL, SYLVERST

Violation Code    Observation

Violation Citation

04-03-4      Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Observed in room 407. Maintenance was called to correct the issue.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4      Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Operator is working on scheduling the inspections as soon as possible. \*\*Repeat Violation\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900055

WESTGATE VACATION VILLAS

License Type: Vacation Rental - Condo

7700 WESTGATE BLVD, KISSIMMEE 34747

Inspection Date: 11/15/2021

Inspection Number: 1089328

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation Code    Observation

Violation Citation

04-01-4      Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only in housekeeping / operations building.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6014058

WYNDHAM GRAND JUPITER AT HARBOURSIDE PLACE

License Type: Hotel

122 SOUNDINGS AVE, JUPITER 33477

Inspection Date: 11/15/2021

Inspection Number: 1161592

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code    Observation

Violation Citation

04-01-4    Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Lobby area.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6202002 AVONDALE PROPERTY HOLDINGS LLC  
 License Type: Apartment 5473 27 ST S #A, ST. PETERSBURG 33712

Inspection Date: 11/16/2021 Inspection Number: 1515142 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Admin. complaint recommended  
 Inspector Name: HOBBS, ANDREW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Extinguisher not in box in laundry room of building 24. It is behind dryers and needs	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Extinguisher not in box in laundry room of building 24. It is behind dryers and needs to be recharged Building 3	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Building 24 - From follow-up inspection 2021-11-16: Building 24 is normal. Building 4 is sounding with trouble lights **Time Ext	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Building 24	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6207769 THE BEACHVIEW HOTEL  
 License Type: Motel 325 S GULFVIEW BLVD, CLEARWATER BEACH 33767

Inspection Date: 11/19/2021 Inspection Number: 1221467 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: KOUSTIS, TIMOTHY Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Next to 216.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Santa Rosa County**

License Number: 6700053

QUALITY INN & SUITES

License Type: Motel

51 GULF BREEZE PKWY, GULF BREEZE 32561-4461

Inspection Date: 11/16/2021

Inspection Number: 1218196

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: ALBRITTON, GREGORY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
Fire extinguisher next to room 148 and 151.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Sarasota County**

License Number: 6804785

LONGITUDE 82 SARASOTA

License Type: Apartment

5900 WILKINSON RD, SARASOTA 34233

Inspection Date: 11/19/2021

Inspection Number: 1517205

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: CATTLEY, RAYMOND

Violation Code    Observation

Violation Citation

04-01-4    Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Honeywell System trouble light and silenced.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**St. Lucie County**

License Number: 6600789

ROYAL INN BEACH HOTEL

License Type: Motel

222 HERNANDO ST, FORT PIERCE 34949-3239

Inspection Date: 11/19/2021

Inspection Number: 1217971

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HYNES, MONICA

Violation Code    ObservationViolation Citation

04-03-4      Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only.  
Room 204 does not show power light.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6602567

ATLANTIC AT TRADITION

License Type: Apartment

10297 SW VILLAGE PKWY, PORT ST LUCIE 34987

Inspection Date: 11/17/2021

Inspection Number: 1514378

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HYNES, MONICA

Violation Code    ObservationViolation Citation

04-01-4      Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Trouble light in building 3

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7401479 EL CARIBE RESORT & CONFERENCE CENTER  
 License Type: Motel 2125 S ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 11/19/2021 Inspection Number: 1219609 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: WOOD, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  -chief engineer states part is on backorder	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400945 QUALITY INN OCEANFRONT  
 License Type: Motel 295 S. ATLANTIC AVE, ORMOND BEACH 32176

Inspection Date: 11/19/2021 Inspection Number: 1217469 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Extension given, pending  
 Inspector Name: RUTLEDGE, REBECCA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2021-11-19:	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.