

Alachua County

License Number: 1102123

BAYMONT INN & SUITES

License Type: Motel

6901 NW 4 BLVD, GAINESVILLE 32607

Inspection Date: 11/22/2021

Inspection Number: 1218386

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: CASEY, KEITH

Violation Code Observation

Violation Citation

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Observed the fire extinguisher at the North stairwell is indicated in the recharge zone. - From follow-up inspection 2021-11-22: No change **Time Extended**

01-02-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bay County

License Number: 1304199 BY THE BAY BUNGALOWS
 License Type: Apartment 3803 W 17 ST, PANAMA CITY 324011274

Inspection Date: 11/24/2021 Inspection Number: 1513198 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LYNN, NICKOLAS

Violation Code Observation

Violation Citation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. On front of unit 3.

01-02-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1300481 VIEUX CARRE APARTMENTS
 License Type: Apartment 2405 STANFORD RD, PANAMA CITY 32405

Inspection Date: 11/24/2021 Inspection Number: 1529412 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LYNN, NICKOLAS

Violation Code Observation

Violation Citation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside D218

01-02-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1300977 TURTLE LAKE APARTMENTS
 License Type: Apartment 4324 W 20TH STREET, PANAMA CITY 32405

Inspection Date: 11/24/2021 Inspection Number: 1521723 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LYNN, NICKOLAS

Violation Code Observation

Violation Citation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside N150. front of building F.
 Repeat Violation

01-02-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bay County

License Number: 1305101

RADISSON PANAMA CITY BEACH

License Type: Motel

15325 FRONT BEACH RD, PANAMA CITY BCH 32413

Inspection Date: 11/24/2021

Inspection Number: 1218471

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILSON, MISTY

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1618968 SPRINGHILL SUITES
 License Type: Hotel 151 SW 18 CT, DANIA 33004

Inspection Date: 11/24/2021 Inspection Number: 1161527 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LONDONO, GLORIA

Violation Code Observation

Violation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620697 HILTON GARDEN INN FT LAUDERDALE
 License Type: Hotel 180 SW 18 AVE, DANIA 33004

Inspection Date: 11/24/2021 Inspection Number: 1161521 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LONDONO, GLORIA

Violation Code Observation

Violation Citation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 10/02/21

08-01-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1603811 LOMAR PROPERTY GROUP LLC
 License Type: Apartment 3604 TAYLOR ST, HOLLYWOOD 33021

Inspection Date: 11/24/2021 Inspection Number: 1533548 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CHRISTGEN, THOM

Violation Code Observation

Violation Citation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed on the extinguisher to the left of the main door to unit 1.

01-02-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1604530 LOMAR APARTMENTS
 License Type: Apartment 314 S LUNA CT, HOLLYWOOD 33021

Inspection Date: 11/23/2021 Inspection Number: 1533523 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CHRISTGEN, THOM Inspection

Violation Code Observation Violation Citation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed on the extinguisher across the hallway from unit 9.

01-02-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1607670 CRYSTAL APARTMENTS
 License Type: Apartment 107 NE 8 ST, POMPANO BEACH 33060

Inspection Date: 11/24/2021 Inspection Number: 1527909 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CUDEMOS, HAIDA

Violation Code Observation Violation Citation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed next to apartment 2 on first floor.

01-02-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620857 THE ATLANTIC HOTEL & SPA
 License Type: Hotel 601 N FORT LAUDERDALE BEACH BLVD, FORT LAUDERDALE 33304

Inspection Date: 11/23/2021 Inspection Number: 1163485 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRANN, JUSTIN

Violation Code Observation Violation Citation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

08-01-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2102425

VILLAS OF CAPRI APARTMENTS

License Type: Apartment

7725 TARA CIR, NAPLES 34104-6482

Inspection Date: 11/24/2021

Inspection Number: 1528350

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DILLON, TIMOTHY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed the fire panel is showing a trouble alarm.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2312003 SPECTRUM NETWORK
 License Type: Apartment 31 NW 5 ST, HOMESTEAD 33030

Inspection Date: 11/22/2021 Inspection Number: 1513687 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: LEIDECKER, EDILMA

Violation Code ObservationViolation Citation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed the two portable fire extinguishers (first and second floor) locked in a box.

01-06-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2324834 ALEDITH APTS
 License Type: Apartment 174 NW 2 AVE, HOMESTEAD 330305866

Inspection Date: 11/23/2021 Inspection Number: 1520564 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEIDECKER, EDILMA

Violation Code ObservationViolation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2315808 SUPER 8 MOTEL
 License Type: Motel 1202 N KROME AVE, FLORIDA CITY 33034

Inspection Date: 11/22/2021 Inspection Number: 1218568 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEIDECKER, EDILMA

Violation Code ObservationViolation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Located at water heater room.

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2311674 APARTMENTOS SEGOVIA
 License Type: Apartment 119 NW 16 AVE, MIAMI 33125

Inspection Date: 11/22/2021 Inspection Number: 1528418 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, ERIK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed extinguishers with no braking device located between units 1 and 2, and 11 and 12.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330635 ROBERT KING HIGH, LLC
 License Type: Apartment 1407 NW 7 ST, MIAMI 33125

Inspection Date: 11/24/2021 Inspection Number: 1529698 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ALVAREZ, MARGARET

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329222 JW MARRIOTT MARQUIS MIAMI
 License Type: Hotel 255 BISCAYNE BLVD WAY, MIAMI 33131

Inspection Date: 11/23/2021 Inspection Number: 1161005 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed by the front desk. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4		61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329287 SEASIDE APARTMENT HOTEL
 License Type: Hotel 7310 HARDING AVE, MIAMI BEACH 33141

Inspection Date: 11/22/2021 Inspection Number: 1162298 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, VICENTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed in hall between units 311 and 312.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329721 NORMANDY REAL ESTATE CORP
 License Type: Apartment 1975 CALAIS DR, MIAMI BEACH 33141

Inspection Date: 11/24/2021 Inspection Number: 1523823 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, VICENTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device in fire extinguisher boxes at the parking entrance area. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2302132

MERLIN APTS LLC

License Type: Apartment

1245 NW 58 ST, MIAMI 33142

Inspection Date: 11/24/2021

Inspection Number: 1526688

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: UNZAGA, MILADYS

Violation Code Observation

Violation Citation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device on extinguisher located between units 9 and 10.

01-06-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Flagler County

License Number: 2800588

THE LODGE AT HAMMOCK BEACH

License Type: Hotel

105 16 RD, PALM COAST 32137

Inspection Date: 11/23/2021

Inspection Number: 1160072

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BADDING, MELANIE

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
In room #5 fire extinguisher in recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3902679

BUDGET INN EAST

License Type: Motel

4011 E COLUMBUS DR, TAMPA 33605

Inspection Date: 11/24/2021

Inspection Number: 1221234

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: EHLERS, MICHAEL

Violation Code Observation

Violation Citation

- From initial inspection : Damaged electrical wire(s). For reporting purposes only. By room 201. ****Repeat Violation**** - From follow-up inspection 2021-11-24: Damaged electrical wire(s) by room 201.

****Admin Complaint****

07-01-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301449

ARIUM JENSEN BEACH

License Type: Apartment

1010 NW FRESCO WAY, JENSEN BEACH 34957

Inspection Date: 11/23/2021

Inspection Number: 1528602

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation CodeObservationViolation Citation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Bldg 940 by unit 105.

01-02-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5301452

CARIBBEAN SHORES WATERFRONT RESORT

License Type: Hotel

2625 NE INDIAN RIVER DR, JENSEN BEACH 34957

Inspection Date: 11/24/2021

Inspection Number: 1161490

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation CodeObservationViolation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Cleared during inspection. **Corrected On-Site**

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400040

SUNSET CITY LESSEE

License Type: Motel

508 SOUTH ST, KEY WEST 33040

Inspection Date: 11/22/2021

Inspection Number: 1219593

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ORDONEZ, CATALINA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5603260

TWIN OAKS APARTMENTS

License Type: Apartment

102 BANNER CT, CRESTVIEW 32536

Inspection Date: 11/24/2021

Inspection Number: 1531852

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BURROUGHS, RICHARD

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.
 - apartment 112: backside porch light fixture missing. The wires are exposed.
 They have been capped.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900204

RAMADA PLAZA HOTEL & INN GATEWAY

License Type: Motel

7470 HWY 192 W, KISSIMMEE 34747

Inspection Date: 11/23/2021

Inspection Number: 1217777

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: IRVEN, RYAN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5913594

CORTLAND REUNION

License Type: Apartment

7995 HAVEN WAY, KISSIMMEE 34747

Inspection Date: 11/24/2021

Inspection Number: 1515100

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: IRVEN, RYAN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5913613

ARIA APARTMENTS AT REEDY CREEK

License Type: Apartment

3020 REEDY CREEK BLVD., KISSIMMEE 34747

Inspection Date: 11/24/2021

Inspection Number: 1527126

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6100216

TWILITE MOTEL

License Type: Motel

4040 GALL BLVD, ZEPHYRHILLS 33542

Inspection Date: 11/24/2021

Inspection Number: 1217550

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: POWELL, DAVID

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher observed with dial in the recharge zone by unit 119.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6208393 SERENITY CREEK CAPITAL LLC
 License Type: Apartment 4201 49 ST N, ST. PETERSBURG 33709

Inspection Date: 11/24/2021 Inspection Number: 1522156 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HEFFNER, CHRISTOPHER

Violation Code ObservationViolation Citation

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Between units 306 and 307.

01-01-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6205545 MARISOL VISTA APARTMENTS
 License Type: Apartment 1280 N 102 AVE, ST. PETERSBURG 33716

Inspection Date: 11/22/2021 Inspection Number: 1524893 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: LOZANO, KELVIN

Violation Code ObservationViolation Citation

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher next to unit 5-203 - From follow-up inspection 2021-10-20: - From follow-up inspection 2021-11-22:

01-02-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215767 HILTON HOTEL ST PETERSBURG CARILLON PARK
 License Type: Hotel 950 LAKE CARILLON DR, ST. PETERSBURG 33716

Inspection Date: 11/22/2021 Inspection Number: 1160945 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LOZANO, KELVIN

Violation Code ObservationViolation Citation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FL 130735, 130736, 133820, 133819 expired 08/07/2021

08-01-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6214076

EXTENDED STAY HOTELS

License Type: Motel

2311 ULMERTON RD, CLEARWATER 33762

Inspection Date: 11/23/2021

Inspection Number: 1217904

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAY-WALKER, LISA

Violation Code

Observation

Violation Citation

Boiler certificate or insurance inspector's boiler report expired 133787, 133768 1/30/2020. For reporting purposes only. ****Repeat Violation****

08-01-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6801281

HYATT REGENCY SARASOTA

License Type: Hotel

1000 BLVD OF THE ARTS, SARASOTA 34236

Inspection Date: 11/22/2021

Inspection Number: 1160247

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back - Admin. complaint recommended

Inspector Name: MCKEON, MICHAEL

Violation Code

Observation

Violation Citation

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Expired 6/25/21

- From follow-up inspection 2021-11-22: **Time Extended**

08-01-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501641

LA QUINTA INN & SUITES

License Type: Hotel

215 ANASTASIA BLVD, SAINT AUGUSTINE 32080

Inspection Date: 11/23/2021

Inspection Number: 1159477

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: HARTMANN, MICHELLE

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only
 208 and 207, 226, 233 and 202 hearing impaired detector does not sound alarm. Room 202 does not strobe. ****Warning****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406518 COMFORT INN AND SUITES
 License Type: Hotel 103 S OCEAN AVE, DAYTONA BEACH 32118

Inspection Date: 11/24/2021 Inspection Number: 1160926 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WOOD, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
06-01-4	Path to door marked as an exit is blocked. For reporting purposes only. -laundry room, large folding table blocking access to marked fire exit door -manager stated moving table as soon as possible **Corrected On-Site**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406520 MICK'S BEACH HIDEAWAY
 License Type: Motel 2009 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 11/22/2021 Inspection Number: 1219507 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WOOD, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406492 BEST WESTERN
 License Type: Hotel 1730 S RIDGEWOOD AVE, EDGEWATER 32132

Inspection Date: 11/23/2021 Inspection Number: 1160890 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PICHARDO, RENEE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.