

Bay County

License Number: 1305148

TWEEN BAYS MOTEL

License Type: Motel

4508 W HWY 98, PANAMA CITY 32401

Inspection Date: 11/29/2021

Inspection Number: 1219606

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Audible alarm only, flash does not function.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1503827 ARCH CREEK RUN APARTMENTS
 License Type: Apartment 173 RACHEL ST, MELBOURNE 32901

Inspection Date: 12/03/2021 Inspection Number: 1526709 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MITTEN, JAMES

Violation Code Observation Violation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. ****Corrected On-Site****
 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1502495 THE PAVILIONS AT MONTEREY LLC
 License Type: Apartment 1635 MONTEREY DR, PALM BAY 32905

Inspection Date: 11/30/2021 Inspection Number: 1533571 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: VAUGHAN, COURTNEY

Violation Code Observation Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1505692 HOME2 SUITES CAPE CANAVERAL
 License Type: Hotel 9004 ASTRONAUT BLVD, CAPE CANAVERAL 32920-4601

Inspection Date: 12/02/2021 Inspection Number: 1159785 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HICKS, GEORGE RANDY

Violation Code Observation Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Rooftop duct, detector relay.
 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1604792 BEACHCOMBER RESORT AND VILLAS
 License Type: Hotel 1200 S OCEAN BLVD, POMPANO BEACH 33062-6609

Inspection Date: 11/29/2021 Inspection Number: 1161015 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BURGGRAVE, BROCK

Violation Code Observation Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621209 NEW RIVER YACHT CLUB
 License Type: Apartment 400 SW 1ST AVE, FORT LAUDERDALE 33301

Inspection Date: 11/30/2021 Inspection Number: 1533561 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRANN, JUSTIN

Violation Code Observation Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Inspector will email inspection report to Fire Marshall for review. 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621715 LAUREAT
 License Type: Apartment 790 E BROWARD BLVD, FORT LAUDERDALE 33301

Inspection Date: 11/30/2021 Inspection Number: 1533563 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRANN, JUSTIN

Violation Code Observation Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Inspector will email inspection report to Fire Marshall for review. 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620914 ROLO BEACH HOTEL
 License Type: Hotel 701-709 ORTON AVE, FORT LAUDERDALE 33304

Inspection Date: 11/29/2021 Inspection Number: 1159516 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: BRANN, JUSTIN

Violation Code Observation Violation Citation

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. By 11A.

01-01-4 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1618388 HYATT PLACE
 License Type: Hotel 8530 W BROWARD BLVD, PLANTATION 33324

Inspection Date: 11/29/2021 Inspection Number: 1162115 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SMITH, CORETTA

Violation Code Observation Violation Citation

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

08-03-4 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1619757 SONESTA ES SUITES FORT LAUDERDALE PLANTATION
 License Type: Hotel 410 N PINE ISLAND RD, PLANTATION 33324

Inspection Date: 11/29/2021 Inspection Number: 1162148 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SMITH, CORETTA

Violation Code Observation Violation Citation

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

08-03-4 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2102692

FAIRFIELD INN & SUITES NAPLES

License Type: Hotel

3808 WHITE LAKE BLVD, NAPLES 34117

Inspection Date: 12/02/2021

Inspection Number: 1159402

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DILLON, TIMOTHY

Violation CodeObservationViolation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed the fire panel in the front office is showing a trouble alert.

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2101012

MARCO ISLAND HILTON BEACH RESORT & SPA

License Type: Hotel

560 S COLLIER BLVD, MARCO ISLAND 34145

Inspection Date: 12/02/2021

Inspection Number: 1160531

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GRAVES, PETER

Violation CodeObservationViolation Citation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certification has expired on two boilers. 059218/6/17/21, 094304/6/17/21,

08-01-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Columbia County

License Number: 2200197 GATEWAY INN
 License Type: Motel 3783 W US HWY 90, LAKE CITY 32055

Inspection Date: 11/30/2021 Inspection Number: 1218427 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BAILEY, KIMBERLY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In laundry room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2200437 JASMINE GARDEN INN
 License Type: Motel 352 NW KNIGHTS AVE, LAKE CITY 32055

Inspection Date: 11/30/2021 Inspection Number: 1218026 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: BAILEY, KIMBERLY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Inside laundry room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2301560 ANCHOR HOTEL
 License Type: Hotel 903 W 1 AVE, HIALEAH 33010

Inspection Date: 11/29/2021 Inspection Number: 1162701 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, EDGAR

Violation Code Observation Violation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By room #15. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-02-4		509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2305461 MAZAL INVESTMENTS 32
 License Type: Apartment 251 NE 10 ST, HOMESTEAD 33030

Inspection Date: 12/03/2021 Inspection Number: 1524605 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: LEIDECKER, EDILMA

Violation Code Observation Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. One located at building 1045 NE.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-06-4		509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2308299

PARK MOTEL

License Type: Motel

600 S KROME AVE, HOMESTEAD 33030

Inspection Date: 11/29/2021

Inspection Number: 1217931

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. One located between room 4 and 5.
Repeat Violation

01-06-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2325601

PEREZ & PEREZ

License Type: Apartment

92 NE 10 STREET, HOMESTEAD 33030

Inspection Date: 11/29/2021

Inspection Number: 1513652

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed two fire extinguisher locked in a boxes, one next to unit 5 and one next to unit 8. **Repeat Violation**

01-06-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2305973

MAZAL INVESTMENTS 33 LLC

License Type: Apartment

777 NE 11 ST, HOMESTEAD 33030-4900

Inspection Date: 12/01/2021

Inspection Number: 1522238

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328955 SUPER 8 MOTEL
 License Type: Motel 1196 N KROME AVE, FLORIDA CITY 33034

Inspection Date: 11/22/2021 Inspection Number: 1219209 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEIDECKER, EDILMA

Violation Code Observation Violation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. One located next to room 139. 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2313312 ADRIANA APARTMENTS.
 License Type: Apartment 1542 NW 3 ST, MIAMI 33125

Inspection Date: 11/29/2021 Inspection Number: 1521249 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ALVAREZ, MARGARET

Violation Code Observation Violation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. **Repeat Violation** 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2323680 RIO MIAMI APARTMENTS LLC
 License Type: Apartment 1310 NW 22 AVE, MIAMI 33125

Inspection Date: 11/29/2021 Inspection Number: 1524078 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, ERIK

Violation Code Observation Violation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed extinguishers with no braking devices located by unit 308, between units 311 and 312, by unit 208. 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2317959

DOUBLETREE MIAMI MART AIRPORT HOTEL

License Type: Hotel

711 NW 72 AVE, MIAMI 33126

Inspection Date: 11/30/2021

Inspection Number: 1163545

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ORDONEZ, CATALINA

Violation CodeObservationViolation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-04-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329489

AC & ELEMENT HOTEL BRICKELL MIAMI

License Type: Hotel

115 SW 8 ST, MIAMI 33130

Inspection Date: 12/02/2021

Inspection Number: 1161736

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

08-03-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2316974 HYATT REGENCY MIAMI
 License Type: Hotel 400 SE 2 AVE, MIAMI 33131

Inspection Date: 11/30/2021 Inspection Number: 1161509 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only. Operator printed and posted the boiler certifications for FL 012165, expires 07/16/22; FL 012166, expires 07/16/22 **Corrected On-Site**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328937 THE RITZ CARLTON HOTEL COCONUT GROVE
 License Type: Hotel 3300 SW 27TH AVE, COCONUT GROVE 33133

Inspection Date: 11/30/2021 Inspection Number: 1162082 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MASKASEM, SUPPACHAI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 2 boilers certificates expired: 098749, 098748 exp 06/11/21. The two boilers listed were inspected 11/29/2021. Still waiting on the update certificates. **Cor	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2308454 YURIANI INVESTMENTS LLC
 License Type: Apartment 1421 SW 6 ST, MIAMI 33135

Inspection Date: 12/02/2021 Inspection Number: 1532354 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. **Warning** - From follow-up inspection 2021-12-02: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2301119

JENNAY APTS

License Type: Apartment

627 - 641 10 ST, MIAMI BEACH 33139

Inspection Date: 11/29/2021

Inspection Number: 1519083

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
Near apartment 9.

01-06-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2323934

635 11TH ST

License Type: Apartment

635 11 ST, MIAMI BEACH 33139

Inspection Date: 12/02/2021

Inspection Number: 1528663

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
Located on 2nd floor.

01-01-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329464

DAKOTA PARK SOUTH INC

License Type: Apartment

1036 LENOX AVE, MIAMI BEACH 33139

Inspection Date: 11/30/2021

Inspection Number: 1513984

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.

01-06-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330598

PIERRE ON THE BAY APTS

License Type: Apartment

2050-2070 BAY DR, MIAMI BEACH 33141

Inspection Date: 11/29/2021

Inspection Number: 1532101

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed missing breaking device for extinguisher box by unit 515

01-05-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2306730

SHERRY FRONTENAC HOTEL

License Type: Hotel

6565 COLLINS AVE, MIAMI BEACH 331414613

Inspection Date: 11/29/2021

Inspection Number: 1161647

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed expiration date on 07/09/2021 for boilers with jurisdiction numbers: 059292 and 057119. As per Operator, in process of certification.

08-01-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330699

SOUTH MIAMI PLAZA PRESERVATION

License Type: Apartment

6701 SW 62 AVE, SOUTH MIAMI 33143

Inspection Date: 11/29/2021

Inspection Number: 1533284

Inspection Type: Lodging-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PICO, JORGE

Violation CodeObservationViolation Citation

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

08-03-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329351 FOUR SEASONS HOTEL THE SURF CLUB
License Type: Hotel 9011 COLLINS AVE, SURFSIDE 33154

Inspection Date: 12/02/2021 Inspection Number: 1162237 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, VICENTE

Violation Code Observation Violation Citation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed invoice for boilers inspection issued on 06/08/2021. Waiting for Certificates. **Corrective Action Taken**

08-01-4 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2314513 ALOFT MIAMI DADELAND
License Type: Motel 7600 N KENDALL DR, MIAMI 33156

Inspection Date: 11/29/2021 Inspection Number: 1218250 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
Inspector Name: PICO, JORGE

Violation Code Observation Violation Citation

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2021-10-28: Observed Trouble/alarm light illuminated on the fire alarm control panel. For reporting

04-01-4 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310769 BETTY APARTMENTS
License Type: Apartment 2244 NE 173 ST, NORTH MIAMI BEACH 331602931

Inspection Date: 11/24/2021 Inspection Number: 1522759 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TAYLOR, JOHN

Violation Code Observation Violation Citation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to Apt 21.

01-06-4 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330419		PRESTIGE VILLAGE	
License Type: Apartment		13055 NE 6 AVE, NORTH MIAMI 33161	
Inspection Date: 11/29/2021	Inspection Number: 1529420	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SUAREZ, LEOPOLDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2307022		NORGATE APARTMENTS	
License Type: Apartment		1237 NE 128 ST, NORTH MIAMI 331615184	
Inspection Date: 11/29/2021	Inspection Number: 1527356	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SUAREZ, LEOPOLDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329393		ALOFT MIAMI AVENTURA	
License Type: Hotel		2910 NE 207 ST, AVENTURA 33180	
Inspection Date: 11/30/2021	Inspection Number: 1163118	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
08-01-4		61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Duval County

License Number: 2613403 DRIFT AT TOWN CENTER EAST APARTMENTS
 License Type: Apartment 5000 KERNAN BLVD S., JACKSONVILLE 32224

Inspection Date: 12/02/2021 Inspection Number: 1533567 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FICHTER, GARRICK Inspection

Violation Code Observation Violation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
 In building 5. Fire alarm panel has an alert stating "trouble in system" NAC 2 Fault". Alarm date 11022021 9:57A

04-01-4 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612170 EXTENDED STAY AMERICA
 License Type: Motel 10020 SKINNER LAKE DR, JACKSONVILLE 32246

Inspection Date: 12/01/2021 Inspection Number: 1219527 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation Code Observation Violation Citation

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Two boilers have a decal with current date, expiration on 2022 but no certificates available

08-03-4 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613429 THE RIDLEY APARTMENTS
 License Type: Apartment 12517 BEACH BLVD, JACKSONVILLE 32246

Inspection Date: 08/18/2021 Inspection Number: 1533583 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: THOMAS, PHILIP

Violation Code Observation Violation Citation

Priority: Reporting
 Observed: No portable fire extinguisher present on the premises. For reporting purposes only.
 No fire extinguisher in fire box located between garages G18-03 and G18-04

01-04-4 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2700097

DAYS INN

License Type: Motel

710 N PALAFOX ST, PENSACOLA 32501

Inspection Date: 11/30/2021

Inspection Number: 1218184

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ALBRITTON, GREGORY

Violation CodeObservationViolation Citation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Jurisdiction number-B00069364/ Expiration Date-05/07/2021

08-01-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 63 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2704018

NEW WORLD INN

License Type: Motel

600 S PALAFOX ST, PENSACOLA 32502

Inspection Date: 11/09/2021

Inspection Number: 1218179

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: GARDNER, GREGORY

Violation CodeObservationViolation CitationBoiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
04/25/2021 099673

08-01-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 63 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2702162

RED ROOF INN

License Type: Motel

7340 PLANTAION RD, PENSACOLA 32504

Inspection Date: 12/03/2021

Inspection Number: 1219640

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BURROUGHS, RICHARD

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
 - 134981, 06/06/2021
 - 489959, 09/06/2021.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 63 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Gilchrist County

License Number: 3100004

CADILLAC MOTEL

License Type: Motel

7490 N HWY 19, FANNING SPRINGS 32693

Inspection Date: 12/01/2021

Inspection Number: 1218686

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TORRES, WILLIAM

Violation Code

Observation

Violation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed portable fire extinguisher pressure gauge indicating need to recharge between guestroom 116 and 117	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-02-4		509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3912062 ROCKY CREEK APARTMENTS
License Type: Apartment 6820 W HILLSBOROUGH AVE, TAMPA 33634

Inspection Date: 12/03/2021 Inspection Number: 1517451 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ZHANG, JACKY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Between garage G57 and G 58 by car wash area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913830 EQUESTRAIN PARC AT HIGHWOOD PRESERVE
License Type: Apartment 18591 BRIDLE CLUB DR, TAMPA 33647

Inspection Date: 12/02/2021 Inspection Number: 1524037 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: POWELL, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. observed fire extinguishers in the recharge zone by units 8-18201, 6-18347, and 14-18145	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5300176 THE PARK VIEW
 License Type: Apartment 2211 NE DIXIE HWY, JENSEN BEACH 34957

Inspection Date: 12/01/2021 Inspection Number: 1530785 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: PETROW, MICHAEL

Violation Code Observation Violation Citation

- From initial inspection : No smoke detector provided in guest room/unit. For reporting purposes only. Missing in unit 17. - From follow-up inspection 2021-12-01: Unable to verify, tenant occupied. **Time Extended**

04-02-4 509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5301447 SUBURBAN EXTENDED STAY HOTEL STUART
 License Type: Hotel 1900 SE FEDERAL HWY, STUART 34994

Inspection Date: 12/02/2021 Inspection Number: 1159645 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: PETROW, MICHAEL

Violation Code Observation Violation Citation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher near 237.

01-02-4 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5301450 MACKNIGHT RENTAL
 License Type: Apartment 524 SW CAMDEN AVE, STUART 34994

Inspection Date: 11/29/2021 Inspection Number: 1528818 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PETROW, MICHAEL

Violation Code Observation Violation Citation

No portable fire extinguisher observed on the premises. For reporting purposes only.

01-04-4 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5403191

CASA MARINA A WALDORF ASTORIA RESORT

License Type: Hotel

1500 REYNOLDS ST, KEY WEST 33040

Inspection Date: 11/29/2021

Inspection Number: 1163484

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: ORDONEZ, CATALINA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Nassau County

License Number: 5500098 SHIP INN
 License Type: Motel 542953 US HWY 1, CALLAHAN 32011

Inspection Date: 11/30/2021 Inspection Number: 1218319 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: ROZIER, TORRANCE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. . For reporting purposes only. Gas tank store between door 19 and 20	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5500982 TOPAZ OAKS APARTMENTS
 License Type: Apartment 45160 EWING PARK RD, CALLAHAN 32011

Inspection Date: 12/01/2021 Inspection Number: 1529633 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ROZIER, TORRANCE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored outside door . For reporting purposes only. 1)2 tanks one hooked up to grill in front of door 38 2)tank hooked up to grill in front of door 42 3) tank hooked up to grill door 48	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811128 KATERINA HOTEL ORLANDO
 License Type: Hotel 830 LEE RD, ORLANDO 32810

Inspection Date: 12/02/2021 Inspection Number: 1163583 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: MONTGOMERY, DOREEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. Room 309	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5804660 RAMADA LAKEFRONT
 License Type: Motel 6500 INTERNATIONAL DR, ORLANDO 328198218

Inspection Date: 11/30/2021 Inspection Number: 1221570 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: BACHOO, SAVITRI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5803952 EMBASSY SUITES HOTEL I DRIVE
 License Type: Hotel 8978 INTERNATIONAL DR, ORLANDO 328199336

Inspection Date: 11/29/2021 Inspection Number: 1161040 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: QUINONES, ANTONIO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - Alert in 7th and 4th floors rooms 720 and 430. - From follow-up inspection 2021-11-29: Old alerts corrected, new alerts room 7	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811108 RESIDENCE INN ORLANDO AIRPORT
 License Type: Hotel 7024 AUGUSTA NATIONAL DR, ORLANDO 32822

Inspection Date: 11/30/2021 Inspection Number: 1160989 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: LORENZO, ANA

Violation Code Observation Violation Citation

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only./ system trouble at main fire panel - From follow-up inspection 2021-11-30: not completed **Time Extended**

04-01-4 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5804293 THE LANDING AT EAST MIL
 License Type: Apartment 4937 WATERWAY CT, ORLANDO 32839

Inspection Date: 11/30/2021 Inspection Number: 1522065 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PASIECKI, VICTORIA

Violation Code Observation Violation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
 Building 4916

04-01-4 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5901202

QUALITY INN & SUITES BYTHE PARKS

License Type: Motel

2945 ENTRY POINT BLVD, KISSIMMEE 34747

Inspection Date: 12/02/2021

Inspection Number: 1218086

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014078

WEST PALM BEACH CANOPY

License Type: Hotel

380 TRINITY PL, WEST PALM BEACH 33401

Inspection Date: 12/03/2021

Inspection Number: 1159500

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOLDMAN, BARRY

Violation Code

Observation

Violation Citation

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. J# 138444, 148445 - operator states waiting on certificates.
 Corrective Action Taken **Repeat Violation**

08-03-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6000078

APTS

License Type: Apartment

1550 FOREST HILL BLVD, WEST PALM BEACH 33406-6034

Inspection Date: 11/30/2021

Inspection Number: 1521090

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MONTILLA, NATHALIE

Violation Code

Observation

Violation Citation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
 Near apartment 5

01-02-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6004110

1031 SOUTH WOOSTER LTD

License Type: Motel

1901 PALM BEACH LAKES BLVD., WEST PALM BEACH 33409

Inspection Date: 12/03/2021

Inspection Number: 1217742

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SEVILLA, FREDDY

Violation CodeObservationViolation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6002759

CONGRESS MOTEL AND APARTMENTS

License Type: Motel

4787 S CONGRESS AVE, LAKE WORTH 33461

Inspection Date: 11/29/2021

Inspection Number: 1219131

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: MONTILLA, NATHALIE

Violation CodeObservationViolation Citation

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Between room 11 and 10 - From follow-up inspection 2021-11-29: **Time Extended**

01-02-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6003850

JUPITER BEACH RESORT

License Type: Motel

5 N A1A, JUPITER 33477

Inspection Date: 12/01/2021

Inspection Number: 1219853

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Lobby area/Front desk area. **Repeat Violation**

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6203064

TRADEWINDS SANDPIPER BEACH RESORT

License Type: Motel

6000 GULF BLVD, ST. PETE BEACH 33706

Inspection Date: 12/03/2021

Inspection Number: 1218415

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: DAY-WALKER, LISA

Violation CodeObservationViolation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Yellow Trouble light illuminated in front lobby. **Repeat Violation**

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6203469

MAGNUSON HOTEL MARINA COVE

License Type: Motel

6800 SUNSHINE SKYWAY LN S, ST PETERSBURG 337114901

Inspection Date: 12/03/2021

Inspection Number: 1217240

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HEFFNER, CHRISTOPHER

Violation CodeObservationViolation Citation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Boilers are having carbon monoxide detectors updated. Inspector is coming out today to do boiler inspection when installation is complete.

08-01-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6200176 TROPICAL INN & SUITES
 License Type: Motel 1320 CLEVELAND ST, CLEARWATER 33755
 Inspection Date: 11/30/2021 Inspection Number: 1219216 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: PEARCE, LAURA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Missing tool to break cover near room 204	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215832 CANDLEWOOD SUITES SAFETY HARBOR
 License Type: Hotel 2471 MCMULLEN BOOTH RD, CLEARWATER 33759
 Inspection Date: 12/03/2021 Inspection Number: 1160357 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: PEARCE, LAURA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. In the electrical room on the first floor - maintenance supervisor cleared Fire alarm panel trouble light	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6214361 FAIRFIELD INN BY MARRIOTT ST PETERSBURG CLEARWATER
 License Type: Hotel 3211 EXECUTIVE DR, CLEARWATER 33762
 Inspection Date: 11/30/2021 Inspection Number: 1160780 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: WILMOT, TASHARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. -at office door on first floor **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215766

HILTON GARDEN INN

License Type: Hotel

4052 TAMPA RD, OLDSMAR 34677

Inspection Date: 12/03/2021

Inspection Number: 1159729

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PEARCE, LAURA

Violation CodeObservationViolation Citation

Trouble/alarm light illuminated on the fire alarm control panel by entrance . For reporting purposes only.

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6204404

DUNEDIN COVE MOTEL

License Type: Motel

1220 MAIN STREET, DUNEDIN 34698

Inspection Date: 11/29/2021

Inspection Number: 1219027

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PEARCE, LAURA

Violation CodeObservationViolation Citation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Issuing tool to break cover between rooms 22 and 23

01-06-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-02-4

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-04-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6300996

QUALITY INN & SUITES WINTER HAVEN

License Type: Motel

5651 CYPRESS GARDENS BLVD, WINTER HAVEN 33884

Inspection Date: 11/30/2021

Inspection Number: 1221568

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JACKSON, SHARON

Violation Code

Observation

Violation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6309283

ARTISAN LIVING BELLA CITTA

License Type: Apartment

1205 VENICE BLVD, DAVENPORT 33897

Inspection Date: 11/30/2021

Inspection Number: 1511178

Inspection Type: Lodging-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JACKSON, SHARON

Violation Code

Observation

Violation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Putnam County

License Number: 6400054

REGENCY INN

License Type: Motel

100 FEDERAL ST, PALATKA 32177

Inspection Date: 12/01/2021

Inspection Number: 1219570

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BELLEMARE, RYAN

Violation Code

Observation

Violation Citation

07-04-4

Electrical outlet damaged to indicate a malfunction. For reporting purposes only.
Room 104 ac plug hanging from wall.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6804704 HOLIDAY INN EXPRESS & SUITES SARASOTA EAST/I-75
 License Type: Hotel 5730 GANTT RD, SARASOTA 34233

Inspection Date: 11/29/2021 Inspection Number: 1161371 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: CATTLEY, RAYMOND

Violation Code Observation Violation Citation

- From initial inspection : Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Observed outlet cover missing outside west side of building near entrance door. - From follow-up inspection 2021-11-29: **Time Extended**

07-04-4 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6800192 BAYMONT INN AND SUITES
 License Type: Motel 1425 S TAMIAMI TRAIL, SARASOTA 34239

Inspection Date: 12/02/2021 Inspection Number: 1219016 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: CATTLEY, RAYMOND

Violation Code Observation Violation Citation

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed Fire System Silent Knight with 2 warnings, system trouble and system silence. - From follow-up inspection 2021-12-02:

04-01-4 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6900010

SEMINOLE GARDENS

License Type: Apartment

1600 W 5 ST, SANFORD 32771

Inspection Date: 11/30/2021

Inspection Number: 1528763

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Laundry room. - From follow-up inspection 2021-11-30:

01-02-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6600887

VIRGINIA PARK RESIDENCES

License Type: Apartment

2102 S 29 ST, FT PIERCE 349476953

Inspection Date: 11/29/2021

Inspection Number: 1525407

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: HARROD, JESSICA

Violation Code

Observation

Violation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only. No lights not working for panel building G

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Suwannee County

License Number: 7100240 LO MOTEL
 License Type: Motel 823 HOWARD ST W, LIVE OAK 32064

Inspection Date: 11/29/2021 Inspection Number: 1219405 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BAILEY, KIMBERLY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. At single story building. Operator stated those rooms are only used for storage no power or water provided at tha	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7100241 ROYAL INN
 License Type: Motel 966 US 129 N, LIVE OAK 32064

Inspection Date: 11/29/2021 Inspection Number: 1218609 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: BAILEY, KIMBERLY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher in laundry. Between 202 and 203.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7401657 THE SHORES RESORT & SPA
 License Type: Motel 2637 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 11/29/2021 Inspection Number: 1221569 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WOOD, JUSTIN

Violation Code Observation Violation Citation

08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 10/22/2021	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-06-4		509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400746 507 ORMOND BEACH LLC
 License Type: Motel 507 S ATLANTIC AVE, ORMOND BEACH 32176

Inspection Date: 11/30/2021 Inspection Number: 1221601 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: RUTLEDGE, REBECCA

Violation Code Observation Violation Citation

08-06-4	Combustibles stored in boiler room. For reporting purposes only. -Wood stored in close proximity to hot water heater.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	---

Volusia County

License Number: 7406522

OM HOSPITALITY OF DELTONA LLC

License Type: Motel

481 DELTONA BLVD, DELTONA 32725

Inspection Date: 12/02/2021

Inspection Number: 1218681

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Notified Lisa Nadeau, Deltona Fire Inspector, 386-878-8656.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.