

Alachua County

License Number: 1102198

MEADOWCREST APARTMENTS

License Type: Apartment

110 NW 39 AVE, GAINESVILLE 32609

Inspection Date: 12/15/2021

Inspection Number: 1533776

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: CASEY, KEITH

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Observed the fire extinguisher at 13A indicates it is not fully charged.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Baker County

License Number: 1200077

RED ROOF INN

License Type: Motel

151 WOODLAWN RD, MACCLENNY 32063

Inspection Date: 12/15/2021

Inspection Number: 1219555

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
 Fire extinguisher by room 209 is missing. Manager is aware, has unit and needs to reinstall holder for extinguisher. ****Corrective Action Taken****

01-03-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620874 HOLIDAY INN EXPRESS & SUITES
 License Type: Hotel 205 N FEDERAL HWY, DANIA BEACH 33004

Inspection Date: 12/14/2021 Inspection Number: 1162580 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LONDONO, GLORIA

Violation Code Observation Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation**** 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1603033 TROPI ROCK
 License Type: Motel 2900 BELMAR ST, FORT LAUDERDALE 33304

Inspection Date: 12/17/2021 Inspection Number: 1217592 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRANN, JUSTIN

Violation Code Observation Violation Citation

07-01-4 Exposed electrical wire(s - West side of building. For reporting purposes only. 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2101115

INN OF NAPLES

License Type: Hotel

4055 TAMIAMI TRL N, NAPLES 34103

Inspection Date: 12/17/2021

Inspection Number: 1161188

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CESPEDES, SABRINA

Violation CodeObservationViolation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Fire alarm showing trouble.

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2100977

PINE STREET APARTMENTS

License Type: Apartment

2800 PINE ST, NAPLES 34112

Inspection Date: 12/17/2021

Inspection Number: 1527429

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GRAVES, PETER

Violation CodeObservationViolation Citation

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. There is no implement to break the glass to access the fire extinguisher between apartments 1 and 2.

01-05-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2102752

REBECCA'S PLACE

License Type: Apartment

3230 THOMASSON DR, NAPLES 34112

Inspection Date: 12/17/2021

Inspection Number: 1515503

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GRAVES, PETER

Violation CodeObservationViolation Citation

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. No tool to break glass on upstairs fire extinguisher building 3270.

01-05-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329403 GUILD (THE)
 License Type: Hotel 230 NE 4 ST, MIAMI 33128

Inspection Date: 12/14/2021 Inspection Number: 1162146 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CUDEMOS, VIRNA

Violation Code Observation Violation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2311691 CHOOJOO LLC
 License Type: Apartment 1045 SW 4 ST, MIAMI 33130

Inspection Date: 12/10/2021 Inspection Number: 1523733 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CABANAS, NATALIE

Violation Code Observation Violation Citation

No portable fire extinguisher present on the premises. For reporting purposes only.

01-04-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330175 14 PLAZA CORP
 License Type: Apartment 1420/1424 NE MIAMI PL, MIAMI 33132

Inspection Date: 12/15/2021 Inspection Number: 1517244 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CUDEMOS, VIRNA

Violation Code Observation Violation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2308026 GONZALEZ APTS
 License Type: Apartment 1380 SW 6 ST, MIAMI 331353930

Inspection Date: 12/13/2021 Inspection Number: 1532356 Inspection Type: Routine - Lodging Inspection Disposition: Call Back -
 Inspector Name: GARCIA, B OSCAR Complied

Violation Code ObservationViolation Citation

- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
 Warning - From follow-up inspection 2021-12-13: **Time Extended**

01-06-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2303509 1030-1034 JEFFERSON AVE APTS
 License Type: Apartment 1030 JEFFERSON AVENUE, MIAMI BEACH 33139

Inspection Date: 12/14/2021 Inspection Number: 1518442 Inspection Type: Routine - Lodging Inspection Disposition: Warning
 Inspector Name: WILLIAMS, ALFREDA Issued

Violation Code ObservationViolation Citation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Near apparent 4 and 5

01-06-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2304637 TIFFANY HOTEL
 License Type: Hotel 801 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 12/17/2021 Inspection Number: 1163233 Inspection Type: Routine - Lodging Inspection Disposition: Call Back -
 Inspector Name: WILLIAMS, ALFREDA Complied

Violation Code ObservationViolation Citation

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

121050 exp 6/19/20, 121051 exp 6/19/20 - From follow-up inspection
 2021-12-17: 121050 exp 6/19/20, 121051 exp 6/19/20 **Time Extended**

08-01-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2304737 1040 JEFFERSON AVE APTS
 License Type: Apartment 1040 JEFFERSON AVENUE, MIAMI BEACH 33139

Inspection Date: 12/14/2021 Inspection Number: 1513568 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: WILLIAMS, ALFREDA

Violation Code Observation Violation Citation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
 Observed on first floor

01-06-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2305549 PLYMOUTH HOTEL
 License Type: Hotel 336 21 ST, MIAMI BEACH 33139

Inspection Date: 12/13/2021 Inspection Number: 1160512 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: HODGE, KRISTEN

Violation Code Observation Violation Citation

Trouble/alarm light illuminated on the fire alarm control panel located behind front desk. For reporting purposes only.

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2325471 THE EDROY REALTY LLC
 License Type: Apartment 1200 PENNSYLVANIA AVE, MIAMI BEACH 33139

Inspection Date: 12/15/2021 Inspection Number: 1519209 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: WILLIAMS, ALFREDA

Violation Code Observation Violation Citation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.

01-06-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328176		TOWNHOUSE HOTEL	
License Type: Hotel		150 20 ST, MIAMI BEACH 33139	
Inspection Date: 12/13/2021	Inspection Number: 1163350	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. Building is a shared structure with several restaurants located within the same building, issue is related to MYN-TU restaurant. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329100		THE SETAI HOTEL	
License Type: Hotel		2001 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 12/13/2021	Inspection Number: 1159387	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel due to construction/renovation on hotel property. For reporting purposes only. - From follow-up inspection 2021-12-13: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
08-01-4		61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329201		METROPOLE HOTEL	
License Type: Hotel		635 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 12/13/2021	Inspection Number: 1160433	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329344 751 MERIDIAN HOUSE
 License Type: Apartment 751 MERIDIAN AVE, MIAMI BEACH 33139

Inspection Date: 12/15/2021 Inspection Number: 1522069 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: WILLIAMS, ALFREDA

Violation Code ObservationViolation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329347 1355 DREXEL AVENUE LLC
 License Type: Hotel 1355 57 DREXEL AVE, 440 14 ST, MIAMI BEACH 33139

Inspection Date: 12/15/2021 Inspection Number: 1160951 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: WILLIAMS, ALFREDA

Violation Code ObservationViolation Citation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Near room 12

01-06-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-04-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329478 THE GABRIEL SOUTH BEACH
 License Type: Hotel 620-650 OCEAN DRIVE, MIAMI BEACH 33139

Inspection Date: 12/17/2021 Inspection Number: 1162010 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: WILLIAMS, ALFREDA

Violation Code ObservationViolation Citation

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
 626 and 620 buildings with trouble alarm light. - From follow-up inspection
 2021-12-17: **Time Extended**

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2327192

RED SOUTH BEACH

License Type: Hotel

3010 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 12/15/2021

Inspection Number: 1160931

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**

08-01-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-03-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2326199

FININVEST BAY CORP

License Type: Apartment

7050 BONITA DR, MIAMI BEACH 33141

Inspection Date: 12/14/2021

Inspection Number: 1528142

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed missing breaking device in fire extinguisher boxes by unit 14 (front side) and second story back side by units 19 and 22. **Repeat Violation**

01-05-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329161 FININVEST BAY CORP
 License Type: Apartment 7080 BONITA DR, MIAMI BEACH 33141

Inspection Date: 12/14/2021 Inspection Number: 1530511 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, VICENTE

Violation Code ObservationViolation Citation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device on fire extinguisher boxes by units 24, 28, 30 and 34. **Repeat Violation**

01-06-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328882 TOWER KING APT
 License Type: Apartment 13455 NE 6 AVE, NORTH MIAMI 33161

Inspection Date: 12/16/2021 Inspection Number: 1524962 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: UNZAGA, MILADYS

Violation Code ObservationViolation Citation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. No breaking device for extinguisher located in front of unit 104, extinguisher in front of 103, extinguisher in the laundry room , extinguisher in front of the unit 211 , the one in front of the unit 203, extinguisher in front of the unit 311, 308 , 304 and 303.

01-06-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2302043 CONCORD GDN APTS VIL B
 License Type: Apartment 3500 SW 112 AVE, MIAMI 331653460

Inspection Date: 12/17/2021 Inspection Number: 1529867 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DELAMATA, JORGE

Violation Code ObservationViolation Citation

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
 Observed fire extinguisher located inside meter room not having a breaking device.

01-05-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2327833 MIAMI AIRPORT WEST/DORAL TOWNEPLACE SUITES
 License Type: Hotel 10505 NW 36 ST, MIAMI 33178

Inspection Date: 12/14/2021 Inspection Number: 1159660 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: CURRAS, YANLEE

Violation Code Observation Violation Citation

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
 At the time of the inspection observed boiler certificate expired on 3/14/2021. -
 From follow-up inspection 2021-12-09: t the time of the inspection observed boiler certificate expired on 3/14/2021. **Time Extended** - From follow-up inspection 2021-12-14: **Time Extended**

08-01-4 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329192 COURTYARD MIAMI WEST FLORIDA TURNPIKE
 License Type: Hotel 11580 NW 105 ST, MIAMI 33178

Inspection Date: 12/13/2021 Inspection Number: 1162313 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CURRAS, YANLEE

Violation Code Observation Violation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

04-01-4 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

DeSoto County

License Number: 2400261

VERANDA HOUSE

License Type: Apartment

305 W OAK ST, ARCADIA 34266

Inspection Date: 12/17/2021

Inspection Number: 1533657

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: JACKS, ALBERT

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Trouble light, due to missing strobe.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hamilton County

License Number: 3400014 AMERICAN INN
 License Type: Motel 8072 SR 6 W, JASPER 32052

Inspection Date: 12/17/2021 Inspection Number: 1220003 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BAILEY, KIMBERLY

Violation Code ObservationViolation Citation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Left side front side extinguisher.

01-02-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-03-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3400112 BUDGET INN OF JASPER
 License Type: Motel 8182 SR 6 W, JASPER 32052

Inspection Date: 12/17/2021 Inspection Number: 3176416 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BAILEY, KIMBERLY

Violation Code ObservationViolation Citation

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. In front of room 305. Operator placed extinguisher at location. **Corrected On-Site** **Repeat Violation**

01-03-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3400163 MUSTANG INN
 License Type: Motel 8055 SR 6 W, JASPER 32052

Inspection Date: 12/17/2021 Inspection Number: 1219784 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BAILEY, KIMBERLY

Violation Code ObservationViolation Citation

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Next to 157. **Repeat Violation**

01-03-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3902549 PALM AVENUE APARTMENTS
 License Type: Apartment 10610 N 30 ST, TAMPA 33612

Inspection Date: 12/10/2021 Inspection Number: 1533716 Inspection Type: Complaint Full Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: CESAR, RACHEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Building 39 unit C. - From follow-up inspection 2021-12-10: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Inspection Date: 12/13/2021 Inspection Number: 1533716 Inspection Type: Complaint Full Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: CESAR, RACHEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Building 39 unit C. - From follow-up inspection 2021-12-10: **Time Extended** - From follow-up inspection 2021-12-13: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4600402

ROCK LAKE II

License Type: Motel

2937 PALM BCH BLVD, FORT MYERS 339161504

Inspection Date: 12/13/2021

Inspection Number: 1218749

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FREED, JOSEPH

Violation Code

Observation

Violation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Observed smoke alarm dangling from wires in laundry room between Room #26 and Room #25. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4701676 TALLAHASSEE CAPITAL COURTYARD
 License Type: Hotel 1018 APALACHEE PKWY, TALLAHASSEE 32301

Inspection Date: 12/16/2021 Inspection Number: 1161656 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: STESLOW, KEVIN

Violation Code Observation Violation Citation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Boiler certificate expired. Manager stated they had a boiler inspection scheduled for Monday **Corrective Action Taken** **Warning**

08-01-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4703225 PATRICK AVENUE APARTMENTS
 License Type: Apartment 1526 PATRICK AVE, TALLAHASSEE 32310

Inspection Date: 04/08/2021 Inspection Number: 1533763 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: JEFFERS, MARY-BETH

Violation Code Observation Violation Citation

OBSERVED: GAS CAN WITH GASOLINE STORED UNDER A STAIRWELL. FOR REPORTING PURPOSES ONLY.
 GAS CONTAINER WITH GASOLINE STORED UNDER STAIRWELL NEAR APT #1524

PRIORITY: REPORTING

02-08-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5300742

HUTCHINSON ISLAND MARRIOTT BEACH RESORT & MARINA

License Type: Hotel

555 NE OCEAN BLVD, STUART 34996

Inspection Date: 12/13/2021

Inspection Number: 1160959

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: PETROW, MICHAEL

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 63 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5403191

CASA MARINA A WALDORF ASTORIA RESORT

License Type: Hotel

1500 REYNOLDS ST, KEY WEST 33040

Inspection Date: 12/13/2021

Inspection Number: 1163299

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: ORDONEZ, CATALINA

Violation Code

Observation

Violation Citation

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2021-12-13: Trouble/alarm light illuminated on the fire alarm control panel. Operator provided invoice tickets from Johnson Controls company, awaiting parts. **Time Extended**

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Nassau County

License Number: 5500977

CABANA VILLAS

License Type: Apartment

545765 US HIGHWAY 1, CALLAHAN 32011

Inspection Date: 12/14/2021

Inspection Number: 1521936

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ROZIER, TORRANCE

Violation CodeObservationViolation Citation

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. . For reporting purposes only.
Stored in-front of door six and door five

02-08-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5500262

OCEANS AMELIA

License Type: Apartment

1990 S FLETCHER AVE, FERNANDINA BEACH 32034

Inspection Date: 12/13/2021

Inspection Number: 1521728

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ROZIER, TORRANCE

Violation CodeObservationViolation Citation

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only.
Propane gas tank stored near sliding door of unit 1

02-08-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5500303

DIXIE MOTEL

License Type: Motel

551664 US HWY 1, HILLIARD 32046

Inspection Date: 12/17/2021

Inspection Number: 1221937

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ROZIER, TORRANCE

Violation CodeObservationViolation Citation

No smoke detector provided in guest room/unit. For reporting purposes only.
1and 8. Employee placed smoke detectors in rooms. **Corrected On-Site**

04-02-4

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5600157

ECONOMY MOTEL

License Type: Motel

1 SE MIRACLE STRIP PKWY, FT WALTON BCH 325485815

Inspection Date: 12/17/2021

Inspection Number: 1219355

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ADAMSON, ROBERT

Violation Code

Observation

Violation Citation

Fire sprinkler head obstructed/covered. For reporting purposes only.
Sprinkler head in bathroom of room 103 with paper towel inside. Operator states there is a leak.

03-04-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5803221 INDIGO WINTER PARK
 License Type: Apartment 220 S SEMORAN BLVD, WINTER PARK 32792

Inspection Date: 12/17/2021 Inspection Number: 1533691 Inspection Type: Complaint Full Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: MONTGOMERY, DOREEN

Violation Code Observation Violation Citation

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Boiler room 3 (1) certificate expired 2/10/18
 Boiler room 2 (1) certificate expired 2/10/18
 Boiler room 5 (1) certificate expired 2/10/18
 Boiler room 4 (1) certificate expired 2/10/18
 Boiler room 1 (1) certificate expired 2/10/18

5 boilers no certificates - From follow-up inspection 2021-12-17: **Time Extended**

08-01-4 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-03-4 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5804539 LA QUINTA INN ORLANDO AIRPORT WEST #642
 License Type: Motel 7931 DAETWYLER DR, ORLANDO 32812

Inspection Date: 12/17/2021 Inspection Number: 1219491 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LINDSAY, SHARON

Violation Code Observation Violation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only./ trouble and supervisory. **Repeat Violation**

04-01-4 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5809006 EXTENDED STAY AMERICA #9809
 License Type: Hotel 8687 COMMODITY CIR, ORLANDO 32819

Inspection Date: 12/17/2021 Inspection Number: 1159695 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: LUI, SUK HAN

Violation Code Observation Violation Citation

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2021-12-17: **Time Extended**

08-01-4 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811295 ANCORA APARTMENTS
 License Type: Apartment 10107 ANCORA CIR, ORLANDO 32821

Inspection Date: 12/16/2021 Inspection Number: 1524709 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: NIEVES, RAFAEL

Violation Code Observation Violation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
 Observed at alarm panel located in leasing office.

04-01-4 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5805932 INTOWN SUITES ORLANDO SOUTH LLC
 License Type: Hotel 1951 CENTRAL FLORIDA PKWY, ORLANDO 32837

Inspection Date: 12/17/2021 Inspection Number: 1160983 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: ALVIS, DAVID

Violation Code Observation Violation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

04-01-4 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811098

HERITAGE ON MILLENIA APARTMENTS

License Type: Apartment

3757 MILLENIA BLVD, ORLANDO 32839

Inspection Date: 12/16/2021

Inspection Number: 1521544

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PASIECKI, VICTORIA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
At building 4847, 3763 and 3775

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5913608

MAINGATE VILLAGE LLC

License Type: Apartment

2851 MAINGATE CIR, KISSIMMEE 34747

Inspection Date: 12/14/2021

Inspection Number: 1524885

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6005201

OHIO STREET APARTMENTS LLC

License Type: Apartment

2787 OHIO ST, WEST PALM BEACH 33406

Inspection Date: 12/14/2021

Inspection Number: 1517509

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MONTILLA, NATHALIE

Violation Code

Observation

Violation Citation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Located in between apartments 2 and 3

01-02-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6007118

1600 N FEDERAL HWY STE 112, DELRAY BEACH 33483

License Type: Motel

Inspection Date: 12/17/2021

Inspection Number: 1217853

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation Code

Observation

Violation Citation

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. Observed stored inside storage room out south side of property

02-04-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6300723

COZY COURT MOTEL

License Type: Motel

407 WOODLAND AVE, LAKE LAND 33801

Inspection Date: 12/16/2021

Inspection Number: 1217953

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: POWELL, DAVID

Violation Code

Observation

Violation Citation

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Unable to test functioning of hearing impaired device. The test button does not function.

05-02-5

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6900076

FLORIDA HOTEL

License Type: Hotel

500 S OAK AVE, SANFORD 327711880

Inspection Date: 12/15/2021

Inspection Number: 1161237

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Memory light.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406495

HOLIDAY INN DAYTONA BEACH LPGA

License Type: Hotel

137 AUTOMALL CIR, DAYTONA BEACH 32124

Inspection Date: 12/13/2021

Inspection Number: 1162202

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: COREY, DEREK

Violation Code

Observation

Violation Citation

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
System trouble and system silence - From follow-up inspection 2021-11-10:
Time Extended - From follow-up inspection 2021-12-13:

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Walton County

License Number: 7600053

ADAMS MOTEL

License Type: Motel

545 US 90 W, DEFUNIAK SPRINGS 32433

Inspection Date: 12/17/2021

Inspection Number: 1219197

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SHANKLIN, CYNTHIA

Violation CodeObservationViolation Citation

Frayed electrical wire(s). For reporting purposes only.
Frayed wiring hanging from ceiling on exterior left side of office.

07-02-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7600142

DEFUNIAK MOTEL

License Type: Motel

1304 NELSON AVE/HWY 90, DEFUNIAK SPGS 32434

Inspection Date: 12/16/2021

Inspection Number: 1219374

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SHANKLIN, CYNTHIA

Violation CodeObservationViolation Citation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Inside laundry room.

01-02-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-02-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7600355

SUNDOWN INN

License Type: Motel

1295 US HIGHWAY 331 S, DEFUNIAK SPRINGS 32435

Inspection Date: 12/15/2021

Inspection Number: 1217448

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SHANKLIN, CYNTHIA

Violation CodeObservationViolation Citation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
3 fire extinguishers in red near rooms 210,111 and 103.

01-02-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.