

Brevard County

License Number: 1501012

COCOA AFFORDABLE LIVING CENTER

License Type: Motel

900 FRIDAY RD, COCOA 32926

Inspection Date: 12/22/2021

Inspection Number: 1218865

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: FRANZ, LINDA

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. ****Repeat Violation**** ****Admin Complaint****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1610363

GOLDEN SUN PROPERTIES LLC

License Type: Apartment

3741 SW 60 TERR, DAVIE 33314

Inspection Date: 12/22/2021

Inspection Number: 1528988

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BARTON, GEOFFREY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Extinguisher on lower level.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2309662

FLORIDA CITY RENTAL LLC

License Type: Apartment

567 - 575 W PALM DR, FLORIDA CITY 33034

Inspection Date: 12/20/2021

Inspection Number: 1526390

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed portable fire extinguisher locked in a box located at second floor. **Warning**

01-06-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329969

JORGE A LOPEZ

License Type: Apartment

13350 ASWAN RD, OPA-LOCKA 33054

Inspection Date: 12/21/2021

Inspection Number: 1524150

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SUAREZ, LEOPOLDO

Violation CodeObservationViolation Citation

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. On first floor and second floor. **Repeat Violation**

01-03-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2300309

SHIRLEY MAE APARTMENTS

License Type: Apartment

1235 WILMINGTON ST, OPA LOCKA 330543647

Inspection Date: 12/20/2021

Inspection Number: 1513206

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: SUAREZ, LEOPOLDO

Violation CodeObservationViolation Citation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. No breaking device.

01-06-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329489 AC & ELEMENT HOTEL BRICKELL MIAMI
 License Type: Hotel 115 SW 8 ST, MIAMI 33130

Inspection Date: 12/20/2021 Inspection Number: 1163624 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	<p>No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.</p> <p>Observed 3 boilers max input 700, 000 btu water temperature 210&deg;f, located on roof. 3 water heaters located on 5th floor.</p>	<p>61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

License Number: 2330310 1134 APT LLC
 License Type: Apartment 1134 SW 4 ST, MIAMI 33130

Inspection Date: 12/17/2021 Inspection Number: 1524519 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: CABANAS, NATALIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	<p>Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.</p> <p>Observed fire extinguisher on third floor missing breaking device.</p>	<p>509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
04-01-4		<p>509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

Dade County

License Number: 2329207 SPRINGHILL SUITES BY MARRIOTT
 License Type: Hotel 1311 NW 10TH AVE, MIAMI 33136

Inspection Date: 12/21/2021 Inspection Number: 1161614 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. By the front desk. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2313243 8315 MIAMI COURT LLC
 License Type: Apartment 8315 NE MIAMI CT, MIAMI 33138

Inspection Date: 12/20/2021 Inspection Number: 1529041 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SEYBA, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Located on ground level next to washer/dryer. Also observed extinguisher on second floor in recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2304985 1024- 1026 PENN LLC
 License Type: Apartment 1024 26 PENNSYLVANIA AVE, MIAMI BEACH 33139

Inspection Date: 12/21/2021 Inspection Number: 1527780 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed fire extinguisher in rear of building on first floor missing breaking device.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2307581 951 JEFFERSON AVE
 License Type: Apartment 951 JEFFERSON AVE, MIAMI BEACH 33139

Inspection Date: 12/20/2021 Inspection Number: 1521659 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: WILLIAMS, ALFREDA

Violation Code Observation Violation Citation

01-05-4
 Observation: Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
 Observed no breaking device at fire extinguisher at 955 entrance
 Violation Citation: 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2324541 THE FRITZ
 License Type: Hotel 524 OCEAN DR, MIAMI BEACH 33139

Inspection Date: 12/21/2021 Inspection Number: 1163862 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: WILLIAMS, ALFREDA

Violation Code Observation Violation Citation

01-05-4
 Observation: Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
 Observed fire extinguisher on roof near pool area missing breaking device.
 Violation Citation: 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-03-4
 Violation Citation: 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329240 RIVIERA LOFTS HOTEL
 License Type: Hotel 318 20 ST, MIAMI BEACH 33139

Inspection Date: 12/21/2021 Inspection Number: 1163865 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DELAMATA, JORGE

Violation Code Observation Violation Citation

04-01-4
 Observation: Trouble/alarm light illuminated on the fire alarm control panel located behind front desk. For reporting purposes only.
 Violation Citation: 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2314861 SHERATON MIAMI AIRPORT HOTEL & EXECUTIVE MEETING CENTER
 License Type: Hotel 3900 NW 21 ST, MIAMI 33142

Inspection Date: 12/20/2021 Inspection Number: 1163577 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: PRIETO, EDGAR

Violation Code Observation Violation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Located at the front desk. **Repeat Violation**

04-01-4 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2302043 CONCORD GDN APTS VIL B
 License Type: Apartment 3500 SW 112 AVE, MIAMI 331653460

Inspection Date: 12/17/2021 Inspection Number: 1529867 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DELAMATA, JORGE

Violation Code Observation Violation Citation

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
 Observed fire extinguisher located inside meter room not having a breaking device.

01-05-4 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2325310 BIRD ROAD CONDO
 License Type: Apartment 3945 SW 89 AVE, MIAMI 331655477

Inspection Date: 12/22/2021 Inspection Number: 1527604 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ELDER, AUDREY

Violation Code Observation Violation Citation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
 Located near unit 203.

01-02-4 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2327833

MIAMI AIRPORT WEST/DORAL TOWNEPLACE SUITES

License Type: Hotel

10505 NW 36 ST, MIAMI 33178

Inspection Date: 12/20/2021

Inspection Number: 1162524

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CURRAS, YANLEE

Violation Code

Observation

Violation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3902886

OAKWOOD TRACE APARTMENTS

License Type: Apartment

307 ELIZABETH ST, BRANDON 33511

Inspection Date: 12/22/2021

Inspection Number: 1525865

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MOULDER, BRITTANY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Observed at unit 101

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3900634

VALUE LODGE BUSCH GARDENS

License Type: Motel

210 E FOWLER AVE, TAMPA 33612

Inspection Date: 12/21/2021

Inspection Number: 1221978

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: REGAS, ANTHONY

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3902549 PALM AVENUE APARTMENTS
 License Type: Apartment 10610 N 30 ST, TAMPA 33612

Inspection Date: 12/21/2021 Inspection Number: 1533716 Inspection Type: Complaint Full Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: EHLERS, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Building 39 unit C. - From follow-up inspection 2021-12-10: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-03-4		509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-03-4		509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5603607

DESTIN APARTMENTS

License Type: Apartment

100 CALHOUN AVE, DESTIN 32541

Inspection Date: 12/22/2021

Inspection Number: 1531891

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: STEINMAN, MARC

Violation CodeObservationViolation Citation

Charcoal BBQ grill observed on second floor covered exterior balcony.
Unit 202
For reporting purposes only.

02-07-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5603602

CORVET APTS

License Type: Apartment

406- 408-410 CORVET ST, FORT WALTON BEACH 32548

Inspection Date: 12/22/2021

Inspection Number: 1523231

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ADAMSON, ROBERT

Violation CodeObservationViolation Citation

Damaged electrical wire(s). For reporting purposes only.
Low hanging wires connected from outside apartment F to utility pole close to street. **Repeat Violation**

07-01-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5601686

RIVIERA RIDGE TOWNHOMES

License Type: Apartment

500 KELLY MILL RD, VALPARAISO 32580

Inspection Date: 12/22/2021

Inspection Number: 1524088

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: STEINMAN, MARC

Violation CodeObservationViolation Citation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Between units 153-152

01-02-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okeechobee County

License Number: 5700631

OAKS AT SHANNON'S CROSSING

License Type: Apartment

833 HWY 441 SE, OKEECHOBEE 34974

Inspection Date: 12/20/2021

Inspection Number: 1516173

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JACKS, ALBERT

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge, at picnic area. Operator informed maintenance to get recharged. For reporting purposes only ****Corrective Action Taken****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5801635

VACATION LODGE

License Type: Motel

720 S ORANGE BLOSSOM TRL, ORLANDO 32805-3144

Inspection Date: 12/21/2021

Inspection Number: 1218824

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BUCKNER, ELLIOT

Violation Code

Observation

Violation Citation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. ****Repeat Violation****

08-01-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5805932

INTOWN SUITES ORLANDO SOUTH LLC

License Type: Hotel

1951 CENTRAL FLORIDA PKWY, ORLANDO 32837

Inspection Date: 12/20/2021

Inspection Number: 1160983

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back - Complied

Inspector Name: ALVIS, DAVID

Violation Code

Observation

Violation Citation

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2021-12-20: Time extended until next unannounced inspection ****Time Extended****

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900225

SERALAGO HOTEL AND SUITES MAINGATE EAST

License Type: Hotel

5678 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 12/20/2021

Inspection Number: 1163602

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FERTIL, SYLVERST

Violation Code

Observation

Violation Citation

Boiler certificate or insurance inspector's boiler report expired for multiple boilers. For reporting purposes only. **Repeat Violation**

08-01-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900879

THE GRAND ORLANDO RESORT AT CELEBRATION

License Type: Hotel

2900 PKWY BLVD, KISSIMMEE 34747

Inspection Date: 12/20/2021

Inspection Number: 1163860

Inspection Type: Complaint Partial

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

04-01-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5912070

GRAND HOTEL KISSIMMEE

License Type: Hotel

3104 PARKWAY BLVD, KISSIMMEE 34747

Inspection Date: 12/20/2021

Inspection Number: 1161508

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6007320 HOLIDAY INN PALM BEACH- CONFERENCE CENTER
 License Type: Hotel 1301 BELVEDERE RD, WEST PALM BEACH 33405

Inspection Date: 12/21/2021 Inspection Number: 1163861 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SINGH, GAJENDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired on 05/09/2021	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6005868 WYNDHAM GARDEN HOTEL - BOCA RATON
 License Type: Motel 1950 GLADES RD, BOCA RATON 33431

Inspection Date: 12/22/2021 Inspection Number: 1220422 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CUDEMOS, HAIDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 12.11.2021.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6007675

HILTON SUITE HOTEL

License Type: Hotel

7920 GLADES RD, BOCA RATON 33434

Inspection Date: 12/22/2021

Inspection Number: 1162477

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CUDEMOS, HAIDA

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 05-23-2021.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6100019

CHAMPION INN

License Type: Motel

1131 US HWY 19, HOLIDAY 34691

Inspection Date: 12/22/2021

Inspection Number: 1218974

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BENEDICT, TRACY

Violation Code

Observation

Violation Citation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
All fire extinguishers

01-02-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6201702

HILTON GARDEN INN

License Type: Motel

6100 GULF BLVD, ST PETE BEACH 33706-3714

Inspection Date: 12/20/2021

Inspection Number: 1219307

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAY-WALKER, LISA

Violation Code

Observation

Violation Citation

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. 4 Intellihot 499,999 btu insta heat hot water boilers observed.

08-03-4

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6300438

TIGER VILLA MOTEL

License Type: Motel

6000 NEW TAMPA HWY, LAKE LAND 33815

Inspection Date: 12/21/2021

Inspection Number: 1218316

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: POWELL, DAVID

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Hearing impaired device sounds but lacks flashing light.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6309178

STREAMSONG RESORT

License Type: Hotel

1000 STREAMSONG DR, STREAMSONG 33834

Inspection Date: 12/20/2021

Inspection Number: 1159625

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITE, CHERYL

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Putnam County

License Number: 6400067

ECONOMY INN

License Type: Motel

257 N HWY 17, PALATKA 32177

Inspection Date: 12/21/2021

Inspection Number: 1217818

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BIAVA, GRANT

Violation Code

Observation

Violation Citation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
In water heater shed behind two story building.

01-02-4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-07-4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6804811

AMFP IV SAGE PALMER RANCH LLC

License Type: Apartment

12501 HONORE AVE, SARASOTA 34238

Inspection Date: 12/21/2021

Inspection Number: 1520202

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: CATTLEY, RAYMOND

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light on Honeywell Fire System control panel.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6900381

OPAL HOTEL & SUITES

License Type: Motel

230 W SR 436, ALTAMONTE SPRINGS 32714

Inspection Date: 12/20/2021

Inspection Number: 1217714

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MARTIN, LESLIE

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6600214

MAYFLOWER SIX APARTMENTS INC

License Type: Apartment

1017 MAYFLOWER RD, FORT PIERCE 34950

Inspection Date: 12/22/2021

Inspection Number: 1521028

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HARROD, JESSICA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Top floor

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406493

LAQUINTA INN & SUITES

License Type: Hotel

1791 DUNLAWTON AVE, PORT ORANGE 32127-4737

Inspection Date: 12/20/2021

Inspection Number: 1160281

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.