

**Broward County**

License Number: 1608996

MIRAMAR GARDENS LLC

License Type: Apartment

6024 SW 26 ST, MIRAMAR 33023

Inspection Date: 02/22/2022

Inspection Number: 1516912

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GANPAT, INDAR

Violation Code

Observation

Violation Citation

01-01-4      Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.  
Next to unit 207 \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1603577

HARRIS MOTELS

License Type: Motel

5724 PEMBROKE RD, WEST PARK 33023-2338

Inspection Date: 02/22/2022

Inspection Number: 1221085

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GANPAT, INDAR

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to room #2.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1620905

THE DALMAR FORT LAUDERDALE

License Type: Hotel

299 N. FEDERAL HIGHWAY, FORT LAUDERDALE 33301

Inspection Date: 02/21/2022

Inspection Number: 1163872

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation Code    Observation

Violation Citation

04-01-4            Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1620906

ELEMENT FORT LAUDERDALE

License Type: Hotel

299 N FEDERAL HWY, FORT LAUDERDALE 33301

Inspection Date: 02/21/2022

Inspection Number: 1163874

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation Code    Observation

Violation Citation

04-01-4            Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

---

License Number: 1620894

CONRAD FORT LAUDERDALE BEACH

License Type: Hotel

551 N FORT LAUDERDALE BEACH BLVD, FORT LAUDERDALE 33304

**Broward County**

Inspection Date: 02/24/2022

Inspection Number: 1162460

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation CodeObservationViolation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Inspector will email inspection report to Fire Marshall for review. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1613206

BEST WESTERN FT. LAUDERDALE I-95

License Type: Hotel

4800 POWERLINE ROAD, FORT LAUDERDALE 33309

Inspection Date: 02/23/2022

Inspection Number: 1163461

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRAY, ANTHONY

Violation Code    Observation

Violation Citation

08-01-4    Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Observed boiler certification expired on 12/21/2017

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1607221

FORT LAUDERDALE GRAND HOTEL

License Type: Hotel

4900 POWERLINE ROAD, OAKLAND PARK 33309

Inspection Date: 02/25/2022

Inspection Number: 1164187

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROGERS, VERNEL

Violation Code    Observation

Violation Citation

08-01-4            Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.10/24/2021.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Broward County**

License Number: 1602591

PLANTATION INN

License Type: Motel

375 N ST RD 7, PLANTATION 33317

Inspection Date: 02/23/2022

Inspection Number: 1222385

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: NEALY, VALENCIA

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.  
-Observed Fire extinguisher removed, 2nd level corridor across from maintenance room and Fire extinguisher removed, 1st level corridor across from elevator room

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Collier County**

License Number: 2102695

HOLIDAY INN EXPRESS &amp; SUITES NAPLES DOWNTOWN 5TH AVENUE

License Type: Hotel

1785 5 AVE S, NAPLES 34102

Inspection Date: 02/21/2022

Inspection Number: 1162420

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: DILLON, TIMOTHY

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed no proof of boiler certificate for the hotel. Operator supplied before the end of the inspection. \*\*Corrected On-Site\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2309610

9TH STREET HOMESTEAD LLC

License Type: Apartment

190 NW 9 ST, HOMESTEAD 33030

Inspection Date: 02/24/2022

Inspection Number: 1524384

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed portable fire extinguisher missing at unit 180.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed a portable fire extinguisher locked in a box with no means of access between 851 and 853.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2308769

HOLIDAY MOTEL

License Type: Motel

1405 N KROME AVE, FLORIDA CITY 33034-2431

Inspection Date: 02/24/2022

Inspection Number: 1221784

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LODENQUAI, BARRINGTON

Violation Code    Observation

Violation Citation

01-03-4      Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.  
Observed between rooms 103 and 104.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2314576

COUNTRY LODGE

License Type: Motel

651 N KROME AVE, FLORIDA CITY 330343419

Inspection Date: 02/24/2022

Inspection Number: 1221750

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: LODENQUAI, BARRINGTON

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
Observed trouble light illuminated.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2329374

TOWNEPLACE SUITES MIAMI AIRPORT

License Type: Hotel

4021 NW 11TH ST, MIAMI 33126

Inspection Date: 02/25/2022

Inspection Number: 1161085

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: PRIETO, EDGAR

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\*** - From follow-up inspection 2022-02-25: During the time of the callback inspection observed trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Time Extended\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2330237

THE LUXE MIAMI

License Type: Apartment

971 W FLAGLER ST, MIAMI 33130

Inspection Date: 02/25/2022

Inspection Number: 1526663

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CRUZ, EDGAR

Violation Code

Observation

Violation Citation

04-01-4      Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2329386

ALOFT CORAL GABLES

License Type: Hotel

2524 LE JEUNE RD, CORAL GABLES 33134

Inspection Date: 02/23/2022

Inspection Number: 1162295

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: GONZALEZ, ALEJANDRO

Violation Code    Observation

Violation Citation

08-01-4            Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2301749

LITTLE HAVANA - 1444 SW 5TH ST LLC

License Type: Apartment

1444 SW 5TH STREET, MIAMI 33135

Inspection Date: 02/25/2022

Inspection Number: 1527894

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: ORDONEZ, CATALINA

Violation CodeObservationViolation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only. At the time of the inspection did not observed visible fire extinguishers on premises. Observed a sign at the entrance of the building stating that the fire extinguishers are inside the apts.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

---

License Number: 2328473

SILVA APTS

License Type: Apartment

1434 SW 2 ST, MIAMI 33135

Inspection Date: 02/23/2022

Inspection Number: 1515834

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: ORDONEZ, CATALINA

Violation CodeObservationViolation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only. Observed 2 fire extinguishers removed by units 2 and 5.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2307109

WEST GATE APARTMENTS

License Type: Apartment

1445 WEST AVE, MIAMI BEACH 33139

Inspection Date: 02/25/2022

Inspection Number: 1528487

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: ELDER, AUDREY

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.  
Observed no breaking device provided near unit 6.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2328176

TOWNHOUSE HOTEL

License Type: Hotel

150 20 ST, MIAMI BEACH 33139

Inspection Date: 02/25/2022

Inspection Number: 1159892

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ELDER, AUDREY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

---

License Number: 2329100

THE SETAI HOTEL

License Type: Hotel

2001 COLLINS AVE, MIAMI BEACH 33139

**Dade County**

Inspection Date: 02/21/2022

Inspection Number: 1162662

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: ELDER, AUDREY

Violation CodeObservationViolation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed 4 boiler certificates FL096428; FL096429; FL096429; FL096430; FL131411 all expired on 03-01-2019.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2307463

MARSAE APTS

License Type: Apartment

1750 MARSAILLES DR, MIAMI BEACH 331413526

Inspection Date: 02/22/2022

Inspection Number: 1518080

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher by unit 2.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2307644

NORMANDY ISLE APTS

License Type: Apartment

145 N SHORE DR APT 6, MIAMI BEACH 331413923

Inspection Date: 02/24/2022

Inspection Number: 1522745

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PRIETO, VICENTE

Violation Code

Observation

Violation Citation

01-06-4      Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device in fire extinguisher box, building left alley

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329358

PROFESSIONAL MANAGEMENT INC

License Type: Apartment

3650 NW 36TH STREET, MIAMI 33142

Inspection Date: 02/25/2022

Inspection Number: 1513845

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: UNZAGA, MILADYS

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher located on the parking lot , on the right side.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

---

License Number: 2330650

1575 LIBERTY CITY

License Type: Apartment

1575 NW 59 ST, MIAMI 33142

Inspection Date: 02/24/2022

Inspection Number: 1532633

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BROWN, JARON

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
Observed fire extinguisher next to unit 4 in need of a recharge.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2302168

8067 APARTMENTS LLC

License Type: Apartment

8067 SW 73 AVE, MIAMI 33143

Inspection Date: 12/29/2021

Inspection Number: 1519196

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PICO, JORGE

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
Observed the fire extinguisher located on the third floor, in front of Apartment # 26 in need of recharge.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2310421

IGAL MIAMI LLC

License Type: Apartment

2285 NE 172 ST, NORTH MIAMI BEACH 33160

Inspection Date: 02/22/2022

Inspection Number: 1534352

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: TAYLOR, JOHN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2304103

WELLINGTON MANOR APARTMENTS LLC

License Type: Apartment

10805 KENDALL DR, MIAMI 33176

Inspection Date: 02/22/2022

Inspection Number: 1525578

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: ORDONEZ, CATALINA

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2022-02-22: Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. \*\*Time Extended\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2613239

REDDY RENTAL

License Type: Apartment

201 &amp; 211 N 9 ST, JACKSONVILLE BEACH 32250

Inspection Date: 02/21/2022

Inspection Number: 1530770

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: GONZALEZ, MAYRA

Violation CodeObservationViolation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only.  
15 lbs propane tanks stored under stairwell across from apartment #2

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Escambia County**

License Number: 2702303

CLARION INN

License Type: Motel

6919 PENSACOLA BLVD, PENSACOLA 32505

Inspection Date: 02/21/2022

Inspection Number: 1222312

Inspection Type: Complaint Partial

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HATLER, MATTHEW

Violation Code

Observation

Violation Citation

04-02-4 No smoke detector provided in guest room/unit. For reporting purposes only.  
Room 211 no smoke alarm.

509.215(1) and (2) and 509.032(2)(d) FS Reporting:  
509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Hillsborough County**

License Number: 3910982

RAMADA WESTSHORE TAMPA AIRPORT/ROYAL ORCHID RESTAURANT & LOUNGE

License Type: Hotel

1200 N WESTSHORE BLVD, TAMPA 33607

Inspection Date: 02/23/2022

Inspection Number: 1164177

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: CANNELLA, MARK

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

---

License Number: 3905535

AMERICANA INN

License Type: Motel

321 E FLETCHER AVE, TAMPA 336123408

**Hillsborough County**

Inspection Date: 02/24/2022

Inspection Number: 1222384

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: SINGER, ROBERT

Violation CodeObservationViolation Citation

01-02-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Room 102 - From follow-up inspection 2022-02-24: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Room 102	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By room 238 no striker. No striker room 151.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By room 238 no striker. No striker room 151. - From follow-up inspection 2022-02-24: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Indian River County**

License Number: 4101330

STUDIO 6

License Type: Motel

8800 20 ST STE C, VERO BEACH 32966

Inspection Date: 02/24/2022

Inspection Number: 1222390

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SCHUCK, GREGORY

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Missing extinguisher between room 317 and 315

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Manatee County**

License Number: 5102928

M\*STAR BRADENTON

License Type: Motel

6511 14 ST W, BRADENTON 34207

Inspection Date: 02/23/2022

Inspection Number: 1217261

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: CATTLEY, RAYMOND

Violation Code

Observation

Violation Citation

04-01-4      Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Martin County**

License Number: 5300993

PIRATE'S COVE RESORT & MARINA

License Type: Hotel

4307 SE BAYVIEW ST, STUART 34997

Inspection Date: 02/25/2022

Inspection Number: 1162989

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code    Observation

Violation Citation

08-01-4            Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.8/26/2021#123323.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Monroe County**

License Number: 5403191

CASA MARINA A WALDORF ASTORIA RESORT

License Type: Hotel

1500 REYNOLDS ST, KEY WEST 33040

Inspection Date: 02/25/2022

Inspection Number: 1164154

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Orange County**

License Number: 5800833

HOLIDAY INN AND SUITES ACROSS FROM UNIVERSAL

License Type: Hotel

5905 KIRKMAN RD, ORLANDO 32819

Inspection Date: 02/24/2022

Inspection Number: 1162678

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOSTELNY, ROGER

Violation Code

Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

FL239134 exp 11/7/2020

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5809339

COMFORT INN INTERNATIONAL DRIVE

License Type: Motel

8134 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 02/22/2022

Inspection Number: 1222169

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Complied

Inspector Name: BACHOO, SAVITRI

Violation Code

Observation

Violation Citation

05-02-5 - From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.Room 115. - From follow-up inspection 2022-02-22: Room 115 is occupied. \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5811213

LAKE NONA WAVE HOTEL

License Type: Hotel

6100 WAVE HOTEL DR, ORLANDO 32827

Inspection Date: 02/25/2022

Inspection Number: 1163851

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: ALVIS, DAVID

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

License Number: 5900204

RAMADA PLAZA HOTEL &amp; INN GATEWAY

License Type: Motel

7470 HWY 192 W, KISSIMMEE 34747

Inspection Date: 02/23/2022

Inspection Number: 1217777

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: IRVEN, RYAN

Violation CodeObservationViolation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-01-24: \*\*Time Extended\*\* - From follow-up inspection 2022-02-23: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

---

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Hotel

7769 W. IRLO BRONSON MEMORIAL HWY., KISSIMMEE 34747

**Osceola County**

Inspection Date: 02/24/2022

Inspection Number: 1164181

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation CodeObservationViolation Citation

01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Missing striker by room 249 and 119	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

08-01-4      Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6209447

LA QUINTA INN &amp; SUITES - CLEARWATER

License Type: Motel

3301 ULMERTON RD, CLEARWATER 33762

Inspection Date: 02/24/2022

Inspection Number: 1222393

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: MAJEWSKI, JEREMY

Violation CodeObservationViolation Citation

04-01-4

alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
Behind front desk, red Alarm button blinking.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Pinellas County**

License Number: 6215669

BAYSIDE INN PINELLAS PARK - CLEARWATER

License Type: Hotel

9359 US HWY 19 N, PINELLAS PARK 33782

Inspection Date: 02/24/2022

Inspection Number: 1164175

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Admin. complaint recommended

Inspector Name: ZHANG, JACKY

Violation CodeObservationViolation Citation

01-01-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.  
By room 261. - From follow-up inspection 2022-02-24: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.  
By room 261.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Seminole County**

License Number: 6903999

EXTENDED STAY AMERICA #9513

License Type: Hotel

1437 RINEHART RD, SANFORD 32771

Inspection Date: 02/24/2022

Inspection Number: 1161723

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: ANGEL, TERRY

Violation Code    Observation

Violation Citation

08-03-4            No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Seminole County**

License Number: 6900968

CENTRAL FLORIDA HANDS

License Type: Apartment

1311 SANTA BARBARA DR, SANFORD 327735009

Inspection Date: 02/25/2022

Inspection Number: 1526931

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation Code

Observation

Violation Citation

01-03-4      Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. In the laundry room

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.