

Brevard County

License Number: 1500132

CAPE VIEW

License Type: Apartment

630 ADAMS AVE, CAPE CANAVERAL 32920

Inspection Date: 02/28/2022

Inspection Number: 1534470

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: HICKS, GEORGE RANDY

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Unit between 2 and 3.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1502163

HILTON COCOA BEACH OCEANFRONT RESORT

License Type: Hotel

1550 N ATLANTIC AVE, COCOA BEACH 32931

Brevard County

Inspection Date: 02/28/2022

Inspection Number: 1164184

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: HICKS, GEORGE RANDY

Violation Code ObservationViolation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 11/16/21.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

08-01-4 - From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 11/16/21. - From follow-up inspection 2022-02-28: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1600635

WASHINGTON APT

License Type: Apartment

6111 WASHINGTON ST, HOLLYWOOD 33023

Inspection Date: 03/01/2022

Inspection Number: 1520997

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: GANPAT, INDAR

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to storage room

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621024

EL JARDIN APARTMENTS

License Type: Apartment

7391 NW 35 ST, DAVIE 33024

Inspection Date: 03/04/2022

Inspection Number: 1518754

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MCKINNEY, JOHN

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
Observed at buildings 7371 and 7381 on NE 35th St and 7370 and 7380 on NW 37th St.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Observed at building 7390, 7391 NW 74th St fire extinguisher located behind locked door located under the staircase near unit 1 of each building.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620849

THE RITZ CARLTON FT LAUDERDALE

License Type: Hotel

1 N FT LAUDERDALE BEACH BLVD, FORT LAUDERDALE 33304

Inspection Date: 03/01/2022

Inspection Number: 1164188

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation Code Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Per operator boilers were inspected and establishment is awaiting current certificates.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621303

WILTON METROPOLITAN

License Type: Apartment

1220 NE 24 ST, WILTON MANORS 33305

Inspection Date: 03/01/2022

Inspection Number: 1528696

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BARTON, GEOFFREY

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

1) by door to unit 2405

2) opposite unit 3102

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1612730

HOLIDAY INN EXPRESS & SUITES

License Type: Hotel

1500 W COMMERCIAL BLVD, FORT LAUDERDALE 33309

Inspection Date: 02/28/2022

Inspection Number: 1162251

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRAY, ANTHONY

Violation Code Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Observed boilers certification expired 131823 Exp 9/6/2021 131824 Exp 9/6/2021

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620747

EXTENDED STAY AMERICA SUITES #869

License Type: Hotel

5851 N ANDREWS AVE EXT, FORT LAUDERDALE 33309

Broward County

Inspection Date: 03/02/2022

Inspection Number: 1160823

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: GRAY, ANTHONY

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Observed 131659 exp 1/17/2020 131658 exp 1/17/2020 - From follow-up inspection 2022-03-02: Operator awaiting the new certificate.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certification expired on 1/17/2020 **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2317872

DON SHULA'S HOTEL

License Type: Hotel

6842 MAIN ST, MIAMI LAKES 330142074

Inspection Date: 03/03/2022

Inspection Number: 1163269

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VILCHEZ, NABEL

Violation Code Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2327185

REMINGTON APARTMENTS

License Type: Apartment

155 NW 10 ST, HOMESTEAD 33030

Inspection Date: 02/28/2022

Inspection Number: 1529972

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. One located first floor between unit 1 and 2. - From follow-up inspection 2022-02-28: Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. One located first floor between unit 1 and 2. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2327186

REMINGTON APARTMENTS

License Type: Apartment

30100 OLD DIXIE HWY, HOMESTEAD 33030

Inspection Date: 02/28/2022

Inspection Number: 1525281

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

01-06-4

- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed portable fire extinguisher locked located between unit 20 and 21. One located between unit 27 and 28. One located between 5 and 3. - From follow-up inspection 2022-02-28: Observed portable fire extinguisher locked located between unit 20 and 21. One located between unit 27 and 28. One located between 5 and 3. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2320673

BUDGET HOST INN

License Type: Motel

815 N KROME AVE, FLORIDA CITY 33034

Inspection Date: 02/28/2022

Inspection Number: 1221848

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: LODENQUAI, BARRINGTON

Violation Code

Observation

Violation Citation

01-03-4 Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
Observed between rooms 122 and 123, rooms 116 and 117.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328082

DE ARMAS APARTMENT

License Type: Apartment

831 NW 3 ST, MIAMI 33128

Inspection Date: 03/03/2022

Inspection Number: 1515454

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: GOMEZ-SANCHEZ, NELLY

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed fire extinguisher on first floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329470

HOTEL INDIGO MIAMI BRICKELL / ATWELL SUITES MIAMI BRICKELL

License Type: Hotel

145 SW 11 ST, MIAMI 33130

Inspection Date: 03/03/2022

Inspection Number: 1162410

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: CABANAS, NATALIE

Violation CodeObservationViolation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

At the time of the inspection observed two boilers with 700,000 btu. No boiler certificate provided, establishment is still in process to get boilers certified. -

From follow-up inspection 2022-03-03: No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

At the time of the inspection observed two boilers with 700,000 btu. No boiler certificate provided, establishment is still in process to get boilers certified. **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2300698

NATHALIE COURTS APARTMENTS

License Type: Apartment

1521 SW 6 STREET, MIAMI 33135

Inspection Date: 03/02/2022

Inspection Number: 1525598

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330448

VQ EVERGLADES PROPERTIES

License Type: Apartment

1501 SW 6 ST, MIAMI 33135

Inspection Date: 03/02/2022

Inspection Number: 1515285

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2315468

ALY CORP

License Type: Apartment

2015 SW 6 ST, MIAMI 331355801

Inspection Date: 02/23/2022

Inspection Number: 1525145

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. 1st floor and 2nd floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328390

SAGAMORE MIAMI BEACH

License Type: Hotel

1671 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 02/28/2022

Inspection Number: 1160238

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: ELDER, AUDREY

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Observed boiler certificates expired on 07-15-2021. - From follow-up inspection 2022-02-28: Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Observed boiler certificates expired on 07-15-2021. ****Time Extended****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329272

GRAND FLAMINGO CENTER TOWER

License Type: Apartment

1504 BAY RD #1, MIAMI BEACH 33139

Inspection Date: 02/28/2022

Inspection Number: 1528877

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: ELDER, AUDREY

Violation Code

Observation

Violation Citation

08-04-4 - From initial inspection : Boiler certificate not posted in the boiler room. For reporting purposes only. - From follow-up inspection 2022-02-28: Boiler certificate not posted in the boiler room. **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330582

YINDCO GROUP LLC

License Type: Apartment

7724 HARDING AVE, MIAMI BEACH 33141

Inspection Date: 02/28/2022

Inspection Number: 1517702

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

01-06-4

- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device in fire extinguisher box by unit 9. ****Repeat Violation**** - From follow-up inspection 2022-02-28: Observed no breaking device in fire extinguisher box by unit 9. ****Admin Complaint****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329451

RAMADA PLAZA MARCO POLO BEACH RESORT

License Type: Hotel

19201 COLLINS AVENUE, SUNNY ISLES BEACH 33160

Dade County

Inspection Date: 02/28/2022

Inspection Number: 1161821

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: TAYLOR, JOHN

Violation CodeObservationViolation Citation

03-05-4	- From initial inspection : Fire sprinkler head rusted. Located in room 409. For reporting purposes only. - From follow-up inspection 2022-02-28: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificates 134796 & 137117 expired as of 1/28/2022.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2303000

RIVER DEL MAR

License Type: Apartment

1949 NE 172 ST, NORTH MIAMI BEACH 33162

Inspection Date: 03/01/2022

Inspection Number: 1521026

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: STUBBS, CHRISTINE

Violation CodeObservationViolation Citation

04-06-4

Fire alarm control panel emitting an audible alarm. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2303389

ITSHAK AMOS & ILIANA AMOS APT

License Type: Apartment

1991 NE 172 ST, NORTH MIAMI BEACH 331623135

Inspection Date: 03/01/2022

Inspection Number: 1522885

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: STUBBS, CHRISTINE

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Observed the breaking device is missing from the fire extinguisher box next to
apartment #9.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2314566

HONEY SUCKLE APARTMENTS

License Type: Apartment

10710 SW 2 ST, SWEET WATER 33174

Inspection Date: 03/01/2022

Inspection Number: 1520882

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GOMEZ-SANCHEZ, NELLY

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed at front of apartment 1 fire extinguisher locked in a box, missing breaking device.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2325770

CAMDEN AVENTURA

License Type: Apartment

3100 NE 190 ST, AVENTURA 33180

Inspection Date: 02/25/2022

Inspection Number: 1534374

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: TAYLOR, JOHN

Violation CodeObservationViolation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.
Observed exposed wiring by exit gate near building 2975.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2326143

LA QUINTA INN AND SUITES MIAMI CUTLER BAY

License Type: Hotel

10821 CARIBBEAN BLVD, MIAMI 33189

Inspection Date: 03/04/2022

Inspection Number: 1163928

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SWIGERT, RICHARD

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Observed extinguisher with no braking device next to room 414.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2611854

OAK HAMMOCK APARTMENTS

License Type: Apartment

500 ACME ST, JACKSONVILLE 32211

Inspection Date: 03/01/2022

Inspection Number: 1533425

Inspection Type: Lodging-Licensing

Inspection Disposition: Call Back -

Inspector Name: THOMAS, PHILIP

Inspection

Extension given, pending

Violation Code

Observation

Violation Citation

12-04-4

- From initial inspection : High Priority - Balcony/starway/platform collapsed. Building 6 has collapsed landing between first and second floor. Entire landing has fallen 6 feet and is resting on ground. Stairs leading down from second floor end with 6 foot drop. Landing between 2 and 3 floor shows major stress. Area is marked off from bottom but inspector was able to walk up stairway on opposite side of building and cross over on second floor where roped off area had been removed. Operator stated movers are using the second floor to move current tenets. No movers were observed by inspector.
 Units on that side of building are 612 and 611 on third floor, 610 and 609 on second floor, 608 and 607 on first floor. Inspector recommends all units to be vacated. ****Warning**** - From follow-up inspection 2021-11-18: Tenets have been relocated on that side of building. All areas are clearly marked off with caution tape and fencing. Operator has started looking for repair options. ****Time Extended****
 - From follow-up inspection 2022-01-25: Situation is the same. Repairs have not started. Operator states building is empty with no occupants. ****Time Extended****
 - From follow-up inspection 2022-03-01: Operator states the city has cleared the way for construction to be started. ****Time Extended****

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

Escambia County

License Number: 2704018

NEW WORLD INN

License Type: Motel

600 S PALAFOX ST, PENSACOLA 32502

Inspection Date: 03/01/2022

Inspection Number: 1221687

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GARDNER, GREGORY

Violation CodeObservationViolation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
099673
04/25/2021 **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3911768

COURTYARD BY MARRIOTT

License Type: Hotel

102 E CASS ST, TAMPA 33602

Inspection Date: 02/28/2022

Inspection Number: 1164176

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: EHLERS, MICHAEL

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. No striker to access extinguisher. Outside room 504.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3906143

LA QUINTA INN AND SUITES

License Type: Motel

4811 US HWY 301 N, TAMPA 33610

Inspection Date: 02/28/2022

Inspection Number: 1222394

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: COLEMAN, TONYA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3911575

LA QUINTA INN AND SUITES TAMPA USF

License Type: Hotel

3701 E FOWLER AVE, TAMPA 33612

Inspection Date: 03/03/2022

Inspection Number: 1164115

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: CESAR, RACHEL

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Fire extinguisher on 3rd floor near laundry room locked in box. All fire extinguishers are locked on floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Room 422.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3905535

AMERICANA INN

License Type: Motel

321 E FLETCHER AVE, TAMPA 336123408

Inspection Date: 02/28/2022

Inspection Number: 1222384

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: SINGER, ROBERT

Violation Code

Observation

Violation Citation

01-06-4

- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By room 238 no striker. No striker room 151. - From follow-up inspection 2022-02-24: **Time Extended** - From follow-up inspection 2022-02-28: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5202265

CARLTON ARMS OF OCALA

License Type: Apartment

5001 SW 20 ST STE 100, OCALA 34474

Inspection Date: 03/01/2022

Inspection Number: 1527819

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GARNER, DHANIQUA

Violation CodeObservationViolation Citation

07-04-4

Electrical outlet damaged to indicate a malfunction. For reporting purposes only.
Exposed wiring and damage on exterior side of unit #6606. Cable wires are
exposed, black electrical covers in disrepair.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Nassau County

License Number: 5500837

OMNI AMELIA ISLAND RESORT

License Type: Hotel

41 BEACH LAGOON RD, FERNANDINA BEACH 32034

Inspection Date: 03/03/2022

Inspection Number: 1162388

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROZIER, TORRANCE

Violation Code Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only .
6 out of 9;expired

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5801808

CYPRESS LANDING APARTMENTS

License Type: Apartment

5942 WINEGARD RD, ORLANDO 328094865

Inspection Date: 03/02/2022

Inspection Number: 1518356

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PASIECKI, VICTORIA

Violation Code ObservationViolation Citation

04-06-4 Fire alarm control panel emitting an audible alarm. For reporting purposes only.
Next to apt B building 5939

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5913664

DAYS INN

License Type: Motel

4125 W VINE ST, KISSIMMEE 34741

Inspection Date: 02/28/2022

Inspection Number: 1219970

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: BORRERO, AUDREY

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only./ trouble at main fire panel - From follow-up inspection 2022-02-28: **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900225

SERALAGO HOTEL AND SUITES MAINGATE EAST

License Type: Hotel

5678 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 03/02/2022

Inspection Number: 1164204

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: BORRERO, AUDREY

Violation Code Observation

Violation Citation

08-03-4 No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
Per GM they are still waiting to receive the certificates.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900879

DELTA ORLANDO CELEBRATION RESORT

License Type: Hotel

2900 PARKWAY BLVD, KISSIMMEE 34747

Inspection Date: 03/04/2022

Inspection Number: 1164218

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: IRVEN, RYAN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5914876

VACATION VILLAGE AT PARKWAY OWNER'S ASSOCIATION INC

License Type: Vacation Rental - Condo

2949 ARABIAN NIGHTS BLVD, KISSIMMEE 34747

Inspection Date: 02/28/2022

Inspection Number: 1089413

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: IRVEN, RYAN

Violation CodeObservationViolation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Building 20 has 8 boilers and no boiler certificate. - From follow-up inspection 2022-02-28: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6009908

HOMING INN

License Type: Motel

2821 S FEDERAL HWY, BOYNTON BEACH 33435-7796

Inspection Date: 02/28/2022

Inspection Number: 1220271

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: PITRE, ASTRID

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to unit 207 and 202 in building C.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215804

TREASURE BAY RESORT & MARINA

License Type: Hotel

11125 GULF BLVD, TREASURE ISLAND 33706

Inspection Date: 03/04/2022

Inspection Number: 1164142

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HEFFNER, CHRISTOPHER

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
On fire panel in riser room. **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6209447

LA QUINTA INN & SUITES - CLEARWATER

License Type: Motel

3301 ULMERTON RD, CLEARWATER 33762

Inspection Date: 03/01/2022

Inspection Number: 1222393

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: MAJEWSKI, JEREMY

Violation CodeObservationViolation Citation

04-01-4

- From initial inspection : alarm light illuminated on the fire alarm control panel. For reporting purposes only. Behind front desk, red Alarm button blinking. - From follow-up inspection 2022-03-01: Alarm light still blinking **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215669

BAYSIDE INN PINELLAS PARK - CLEARWATER

License Type: Hotel

9359 US HWY 19 N, PINELLAS PARK 33782

Inspection Date: 03/04/2022

Inspection Number: 1164175

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: ZHANG, JACKY

Violation CodeObservationViolation Citation

01-01-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.

By room 261. - From follow-up inspection 2022-02-24: **Time Extended** -

From follow-up inspection 2022-03-04: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6804704

HOLIDAY INN EXPRESS & SUITES SARASOTA EAST/I-75

License Type: Hotel

5730 GANTT RD, SARASOTA 34233

Inspection Date: 03/02/2022

Inspection Number: 1163291

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: CATTLEY, RAYMOND

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light on main panel.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Suwannee County

License Number: 7100241

ROYAL INN

License Type: Motel

966 US 129 N, LIVE OAK 32064

Inspection Date: 03/03/2022

Inspection Number: 1222436

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Between room 203 and 202.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406510

FAIRFIELD INN & SUITES DAYTONA BEACH SPEEDWAY/AIRPORT

License Type: Hotel

1820 CHECKERED FLAG BLVD, DAYTONA BEACH 32114

Inspection Date: 02/28/2022

Inspection Number: 1160548

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: BRANNER, LISELOTTE

Violation Code

Observation

Violation Citation

04-01-4 - From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Duct detector shut down relay RTU 1 - From follow-up inspection 2022-02-28: Manager states getting a bid.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400060

SANDALS INN

License Type: Motel

133 S OCEAN AVE, DAYTONA BEACH 32118

Inspection Date: 03/02/2022

Inspection Number: 1221274

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code Observation

Violation Citation

02-04-4 Gas tank stored inside the building. For reporting purposes only.
 -gas lawnmower inside storage room underneath stairwell near entrance

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7405578

OSMANY MOTEL

License Type: Apartment

111 S GRANDVIEW APT 8, DAYTONA BEACH 32118

Inspection Date: 03/03/2022

Inspection Number: 1525526

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

12-04-4

High Priority - Balcony/platform in severe disrepair.

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

-Upstairs, platform in front of unit 3 at top of stairway is very loose when weight placed in locations near east end of balcony/platform.

-visible wood rot including some small gaps in platform currently covered by piece of wood. ****Warning****

Volusia County

License Number: 7401102

SAGE N SAND

License Type: Motel

3059 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 03/02/2022

Inspection Number: 1221129

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

02-08-4

Gas powered scooter stored under a stairwell. For reporting purposes only.

-front stairway near lobby **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406519

HAWAIIAN INN BEACH RESORT

License Type: Hotel

2301 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 02/28/2022

Inspection Number: 1163318

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code Observation

Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

 -operator states work in process with contractor

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400051

DAYS INN SPEEDWAY

License Type: Motel

2904 W INTL SPEEDWAY BLVD, DAYTONA BEACH 32124

Inspection Date: 03/02/2022

Inspection Number: 1217417

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: ANGEL, TERRY

Violation Code Observation

Violation Citation

08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2022-01-31: **Time Extended** - From follow-up inspection 2022-03-02:	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	---