

Bay County

License Number: 1302937

ECONOLOGDE

License Type: Motel

4411 W HWY 98, PANAMA CITY 324011024

Inspection Date: 03/21/2022

Inspection Number: 1220339

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: LYNN, NICKOLAS

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Fire extinguisher outside 212.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bay County

License Number: 1305340

RENTAL

License Type: Vacation Rental - Condo

8214 PALM COVE BLVD, PANAMA CITY BEACH 32408

Inspection Date: 03/21/2022

Inspection Number: 1089423

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation CodeObservationViolation Citation

04-05-4

No smoke detector provided in guest room/unit. For reporting purposes only.
Smoke detectors in bedrooms, no battery/ not hard wired.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1604705

ADAMS RENTAL

License Type: Apartment

1616 SW 11 ST, FORT LAUDERDALE 33312

Inspection Date: 03/23/2022

Inspection Number: 1516537

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BARTON, GEOFFREY

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
Extinguisher top of left stairway by door to unit 3.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1603352

SKY MOTEL

License Type: Motel

1531 SW 26 ST, FORT LAUDERDALE 33315-2214

Inspection Date: 03/23/2022

Inspection Number: 1221367

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BARTON, GEOFFREY

Violation Code

Observation

Violation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Beside door to unit 37. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1619117

EXTENDED STAY AMERICA SUITES #1561

License Type: Hotel

1450 SE 17 ST CSWY, FORT LAUDERDALE 33316

Broward County

Inspection Date: 03/23/2022

Inspection Number: 1163111

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection

Inspector Name: LONDONO, GLORIA

Completed - No Further Action

Violation CodeObservationViolation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 3/9/2022	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Charlotte County

License Number: 1801522

HOLIDAY INN EXPRESS

License Type: Hotel

24440 SANDHILL BLVD, PORT CHARLOTTE 33983

Inspection Date: 03/19/2022

Inspection Number: 1162132

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SAYED, MOHAMMED

Violation Code

Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. The operator is currently waiting to receive the boiler certificate.
Repeat Violation

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2304144

MIFE INVESTMENT GROUP

License Type: Apartment

950 W 3 AVE, HIALEAH 330103873

Inspection Date: 03/24/2022

Inspection Number: 1525175

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SANCHEZ, JAVIER

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By unit 3.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2312920

TODEL APARTMENTS

License Type: Apartment

1475 W 46 ST, HIALEAH 330127195

Inspection Date: 03/18/2022

Inspection Number: 1513265

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: LODENQUAI, BARRINGTON

Violation Code

Observation

Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed blinking red light on central fire panel, building A.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2312765

SUNSET BAY APTS

License Type: Apartment

4480 PALM AVE, HIALEAH 33013

Inspection Date: 03/21/2022

Inspection Number: 1515240

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: LODENQUAI, BARRINGTON

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Observed unit by apartment 211.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330392

ADA ANTIGUA NO 1 LLC

License Type: Apartment

129 NW 9 AVE, MIAMI 33128

Inspection Date: 03/15/2022

Inspection Number: 1520008

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: GOMEZ-SANCHEZ, NELLY

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no broken device on fire extinguisher on first floor next to apartments #2, Also on second floor next to apartment #6.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329329

EAST MIAMI

License Type: Hotel

788 BRICKELL PLAZA, MIAMI 33131

Inspection Date: 03/21/2022

Inspection Number: 1163390

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation Code

Observation

Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2301886

GRAND FLAMINGO NORTH TOWER

License Type: Apartment

1508 BAY RD #1, MIAMI BEACH 33139

Inspection Date: 03/24/2022

Inspection Number: 1528876

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ELDER, AUDREY

Violation Code

Observation

Violation Citation

08-03-4 No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
Observed 4 500,000 BTU boilers. No boiler certificates available.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2325175

HOTEL OCEAN

License Type: Hotel

1236 OCEAN DR, MIAMI BEACH 33139

Inspection Date: 03/22/2022

Inspection Number: 1163416

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILLIAMS, ALFREDA

Violation Code Observation

Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328823

GENEVA HOTEL

License Type: Hotel

1520 COLLINS AVENUE, MIAMI BEACH 33139

Inspection Date: 03/21/2022

Inspection Number: 1164273

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HODGE, KRISTEN

Violation Code

Observation

Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only located next to front desk lobby area.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329467

THE GOODTIME HOTEL

License Type: Hotel

601 WASHINGTON AVE, MIAMI BEACH 33139

Dade County

Inspection Date: 03/25/2022

Inspection Number: 1161780

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed boiler max input 499,000, water temperature 210f	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2302009

THE ALEXANDER HOTEL

License Type: Hotel

5225 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 03/24/2022

Inspection Number: 1160651

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PRIETO, VICENTE

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329399

DESIGN SUITES MIAMI BEACH

License Type: Hotel

5445 COLLINS AVE STE CU14, MIAMI BEACH 33140

Inspection Date: 03/23/2022

Inspection Number: 1161899

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: UNZAGA, MILADYS

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. The boilers were already inspected on 2/16/2022, but not available certificate. Boiler certificates expired on 2/19/2022.
"

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2305430

SOUTHWIND APTS

License Type: Apartment

2 S SHORE DR, MIAMI BEACH 33141

Inspection Date: 03/22/2022

Inspection Number: 1518997

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device in fire extinguisher box by units 16, 11, 10., 7 and 6.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328328

RITZ CARLTON HOTEL CO

License Type: Hotel

455 GRAND BAY DR, KEY BISCAYNE 33149

Inspection Date: 03/25/2022

Inspection Number: 1162493

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CABANAS, NATALIE

Violation Code

Observation

Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2308152

94TH ST BH UNITED LLC

License Type: Apartment

1025 94 ST, BAY HARBOR ISLANDS 33154

Inspection Date: 03/23/2022

Inspection Number: 1534652

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: PRIETO, VICENTE

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only. Observed in building 1025.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2327022

HOLIDAY INN MIAMI/DORAL AREA

License Type: Hotel

3255 NW 87 AVE, MIAMI 33172

Inspection Date: 03/21/2022

Inspection Number: 1162085

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ALVAREZ, MARGARET

Violation CodeObservationViolation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only. Observed expired boiler certificate posted Manager printed out current certificate and posted in boiler room **Corrected On-Site** **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2327881

STAYBRIDGE SUITES MIAMI/DORAL

License Type: Hotel

3265 NW 87 AVE, MIAMI 33172

Inspection Date: 03/22/2022

Inspection Number: 1162686

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ALVAREZ, MARGARET

Violation CodeObservationViolation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.
Observed expired certificate posted. Manager printed current boiler certificate and posted in boiler room **Corrected On-Site**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2324350

SUN POINT RENTALS

License Type: Apartment

11180 SW 107 ST, MIAMI 331768269

Inspection Date: 03/18/2022

Inspection Number: 1527561

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: ORDONEZ, CATALINA

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Fire extinguisher located by unit 305 and unit 109 in building 11180. Fire
extinguisher located by unit 102 in building 11190.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2324370

THE STRATFORD APARTMENTS

License Type: Apartment

9051 SW 122 AVE, MIAMI 33186

Inspection Date: 03/22/2022

Inspection Number: 1524886

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LODENQUAI, BARRINGTON

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed trouble light illuminated at building #1, as per operator technicians are presently addressing the problem.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2612439

EXTENDED STAY AMERICA

License Type: Hotel

8801 PERIMETER PARK BLVD, JACKSONVILLE 32216

Inspection Date: 03/22/2022

Inspection Number: 1164302

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: VILBRUN, JOSUE

Violation CodeObservationViolation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.
Two active boilers in boiler room but no certificate provided **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2609173

STAYABLE SUITES JACKSONVILLE

License Type: Motel

812 DUNN AVE, JACKSONVILLE 32218

Inspection Date: 03/21/2022

Inspection Number: 1164233

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: PERRY, DENNIS

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
Missing by unit 215.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable.
For reporting purposes only.
No smoke alarm present unit 302 interior hallway.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2608348

DAYS INN

License Type: Motel

8255 DIX ELLIS TRL, JACKSONVILLE 32256

Inspection Date: 03/24/2022

Inspection Number: 1222531

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: JEFFERS, MARY-BETH

Violation Code

Observation

Violation Citation

04-05-4	No smoke detector provided in guest room/unit. For reporting purposes only. Smoke detector in room #141 in disrepair. Operator not to rent room until repaired and re-inspected **Warning**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-04-4	Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Light switch in room #141 in disrepair. Room not to be rented until repaired and re-inspected **Warning**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2705813

MARGARITAVILLE BEACH HOTEL

License Type: Hotel

165 FORT PICKENS RD, PENSACOLA BEACH 32561

Inspection Date: 03/21/2022

Inspection Number: 1162398

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ALBRITTON, GREGORY

Violation Code Observation

Violation Citation

08-03-4 No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Flagler County

Flagler County

License Number: 2800590

FAIRFIELD INN & SUITES

License Type: Hotel

400 OLD KINGS RD, PALM COAST 32137

Flagler County

Inspection Date: 03/21/2022

Inspection Number: 1162924

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: HARTMANN, MICHELLE

Violation Code ObservationViolation Citation

05-02-5	<p>- From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. In room 415. **Repeat Violation** - From follow-up inspection 2022-03-21: ADA in room 407 has no audible alarm. Only flashing li</p>	<p>509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
08-01-4	<p>- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificates expired 12/17/21. - From follow-up inspection 2022-03-21: No Certificates is available. **Admin Complain</p>	<p>61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

Flagler County

08-04-4 - From initial inspection : Boiler certificate not posted in the boiler room. For reporting purposes only.
At the time of inspection boiler certification not posted in boiler room. Person in charge printed and posted during inspection. **Corrected On-Sit

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hernando County

License Number: 3700071

QUALITY INN & SUITES

License Type: Motel

30307 CORTEZ BLVD, BROOKSVILLE 34602

Inspection Date: 03/23/2022

Inspection Number: 1220472

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: COLE, GABRIELLE

Violation Code

Observation

Violation Citation

04-03-4

- From initial inspection : Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Smoke detector in room 100 appears to be disconnected. - From follow-up inspection 2022-03-23: Room 100 occupied.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913720

8014 TOMMY COURT APARTMENTS

License Type: Apartment

8014 TOMMY CT, TAMPA 33619

Inspection Date: 03/21/2022

Inspection Number: 1534681

Inspection Type: Lodging-Licensing

Inspection Disposition: Warning

Inspector Name: KLUSENDORF, JEANNE

Inspection

Issued

Violation CodeObservationViolation Citation

01-03-4

Observed: Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Building 8001
Priority: Reporting

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-01-4

Observed: Damaged electrical wire(s). For reporting purposes only. Electric panel meter by building 1029, hanging off the walls.
Priority: Reporting

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3912086

CFOC TAMPA FL LLC

License Type: Hotel

6800 WOODSTORK RD, TAMPA 33637

Inspection Date: 03/25/2022

Inspection Number: 1162581

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: REGAS, ANTHONY

Violation Code

Observation

Violation Citation

08-06-4

Combustibles stored in boiler room. For reporting purposes only. Observed a pressure washer stored in the boiler room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4600978

SANIBEL SUNSET BEACH RESORT

License Type: Motel

3287 W GULF DR, SANIBEL 33957

Inspection Date: 03/25/2022

Inspection Number: 1218790

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: GONDERMANN, FRANK

Violation CodeObservationViolation Citation

07-04-4

- From initial inspection : Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Exposed wires hanging from ceiling across from room B145 - From follow-up inspection 2022-02-18: **Time Extended** - From follow-up in

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5103312

DAYS INN

License Type: Motel

644 67 ST CIR E, BRADENTON 34208

Inspection Date: 03/25/2022

Inspection Number: 1222538

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: AUBIN, GARY

Violation CodeObservationViolation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.
Observed smoke detector broken in room 207.
Manager stated they have a new smoke detector ordered. **Corrective Action
Taken** **Warning**

509.215(1) and (2) and 509.032(2)(d) FS Reporting:
509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5105024

WATERLINE MARINA RESORT AND BEACH CLUB

License Type: Hotel

5325 MARINA DR, HOLMES BEACH 34217

Inspection Date: 03/24/2022

Inspection Number: 1161104

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: RICHENDOLLAR, SANDRA

Violation Code

Observation

Violation Citation

08-03-4 No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Proof of insurance provided.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5300030

DRIFTWOOD MOTEL OF JENSEN BEACH INC

License Type: Motel

4150 NE INDIAN RIVER DR, JENSEN BEACH 34957

Inspection Date: 03/21/2022

Inspection Number: 1221207

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation Code

Observation

Violation Citation

04-02-4 No smoke detector provided in guest room/unit. For reporting purposes only. Unit 1, missing in separate bedroom. **Corrected On-Site**

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400347

FISHER INN RESORT

License Type: Motel

84951 OVERSEAS HWY, ISLAMORADA 33036

Inspection Date: 03/24/2022

Inspection Number: 1222229

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: WHITEHURST, SCOTT

Violation Code Observation

Violation Citation

03-01-4	No fire sprinkler system installed in a transient lodging establishment three stories or more in height, or over 75 feet in height. For reporting purposes only.	509.215 and 509.032(2)(d) FS Reporting: 509.215 Any public lodging establishment, as defined in this chapter, which is of three stories or more, or over 75 feet in height shall be equipped with an automatic sprinkler system installed in compliance with the provisions prescribed in the National Fire Protection Association publication NFPA No. 13 "Standards for the Installation of Sprinkler Systems. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

Monroe County

License Number: 5402759

COURTYARD BY MARRIOTT

License Type: Hotel

3031 N ROOSEVELT BLVD, KEY WEST 33040

Inspection Date: 03/22/2022

Inspection Number: 1162459

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: VILCHEZ, NABEL

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5809219

SPRINGHILL SUITES

License Type: Hotel

8840 UNIVERSAL BLVD, ORLANDO 32819

Inspection Date: 03/25/2022

Inspection Number: 1162356

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: BACHOO, SAVITRI

Violation Code

Observation

Violation Citation

04-01-4 - From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-03-25:
Time Extended

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5801553

DAYS INN ORLANDO

License Type: Motel

2500 W 33 ST, ORLANDO 32839

Inspection Date: 03/24/2022

Inspection Number: 1222534

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PASIECKI, VICTORIA

Violation Code Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Operator aware and is waiting for inspection

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014047

HYATT PLACE WEST PALM BEACH

License Type: Hotel

295 LAKEVIEW AVE, WEST PALM BEACH 33401

Inspection Date: 03/25/2022

Inspection Number: 1163272

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FRANCO, BROOKE

Violation Code Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6100216

TWILITE MOTEL

License Type: Motel

4040 GALL BLVD, ZEPHYRHILLS 33542

Inspection Date: 03/21/2022

Inspection Number: 1221547

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: POWELL, DAVID

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed a fire extinguisher gauge reading recharge by room 119.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6100353

LA VISTA INN

License Type: Motel

11736 US HIGHWAY 19 N, PORT RICHEY 34668

Inspection Date: 03/22/2022

Inspection Number: 1222512

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BENEDICT, TRACY

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting
purposes only.
Light not blinking

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6212311

MANSION HOUSE

License Type: Bed and Breakfast

105 5 AVE NE, ST. PETERSBURG 33701

Inspection Date: 03/25/2022

Inspection Number: 1094433

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: MURPHY, JAMES

Violation CodeObservationViolation Citation

02-04-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. Inside of laundry room. Housekeeper removed **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215788

HOLLANDER HOTEL

License Type: Hotel

421 4 AVE N, ST. PETERSBURG 33701

Inspection Date: 03/25/2022

Inspection Number: 1163573

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MURPHY, JAMES

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher in hot water heater basement.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6201655

ALTA MAR AT BRODWATER

License Type: Apartment

3901 38 AVE S, ST. PETERSBURG 33711

Inspection Date: 03/22/2022

Inspection Number: 1534667

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HEFFNER, CHRISTOPHER

Violation Code

Observation

Violation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher in laundry room by building 9.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
12-04-4	High Priority - Balcony/starway/platform in disrepair. Balcony's and stairwells have been condemned by AHJ. Balcony violation is due for reinspect with callback date of, April 19,2022.	61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

Pinellas County

License Number: 6209371

LA QUINTA INN

License Type: Motel

7500 US HWY 19 N, PINELLAS PARK 33781

Inspection Date: 03/23/2022

Inspection Number: 1222532

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: RANVILLE, AMANDA

Violation Code

Observation

Violation Citation

06-05-4 Room door of room 140 is extremely hard to open, door sticks very badly.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6904062

VUE ON LAKE MONROE

License Type: Apartment

800 MARBELLA LN, SANFORD 32771

Inspection Date: 03/23/2022

Inspection Number: 1515472

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ANGEL, TERRY

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501720

VACATION RENTAL PROS PROPERTY MANAGEMENT LLC

License Type: Vacation Rental - Dwelling

200 EXECUTIVE WAY STE 200, PONTE VEDRA BEACH 32082

Inspection Date: 03/23/2022

Inspection Number: 1092713

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: GOSAI, MATT

Violation Code

Observation

Violation Citation

07-01-4	Damaged electrical wire(s). For reporting purposes only. Loose and hanging light fixture located outside by south side of downstairs deck walkway. **Warning**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-04-4	Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Loose . damaged , rusty, and hanging electrical outlet located outside by rear deck. **Warning**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501614

STAYABLE SUITES ST AUG

License Type: Motel

2535 SR 16, SAINT AUGUSTINE 32092

Inspection Date: 03/22/2022

Inspection Number: 1222478

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: GOSAI, MATT

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

04-05-4

No smoke detector provided in guest room/unit. For reporting purposes only.
Smoke detectors missing in units 146, 265, 128,109.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406445

THE ANN STEVENS HOUSE

License Type: Bed and Breakfast

201 E KICKLIGHTER RD, LAKE HELEN 32744

Inspection Date: 03/24/2022

Inspection Number: 1094329

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: OCASIO-LOPEZ, LISA

Violation Code Observation

Violation Citation

04-02-4 No smoke detector provided in guest room/unit. For reporting purposes only. In peaches and cream room. **Corrected On-Site**

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Walton County

License Number: 7601511

HIBISCUS COFFEE & GUEST HOUSE

License Type: Bed and Breakfast

85 DEFUNIAK ST, SANTA ROSA BEACH 32459

Inspection Date: 03/24/2022

Inspection Number: 1094786

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SHANKLIN, CYNTHIA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.